



DEFENSE NUCLEAR AGENCY
ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE
BETHESDA, MARYLAND 20814

01082
MAR 5 1985

RSDS

SUBJECT: Changes to the AFRRRI TRIGA Reactor Emergency Plan

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

1. The attached enclosures are changes to the AFRRRI emergency plan. These changes were effected to comply with recommendations made by USNRC staff during the AFRRRI emergency plan appraisal and emergency test exercise. Change one includes an Emergency Action Level (EAL) for the Stack Gas Monitor (SGM) alarm point which is the correction of a misplaced decimal in the original EAL. The change reflects correct alarm points as operationally set, currently and historically, on the SGM. There are two additional changes as noted.
2. The changes were reviewed by the AFRRRI Reactor and Radiation Facility Safety Committee (RRFSC) on 23 February 1984 and found to comply with 10 CFR 50.54q, in that they do not decrease the effectiveness of the plan.
3. These changes were submitted to the USNRC originally on 12 April 1984 but apparently were not placed in the proper distribution channels. We therefore resubmit the original package.
4. This submission is for your information and, under 10 CFR 50.54q, prior approval of the NRC is not required for implementation. These changes should be posted to your documents.

1 Enclosure:
Emergency Plan Chg Doc (5 pages)

Bobby R. Adcock
BOBBY R. ADCKOCK
COL, MS, USA
Director

DISTRIBUTION:
USNRC Region I Administrator (1 copy)
King of Prussia, PA

Document Control Desk (2 copies)
USNRC
Washington, DC 20555

Office of the Dir Nuc Reactor Reg (1 copy)
ATTN: Document Control Desk
USNRC
Washington, DC 20555

ACAS
11

8503080273 850305
PDR ADCKOCK 05000170
F PDR