

May 6, 1996

Mr. Nicholas J. Liparulo, Manager
Nuclear Safety and Regulatory Analysis
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

SUBJECT: PRELIMINARY TEST MATRIX FOR AP600 PASSIVE AUTOCATALYTIC RECOMBINERS

Dear Mr. Liparulo:

Per the request of your staff, enclosed is the preliminary test matrix the Nuclear Regulatory Commission intends to use to evaluate the performance of the passive autocatalytic recombiners. These tests are being conducted at Sandia National Laboratories. The test matrix is preliminary and, therefore, subject to change based on the results of the initial tests.

If you have any questions regarding this matter, you can contact me at (301) 415-1141.

Sincerely,

original signed by:

William C. Huffman, Project Manager
Standardization Project Directorate
Division of Reactor Program Management
Office of Nuclear Reactor Regulation

Docket No. 52-003

Enclosures: As stated

cc w/o enclosure:
See next page

DISTRIBUTION w/enclosure:

Docket File
PUBLIC
WHuffman
TKenyon
MSnodderly, 0-8 H7

PDST R/F
TQuay
DJackson
AMalliokos, T-10 K8
JKudrick, 0-8 H7

BGrimes
RArchitzel
JSebrosky
CAder, T-10 K8

DISTRIBUTION w/o enclosure:

WRussell/FMiraglia, 0-12 G18
EJordan, T-4 D18

AThadani, 0-12 G18
WDean, 0-17 G21

RZimmerman, 0-12 G18
JMoore, 0-15 F18

080021

DOCUMENT NAME: A:PARS.MTX (4D AP600 DISK)

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDST:DRPM	SC:PDST:DRPM					
NAME	WHuffman <i>WCH</i>	RArchitzel <i>RA</i>					
DATE	05/6/96	05/10/96					

OFFICIAL RECORD COPY

9605080087 960506
PDR ADOCK 05200003
A PDR

NRC FILE CENTER COPY

DF03

Mr. Nicholas J. Liparulo
Westinghouse Electric Corporation

Docket No. 52-003
AP600

cc w/o enclosure:

Mr. B. A. McIntyre
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
P.O. Box 355
Pittsburgh, PA 15230

Mr. Ronald Simard, Director
Advanced Reactor Programs
Nuclear Energy Institute
1776 Eye Street, N.W.
Suite 300
Washington, DC 20006-3706

Mr. John C. Butler
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
Box 355
Pittsburgh, PA 15230

Ms. Lynn Connor
Doc-Search Associates
Post Office Box 34
Cabin John, MD 20818

Mr. M. D. Beaumont
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
One Montrose Metro
11921 Rockville Pike
Suite 350
Rockville, MD 20852

Mr. James E. Quinn, Projects Manager
LMR and SBWR Programs
GE Nuclear Energy
175 Curtner Avenue, M/C 165
San Jose, CA 95125

Mr. Sterling Franks
U.S. Department of Energy
NE-50
19901 Germantown Road
Germantown, MD 20874

Mr. John E. Leatherman, Manager
SBWR Design Certification
GE Nuclear Energy, M/C 781
San Jose, CA 95125

Mr. S. M. Modro
Nuclear Systems Analysis Technologies
Lockheed Idaho Technologies Company
Post Office Box 1625
Idaho Falls, ID 83415

Barton Z. Cowan, Esq.
Eckert Seamans Cherin & Mellott
600 Grant Street 42nd Floor
Pittsburgh, PA 15219

Mr. Frank A. Ross
U.S. Department of Energy, NE-42
Office of LWR Safety and Technology
19901 Germantown Road
Germantown, MD 20874

Mr. Ed Rodwell, Manager
PWR Design Certification
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Mr. Charles Thompson, Nuclear Engineer
AP600 Certification
NE-50
19901 Germantown Road
Germantown, MD 20874

Preliminary Test Matrix to Evaluate the Performance of PARs

Test Facility: Surtsey at SNL

<u>Test #</u>	<u>Purpose</u>	<u>PAR Scale</u>	<u>Atmosphere</u>
1	Startup	1/2	2 bar air, no steam, .1%, .2%, ...1%, ... 2.0%H ₂
2	Startup & performance	"	2 bar air, no steam, .8%, .9%, 1.0%, ... 1.3%H ₂
3	"	"	1 bar air, 1 bar steam, .7%, ... 1.3%H ₂
4	Scale & performance	1/2	1 bar air, 1 bar steam, continuous injection of H ₂ and O ₂ until PAR reaches steady state at 2.0%H ₂
5	"	1/8	"
6	"	1/4	"

NOTE:

The tests assume removal of the false floor and any structures from the Surtsey facility that are directly under the PAR. The rest of the supports (horizontal and vertical) will remain in place. PAR location about 1 meter above the floor supports.