

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4500

V. S. BOYER
SR. VICE PRESIDENT
NUCLEAR POWER

December 10, 1984

Docket No. 50-277

Mr. John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: Peach Bottom Atomic Power Station - Unit 2
Piping Replacement Man-REM Estimates

Dear Mr. Stolz:

This letter is submitted as a follow-up to a telephone conference on October 22, 1984, between Mr. Gerald A. Gears, Peach Bottom NRC Project Manager, Mr. Michael Lamastra, NRC Radiation Assessment Branch, and W. M. Alden of Philadelphia Electric Company Licensing staff to provide information concerning unexpectedly high radiation levels in the reactor recirculation pumps following chemical decontamination of the recirculation system piping.

The attached report describes the circumstances and magnitude of the high radiation levels and corrective actions considered and taken to maintain personnel exposure as low as reasonably achievable (ALARA). Since extraordinary measures were taken to effect a mechanical decontamination of the pumps, it is expected that approximately 70 man-rem will be expended in this decontamination effort.

The scope of the pipe replacement modifications has been increased as a result of inspections performed during the outage and will require additional man-rem exposure beyond the original estimates. In April 1984, following refinement of the craft manhours required for the original scope of the work, it was estimated that 1,945 man-rem exposure would be required. However, replacement of the ten recirculation inlet safe ends and two jet

8412130283 841210
PDR ADOCK 05000277
P PDR

Acc 1
11

Mr. John F. Stolz

December 10, 1984


Page 2

pump instrumentation seals will require approximately 300 man-rem more than originally estimated.

If the exposures required for the pump decontamination, recirculation inlet safe ends and jet pump seal replacement are accounted against piping replacement, the total exposure to complete the modifications is estimated to be approximately 2,039 man-rem as indicated in the attached report.

Should you require further information or have any questions, please do not hesitate to contact us.

Very truly yours,



Attachment

cc: J. H. Williams, Resident Inspector

DECONTAMINATION OF RECIRCULATION
SYSTEM PUMPS AND VALVES

INTRODUCTION

In order to maintain personnel exposure as low as reasonable achievable (ALARA) during the pipe installation phase, Philadelphia Electric Company contracted with its NSSS vendor to perform piping decontamination utilizing London Nuclear Ltd. CAN-DECON decontamination reagent. Although the decontamination of the piping was effective, the decontamination of the recirculation pumps was not as effective as expected.

The presence of high radiation levels in the recirculation pumps constitutes a special problem to effect further decontamination of the pump internals. Decisions were made that dose reduction might be effected using other means, i.e., hydrolazing or air injection into the pump cavity followed by water flush. Since the pipe modification project ALARA group was convinced that further dose reductions were possible, special efforts were initiated in the interest of maintaining occupational exposure ALARA.

Chemical decontamination of the recirculation system piping was completed on August 8, 1984. Work efforts during the balance of the month of August were directed at consolidating the radioactive crud from the outboard elbows and the valves. This was accomplished by hydrolancing through openings cut in the pipe and draining through the valve body and suction drains. By the end of August 1984, the

suction and discharge elbows outboard of the valves, except for B suction, had been flushed of high level crud, and the radiation levels in the work area, after installation of temporary shielding around the pumps and on piping hot spots, were low enough to allow installation of valve supports to accommodate removal of the elbows outboard of the valves. The outboard elbows were removed during the first two weeks in September. After removal of the elbows, hydrolancing through the valves was performed in order to flush the remaining crud out of the system and to allow work to be initiated on the pipes between the pumps and valves. During the last two weeks in September, the pipes between the pumps and valves were removed, allowing direct access to the pumps for hydrolancing. Radiation levels inside the pump were 200-300 R/hr and 4000-5000 mr/hr in the work area around both pumps.

At the end of September, after several attempts to reduce the radiation levels on the 'B' recirculation pump by hydroblitz, radiation levels were 175-200 R/hr inside the pump and 30 R/hr at the pump suction cut.

SURVEY DATA

In order to measure the effectiveness of the chemical decontamination, contact dose rate measurements were taken on the piping system prior to and after chemical decontamination. The post-decontamination surveys indicated an effective decontamination

of the piping system, but little or no decontamination of the recirculation pumps and valves. Listed below are the pre and post-decontamination radiation levels associated with the recirculation pumps, valves and adjacent piping.

Surveys #144 (July 31, 1984, pre-decontamination) and #180 (August 8, 1984, post-decontamination) show the following results for the six survey points in and around the pumps and valves. (See Figure 1 for survey point locations):

Survey

<u>Point</u>	<u>Pre-Decon</u> (mr/hr)	<u>Post-Decon</u> (mr/hr)	<u>Physical Location</u>
1	300	75	A discharge riser elbow
2	9000	8000**	A pump body
3	350	35	A suction riser elbow
4	200	30	B discharge riser elbow
5	14000	15000**	B pump body
6	230	30	B suction riser elbow

Survey data for May 9, 1984 and August 8, 1984 show the following results for 12 survey points in and around the pumps and valves. (See Figure 2 for survey point locations):

Survey

<u>Point</u>	<u>Pre-Decon</u> (mr/hr)	<u>Post-Decon</u> (mr/hr)	<u>Physical Location</u>
5P	229	42.9	A suction riser elbow
6B	--	--	A pump suction string section
6P	334	26.5	A pump suction
7P	1617	1060**	A pump body left
8P	--	3590**	A pump body right
9P	146	89.1	A discharge riser elbow bottom
10P	175	33.2	A discharge riser elbow top
11P	208	25.9	B suction riser elbow top
12P	--	53.8	B suction riser elbow bottom
13P	255	62.5	B pump suction string section
14P	793	1040**	B pump body left
15P	238	3150**	B pump body right
16P	187	19.1	B discharge riser elbow bottom

As demonstrated above, all post-decontamination contact dose rates on the pipes adjacent to the pumps and valves were measured in tens of mr/hr, indicating expected decontamination of the pipe. In contrast, the post-decontamination dose rates on the pump (indicated by **) were still reading in thousands of mr/hr, indicating less than expected decontamination of the pumps. Post-decontamination contact measurements were also made on the valves, (See Figure 3, Survey #181) with contact dose rates

reading 1 to 1.2 R/hr, indicating less than expected decontamination of the valves.

The high radiation levels which remained at the pumps and valves caused high radiation levels in the working area at the 116' elevation. Because of these high radiation levels, it was decided that support of the valves, placement of pump shielding, and the placement and alignment of the pipe cutting equipment should be performed with water in the lower part of the recirculation system to provide some shielding. Surveys performed in late June and early July had indicated that water in these pipes reduced the working area radiation levels by approximately 60 percent.

MECHANICAL DECONTAMINATION

Two alternates for crud removal by agitation were considered since it was anticipated that the crud in the recirculation pumps would be as loosely adhered at Peach Bottom as it was at Monticello and access to each side of the pump could be obtained by using the chemical decontamination ports on the suction sides of the pumps and opening the welded flange connections for the valve by-pass on the discharge sides. These alternatives were:

- 1) inject air through a decontamination fitting during the drain and flush operation with the air bubbles providing the agitation

through a scrubbing action; 2) blind hydrolance the pump internals after the system was drained.

Because of concerns that hydrolance nozzles could become wedged in the pump internals during blind hydrolancing and cause increased exposures rather than provide a solution to the high dose rates, it was decided to perform the agitation via air injection. A program was initiated to implement this alternative. A procedure was prepared, equipment was obtained and installed, and final Plant Operations Review Committee approval for the procedure was received on August 14th. During the intervening 6 days (August 8, 1984 to August 14, 1984) radiation levels at the pump and adjacent piping remained stable but high. On August 10, 1984, a Senior Health Physics technician dedicated to the pipe replacement project prepared detailed surveys of both pumps to establish radiation levels for shielding and to estimate the potential exposure expected during installation of valve supports, pipe cutting equipment, and pump shielding (See Figure 4, Survey #188). The detailed surveys showed high radiation levels over the entire surface of the recirculation pump bowls, and also indicated high dose levels (4 to 6R/hr) on the bottom of the pump discharge pipe which had not been observed in this portion of the pipe on August 8, 1984. Neither post-decontamination survey had fixed survey points on this portion of pipe.

Shortly after the detailed pump survey on August 10, 1984, approximately 800 of the 10,000 gallons of water in the system were drained through the decontamination connection. Before the drain was initiated, a flexible plastic tube was connected to the vent on top of the A recirculation pump discharge to serve as a stand pipe to aid in monitoring the water level in the system. During the operation, it was observed that the water in the plastic tube was "muddy", indicating large quantities of particulate in the fluid.

CHRONOLOGY OF EVENTS

Between August 10 and August 14, 1984, no other surveys at the level of the pumps and valves were documented. During work efforts at the 116 ft. elevation, measurements were taken to verify that the dose rates were stable. The project procedures do not require documentation of this type of survey if radiation levels are unchanged. Under stable radiation conditions, detailed surveys are documented each week or when requested. Personnel exposure experienced during the four days was consistent with ALARA reviews based on the August 10 survey; that is, a working level dose rate of 225 to 275 mr/hr

Between August 10 and August 13, a scaffold was erected below the 'A' pump to support the cutting machine and the cutting machine was brought to the 116' level and placed on the 'A' pump suction

pipe. The radiation exposures experienced by the individuals involved with these operations were consistent with the exposure experienced by the Senior Health Physics technician who performed the detailed pump survey on August 10 and with estimates prepared for the ALARA review of these tasks; that is, an average exposure in the work area of 225 to 275 mr/hr. Shortly before midnight, three individuals attempted to set the cutting machine on the A pump suction. Their exposure was documented on the RWP and averaged less than 275 mr/hr for approximately 40 minutes of exposure. Part of their work sequence was video taped and, the tape was examined for this evaluation. Shortly after midnight, three other individuals returned to the pump to realign the machine. The machine was set on the pipe, and an attempt was made to lift the machine up onto the pump suction. The lift was impeded by a lip on the pump, and the pump was jarred by several attempts to lift the 1000 pound cutting machine. These impacts may have caused the movement of the crud on the A pump; however, no comparable impact took place on the B pump.

Survey #191 prepared at 4:00 a.m. on August 14 (Figure 5) indicated that working area dose rates directly under the pumps had increased from 1000 mr/hr to a range of approximately 2000 to 4000 mr/hr.

During the next 30 hours, (4:00 a.m. on August 14 to 10:00 a.m. on August 15), dose levels on the pumps and adjacent pipes continued to change even though there were no external stimuli to initiate the change. Survey #191, taken at 4:00 a.m. on August 14, showed high radiation levels on the bottom on the A pump bowl (See Figure 5). Survey #192, taken at 9:00 p.m., shows that the dose rates on the bottom of the discharge pipes adjacent to the pumps were approximately 5 R/hr (See Figure 6). By 4:00 a.m. on August 15, dose levels at the bottom of the pump suction elbow had risen to 70 and 110 R/hr on the B and A loop, respectively; the dose level on the A pump discharge had risen to 70 R/hr; and work area dose levels had risen to between 600 and 4000 mr/hr on the A loop. Working level dose rates at the suction and discharge valves remained relatively constant at 100 to 500 mr/hr (See Figure 7, Survey #193).

Between noon and 11 p.m. on August 15, 1984, the recirculation system was drained and flushed several times and periodically agitated with short bursts of compressed air. During the day, the radiation levels at the bottom of the pump suction elbow continued to increase as measured with a teletector. At one point, the peak reading on the A pump reportedly reached 700 R/hr and on the B pump, the dose rate exceeded the 1000 R/hr maximum capacity of the teletector.

Late in the evening on the 15th, flushing of the system was terminated because the drain rates were slow. A portion of the drain system (short length of fire hose on each loop), was found kinked and partially plugged. The radiation levels on the drains were reading 50 to 350 R/hr (See Figure 8, Survey #200).

Flushing and draining operation were continued on August 16.

By early morning on August 17th, the lower part of the recirculation system had been drained and filled several times and the dose levels were stable. The high radiation levels adjacent to the pumps, however, had not been reduced. Large radiation sources were distributed from the bottom of the elbow on the suction riser to the bottom of the elbow on the discharge riser on both loops. Figure 9, prepared on August 17th from Survey #206, is typical of the radiation levels observed on both loops.

On August 17, 1984, it was decided to hydrolance the pipes to consolidate the high level deposits distributed throughout the piping at the 116 ft. elevation. Two-inch holes were drilled into the suction and discharge pipes in both loops at the 139 ft. elevation above the location of the high radiation levels. After two days of high pressure hydrolance through the two-inch holes, the high radiation source had been removed from the A discharge elbow but not from the other three elbows. Four large windows were subsequently cut into the piping to allow flushing as well

as hydrolancing. A 12-inch square window was cut into the A loop discharge elbow at the 129 ft. elevation'; 22-inch square windows were cut into the other three pipes at the 139 ft. elevation. Crud was flushed through the body drains on the suction and discharge valves.

On August 22, the A recirculation pump discharge valve body drain was plugged with crud and had a radiation level 350 R/hr. The drains were modified to allow draining and back flushing. By August 23, it was determined that valves installed in the valve body drains constituted a crud trap and prevented adequate flushing. These drains were removed and replaced with flexible plastic hoses. By August 25, 12-inch windows were cut into the outboard suction and discharge elbows to allow direct flushing of the valves.

On August 29, after 12 days of hydrolance, much of the crud in the outboard elbows had been discharged through the drains. Radiation levels on the valves were approximately equal to those which were existent on August 8 at the end of chemical decontamination (See Figures 3 and 10). Therefore, work was initiated to shield the pumps, support the valves, and cut off the outside elbows adjacent to the suction and discharge valves.

During the first two weeks in September, the outboard elbows were removed which allowed direct access to hydrolaze the valves, the pipes between the valves and pumps, and the pump discharge. On

September 13, a survey was made inside the pump discharge with a teletector and radiation levels of 200-300 R/hr were observed. During the last two weeks in September, the pipes between the pumps and valves were removed, which allowed direct access to the pumps.

At the end of September, after several attempts to hydrolaze the 'B' pump, radiation levels inside the pump were 175-200 R/hr and at the pump suction pipe cut were 30 r/hr.

POSTULATED CAUSE

The most likely source of the increased levels of radiation in the pipes adjacent to the pumps is presumed to be radioactive deposits which existed in the pump internals (impeller and casing) and were subsequently dislodged during the activities on August 14 and 15. It has been postulated that the decontamination fluid was unable to completely dissolve these deposits, but did weaken or break the bonds which held them on the internal surfaces of the pump.

Subsequent soaking for six days in a very weak solution of decontamination fluid and demineralized water softened the deposits or weakened these bonds. It is possible that the activity of the individuals working on the A pump may have caused the initial movement of the surface deposits, and the high level

deposits observed at the bottom of the pump suction elbow on August 15. However, since no comparable activities took place on the B pump, the movement may have been solely caused by the softening action and gravity. The compressed air injected into the system on August 15 enhanced the movement of these radioactive deposits and distributed them throughout the horizontal pipes and the valves at the 116 ft. and 119 ft. elevations. The high levels of radiation were the result of the redistribution of this radioactive material into a "less shielded" and "physically proximate" location in the piping system.

Pre-decontamination crud analysis of pipe (flange) film indicated about 16% chrome and 63% iron. Process qualification testing confirmed solubility of this crud form with the London Nuclear CAN-DECON decontamination reagent. This is supported by the decontamination factors achieved on the pipe. Post-decontamination crud analysis of samples obtained during hydrolance operations indicates a higher chrome (in the range of 46-62%) content than iron. During laboratory testing, these high chrome samples were not soluble in CAN-DECON reagent. More recent laboratory analysis was performed to affect a conclusion which would indicate that a two-step chemical decontamination process (reduction followed by oxidation) may dissolve the high chrome crud deposits.

For reasons currently unknown, oxides which formed on the pump surfaces are not similar to the oxides formed on the pipe surfaces. Additional investigation is underway to gain insight into the differences between pipe and pump crud deposits.

CORRECTIVE ACTIONS

Five options were considered in order to eliminate the radiation sources in the recirculation pumps to reduce area dose and maintain personnel exposure related to pipe installation As Low As Reasonably Achievable. These options are listed below.

1. Chemical Decontamination

This option would utilize a decontamination reagent other than the London Nuclear Ltd. reagent which was utilized successfully for pipe decontamination. The reagent selection would be based on the analysis of known pump crud samples which have been collected.

2. Removal of Pump Internals and Decontamination

Removal of the pump internals provides direct access to the internal surfaces, grooves and crevices that can trap radioactive crud. In addition to the decontamination of these areas, the wear ring,

hydrostatic bearing, shaft, and other parts of the pump internals can be inspected. The pressure retaining parts of the pump can also be inspected in accordance with ASME Section XI inservice inspection requirements.

3. Replacement of the Pump Case and Internals

Replacement of the pump case and internals requires replacement of the entire pump including case, internals, coupling, and driver mount with another unit minimizing interchangeability rework.

4. Remote Crud Trap Cleanup

Remote clean-up is a process by which an apparatus such as a water supply nozzle is inserted through the discharge nozzle of the pump. The water nozzle would be guided by the pump case and the impeller, while it is supported by a flexible shaft. The flush from the apparatus could drain through the pump suction or discharge or be sipped by another close proximity vacuum sipper.

5. Special Shielding Designs

In order to continue the work without removal of the high radiation sources in the pumps, special shielding

could be installed in and around pump to reduce exposure.

Evaluation of the advantages, disadvantages and the ALARA impact of the options presented above resulted in the selection of Option 2, Removal of Pump Internals and Decontamination. This option will be performed on both recirculation pumps. The following work items are required for the decontamination:

- o Removal of the pump-motor coupling spacer
- o Motor removal
- o Motor storage
- o Removal of the pump seal/coupling
- o Removal of the motor mount
- o Set-up of shielded cask to receive pump internals
- o Removal of pump internals
- o Perform hydrolazing and/or glass bead blasting as needed
- o Decontamination of the internals
- o Appropriate Inspections
- o Reassembly of the pump and motor

The hydrolazing and/or glass bead blasting will be performed utilizing a high pressure water source. Hydrolazing or high pressure glass bead blasting will be performed on the pump shaft and impeller by alternately lifting and rotating the pump internals in specified increments. The shaft and impeller will

be hoisted into a shielded cask, for transport to the Unit 2 refuel floor for further decontamination if required.

With the pump shaft and impeller removed, the internal surfaces of the pump casing will be surveyed to determine the location of the radiation sources and to establish a baseline for assessment of the effectiveness of the decontamination. The ultimate decontamination method to be utilized on the pump casing internals is dependent upon the results of these surveys. Since direct access to the source areas will be available, there is a high degree of assurance that this option will result in successful decontamination of the pump internals. All operations involved in this process will be performed with prior ALARA review. The water spray will be contained and the residue collected for disposal.

MAN-REM ESTIMATES

The initial Man-REM estimate prior to start of the outage to complete piping replacement modifications was 1,810 Man-REM as submitted via letter, S. L. Daltroff, PECO, to J. F. Stolz, USNRC, on March 8, 1984. Further refinement in the manhour estimates completed in mid-April, 1984, indicated at that time that a man-REM expenditure of 1,945 would be required to complete all pipe replacement modification work. These estimates were based on the following scope of work:

Original Scope

- o complete replacement of recirculation system piping loops A and B
- o replacement of Residual Heat Removal (RHR) system shutdown cooling suction and return piping inside containment
- o replacement of a portion of the RHR head spray piping inside containment
- o replacement of a portion of the reactor water cleanup (RWCU) piping outside containment
- o replacement of the RWCU containment penetration

Expanded Scope

As a result of indications discovered while performing additional weld inspections during the outage, the scope of work has been increased, since the time of the April man-REM estimates, to include the following:

- o replacement of two jet pump instrumentation seal reducers
- o replacement of ten recirculation inlet riser safe ends

An ALARA milestone review of all pipe modification related tasks was completed following pipe removal to assess the accumulated man-REM exposure for the completed phases of the project.

After 26 weeks of outage time, the pipe replacement modifications have accumulated 870 man-REM in 32,550 radiation work permit (RWP) hours. The April, 1984, man-REM estimate and the actual man-REM exposure for the three phases of the project completed to date is as follows:

<u>Project Phase</u>	April 1984	
	<u>Estimated</u> <u>Man-REM</u>	<u>Actual</u> <u>Man-REM Exposure</u>
I Pre-Decontamination	445	386.5
II Pipe Decontamination	38	40.4
III Pipe Removal	516	326.3

The actual exposures through the pipe removal phase are tracking at approximately 78% of the April exposure estimates.

The April, 1984, man-REM estimates for project phases IV and V (Pipe Replacement and Restoration) were 887 man-REM and 59 man-REM, respectively. The Pipe Replacement Phase of the project is being re-estimated due to the increased scope of work consisting of the replacement of two jet pump instrumentation seal reducers, the ten recirculation system inlet riser safe ends, and installation phase modifications required because of deferral of work in the vicinity of the recirculation pumps. Additionally, the man-REM exposure required for the unforeseen necessity of

decontaminating the recirculation pumps will contribute to the projected man-REM to complete the piping modifications. The estimated exposure to complete the Pipe Replacement and Restoration phases of the project are as follows:

<u>Project Phase</u>	April 1984 Estimate <u>Man-REM</u>	Current Estimate <u>Man-REM</u>
IV Pipe Replacement	887	887
o Pump Decontamination	N/A	70
o Jet Pump Instrumentation Seal	N/A	80
o Recirc Inlet Riser Safe Ends	N/A	190
o Total (phase IV)	887	1227
V Restoration	59	59

Both the April, 1984, estimate and current estimate are based on an area dose rate of 150 mr/hr following pipe decontamination. The accuracy of the current estimates for the Pipe Replacement and Restoration phases is dependent upon the results achieved in performing the recirculation pump decontamination described.

A comparison of the current estimates based on the increased scope of work, actual man-REM exposure tracked to date and the April, 1984, estimate is as follows:

<u>Project Phase</u>	April 1984 Estimate <u>Man-REM</u>	Estimate based on Actual through Phase III completion <u>Estimated Man-REM</u>
I Pre-Decontamination	445	386.5**
II Piping Decontamination	38	40.4**
III Pipe Removal	516	326.3**
IV Pipe Replacement	887	1227
V Restoration	59	59
	1945	2039.2

**Denotes actual dose expended.

Work is proceeding on decontamination of the pump with both impellers having been hydroblitzed and removed from the drywell. At completion of decontamination, performance of radiological surveys will indicate the effectiveness of the hydrolazing. The surveys will be utilized to perform a re-estimate of the Pipe Replacement and Restoration phase man-REM exposure to complete the project.




FIGURE 1

PEACH BOTTOM UNIT 2
 DATE _____
 TIME _____
 SURVEY TAKEN BY _____

- NOTES
1. SURVEY POINTS SHOWN
 2. ADDITIONAL POINTS MAY BE TAKEN
 3. ALL POINTS TO BE RECORDED ON TABLE B.13

RECIRCULATION PUMP

FIGURE 2

.c 1




FIGURE 3A

PBAPS - RADIATION-CONTAMINATION - DIAGRAM SHEET

UNIT 2 . UNIT 3

196-21309 12/81
DOCTYPE 502

R.W.P. NO. 2-01-513

SURVEY NO. 181

DATE. 8-9-89


TIME. 19:25

SURVEY BY. Luttrell

AREA. 1' X 2' Drywell 116" ¹⁴ 13-53 VALVES A-B

AREA DIAGRAM - REMARKS

Posta Shielding EVALUATION
PRE -



NOTE

G/A WALKWAY: 200-400 mR/hr
G/A AT TOP OF VALVE: 300-700 mR/hr
INST. USED: ROZA ^H 2541

LEGEND:

△ - SMEAR

○ - CONTACT RADIATION READING

FIGURE 4A

PHAPS - RADIATION CONTAMINATION DIAGRAM SHEET

196-21309 12/81
DOCTYPE 502

UNIT 2 UNIT 3

R.W.P. NO. 2-01-054-3
SURVEY NO. 198


DATE: 8/10/84 TIME: 12:00

SURVEY BY W. Rogers

AREA: Rx 2 116' 'A' Pump


H.P.
1.0 hour / 225m

AREA DIAGRAM - REMARKS



6.0-4.0 R/hr constant
2.5 R R/hr @ 18"
decreases to 2 R/hr

TURND PUMP.
Decreases down to 800 R/hr
toward Valve



AT 18" READINGS OF
1000-1200 R/hr chest high
for workers under pump
Hear level less.

2.5 R/hr valve closed
R/hr
= P:OT

page 2 of 3

LEGEND

SMEAR

CONTACT RADIATION READING

FIGURE 4B

PHAPS - RADIATION-CONTAMINATION - DIAGRAM SHEET

196 21309 12/81
DOCTYPE 502

UNIT 2 UNIT 3

R.W.P. NO. 1-01-0593

SURVEY NO. 1


DATE 8/1/84

TIME 12:00

SURVEY BY W. Rogers

AREA 116' 13' Recirc Pump

AREA DIAGRAM - REMARKS



DISCONTINUITY will
Be in 1000-1200
with AREA to
...
...
...
...
...
by ladder with
line of sight.

FIGURE 5A

PHAPS RADIATION - CONTAMINATION - AIRBORNE SURVEY

PHAPS FORM 12-81
REV 10-81

UNIT 2 UNIT 3

RWP NO 2-94-0776

SURVEY NO 191

DATE 8/14/84 TIME 1400

SURVEY BY Gustelle

AREA A Recirc Pump

REASON Determine Dose Rates

RADIATION INSTRUMENT SERIAL NO C.2540 202A

ITEM	BETA MICR/HR	GAMMA MICR/HR	NEUTRON MICR/HR	TOTAL MICR/HR	DISTANCE
Contact on Pump		2-14 μ /hr		2-14 μ /hr	1"
Work Area on Scaffold		1.5-4 μ /hr		1.5-4 μ /hr	8-10"

CONTAMINATION - INSTRUMENT SERIAL NO _____

AIRBORNE - INSTRUMENT SERIAL NO _____

ITEM	BETA-GAMMA DPM/100cm ²	ALPHA DPM/100cm ²	SAMPLING	
			AVERAGE FLOW RATE	COUNTER
			START	
			STOP	
			ISOTOPES	

REMARKS:

FIGURE 5B

PHAPS - RADIATION-CONTAMINATION - DIAGRAM SHEET

196-21309 12/81
DOCTYPE 502

UNIT 2 UNIT 3

R.W.P. NO. 2-94-0776

SURVEY NO. 191


DATE 8/14/87

TIME 0400

SURVEY BY Santrell

AREA A Resirc Pump

AREA DIAGRAM - REMARKS



LEGEND:

\triangle = SMEAR

\circ = CONTACT RADIATION READING

FIGURE 5C

PUMPS - RADIATION CONTAMINATION - DIAGRAM SHEET

196 21309 12/81
DOCTYPE 507

UNIT 2 UNIT 3

RWP NO 3-94-0776

SURVEY NO 191

DATE 8/14/84


TIME 0400

SURVEY BY Soutall

AREA A Recirc Pump

AREA DIAGRAM REMARKS

Dose rates on contact with bottom of pump volute and work Area ~~500~~ below.



LEGEND

△ · SMEAR

○ · CONTACT RADIATION READING

FIGURE 6

PBAPS RADIATION - CONTAMINATION - AIRBORNE SURVEY

FORM 17-70 REV 12/81
100-100-102

UNIT 2 UNIT 3

RWP NO 2-94-0637

SURVEY NO 192

DATE 8-14-84

TIME - 2100

SURVEY BY - W. M. Murray

AREA U2 D/W 116' A & B Recirc Pump Discharge

REASON - INSTALLING LEVEL INDICATORS

RADIATION - INSTRUMENT TELETECTOR
SERIAL NO. 29642

ITEM	BETA MRAD/HR	GAMMA MR/HR	NEUTRONS MREM/HR	TOTAL MREM/HR	DISTANCE
1 A" Recirc Disch. Pipe @ Indicator	ND	400/75	N/A	400/75	CONTACT / 3'
2 A" Recirc Disch. Pipe Bottom	ND	5000/400	N/A	5000/400	CONTACT / 18"
3 B" Recirc Disch. Pipe @ Ind.	ND	2000/100	N/A	2000/100	CONTACT / 3'
4 B" Recirc Disch. Pipe Bottom	ND	5000/500	N/A	5000/500	CONTACT / 18"
5					
6					
7					
8					

CONTAMINATION - INSTRUMENT SERIAL NO. _____

AIRBORNE - INSTRUMENT SERIAL NO. _____

ITEM	BETA+GAMMA DPM/100 cm ²	ALPHA DPM/100 cm ²	SAMPLING		
			START -	AVERAGE FLOW RATE	COUNTER
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

FIGURE 7A

PBAPS RADIATION - CONTAMINATION - AIRBORNE SURVEY

96-21268 REV. 12/81
DOCTYPES 602

UNIT 2 - UNIT 3

R.W.P. NO. 2-01-0543

SURVEY NO. 193

DATE - 8/15/84

TIME - 0400

SURVEY BY - Scutelle/Henry

AREA - Rc 2 D/W 116'

REASON - RWP update E 'B' & 'A' Recirc. Pump.

RADIATION - INSTRUMENT Tale 31504 6/14/85
SERIAL NO. ROZA 12542 8/8/85

ITEM	BETA MRAD/HR	GAMMA MR/HR	NEUTRONS MREM/HR	TOTAL MREM/HR	DISTANCE
1 Gen Area 116'	ND-2 $\frac{Rad}{hr}$	50-4 $\frac{R/hr}$	N/A	50-6 $\frac{Rem}{hr}$	Field
2 Pipes/Valves/Pumps	ND-40 $\frac{Rad}{hr}$	1-110 $\frac{R/hr}$	↓	1-150 $\frac{Rem}{hr}$	1'
3					
4					
5					
6					
7					
8					

SEE MAP

CONTAMINATION - INSTRUMENT ROZA 12542 AIRBORNE - INSTRUMENT 10 vol. 13-84
SERIAL NO. ROZA 12542 SERIAL NO. 13-84

ITEM	BETA MRAD/HR	GAMMA MR/HR	PHOSPHOR DPM/100 CM ²	SAMPLING	AVERAGE FLOW RATE	COUNTER
1 floor	24	NA	NA	START - 2045		
2 floor	24			STOP - 0320	FT ³ /MIN. 1.0	EFF. 398
3 floor	8			GROSS COUNTS		
4 floor	12			15,397	BKGD CPM 24	NET CPM 1516
5 floor	8			10 min		
6 floor	16			NET CPM 1516		
7 floor	16			SCALER EFF. 398	395	1.6N101
8 floor	8			VOL. 6.10 ¹⁰		
9 Valve	16			ISOTOPES		
10 Scaff around Pump	8					
11 floor	16					
12 Scaff around Pump	4					
13 wall/inter	12					
14 wall/inter	12					
15 wall/inter	4					

REMARKS:

FIGURE 7C

PBAPS - RADIATION-CONTAMINATION - DIAGRAM SHEET

194-21309 12/81
DOCTYPE 502

UNIT 2 UNIT 3

R.W.P. NO. 2-01-0543

SURVEY NO. 193

DATE 08-15-84

TIME 0115

SURVEY BY R.H. Tomlinson

AREA Rx 2 D/W 116' @ Recirc Pump "B"

AREA DIAGRAM - REMARKS

"B" Suction Valve NO-43B

150-200 ^{HR}/HR CT.

1.5 R/HR @ Bottom

40 RAD/HR S CT.

"B" Discharge Valve NO-53B

100-250 ^{HR}/HR CT.

450 ^{HR}/HR @ Bottom

1 RAD/HR S CT.

"A" Suction Valve NO-43A

150-200 ^{HR}/HR CT. 2.5 ^{HR}/HR 500 ^{HR}/HR @ B

4.5 R/HR @ Bottom CT.

40 RAD/HR S CT.


"A" Discharge Valve NO-53A

150 ^{HR}/HR - 25 ^{HR}/HR @ 150 @ B

2 R/HR @ Bottom CT.

40 RAD/HR S CT.

RECIRC PUMP
"B"



LEGEND:

○ - CONTACT RADIATION READING.

FIGURE 7D

PBAPS - RADIATION-CONTAMINATION - DIAGRAM SHEET

196-21309 12/81
DOCTYPE 602

UNIT 2 . UNIT 3

R.W.P. NO. 2-01-0543

SURVEY NO. 193


DATE 08-15-84

TIME 0115

SURVEY BY R.K. Tomlinson

AREA Rx² D/w 116' C. Recirc Pump "B"

AREA DIAGRAM - REMARKS



= DOSE RATE @ 90 HEAD LEVEL ON SCAFFOLD ≈ 6-12" FROM PUMP BOTTOM

LEGEND:

△ - OMEGA

○ - CONTACT RADIATION READING

(ORIGINAL)

ROZA # 2540 C.D.D. 5/9/84

FIGURE 7E

PBAPS - RADIATION-CONTAMINATION - DIAGRAM SHEET

196-21309 12/81
DOCTYPE 602

UNIT 2 . UNIT 3

R.W.P. NO. 2-01-0543

SURVEY NO. 193


DATE. 08-15-84

TIME. 0330


SURVEY BY. SAUTELLE

AREA. Rx 2 D/W 116' @ RECIRC PUMP "A"

AREA DIAGRAM - REMARKS



LEGEND:



○ - CONTACT RADIATION READING

FIGURE 8

RBAPS RADIATION - CONTAMINATION - AIRBORNE SURVEY

196 21248 REV. 12/81
DOC TYPE 502

UNIT 2 - UNIT 3

3

R.W.P. NO. 2-940637

SURVEY NO. 200

DATE - 8/16/54

TIME - 0200

SURVEY BY - [Signature]

AREA - 1/6' x 1 D/W (Sub Coverage)

REASON - Changing drain line hoses for decoupling sys of ATR

RADIATION - INSTRUMENT SERIAL NO. T-1e 09641
Rosa 9542

ITEM	BETA MRAD/HR	GAMMA MR/HR	NEUTRONS MREM/HR	TOTAL MREM/HR	DISTANCE
1 Fire Hose Fittings on A section	ND	50R to	NA	50R to	Contact
2 drain line	ND	350R	NA	350R	Contact
3 " " " " "	ND	1R to 10R	NA	1R to 10R	6" to field
4 Fire hose Fittings on B section	ND	1R to	NA	1R to	Contact
5 drain line	ND	3R	NA	3R	Contact
6 " " " " "	ND	300 to 1000	NA	300 to 1000	15" x Field
7 Fire hose off B side	ND	500 to	NA	500 to	Contact
8		3000		3000	Contact

CONTAMINATION - INSTRUMENT SERIAL NO. _____

AIRBORNE - INSTRUMENT SERIAL NO. 3-54

ITEM	BETA+GAMMA DPM/100 cm ²	ALPHA DPM/100 cm ²
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		

SAMPLING

START - 1920 AVERAGE FLOW RATE _____ COUNTER _____

STOP - 1925 FT³/MIN 1.0 EFF .400

GROSS COUNTS 15335 BKGD CPM 20 NET CPM 1514

COUNTING TIME 10

NET CPM 1514

SCALER EFF 1.4 VOL 1.5 $\cdot 6 \cdot 10^{-4}$

ISOTOPES

REMARKS: NOTE: B side was checked and no contamination found.

FIGURE 9A

PBAPS RADIATION - CONTAMINATION - AIRBORNE SURVEY

114 21268 HLX 12/81
INSTRUMENT 502


UNIT 2 - UNIT 3

RWP NO. 2-01-0543

SURVEY NO. 206

DATE - 8-17-84


TIME - 0030

SURVEY BY - 
G.R. CICOTTE

AREA - RX2 DRYWELL AT B RECIRC PUMPS

REASON - CHANGE CONDITIONS / POST DECON FLUSH

RADIATION - INSTRUMENT SERIAL NO. 29641
6128

ITEM	BETA MRAD/HR	GAMMA MR/HR	NEUTRONS MREM/HR	TOTAL MREM/HR	DISTANCE
1	<p>SEE MAP - ALL READINGS IN R/HR \times</p> 				
2					
3					
4					
5					
6					
7					
8					

CONTAMINATION - INSTRUMENT SERIAL NO. _____

AIRBORNE - INSTRUMENT SERIAL NO. _____

ITEM	BETA+GAMMA DPM/100 cm ²	ALPHA DPM/100 cm ²	SAMPLING		
			START -	AVERAGE FLOW RATE	COUNTER
1	<p>NA</p>	<p>NA</p>	STOP -	FT ³ /MIN	EFF
2			GROSS COUNTS	BKGD CPM	NET CPM
3			COUNTING TIME		
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					

REMARKS: NOT FOR EXPOSURE CONTROL: G-M INSTRUMENT

8-17-84/0030

FIGURE 9C

