

Document No.

**ALPHA-605**


Document Title

**PANDA Transient Tests**

**M3B Integral System Test  
Apparent Test Results**

Revision Status						
Rev.	Prepared / Revised by	Approval / Date			Issue Date	Remarks
		P-PM	G-PM	G-SQR		
0	C. Aubert	J. R. 10-IV-96	J. Torbeck 10 April 96	G. Wingate 10 April 96	11 April 96	G-PM & G-SQR approvals on file (P-ERM-37, p 2)





PAUL SCHERRER INSTITUT

Registrierung  
TM-42-96-07  
ALPHA-605-0

Titel  
PANDA Transient Tests  
M3B Integral System Test  
Apparent Test Results

Ersetzt  
---

Autoren/  
Autorinnen  
C. Aubert, J. Dreier, O. Fischer, M. Huggenberger, S. Lomperski,  
H.J. Strassberger

Erstellt  
10.04.96

Summary:

This Apparent Test Results (ATR) report is compiled in accordance with the requirements specified in the Test Plan (TP) 25A5764R2 (GE document) section 10. The report covers the results for the PANDA Transient Test M3B. The ATR summarizes the apparent results and includes: test number, test objective, test date and time, data recording period, data analysis period, name of data file and ORACLE data tables, list of failed or unavailable instruments considered to be required for the test, list of required instruments with zero or reference check points not in tolerance or in over-range or under-range during test, deviations from test procedure and problems which occurred during test. Statements are made whether or not the test objective has been reached and the data were recorded correctly. A table of actual initial conditions based on average and standard deviation over one minute time period just before the test start for all parameters with a specified acceptance criteria in section 9.2 of TP is provided as well as time history plots over test duration for all top priority measurements.

Verteiler	Abt.	Empfänger/Empfängerinnen	Expl.	Abt.	Empfänger/Empfängerinnen	Expl.		Expl.
	42	G. Yadigaroglu G. Varadi C. Aubert T. Bandurski J. Dreier O. Fischer J. Heilzer M. Huggenberger S. Lomperski H.J. Strassberger	1 1 1 1 1 1 1 1 1 1		GE San Jose CA <del>IBM</del> (for distribution at GE to J.R. Fitch, G.A. Wingate, B.S. Shiralkar, DRF No. T10-00005)		Bibliothek Reserve Total Seiten Beilagen Informationsliste D 1 2 3 4 5 8 9 A Visum Abt./Laborleitung	 6 19 22 - -
		PANDA Documentation	2					

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

<b>Contents:</b>	<b>Page</b>
1. Test Objectives	5
2. Reference Documents	5
3. Test Date/Time	5
4. Data Recording Period	5
5. File Names	5
6. ORACLE Data Tables	5
7. RPV Power Curve	6
8. Test Instrumentaion	6
9. Deviations from Test Procedure	6
10. List of Deviations from Requested Initial Conditions	7
11. Test Processing	7
12. Water Temperature for PCC Pool Refilling	7
13. Requested Initial Conditions	7
Data Analysis Period for Initial Conditions	7
Environment Parameters	8
RPV Parameters	8
DRYWELL Parameters	8
SUPPRESSION CHAMBER Parameters	9
GDCS Parameters	10
PCC1 Pool Parameters	11
PCC2 Pool Parameters	11
PCC3 Pool Parameters	12
14. Graphs	
M3B Test - Vacuum Breaker Opening	13
M3B Test - RPV, Drywell and Wetwell Pressures	14
M3B Test - Drywell and Wetwell Air Partial Pressures	15
M3B Test - RPV Heater Power	16
M3B Test - RPV and Drywell Temperatures	17
M3B Test - Wetwell Temperatures	18
M3B Test - PCC Lower Drum and GDCS Return Line Water Temperatures	19
M3B Test - PCC Vent Line Gas Temperatures	20
M3B Test - Main Steam Line & PCC Feed Line Flows	21
M3B Test - PCC Pool Water Level	22

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

## TEST M3B

**1. TEST OBJECTIVES:**

The objectives of the PANDA integral system tests are to provide additional data to: a) confirm the capability of TRACG to predict SBWR containment system performance, including potential systems interaction effects (*Integral System Tests*) and b) demonstrate startup and long-term operation of a passive containment cooling system (*Concept Demonstration*).

The specific objective of test M3B which was conducted with nominal post-LOCA conditions after a Main Steam Line Break is to establish the base case and demonstrate transient system response and repeatability.

**2. REFERENCE DOCUMENTS:**

Test Plan: GE document 25A5764R2  
Test Procedure: ALPHA-520-2

**3. TEST DATE/TIME:**

Test Start: 31-OCT-95 / 18:25:38  
Test Stop: 01-NOV-95 / 14:38:26  
Test Duration: 20:12:48  
Test Period: 0 to 72768 sec

**4. DATA RECORDING PERIOD:**

Start: 31-OCT-95 / 18:02:22  
Stop: 01-NOV-95 / 14:38:26  
Data Recording Period: -1396 to 72768 sec

**5. FILE NAMES:**

Raw Data: panda\_M3B.dat  
DAS-Configuration / Channel List: kbt99999999.o12

**6. ORACLE DATA TABLES:**

PANDA\_M3B\_MT\_LINE  
PANDA\_M3B\_MT\_POOL  
PANDA\_M3B\_MT\_REF  
PANDA\_M3B\_MT\_VESSEL  
PANDA\_M3B\_M\_OTHER  
PANDA\_M3B\_M\_TIME  
PANDA\_M3B\_KBT  
INFO\_TESTS

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

**7. RPV POWER CURVE:**

Power analysis<sup>1</sup> period: 20 to 20600 sec and 21800 to 72768 sec

Maximum negative deviation:

Maximum positive deviation:

Standard deviation:

Power curve tolerance: ±25.0 [kW]

Definition of RPV power deviation ( $\Delta$ Power) and standard deviation ( $\sigma$ ):

$$\Delta\text{Power} = \text{Power}_{\text{th}} - \sum_{j=1}^6 \text{MW.RP.j}$$

$$\sigma = \sqrt{\frac{1}{n} \sum_{k=1}^n \left( \text{Power}_{\text{th}}^* - \sum_{j=1}^6 \text{MW.RP.j}^* \right)^2}$$

$\text{Power}_{\text{th}}$ : theoretical power

$\sum_{j=1}^6 \text{MW.RP.j}$ : measured power

$n$ : # of measurements throughout the test

**8. TEST INSTRUMENTATION****LIST OF FAILED OR UNAVAILABLE REQUIRED INSTRUMENTS:**

Air partial pressure in DW1	MPG.D1.3	Back-up instrument: MPG.D1.2
Air partial pressure in DW2	MPG.D2.2	(see NCR P-016)
	MPG.D2.3	(see NCR P-016)

**LIST OF REQUIRED INSTRUMENTS WITH ZERO NOT IN TOLERANCE OR OVER-RANGE OR UNDER-RANGE DURING TEST:**

None

**9. DEVIATIONS FROM TEST PROCEDURE:**

None

<sup>1</sup> The power curve analysis has been performed without including power spikes due to switching between rod groups (see NCR P-013). This analysis does also not include a test period of 1200 seconds (between 20600 and 21800 sec); it is covered by NCR P-015.

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

10. LIST OF DEVIATIONS FROM REQUESTED INITIAL CONDITIONS:

11. TEST PROCESSING

PROBLEMS:

None

HAS THE TEST OBJECTIVE BEEN REACHED:

Yes

HAVE THE DATA BEEN CORRECTLY RECORDED:

Yes

12. WATER TEMPERATURE FOR PCC POOL REFILLING

13. REQUESTED INITIAL CONDITIONS

DATA ANALYSIS PERIOD FOR INITIAL CONDITIONS:

Data analysis period: -556 to -496 sec

Initial conditions are calculated over one minute just before connection of Drywells to RPV (phase n°123.9 of Test Procedure)

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M3B

TABLE OF INITIAL CONDITIONS

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Tolerance Value
----------	-----------	------	---------------	--------------------	---------------------------

ENVIRONMENT PARAMETERS

Atmospheric pressure	MP.EN	bar			
Temperature of saturation for atmospheric pressure ( $T_{sat\_EN}$ )		C			

RPV PARAMETERS

Total pressure	MP.RP.1	bar			
Fluid temperatures:					
Spatial average	$T_{F\_mean}(RP)$	C			
Local	MTF.RP.1	C			
	MTF.RP.2	C			
	MTF.RP.3	C			
	MTF.RP.4	C			
	MTF.RP.5	C			
Water level	ML.RP.1	m			

DRYWELL PARAMETERS

*Total pressure	MP.D1	bar			
Air partial pressure	MPG.D1.1	bar			
	MPG.D1.2	bar			
	MPG.D2.1	bar			
	MPG.D2.2	bar			
Gas temperatures:					
Spatial average	$T_{G\_mean}(D1)$	C			
Local	MTG.D1.1	C			
	MTG.D1.2	C			
	MTG.D1.3	C			
	MTG.D1.4	C			
	MTG.D1.5	C			
	MTG.D1.6	C			

\* The Drywell total pressures are not independent variables, they are given by temperatures and air partial pressures. The corresponding tolerance is calculated from temperature and gas partial pressure tolerances.



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M3B

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------

DRYWELL PARAMETERS (Cont'd)

Spatial average	T <sub>G_mean</sub> (D2)	C				
Local	MTG.D2.1	C				
	MTG.D2.2	C				
	MTG.D2.3	C				
	MTG.D2.4	C				
	MTG.D2.5	C				
	MTG.D2.6	C				
Water level	ML.D1	m				
	ML.D2	m				

SUPPRESSION CHAMBER PARAMETE

Total pressure	MP.S1	bar				
** Air partial pressure	MPG.S1	bar				
	MPG.S2	bar				
Water temperatures:						
Spatial average	T <sub>w_mean</sub> (S1)	C				
Local	MTL.S1.1	C				
	MTL.S1.2	C				
	MTL.S1.3	C				
	MTL.S1.4	C				
	MTL.S1.5	C				
	MTL.S1.6	C				
Spatial average	T <sub>w_mean</sub> (S2)	C				
Local	MTL.S2.1	C				
	MTL.S2.2	C				
	MTL.S2.3	C				
	MTL.S2.4	C				

\*\*The Suppression Chamber air partial pressures are not independant variables, they are given by temperatures and total pressures. The corresponding tolerance is calculated from temperature and total pressure tolerances.

PANDA INTEGRAL SYSTEM TEST  
 APPARENT TEST RESULTS

TEST M3B

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------

SUPPRESSION CHAMBER PARAMETERS (Cont'd)

Water Temperatures:

Local	MTL.S2.5	C				
	MTL.S2.6	C				

Gas temperatures:

Spatial average	T <sub>G_mean</sub> (S1)	C				
Local	MTG.S1.1	C				
	MTG.S1.2	C				
	MTG.S1.3	C				
	MTG.S1.4	C				
	MTG.S1.5	C				
	MTG.S1.6	C				

Spatial average	T <sub>G_mean</sub> (S2)	C				
Local	MTG.S2.1	C				
	MTG.S2.2	C				
	MTG.S2.3	C				
	MTG.S2.4	C				
	MTG.S2.5	C				
	MTG.S2.6	C				

Water level	ML.S1	m				
	ML.S2	m				

GDCS PARAMETERS

Total pressure	MP.GD	bar				
----------------	-------	-----	--	--	--	--

Fluid temperatures:

Spatial average	T <sub>F_mean</sub> (GD)	C				
Local	MTF.GD.1	C				
	MTF.GD.2	C				
	MTF.GD.3	C				
	MTF.GD.4	C				

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M3B

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------

GDCS PARAMETERS (Cont'd)

	MTF.GD.5	C				
	MTF.GD.6	C				
	MTF.GD.7	C				
Water level	ML.GD	m				

PCC1 POOL PARAMETERS

Water temperatures:

Spatial average	$T_{w\_mean}(U1)$	C				
Local	MTL.U1.1	C				
	MTL.U1.2	C				
	MTL.U1.3	C				
	MTL.U1.4	C				
	MTL.U1.5	C				
	MTL.U1.6	C				
	MTL.U1.7	C				
Water level	ML.U1	m				

PCC2 POOL PARAMETERS

Water temperatures:

Spatial average	$T_{w\_mean}(U2)$	C				
Local	MTL.U2.1	C				
	MTL.U2.2	C				
	MTL.U2.3	C				
	MTL.U2.4	C				
	MTL.U2.5	C				
	MTL.U2.6	C				
	MTL.U2.7	C				
Water level	ML.U2	m				

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M3B

TABLE OF INITIAL CONDITIONS (Cont'd)


VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	------------------	-----------------------	--------------------	-----------

PCC3 POOL PARAMETERS


Water temperatures:

Spatial average	T <sub>w_mean</sub> (U3)	C				
Local	MTL.U3.1	C				
	MTL.U3.2	C				
	MTL.U3.3	C				
	MTL.U3.4	C				
	MTL.U3.5	C				
	MTL.U3.6	C				
	MTL.U3.7	C				
	MTL.U3.8	C				
	MTL.U3.9	C				
	MTL.U3.10	C				
	MTL.U3.11	C				
	MTL.U3.12	C				
	MTL.U3.13	C				
	MTL.U3.14	C				
	MTL.U3.15	C				
	MTL.U3.16	C				
	MTL.U3.17	C				
	MTL.U3.18	C				
	MTL.U3.19	C				
Water level	ML.U3	m				


PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B




# M3B Test – Drywell and Wetwell Air Partial Pressures




PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B









PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B




# M3B Test – PCC Lower Drum and GDCS Return Line Water Temperatures




PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

### M3B Test – PCC Vent Line Gas Temperatures




PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

# M3B Test – Main Steam Line & Feed Line Flows



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B

### M3B Test – PCC Pool Water Level



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M3B