

Document No.

**ALPHA-607**


Document Title

**PANDA Transient Tests**

**M7 Integral System Test  
Apparent Test Results**

Revision Status						
Rev.	Prepared / Revised by	Approval / Date			Issue Date	Remarks
		P-PM	G-PM	G-SQR		
0	C. Aubert	<i>J. Torbeck</i> 16-IV-96	J. Torbeck 16 April 96	G. Wingate 16 April 96	17 April 96	G-PM & G-SQR approvals on file (P-ERM-38, p.2)





PAUL SCHERRER INSTITUT

Registrierung  
TM-42-96-09  
ALPHA-607-0

Titel  
PANDA Transient Tests  
M7 Integral System Test  
Apparent Test Results

Ersetzt  
---

Autoren/  
Autorinnen  
C. Aubert, J. Dreier, O. Fischer, M. Huggenberger, S.Lomperski,  
H.J. Strassberger

Erstellt  
16.04.96

**Summary:**

This Apparent Test Results (ATR) report is compiled in accordance with the requirements specified in the Test Plan (TP) 25A5764R3 (GE document) section 10. The report covers the results for the PANDA Transient Test M7. The ATR summarizes the apparent results and includes: test number, test objective, test date and time, data recording period, data analysis period, name of data file and ORACLE data tables, list of failed or unavailable instruments considered to be required for the test, list of required instruments with zero or reference check points not in tolerance or in over-range or under-range during test, deviations from test procedure and problems which occurred during test. Statements are made whether or not the test objective has been reached and the data were recorded correctly. A table of actual initial conditions based on average and standard deviation over one minute time period just before the test start for all parameters with a specified acceptance criterion in section 9.2 of TP is provided as well as time history plots over test duration for all top priority measurements.

Verteiler	Abt.	Empfänger/Empfängerinnen	Expl.	Abt.	Empfänger/Empfängerinnen	Expl.		Expl.
42		G. Yadigaroglu	1		<u>GE San Jose CA</u>	1	Bibliothek	
		G. Varadi	1		J.E. Torbeck		Reserve	6
		C. Aubert	1		(for distribution at GE to		Total	19
		T. Bandurski	1		J.R. Fitch, G.A. Wingate,		Seiten	22
		J. Dreier	1		B.S. Shiralkar,		Beilagen	-
		O. Fischer	1		DRF No. T10-00005)		Informationsliste	
		J.Healzer	1				D 1 2 3 4 5 8 9 A	
		M. Huggenberger	1				Visum Abt./Laborleitung:	
		S. Lomperski	1					
	H.J. Strassberger	1						
		PANDA Documentation	2					

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

Contents:	Page
1. Test Objectives	5
2. Reference Documents	5
3. Test Date/Time	5
4. Data Recording Period	5
5. File Names	5
6. ORACLE Data Tables	5
7. RPV Power Curve	6
8. Test Instrumentation	6
9. Deviations from Test Procedure	6
10. List of Deviations from Requested Initial Conditions	7
11. Test Processing	7
12. Requested Initial Conditions	7
-Data Analysis Period for Initial Conditions	7
Environment Parameters	8
RPV Parameters	8
DRYWELL Parameters	8
SUPPRESSION CHAMBER Parameters	9
GDCS Parameters	10
PCC1 Pool Parameters	11
PCC2 Pool Parameters	11
PCC3 Pool Parameters	11
13. Graphs	
M7 Test - RPV, Drywell and Wetwell Pressures	13
M7 Test - Drywell and Wetwell Air Partial Pressures	14
M7 Test - RPV Heater Power	15
M7 Test - RPV and Drywell Temperatures	16
M7 Test - Wetwell Temperatures	17
M7 Test - PCC Lower Drum and GDCS Return Line Water Temperatures	18
M7 Test - PCC Vent Line Gas Temperatures	19
M7 Test - Main Steam Line & PCC Feed Line Flows	20
M7 Test - Main Vent Line 1 Temperatures	21
M7 Test - Main Vent Line 2 Temperatures	22

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

**1. TEST OBJECTIVES:**

The objectives of the PANDA integral system tests are to provide additional data to: a) confirm the capability of TRACG to predict SBWR containment system performance, including potential systems interaction effects (*Integral System Tests*) and b) demonstrate start-up and long-term operation of a passive containment cooling system (*Concept Demonstration*).

The specific objective of test M7, which was initiated with Drywells and PCC units filled with air, is to provide data to determine the PCC condenser start-up characteristics when blanketed with noncondensable gas.

**2. REFERENCE DOCUMENTS:**

Test Plan:	GE document 25A5764R3
Test Procedure:	ALPHA-521-0

**3. TEST DATE/TIME:**

Test Start:	14-NOV-95 / 19:10:30
Test Stop:	15-NOV-95 / 00:20:43
Test Duration:	05:10:13
Test Period:	0 to 18613 sec

**4. DATA RECORDING PERIOD:**

Start:	14-NOV-95 / 18:57:10
Stop:	15-NOV-95 / 00:20:43
Data Recording Period:	-800 to 18613 sec

**5. FILE NAMES:**

Raw Data:	panda_M7.dat
DAS-Configuration / Channel List:	kbt99999999.o12

**6. ORACLE DATA TABLES:**

PANDA\_M7\_MT\_LINE  
PANDA\_M7\_MT\_POOL  
PANDA\_M7\_MT\_REF  
PANDA\_M7\_MT\_VESSEL  
PANDA\_M7\_M\_OTHER  
PANDA\_M7\_M\_TIME  
PANDA\_M7\_KBT  
INFO\_TESTS

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

**7. RPV POWER CURVE:**

Power analysis period: 20 to 18613 sec

Mean value

Maximum negative deviation:

Maximum positive deviation:

Standard deviation:

Power curve tolerance:  $\pm 25.0$  [kW]

Definition of RPV power deviation ( $\Delta$ Power) and standard deviation ( $\sigma$ ):

$$\Delta \text{Power} = \text{Power}_{th} - \sum_{j=1}^6 \text{MW.RP.j}$$

$$\sigma = \sqrt{\frac{1}{n} \sum_{m=1}^n \left( \text{Power}_{th}^m - \sum_{j=1}^6 \text{MW.RP.j}^m \right)^2}$$

$\text{Power}_{th}$ : theoretical power

$\sum_{j=1}^6 \text{MW.RP.j}$ : measured power

$n$ : # of measurements throughout the test

**8. TEST INSTRUMENTATION**

**LIST OF FAILED OR UNAVAILABLE REQUIRED INSTRUMENTS:**

Air partial pressure in DW1	MPG.D1.3	Back-up instrument: MPG.D1.2
Air partial pressure in DW2	MPG.D2.3	Back-up instrument: MPG.D2.2

**LIST OF REQUIRED INSTRUMENTS WITH ZERO NOT IN TOLERANCE OR OVER-RANGE OR UNDER-RANGE DURING TEST:**

None

**9. DEVIATIONS FROM TEST PROCEDURE:**

None

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

## TEST M7

**10. LIST OF DEVIATIONS FROM REQUESTED INITIAL CONDITIONS:****11. TEST PROCESSING****PROBLEMS:**

None

**HAS THE TEST OBJECTIVE BEEN REACHED:**

Yes

**HAVE THE DATA BEEN CORRECTLY RECORDED:**

Yes

**12. REQUESTED INITIAL CONDITIONS****DATA ANALYSIS PERIOD FOR INITIAL CONDITIONS:**

Data analysis period: -120 to -60 sec

Initial conditions are calculated over one minute just before connection of Drywells to RPV (phase n°113.9 of Test Procedure)

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

TABLE OF INITIAL CONDITIONS

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Tolerance Value
----------	-----------	------	---------------	--------------------	---------------------------

ENVIRONMENT PARAMETERS

Atmospheric pressure	MP.EN	bar			
Temperature of saturation for atmospheric pressure ( $T_{sat\_EN}$ )		C			

RPV PARAMETERS

Total pressure	MP.RP.1	bar			
Fluid temperatures:					
Spatial average	$T_{F\_mean}(RP)$	C			
Local	MTF.RP.1	C			
	MTF.RP.2	C			
	MTF.RP.3	C			
	MTF.RP.4	C			
	MTF.RP.5	C			
Water level	ML.RP.1	m			

DRYWELL PARAMETERS

*Total pressure	MP.D1	bar			
Air partial pressure	MPG.D1.1	bar			
	MPG.D1.2	bar			
	MPG.D2.1	bar			
	MPG.D2.2	bar			
Gas temperatures:					
Spatial average	$T_{G\_mean}(D1)$	C			
Local	MTG.D1.1	C			
	MTG.D1.2	C			
	MTG.D1.3	C			
	MTG.D1.4	C			
	MTG.D1.5	C			
	MTG.D1.6	C			

\* The Drywell total pressures are not independent variables, they are given by temperatures and air partial pressures. The corresponding tolerance is calculated from temperature and air partial pressure tolerances.



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------

DRYWELL PARAMETERS (Cont'd)

Spatial average	T <sub>G_mean</sub> (D2)	C				
Local	MTG.D2.1	C				
	MTG.D2.2	C				
	MTG.D2.3	C				
	MTG.D2.4	C				
	MTG.D2.5	C				
	MTG.D2.6	C				
Water level	ML.D1	m				
	ML.D2	m				

SUPPRESSION CHAMBER PARAMETER

Total pressure	MP.S1	bar				
** Air partial pressure	MPG.S1	bar				
	MPG.S2	bar				

Water temperatures:

Spatial average	T <sub>w_mean</sub> (S1)	C				
Local	MTL.S1.1	C				
	MTL.S1.2	C				
	MTL.S1.3	C				
	MTL.S1.4	C				
	MTL.S1.5	C				
	MTL.S1.6	C				
Spatial average	T <sub>w_mean</sub> (S2)	C				
Local	MTL.S2.1	C				
	MTL.S2.2	C				
	MTL.S2.3	C				
	MTL.S2.4	C				
	MTL.S2.5	C				
	MTL.S2.6	C				

\*\*The Suppression Chamber air partial pressures are not independent variables, they are given by temperatures and total pressures. The corresponding tolerance is calculated from temperature and total pressure tolerances.

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------

SUPPRESSION CHAMBER PARAMETERS (Cont'd)

Gas temperatures:

Spatial average	T <sub>G_mean</sub> (S1)	C				
Local	MTG.S1.1	C				
	MTG.S1.2	C				
	MTG.S1.3	C				
	MTG.S1.4	C				
	MTG.S1.5	C				
	MTG.S1.6	C				
Spatial average	T <sub>G_mean</sub> (S2)	C				
Local	MTG.S2.1	C				
	MTG.S2.2	C				
	MTG.S2.3	C				
	MTG.S2.4	C				
	MTG.S2.5	C				
	MTG.S2.6	C				
Water level	ML.S1	m				
	ML.S2	m				

GDCS PARAMETERS

Total pressure	MP.GD	bar				
Fluid temperatures:						
Spatial average	T <sub>F_mean</sub> (GD)	C				
Local	MTF.GD.1	C				
	MTF.GD.2	C				
	MTF.GD.3	C				
	MTF.GD.4	C				
	MTF.GD.5	C				
	MTF.GD.6	C				
	MTF.GD.7	C				
Water level	ML.GD	m				

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS

TEST M7

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------

PCC1 POOL PARAMETERS

Water temperatures:

Spatial average	T <sub>w_mean</sub> (U1)	C				
Local	MTL.U1.1	C				
	MTL.U1.2	C				
	MTL.U1.3	C				
	MTL.U1.4	C				
	MTL.U1.5	C				
	MTL.U1.6	C				
	MTL.U1.7	C				
Water level	ML.U1	m				

PCC2 POOL PARAMETERS

Water temperatures:

Spatial average	T <sub>w_mean</sub> (U2)	C				
Local	MTL.U2.1	C				
	MTL.U2.2	C				
	MTL.U2.3	C				
	MTL.U2.4	C				
	MTL.U2.5	C				
	MTL.U2.6	C				
	MTL.U2.7	C				
Water level	ML.U2	m				

PCC3 POOL PARAMETERS

Water temperatures:

Spatial average	T <sub>w_mean</sub> (U3)	C				
Local	MTL.U3.1	C				
	MTL.U3.2	C				
	MTL.U3.3	C				

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

TABLE OF INITIAL CONDITIONS (Cont'd)

VARIABLE	PROCESSID	UNIT	Average Value	Standard Deviation	Requested Value	Tolerance
----------	-----------	------	---------------	--------------------	-----------------	-----------


PCC3 POOL PARAMETERS (Cont'd)

Water temperatures:

Local


	MTL.U3.4	C				
	MTL.U3.5	C				
	MTL.U3.6	C				
	MTL.U3.7	C				
	MTL.U3.8	C				
	MTL.U3.9	C				
	MTL.U3.10	C				
	MTL.U3.11	C				
	MTL.U3.12	C				
	MTL.U3.13	C				
	MTL.U3.14	C				
	MTL.U3.15	C				
	MTL.U3.16	C				
	MTL.U3.17	C				
	MTL.U3.18	C				
	MTL.U3.19	C				
Water level	ML.U3	m				

# M7 Test – RPV, Drywell and Wetwell Pressures




PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7




PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS


TEST M7



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7









PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

### M7 Test – PCC Lower Drum and GDCS Return Line Water Temperatures




[C] M7 Test - PCC Vent Line Gas Temperatures




PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

### M7 Test – Main Steam Line & PCC Feed Line Flows



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

[C] M7 Test – Main Vent Line 1 Temperatures



PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

PANDA INTEGRAL SYSTEM TEST  
APPARENT TEST RESULTS  
TEST M7

