

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) DONALD C. COOK NUCLEAR PLANT UNIT 1	DOCKET NUMBER (2) 0 5 0 0 0 3 1 5	PAGE (3) 1 OF 0 1
----------------------------------------------------------	--------------------------------------	----------------------

TITLE (4)  
MISSED AUXILIARY BUILDING VENT SAMPLE

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)
1	1	12	8	4	0	2	9	0	0	5	0	0
1	1	12	8	4	0	2	9	0	1	2	1	1

OPERATING MODE (9) 1	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)										
POWER LEVEL (10) 0 5 0	20.402(b)	20.405(c)	50.73(a)(2)(iv)	73.71(b)							
	20.405(a)(1)(i)	50.36(c)(1)	50.73(a)(2)(v)	73.71(c)							
	20.405(a)(1)(ii)	50.36(c)(2)	50.73(a)(2)(vii)		OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
	20.405(a)(1)(iii)	X 50.73(a)(2)(i)	50.73(a)(2)(viii)(A)								
	20.405(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)								
	20.405(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)								

LICENSEE CONTACT FOR THIS LER (12)

NAME T.A. KRIESEL - TECHNICAL PHYSICAL SCIENCES DEPARTMENT	TELEPHONE NUMBER 6 1 6 4 6 5 - 5 9 0 1
---------------------------------------------------------------	-------------------------------------------

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS

SUPPLEMENTAL REPORT EXPECTED (14) <input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE) <input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15) MONTH DAY YEAR
------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

ON NOVEMBER 12, 1984 AT 1000 HOURS WITH THE REACTOR COOLANT SYSTEM IN MODE 1 AT 50 PERCENT REACTOR THERMAL POWER, TECHNICAL SPECIFICATION 3.3.3.10 TABLE 3.3-13 ITEM 3a ACTION STATEMENT NUMBER 28 WAS NOT MET. THIS OCCURRED WHEN A CHEMICAL/RADIATION PROTECTION TECHNICIAN FAILED TO TAKE THE REQUIRED 8 HOUR GRAB SAMPLE AND ANALYZE IT FOR GROSS ACTIVITY AS REQUIRED BY THE ACTION STATEMENT DUE TO THE INOPERABILITY OF THE AUXILIARY BUILDING VENT RADIATION MONITOR (IEEE FUNCTION IDENTIFIER - IL). WITH THE RADIATION MONITOR INOPERABLE THE GRAB SAMPLE WAS REQUIRED AT 1000 HOURS. THE SAMPLE WAS ACTUALLY TAKEN AT 1036 HOURS WHICH EXCEEDS THE ACTION STATEMENT REQUIREMENT BY 36 MINUTES.

TO PREVENT RECURRENCE THE CHEMICAL/RADIATION PROTECTION TECHNICIAN WAS REINSTRUCTED IN THE IMPORTANCE OF TECHNICAL SPECIFICATION REQUIRED SAMPLING AND THAT THESE SAMPLES MUST TAKE PRIORITY OVER OTHER WORK.

8412130413 841211  
PDR ADOCK 05000315  
PDR  
S