

LICENSEE: Georgia Power Company, et al.

FACILITY: Vogtle Electric Generating Plant, Units 1 and 2

SUBJECT: SUMMARY OF APRIL 22, 1996, MEETING WITH GEORGIA POWER COMPANY ON A PROPOSAL FOR ALLOWED OUTAGE TIME FOR THE EMERGENCY DIESEL GENERATORS

Representatives of Georgia Power Company (GPC) met with members of the NRC staff at 1:00 p.m. on April 22, 1996, at NRC headquarters, Rockville, Maryland. The purpose of the meeting was to brief the NRC staff on a GPC proposal for a technical specification change that would provide for a 14-day allowed outage time for the Vogtle Electric Generating Plant (VEGP) emergency diesel generators (EDGs). Enclosure 1 is a list of attendees.

The licensee's briefing was organized and presented in accordance with the slides and charts enclosed as Enclosure 2.

After the licensee presented their conclusions, the staff identified three open items. The proposal needed to include information concerning: (1) the vulnerability of the Plant Wilson (PW) line to extreme weather conditions (at the PW and the VEGP ends); (2) the time required for PW to provide power to the VEGP Class 1E buses; and, (3) the reliability of the PW combustion turbines. A fourth open item was identified in a follow-on telephone conversation on April 25, 1996 (Wheeler for the NRC; Lewis, et. al. for the licensee). This item pointed out the need for the proposal to include, as ancillary information, the impact on the probabilistic risk assessment (PRA) core damage frequency of modeling the existing capability to cross connect EDGs from one unit to the Class 1E buses of the other unit (an existing capability not modeled in the current PRA due to the very low likelihood that such a lineup would become necessary to maintain safe plant operations).

The licensee informed the staff that they would endeavor to have their proposal completed and formally sent to the NRC in 2 weeks.

The meeting adjourned at approximately 4:10 p.m.

090001

^{/s/}
Louis L. Wheeler, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosures: 1. List of Attendees
2. Briefing Slides

DISTRIBUTION (Hard Copy):
Docket File OGC, 0-15 B18
PUBLIC ACRS, TWF
PDII-2 r/f LWheeler

cc w/encl: See next page

DISTRIBUTION (E-Mail):

WRussell/FMiraglia EJordan A. Pal
RZimmerman LBerry M. Wohl
SVarga GTracy, EDO C. Harbuck
EMerschhoff, RII JZwolinski P. Skinner, RII
JCalvo DThatcher

DFOI
111

To receive a copy of this document, indicate in this box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD22:DRPE	E	PM:PD22:DRPE	D:PD22:DRPE				
NAME	LBerry		DWberle/cdw	HBerkow				
DATE	5/6/96		5/6/96	5/6/96				

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\VOGTLE\MEETSUM.AOT

9605090248 960506
PDR ADOCK 05000424
P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 6, 1996

LICENSEE: Georgia Power Company, et al.

FACILITY: Vogtle Electric Generating Plant, Units 1 and 2

SUBJECT: SUMMARY OF APRIL 22, 1996, MEETING WITH GEORGIA POWER COMPANY ON A PROPOSAL FOR ALLOWED OUTAGE TIME FOR THE EMERGENCY DIESEL GENERATORS

Representatives of Georgia Power Company (GPC) met with members of the NRC staff at 1:00 p.m. on April 22, 1996, at NRC headquarters, Rockville, Maryland. The purpose of the meeting was to brief the NRC staff on a GPC proposal for a technical specification change that would provide for a 14-day allowed outage time for the Vogtle Electric Generating Plant (VEGP) emergency diesel generators (EDGs). Enclosure 1 is a list of attendees.

The licensee's briefing was organized and presented in accordance with the slides and charts enclosed as Enclosure 2.

After the licensee presented their conclusions, the staff identified three open items. The proposal needed to include information concerning: (1) the vulnerability of the Plant Wilson (PW) line to extreme weather conditions (at the PW and the VEGP ends); (2) the time required for PW to provide power to the VEGP Class 1E buses; and, (3) the reliability of the PW combustion turbines. A fourth open item was identified in a follow-on telephone conversation on April 25, 1996 (Wheeler for the NRC; Lewis, et. al. for the licensee). This item pointed out the need for the proposal to include, as ancillary information, the impact on the probabilistic risk assessment (PRA) core damage frequency of modeling the existing capability to cross connect EDGs from one unit to the Class 1E buses of the other unit (an existing capability not modeled in the current PRA due to the very low likelihood that such a lineup would become necessary to maintain safe plant operations).

The licensee informed the staff that they would endeavor to have their proposal completed and formally sent to the NRC in 2 weeks.

The meeting adjourned at approximately 4:10 p.m.

A handwritten signature in cursive script, appearing to read "Louis L. Wheeler".

Louis L. Wheeler, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosures: 1. List of Attendees
2. Briefing Slides

cc w/encl: See next page

Georgia Power Company

cc:

Mr. J. A. Bailey
Manager - Licensing
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Mr. J. B. Beasley
General Manager, Vogtle Electric
Generating Plant
P. O. Box 1600
Waynesboro, Georgia 30830

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW., Suite 2900
Atlanta, Georgia 30323

Office of Planning and Budget
Room 615B
270 Washington Street, SW.
Atlanta, Georgia 30334

Office of the County Commissioner
Burke County Commission
Waynesboro, Georgia 30830

Mr. J. D. Woodard
Senior Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Mr. C. K. McCoy
Vice President - Nuclear
Vogtle Project
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Vogtle Electric Generating Plant

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE. Suite 1252
Atlanta, Georgia 30334

Attorney General
Law Department
132 Judicial Building
Atlanta, Georgia 30334

Mr. Thomas P. Mazingo
Program Manager
Nuclear Operations
Oglethorpe Power Corporation
2100 East Exchange Place
P. O. Box 1349
Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
12th Floor
1050 Connecticut Avenue, NW.
Washington, DC 20036

Arthur H. Dombey, Esquire
Troutman Sanders
NationsBank Plaza
600 Peachtree Street, NE.
Suite 5200
Atlanta, Georgia 30308-2216

Resident Inspector
U. S. Nuclear Regulatory Commission
8805 River Road
Waynesboro, Georgia 30830

LIST OF ATTENDEES

NRC

H. Berkow
J. Calvo
L. Wheeler
D. Thatcher
M. Pratt
A. Pal
M. Wohl
C. Harbuck

GPC

L. Ward
S. Kitchens
J. Bailey
K. Pope
A. Streetman
J. Stringfellow
S. Swanson

**MEETING BETWEEN NRC AND GPC
EXTENDED DIESEL GENERATOR
ALLOWED OUTAGE TIME**

APRIL 22, 1996

1:00 PM

AGENDA

I. INTRODUCTION

- PROPOSED EXTENDED ALLOWED OUTAGE TIME (AOT)
- OVERVIEW OF STANDBY AUXILIARY TRANSFORMER (SAT)/PLANT WILSON
- VIDEO OF SAT INSTALLATION

**II. COMPARISON OF PHYSICAL CONFIGURATIONS
VEGP TO PBAPS**

III. NUMARC 8700 GUIDELINES COMPARISON

IV. CDF COMPARISON


V. SAFETY BENEFIT OF EXTENDED DG AOT

VI. SUMMARY

- OPEN ISSUES
- SCHEDULE

**CURRENT PROPOSED VEGP DG EXTENDED
ALLOWED OUTAGE TIME**

- **UP TO AND NOT TO EXCEED 14 DAYS
PROVIDED STANDBY AUXILIARY
TRANSFORMER (SAT) IS AVAILABLE**
- **3 DAYS IF SAT IS NOT AVAILABLE**
- **IF AN EXTENDED OUTAGE IS IN
PROGRESS AND THE SAT BECOMES
UNAVAILABLE, DG MUST BE
RESTORED WITHIN 3 DAYS BUT NOT
TO EXCEED 14 DAYS**
- **PATTERNED AFTER PEACH BOTTOM
IMPROVED TS**



REVISIONS

NO. 1	DATE	DESCRIPTION
1	10/1/55	ISSUED FOR CONSTRUCTION
2	10/15/55	REVISIONS TO ELECTRICAL SYMBOLS
3	10/25/55	REVISIONS TO ELECTRICAL SYMBOLS
4	11/10/55	REVISIONS TO ELECTRICAL SYMBOLS
5	11/25/55	REVISIONS TO ELECTRICAL SYMBOLS

APPENDIX

SEE DRAWING NO. 100-1000 FOR ELECTRICAL SYMBOLS

SEE DRAWING NO. 100-1000 FOR ELECTRICAL SYMBOLS

LEGEND

○ = MOTOR

□ = TRANSFORMER

— = WIRE

— = PIPING


— = CONTROL WIRE

— = INSTRUMENT WIRE

— = SIGNAL WIRE


SOUTHERN COMPANY SERVICES, INC.
GEORGIA POWER COMPANY
ATLANTA VOEGTLE NUCLEAR PLANT

DATE: 10/1/55
 DRAWN BY: [Name]
 CHECKED BY: [Name]
 APPROVED BY: [Name]




PLANT VENTILATION LABORATORIES

1	2	3	4	5	6	7	8	9	10
11	12	13	14	15	16	17	18	19	20
21	22	23	24	25	26	27	28	29	30
31	32	33	34	35	36	37	38	39	40
41	42	43	44	45	46	47	48	49	50
51	52	53	54	55	56	57	58	59	60
61	62	63	64	65	66	67	68	69	70
71	72	73	74	75	76	77	78	79	80
81	82	83	84	85	86	87	88	89	90
91	92	93	94	95	96	97	98	99	100





ELECTRICAL DISTRIBUTION - ONE LINE
DIAGRAM



ON - SITE AC

10-07-01-001-004
 1-03-01-01-002-002
 1-1-01-01-001-005
 1E-01-01-001-001





PEACH BOTTOM ATOMIC POWER STATION SBO LINE AND PSI PROJECT

NUMARC 8700 Criteria for AAC Power Sources and miscellaneous info	Vogtle Electric Generating Plant	Peach Bottom (Docketed Interpretation)
SBO Duration and Coping Method	4 hours coping - (AC Independent)	8 hours / AAC power source
Type of AAC Source	Wilson Combustion Turbine Facility - 6 CTs @ 60 MVA, 2 CTs with enhanced blackstart capability	Conowingo Hydro Facility - Black start capable - (11 units - 7 @ 36 MW and 4 @ 65 MW)
AAC Line Capacity and Operation	12.5 MVA at 13.8 kV, energized continuously but unloaded	15 MVA at 34.5 kV, energized continuously and minimally loaded
AAC Interconnecting Line Design	Direct buried cable and concrete duct run - 1 mile	Submerged cable - 9 miles
AAC Source Connection Design	Wilson substation - manually operated disconnects switches and remotely operated circuit breaker	Conowingo substation circuit breaker
AAC Load Connection Design	Wilson/SAT line terminates in the VEGP low voltage switchyard - disconnect switches.	Conowingo line terminates into small new switchyard then to existing SU switchgear.
Common Cause Failure Vulnerability -	Cable bus is shared. Wilson - completely independent facility.	Distribution system route is shared. Conowingo - completely independent facility.
Nuclear Facility AAC Annunciation Provided	VEGP Control Room	Peach Bottom Control Room
Normal emergency shutdown loads	6.4 MVA (maximum) (1 train - LOSEP/SI)	9 MW (SBO loads for units 2 & 3)
AAC Operations and Staffing	"On-Call" VEGP staff - Travel from VEGP to Wilson = 1 mile	Staffed continuously but NOT under Peach Bottom Management
Blackstart availability	< 4 hours	< 1 hour
Power Quality / Stability	Wilson/SAT line has been NRC approved as a qualified offsite circuit. (GDC 17) Any 1 CT can maintain stable voltage and frequency	Conowingo line has <u>not</u> been approved as a qualified offsite AC circuit. Requires 2 units to maintain transient stability during shutdown. 1 @ 36 MW and 1 @ 65 MW

NUMARC 8700 Criteria for AAC Power Sources and miscellaneous info	Vogle Electric Generating Plant	Peach Bottom (Docketed Interpretation)
<p>NUMARC-8700 AAC Performance Measures</p> <p>(1) Facility Generating Source Reliability/Availability data</p> <p>(2) AAC source alignment functional testing</p> <p>(3) Timed blackstart of AAC with complete alignment and loading of safe shutdown equipment or equivalent load characteristics</p>	<p>Vogle / Wilson CT Facility</p> <p>(1) > 95% available</p> <p>(2) Performed regularly</p> <p>(3) Blackstart functional test on 1 of enhanced blackstart CTs - (Not timed.)</p>	<p>Peach Bottom / Conowingo Dam</p> <p>(1) 95% target Availability</p> <p>(2) Approximately every two years</p> <p>(3) Timed blackstart with alignment performed during pre-operational testing</p>
<p>System/Grid Recovery Priority, Protocol, Communications</p>	<p>Priority from multiple choices 1) System Inter-tie 2) Harlee Branch 3) Wallace Dam 4) Wilson CT Facility -</p> <p>Restoration alignments are pre-analyzed, and switching requirements are proceduralized.</p>	<p>Communication between Conowingo and Peach Bottom - only through System dispatcher</p>
<p>Equipment QA and maintenance</p>	<p>Standard utility maintenance practices.</p> <p>Qualified GDC 17 source, Maintenance rule (10 CFR 50.65) applies.</p>	<p>Standard utility maintenance practices.</p>
<p>Weather Protection</p>	<p>Wilson is protected from adverse weather</p> <p>Severe Weather - Minimal protection</p> <p>Extremely severe weather - No protection</p>	<p>Hydro facility - some weather advantage</p> <p>Severe Weather - Minimal protection</p> <p>Extremely severe weather - No protection</p>

Wilson/SAT Line

- Power Source General Criteria

1. Wilson Combustion Turbine Generating Facility
2. Peaking Power - 6 Units @ 60 MVA
3. Distance from VEGP = 1 mile

- Connectability

1. Underground route from Wilson to VEGP
2. Not normally connected to on or off-site electrical distribution
3. Bypasses the VEGP switchyard offsite bus breaker-and a half distribution scheme
4. Connection by disconnect switches to any train of either Unit for shutdown purposes

- Minimal Potential for Common Cause Failure

1. Plant Wilson is a completely self sufficient generating facility
2. Interconnection design -
 - Protective relaying provided to isolate faults
 - Ground potential difference minimized
 - Components sized for potential fault currents

- Availability After onset of Station Blackout

1. Blackstart capable and aligned for safe shutdown purposes < 4 hrs
2. Envelopes the VEGP Station Blackout AC Independent coping analysis

- Capacity

1. Fully capable of supplying power for one complete safety train of normal shutdown systems and equipment
2. Capable of dual unit shutdown with manual actions

- Operation and reliability

1. Wilson/SAT Line continuously energized
2. Availability > 95%

PBAPS

CONDITIONS	CDF (/rx-yr)	% OF BASE CASE
BASE CASE	5.77E-06	100
1 DG OUT 30d WITHOUT CONOWINGO	7.46E-06	129
1 DG OUT 30d WITH CONOWINGO	5.45E-06	94.5

RELATIVE WORTH OF CONOWINGO = $129 - 94.5 / 129 = 27\%$

VEGP

CONDITIONS	CDF (/rx-yr)	% OF BASE CASE
BASE CASE	4.45E-05	100
1 DG OUT 30d WITHOUT PLANT WILSON	5.80E-05	130
1 DG OUT 30d WITH PLANT WILSON	3.36E-05	75.5

RELATIVE WORTH OF PLANT WILSON = $130 - 75.5 / 130 = 42\%$

VEGP DIESEL GENERATOR AOT INFORMATION

<u>CONDITION</u>	<u>CDF NO PW RECOVERY</u>	<u>CDF WITH PW RECOVERY</u>	<u>% CDF REDUCTION</u>
HISTORICAL MAINTENANCE	4.45 E-05	2.875 E-05	35 % ⁽¹⁾
3 DAY DG AOT	4.685 E-05	2.956 E-05	37 % ⁽²⁾
7 DAY DG AOT		3.063 E-05	34 % ⁽²⁾
14 DAY DG AOT		3.251 E-05	30 % ⁽²⁾
21 DAY DG AOT		3.440 E-05	26 % ⁽²⁾

(1) BASED ON 4.45 E-05

(2) BASED ON 4.685 E-05

CDF - CORE DAMAGE FREQUENCY

PW - PLANT WILSON

AOT - ALLOWED OUTAGE TIME

POTENTIAL SAFETY BENEFIT OF EXTENDED DG AOT

- **NUREG 1449 LISTED A LOSP WITH AN EDG OUT OF SERVICE DURING SHUTDOWN AS THE NUMBER ONE EXAMPLE OF AN EVENT WITH A CONDITIONAL CORE MELT PROBABILITY ABOVE 1 E-04**
 - **POTENTIAL FOR HIGHER PROBABILITY OF AN INITIATING EVENT DURING SHUTDOWN**
 - **CORE COOLING DEFENSE IN DEPTH IS REDUCED DURING SHUTDOWN**
 - **HUMAN FACTORS - NON ROUTINE PLANT CONFIGURATIONS**
 - **ELECTRICAL DEFENSE IN DEPTH IS REDUCED DURING SHUTDOWN**

- **AT VEGP DG MAINTENANCE HAS TO BE PERFORMED DURING SHUTDOWN BECAUSE OF RESTRICTIVE TS AOT (3 DAYS)**

- **AN EXTENDED AOT THAT WOULD ALLOW ON LINE DG MAINTENANCE COULD PROVIDE NET SAFETY BENEFIT BY REDUCING THE RISK OF THE ABOVE FACTORS**

SUMMARY

VEGP Conclusions :

- Overall safety benefit balancing shutdown and operating risk, with proposed EDG AOTs
- The Wilson/SAT source compares favorably with Peach Bottom/Conowingo source on a technical basis
- Believe that VEGP is within the “four corners of the envelope” of the Peach Bottom/Conowingo source
- ITS should be approved by NRC with the proposed EDG AOTs

Open Issues:

- To be identified by the NRC

Schedule:

- Can we establish one ?