

May 2, 1996

LICENSEE: Northern States Power Company (NSP)

FACILITY: Prairie Island Nuclear Generating Plant, Units 1 and 2

SUBJECT: MEETING WITH NSP TO DISCUSS 1% POWER UPRATE FROM INSTRUMENT ERROR REDUCTION

On April 24, 1996, the staff met with representatives from NSP and Excel Services to discuss a possible 1% power uprate of the Prairie Island units. Attachment 1 contains a list of meeting attendees. Representatives from NSP and Excel Services made presentations detailing the potential power uprate. Attachment 2 is a copy of the overhead slides used during the presentations.

The 1% power uprate is made feasible due to the installation of more accurate feedwater flow meters, which reduces the uncertainty in the core thermal power calculation by approximately 1%. The power uprate would require both a Technical Specification amendment and an exemption from a portion of 10 CFR Part 50, Appendix K. The licensee plans to submit its application to the NRC for review by December 1996.

Original Signed By: L. Tran

Beth A. Wetzel, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos: 50-282, 50-306

Attachments: As stated

cc w/att: See next page

DOCUMENT NAME: G:\WPDOCS\PRAIRIE\PIMTG496.SUM

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD31	C	PM:PD31	E	(A)D:PD31
NAME	CJamerson		BWetzel	LR	MReinhart
DATE	5/2/96		5/2/96		5/2/96

OFFICIAL RECORD COPY

9605090252 960502
PDR ADOCK 05000282
P PDR

DF01
111
NRC FILE CENTER COPY

MEETING SUMMARY DATED: May 2, 1996

DISTRIBUTION:

HARD COPY

Docket File
PUBLIC
PD3-1 Reading
OGC
ACRS

E-MAIL

W. Russell/F. Miraglia
R. Zimmerman
J. Roe(JWR)
E. Adensam(EGA1)
M. Reinhart(FMR)
B. Wetzel(BAW)
C. Jamerson(CAJ1)
E. Jordan (e-mail to JKR)
T. J. Kim (TJK3)
H. Balukjian(HXB)
C. Douth(CKD)
J. Ganiere(JKG)
B. McCabe, RIII
M. Jordan, RIII

090062



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 2, 1996

LICENSEE: Northern States Power Company (NSP)

FACILITY: Prairie Island Nuclear Generating Plant, Units 1 and 2

SUBJECT: MEETING WITH NSP TO DISCUSS 1% POWER UPRATE FROM INSTRUMENT ERROR
REDUCTION

On April 24, 1996, the staff met with representatives from NSP and Excel Services to discuss a possible 1% power uprate of the Prairie Island units. Attachment 1 contains a list of meeting attendees. Representatives from NSP and Excel Services made presentations detailing the potential power uprate. Attachment 2 is a copy of the overhead slides used during the presentations.

The 1% power uprate is made feasible due to the installation of more accurate feedwater flow meters, which reduces the uncertainty in the core thermal power calculation by approximately 1%. The power uprate would require both a Technical Specification amendment and an exemption from a portion of 10 CFR Part 50, Appendix K. The licensee plans to submit its application to the NRC for review by December 1996.

A handwritten signature in cursive script, appearing to read "Beth A. Wetzel".

Beth A. Wetzel, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos: 50-282, 50-306

Attachments: As stated

cc w/att: See next page

Northern States Power Company

Prairie Island Nuclear Generating
Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

Mr. Roger O. Anderson, Director
Licensing and Management Issues
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

Site General Manager
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, Minnesota 55089

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
455 Minnesota Street
Suite 900
St. Paul, Minnesota 55101-2127

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
1719 Wakonade Drive East
Welch, Minnesota 55089-9642

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Jeff Cole, Auditor/Treasurer
Goodhue County Courthouse
Box 408
Red Wing, Minnesota 55066-0408

Kris Sanda, Commissioner
Department of Public Service
121 Seventh Place East
Suite 200
St. Paul, Minnesota 55101-2145

Site Licensing
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, Minnesota 55089

March 1995

MEETING ATTENDEES

<u>Name</u>	<u>Organization</u>
B. Wetzel	NRC
T. Kim	NRC
H. Balukjian	NRC
C. Douth	NRC
J. Ganiere	NRC
D. Vincent	NSP
T. Verbout	NSP
J. Regan	Corey-Regan Inc.
A. Winter	Excel Services
J. Harrison	Excel Services
J. Voss	Excel Services

Prairie Island Nuclear Plant

1% Power Uprate from Instrument Error Reduction

Meeting Participants

- Tom Verbout Northern States Power
- Dale Vincent Northern States Power
- Jerry Voss Excel Services
- Andy Winter Excel Services
- John Harrison Excel Services
- Jenny Regan Corey Regan

Performance Changes

- Instrument Error Reduction
- Turbine upgrade
- Steam Generator Tube Performance

Regulatory Impact

- License Changes
 - » Rated Thermal Power
- Technical Specification Changes
- Specific Exemption
 - » 10CFR50 Appendix K

Appendix K

- 10CFR 50 Appendix K
 - » “. . . it shall be assumed that the reactor has been operating continuously at a power level at least 1.02 times the licensed power level (to allow for such uncertainties as instrument error) . . .”

Specific Exemption

- 10 CFR 50.12
 - » (a)(2)(ii) - not necessary
 - » (a)(2)(vi) - other material circumstance

Bases for Appendix K 102% Requirement

- 10 CFR 50 Appendix K History
- Regulatory Guide 1.49 History
- Licensing and Design Bases Review

Calorimetric Overview

- Purpose
- Present configuration and methods of calculation
- Instrument accuracy and its effect on calorimetric uncertainty
- Calorimetric results with previous configuration (w/o LEFM)
- Calorimetric Results with new configuration (w/LEFM)

Calorimetric Technical Methodology

- Determine equations used for obtaining thermal power
- Determine individual instrument uncertainties
- Combine instrument uncertainties using ISA-S67.04

Calorimetric Presentation (continued)

- Determine process errors and associated uncertainties
- Determine uncertainty of each process
- Determine corresponding thermal power error for each process uncertainty
- Combine thermal power errors to yield overall calorimetric uncertainty

Calorimetric Conclusion

- Based on the uncertainties associated with the calorimetric instruments and processes, it can be demonstrated that the calorimetric uncertainty is less than 0.5% of thermal power

Accuracy Analysis
Methodology Feedwater Mass
Flow by LEFM

Method of ASME PTC 19.1

- Define Measurement Process
- List Elemental Error Sources
- Estimate Elemental Errors
- Calculate Bias and Precision Errors for Each Parameter
- Propagate the Bias and Precision Errors
- Calculate Uncertainty

LEFM Error Sources

- Timing and electronic errors
- Geometry measurement
- Fluid property correlations
- Hydraulic profile measurement

ASME Power Test Code (PTC) 19.1, Part 1, 1985

- “Measurement Uncertainty, Instruments and Apparatus”
- Specifies procedures for evaluation of uncertainties and propagation of those errors to total uncertainties
- Method used for LEFM mass flow measurement uncertainty

LEFM Operation

- Ultrasonic transit time flow meter, repeatedly measures flow velocity by difference in transit time of upstream and downstream pulses
- Four chordal acoustic paths across flow metering section, transducers mounted in recessed wells
- Volumetric flow obtained by integrating across four acoustic paths, using profile factor




Figure 2. Acoustic Flowmeter Pipe Application — Typical Installation Geometry

LEFM Elemental Errors

- Pulse time of flight and differential measurement
- Pipe inner diameter
- Distance from path to pipe centerline
- transducer face-to-face path length
- Acoustic path angle
- Gaussian integration precision
- Fluid pressure precision
- Fluid temperature correlation
- Fluid density correlation
- Hydraulic profile factor measurement

Error Propagation

- Mass flow sensitivity coefficient calculated for each elemental error contribution by partial differentiation of flow algorithm
- Resulting errors combined by algebraic sum if dependent, by root-sum-square if independent

Error Propagation (continued)

- Mass flow accuracy calculated as percent of flow in each of two feed lines, then a percent of total feed mass flow, propagating errors algebraically or by RSS as appropriate

Results-LEFM Calculated Mass Flow Accuracy

- Two flow meters, one on each steam generator supply line
- Each meter accurate to +/- 0.59% mass flow in each line
- Total rated feedwater mass flow accuracy +/- 0.45%

Conclusions

- LEFM reduces calorimetric error
- PI submittal target - December 1996