

May 6, 1996

LICENSEE: Northern States Power Company (NSP)

FACILITY: Monticello Nuclear Generating Plant

SUBJECT: MEETING WITH NSP TO DISCUSS THE STATUS OF LICENSING ISSUES

On April 11, 1996, the staff met with a representative from NSP to discuss the status of licensing issues for Monticello, including the proposed power uprate program. A list of meeting attendees is attached.

The focus of the discussion was on the status of the licensee's current effort to develop a technical specification amendment request package on power uprate. NSP is working with General Electric to perform engineering analyses to support its application for an extended power uprate (up to 1775 Mwt or 6.3 percent of the currently licensed power level of 1670 Mwt). The licensee stated that it is following the guidelines established in the NRC staff position paper, "NRR Position Concerning Generic BWR Extended Power Uprate Program," issued on February 8, 1996.

No significant modifications to the nuclear steam supply systems and components are expected; however, some major balance-of-plant equipment modifications (i.e., main turbine replacement) have been identified to support the proposed power uprate. The turbine replacement work is currently ongoing while the plant is in a refueling outage. The licensee's application for power uprate is expected in June 1996.

Original Signed By:

Tae Kim, Senior Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No: 50-263

Attachment: As stated

cc w/att: See next page

DOCUMENT NAME: G:\WPDOCS\MONTICELLO\MTG496.SUM

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD31	PM:PD31	(A)D:PD31
NAME	CJamerson	TJKim	MReinhart
DATE	5/3/96	5/6/96	5/6/96

OFFICIAL RECORD COPY

090067

NRC FILE CENTER COPY

9605100091 960506
PDR ADOCK 05000263
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 6, 1996

LICENSEE: Northern States Power Company (NSP)

FACILITY: Monticello Nuclear Generating Plant

SUBJECT: MEETING WITH NSP TO DISCUSS THE STATUS OF LICENSING ISSUES

On April 11, 1996, the staff met with a representative from NSP to discuss the status of licensing issues for Monticello, including the proposed power uprate program. A list of meeting attendees is attached.

The focus of the discussion was on the status of the licensee's current effort to develop a technical specification amendment request package on power uprate. NSP is working with General Electric to perform engineering analyses to support its application for an extended power uprate (up to 1775 MWt or 6.3 percent of the currently licensed power level of 1670 MWt). The licensee stated that it is following the guidelines established in the NRC staff position paper, "NRR Position Concerning Generic BWR Extended Power Uprate Program," issued on February 8, 1996.

No significant modifications to the nuclear steam supply systems and components are expected; however, some major balance-of-plant equipment modifications (i.e., main turbine replacement) have been identified to support the proposed power uprate. The turbine replacement work is currently ongoing while the plant is in a refueling outage. The licensee's application for power uprate is expected in June 1996.

A handwritten signature in cursive script, appearing to read "Tae Kim".

Tae Kim, Senior Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No: 50-263

Attachment: As stated

cc w/att: See next page

Northern States Power Company

Monticello Nuclear Generating Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, Minnesota 55362

Plant Manager
Monticello Nuclear Generating Plant
ATTN: Site Licensing
Northern States Power Company
2807 West County Road 75
Monticello, Minnesota 55362-9637

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, Minnesota 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, Minnesota 55119

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Commissioner of Health
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, Minnesota 55440

Darla Groshens, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, Minnesota 55313

Kris Sanda, Commissioner
Department of Public Service
121 Seventh Place East
Suite 200
St. Paul, Minnesota 55101-2145

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
445 Minnesota Street
Suite 900
St. Paul, Minnesota 55101-2127

Mr. Roger O. Anderson, Director
Licensing and Management Issues
Northern States Power Company
414 Nicollet Mall
Minneapolis, MN 55401

MEETING ATTENDEES

<u>Name</u>	<u>Organization</u>
T. Kim	NRC
F. Akstulewicz	NRC
S. Flanders	NRC
C. Craig	NRC
M. Young	NRC
M. Engen	NSP

SUMMARY OF APRIL 11, 1996 MEETING DATED: May 6, 1996

DISTRIBUTION:

HARD COPY

Docket File
PUBLIC
PD3-1 Reading
OGC
ACRS
T. J. Kim

E-MAIL

W. Russell/F. Miraglia(FJM)
R. Zimmerman(RAZ)
J. Roe(JWR)
E. Adensam(EGA1)
M. Reinhart(FMR)
T. Kim(TJK3)
C. Jamerson(CAJ1)
E. Jordan(JKR)
B. McCabe(BCM)
M. Jordan, RIII(MJJ)
F. Akstulewicz(FMA)
S. Flanders(SCF)
C. Craig(CMC1)
M. Young(MAY)