ORIGINAL **UNITED STATES NUCLEAR REGULATORY COMMISSION**

IN THE MATTER OF:

DOCKET NO: 50-322-0L

LONG ISLAND LIGHTING COMPANY

(Shoreham Nuclear Power Station)

LOCATION: HAUPPAUGE, NEW YORK

PAGES: 28768 - 28862

DATE:

FRIDAY, MARCH 8, 1985

expris to 19SCBP, E/W-439

ACE-FEDERAL REPORTERS, INC.

ADDCK 05000322

Official Reporters 444 North Capitol Street Washington, D.C. 20001 (202) 347-3700

NATIONWIDE COVERAGE

UNITED STATES OF AMERICA

2

1

NUCLEAR REGULATORY COMMISSION

3

4

5

6

7

9

8

10

11

12

13

14

15

16

17

18

19

20

21

22

23

Ace-Federal Reporters, Inc.

24 25 LONG ISLAND LIGHTING COMPANY

In the matter of:

(Shoreham Nuclear Power Station):

Court of Claims, State Office Building, Hauppauge, Long Island, New York.

Docket No. 50-322-OL

Friday, March 8, 1985.

The hearing in the above-entitled matter was reconvened, pursuant to adjournment, at 9:00 a.m. BEFORE:

> JUDGE LAWRENCE BRENNER, Chairman, Atomic Safety and Licensing Board.

JUDGE PETER A. MORRIS, Member.

JUDGE GEORGE A. FERGUSON, Member.

APPEARANCES:

On behalf of Long Island Laghting Company:

TIM ELLIS, Esq., Hunton and Williams, Richmond, Virginia.

ODES L. STROUPE, JR., Esq. Hunton and Williams, Raleigh, North Carolina.

On behalf of Suffolk County:

ALAN DYNNER, Esq. and DOUGLAS SCHEIDT, Esq., Kirkpatrick and Lockhart,

Washington, D. C.

On behalf of the Commission Staff:

' Ace-Federal Reporters, Inc.

RICHARD GODDARD, Esq. and BERNARD M. BORDENICK, Esq., Nuclear Regulatory Commission,

Washington, D. C.

CR22263.0 WRB/sjg

CONTENTS

BOARD

WITNESSES DIRECT CROSS REDIRECT RECROSS EXAM

Charles Rau 3 Edward J. Youngling) Milford M. Schuster) Duane P. Johnson and

Harry F. Wachob by Mr. Ellis

by Mr. Dynner by Mr. Ellis by Judge Morris 28790

28800 28809

28848

RECESSES:

A.M. - 28841

7 LAY-IN - ADDITIONAL CINDER BLOCK TESTIMONY BY DR. DUANE P. JOHNSON, DR. CHARLES A. RAU, JR., MILFORD H. SCHUSTER, DR. 10 HARRY F. WACHOB AND EDWARD J. YOUNGLING ON BEHALF OF LONG ISLAND LIGHTING COMPANY; TWO-PAGE STIPULATION OF JANUARY 14, 1985, SIGNED BY COUNSEL FOR ALL PARTIES RE: CAM GALLERY CRACKS, Follows Page 28799.

EXHIBITS

13 NUMBER IDENTIFIED RECEIVED 28844 28844

LILCO Exhibit C-43

15 16

12

5

6

7

17

18

19

20

21

22

23

Ace-Federal Reporters, Inc. 25

PROCEEDINGS

2

JUDGE BRENNER: Good morning. We are on the record

3

now.

Mr. Stroupe, you said you had a preliminary matter.

Is it something that we have to take up this week?

MR. STROUPE: Yes, your Honor, I believe so.

7

5

6

8

10

11

12

13

14

15

16

17

18

19

20

22

21

23

25

2.4

So at this time we would renew that motion. turns out that the crankshaft stress in both those instances was contained in prior LILCO crankshaft exhibits, Exhibit C-16 and Exhibit C-17 from the hearing last fall, and it has the stresses, as can be seen from that proffered testimony,

In response yesterday to your question as to whether or not I wish to make an offer of proof with regard to the motion I made or the proposal I made to present the testimony of Paul R. Johnston, I would now like to present to the Board proffered testimony which I have already furnished a copy of to the CAunty and to the Staff.

'I would just like to state for the record several things:

One, that we believe indeed that this is in the nature of rebuttal testimony because it addresses two issues raised in the questioning of Dr. Bush where we believe he was incorrect in the statements that he made, specifically with regard to the crankshaft stresses, and specifically with regard to tensile stresses.

WRB/eb2

7

10

11

12

18

19

20

23

from 1750 kw up to 3800 kw. And we would make that offer of proof this morning.

JUDGE BRENNER: Well, we'll consider it, not right now. You've made a motion for reconsideration and we will consider whether to reconsider it. We won't be able to do that today.

You had better give us the exhibits, just one copy for the Board to share on loan would be fine, if you could do that Monday.

MR. STROUPE: I will do that.

JUDGE BRENNER: We will look at it on Monday.

MR. STROUPE: Also in an effort to try to assist the Board, I believe one of the Board members, perhaps Judge Morris, asked for the ABS certificates, or grade of the ABS metal for the crankshafts. And that is contained also in LILCO Crankshaft Exhibit C-12, which is already in the record. And if the Board wishes, we will make copies of that available Monday, too.

JUDGE BRENNER: Why don't you do that also?

But we want to get from Dr. Bush what he thinks the composition is, and then we will have it in both places. I at least don't know what C-12 is off-hand.

MR. GODDARD: Judge Brenner, Dr. Bush informed me this morning that he misstated a matter in response to a question asked I believe by Judge Ferguson yesterday. He has

1

3

4 5

6 7

8

9

10

11 12

13

15

16

17

20

19

22

23

24

prepared something. We would like him to read it into the record this morning to correct his testimony of yesterday.

JUDGE BRENNER: Have you discussed this with the other parties?

MR. GODDARD: I have discussed it with the other parties. They have not had a chance to read the information that's involved. It is a correction to one of Dr. Bush's answers vesterday.

JUDGE BRENNER: What is the subject?

MR. GODDARD: It was with regard to the stresses on the crankshaft, the tension on the crankshaft.

JUDGE BRENNER: Well, I don't know what he is going to say of course. It might be better to do it now, so we don't have to then go back in case it leads to questions of other witnesses also.

Does any party have a problem?

MR. STROUPE: Your Honor, we don't. We believe this relates to a portion of the rebuttal testimony that we have proffered.

MR. DYNNER: I would like to see what he is going to say because if it is going to reopen new issues, then I would object. If it is just a simple correction of a number or something like that, I would not object.

JUDGE BRENNER: All right. Well, of course we will allow the witness to make a correction, and if it is something

3

5

7

10

11

12

14

else we will deal with it.

All right, I guess you want Dr. Bush back on the stand.

MR. GODDARD: Yes, that's correct.

Dr. Bush, will you please take the stand at this time?

JUDGE BRENNER: And as long as you are going to be focusing or asking him questions, Mr. Goddard, ask him about the composition of the ABS metal in the crankshaft at Shoreham. Whereupon,

SPENCER H. BUSH

resumed the stand and, having been previously duly sworn, was examined and testified further as follows: .

MR. GODDARD: I will also state at this time for the information of all parties that testimony was served on all parties and the Board entitled "Testimony of Carl H. Berlinger on Load Contentions Concerning TDI Emergency Diesel Generators at the Shoreham Nuclear Power Station," dated February 5, 1985.

Neither Dr. Berlinger nor any other Staff witness will sponsor that testimony, and it will not be introduced into evidence in this proceeding. I don't want anybody to be confused by the fact that we served it and --

JUDGE BRENNER: Moreover, you emphasized that and drew our attention to it just recently, so it is good you made

20

22

the statement.

2

1

3

5

6

7 8

9

10

12

13

14

16

17

18

19

20

21

22

23

24

25 A Yes, I am.

I will state for the record that in fact it is not testimony. There is no substantive testimony in it whatsoever. It is one page which states his name and occupation, his qualifications. He references the fact that a copy of his qualifications is in the record. And beyond that, the testimony, so-called, states in its entirety that:

"This testimony is for purposes of

stating that the joint testimony filed by our consultant contractor, Battelle Pacific

Northwest Laboratory, has been reviewed by the
NRC Staff and that their testimony has been accepted for filing on behalf of the NRC Staff."

Since it is not going to be in the record, I want to say that I disagree with your characterization of it as testimony. And now we know what it said in case anybody wants to disagree with my characterization.

Go ahead.

MR. GODDARD: Thank you, Judge Brenner.

FURTHER DIRECT EXAMINATION

BY MR. GODDARD:

Q Dr. Bush, yesterday you indicated you would provide the composition of the ABS steel for the Board upon request.

Are you prepared to do so at this time?

Q Please proceed.

Ace-Federal Reporters, I

A The shafts, as either certified by ABS or going directly to the Krupp records have carbon contents ranging from .46 to .50 percent, silicon contents ranging from .05 to .12 percent, manganese contents ranging from .65 to .70 percent, phosphores contents ranging from .006 to .010 percent, sulphur contents ranging from .008 to .010 percent, chromium contents --

JUDGE BRENNER: Let me stop you for a minute, Dr. Bush. I want to check something.

(Pause.)

JUDGE BRENNER: Go ahead, Dr. Bush. I'm sorry.

THE WITNESS: Chromium contents from .63 to :69 percent, and in one instance, aluminium content of .003 percent which would be used as a grain refiner.

In essence, these are what one calls a 50 carbon steel with the exception of the chromium, and at that level of chromium it would fall in the range that ASTM would designate roughly as a 50 50 steel.

The attachments consist of the American Bureau of Shipping Reports, as I cited and, in addition, the reports from Krupp.

MR. GODDARD: Thank you, Dr. Bush.

BY MR. GODDARD:

O Dr. Bush, you indicated to me this morning that you

1

3

4 5

6

8

9

10

12

11

14

13

15

16

17

18

19

20

22

23

24

ce-Federal Reporters, I

25

wished to correct a misstatement which you made on the record yesterday in response to a question asked by Judge Ferguson. Are you prepared to do so at this time?

A Yes.

Q Will you please state the subject matter of the question to which you initially responded?

A The specific item as to which I was incorrect in my statement had to do with a misrepresentation of the tensile load, and I would like to clarify the record by indicating why it would not be important in the first place and, secondly, in that fact that it is taken care of automatically in effect, if I may do so.

Q D & Bush, before you proceed, I notice you are apparently reading from a few pages which you have in front of you. Were those prepared by you?

A Yes.

Q When did you prepare those notes?

A About five o'clock this morning.

Q Did you prepare those by yourself and without discussion of the content thereof with any other person?

A That's correct.

Q And your purpose in doing so was to correct what you perceived as a misstatement made on the record yesterday?

A That's correct.

Q Thank you.

Will you proceed, please?

2

3

5

6

7 8

9

10

11

12

13

14

15

16

17

18

19

20

21

22 23

24

25

My statements to questions by Judge Ferguson were incorrect in one specific respect. I misrepresented the tensile load on the shaft by equating it to the value of the tension strain gauge values. I certainly knew better and can only attribute it to battle fatigue, plus a massive injection of undigested data which I received the previous day.

In fact our method of analysis which was a vector summation of bending and torsional stresses will yield a maximum equivalent alternating stress comparable to that cited in the Failure Analysis document which I cited on March 7th.

Tensile stresses should play little or not role if one examined the rotating shaft for the following reasons:

The shaft rests on a bearing surface so in essence it floats. This means one would not expect major end thrust leading to axial tension or compression. A rotating shaft, particularly one transmitting loads through a gear train, will be subjected to twisting generating torsional stresses along the shaft.

The rapid rotation of the shaft, particularly with a shaft such as a crankshaft where the local centers of gravity are offset from the centerline of the shaft, will cause portions of that shaft to essentially lift off its

7 8

and 1 24

seat, generating highly localized bending stresses. These will concentrate at the discontinuity regions where crank joins shaft, and these discontinuity regions, parenthetically the fillets, are the region of maximum stress concentration and highest probability of failure.

As noted previously, II misrepresented the tension stress gauge as tensile stress. In fact there are two gauges, 45 degrees tension and compression, whose product is resolved in the torsional shear, plus a minor component of tension, plus a bending gauge. In fact the tensile stress in essence is buried in the data and it is a small value.

One can combine into major and minor principal stresses which are again combined into a mean stress and an alternating stress component which is the common approach.

Otherwise the bending and shear stresses can be combined vectorially providing the phase relationships of load versus angle of rotation, providing these are known.

Tensile stresses are a factor at much higher rotational speeds such as occur in large steam turbines.

However, they are circumferential, not axial. Here the speed will tend to lift off the shrunk-on disks on the shaft, and tensile stresses will be the principal cause of failure.

The RPMs are much higher than in a crankshaft, usually 3600, so it is a different phenomenon.

2

yesterday, Dr. Bush?

3

Yes.

5

6

7

8

9

10

11

12

* 13

14

16

15

XZXZXZX

17

19

18

20

21

22

23

24

25

MR. GODDARD: Judge Brenner, the Staff has nothing more for Dr. Bush on this issue; and to that extent he is available for cross-examination by the parties, if the Board is satisfied with the correction and have no further questions

JUDGE BRENNER: Mr. Dynner?

MR. DYNNER: No questions.

JUDGE BRENNER: I guess I should have asked LILCO

Does that conclude the correction to your statement

first.

themselves.

MR. STROUPE: Yes, .I have some questions, Judge Brenner.

CROSS-EXAMINATION

BY MR. STROUPE:

Dr. Bush, I'm going to hand you a report --

JUDGE BRENNER: Let me tell you, Mr. Stroupe, I'm going to be very careful about limiting you to questions on his clarifications and not using this as an avenue for which other procedural mechanisms need to be employed to introduce yet further evidence.

MR. STROUPE: I understand that, Judge Brenner.

JUDGE BRENNER: Okay. So make it easy on yourself by keeping that in mind in advance.

BY MR. STROUPE:

2

1

3

4 5

6

7 8

9

10

11

12

13

14

15

17

18

19

20

21

22

23

24

25

Q Dr. Bush, I'm going to hand "ou a document entitled "Field Tests of Emergency Diesel Generator 103 With 13 by 12 Crankshaft", prepared for Shoreham Nuclear Power Station Long Island Lighting Company, dated April 1984, entitled "LILCO Crankshaft Exhibit No. 16", previously filed in this proceeding; and I direct your attention to Table B-4 at page B-5 thereof.

MR. STROUPE: I do not have extra copies of this because I did not know this was going to happen this morning, Judge Brenner.

JUDGE BRENNER: Well, none of us have copies.

MR. STROUPE: This is the table that he read into the record yesterday in response to Judge Ferguson's question, the answer 29,800 psi for the tensile stresses.

(Exhibiting document to counsel.)

JUDGE BRENNER: Let me put it to you this way: does LILCO disagree with anything Dr. Bush just said this morning?

MR. STROUPE: No, Judge Brenner. However, I believe we should be entitled to some further amplification of what he has said, in view of the fact that part of our rebuttal testimony would have gone to that very subject.

JUDGE BRENNER: That's my problem.

MR. STROUPE: He has admitted on the record, Judge Brenner, that the statement was incorrect, which is the

position I took this morning.

MR. DYNNER: I'll object to handing the witness this document, which I haven't had a chance to look at with any care, or have my consultants read and understand. I think if he wants to cross-examine the witness, he ought to do it on the basis of the statements the witness just made and not hand him new documents.

JUDGE BRENNER: Well, let's let him go a little bit, because I'm not sure it's a new document.

You had better put the foundation in to see if this is what Dr. Bush was using yesterday when he testified.

BY MR. STROUPE:

Q. Dr. Bush, is that, in fact, the document from which you responded to Judge Ferguson's questioning yesterday, and indicated that the tensile stresses were -- the highest figure was 29,800?

(Handing document to the witness.)

A. Yes. And then, I think, I corrected and said that it was the major principle stress, in the testimony.

I would like to clarify, as I said yesterday, I had had approximately 30 minutes to examine this document, which is hardly enough for this number of pages.

Q Dr. Bush, under the column at 3500 kw, where the figure 29,800 psi is found as a major principle stress, do I understand your statement this morning to say that, in your

Ace-Federal Reporters, Inc.

Ace-Federal Reporters, Inc. opinion, this is not a tensile or axial stress?

- A. That's correct.
- Q And did you indeed say that this represents simply the shear and bending stresses relative to a different set of axes?

MR. DYNNER: Objection. Asked and answered. The witness has explained it, and all he is doing is having him regurgitate what he read from his statement.

JUDGE BRENNER: We'd like to make sure it's clear.

Dr. Bush?

of some things such as sines rule to establish a value. I would comment that sines is cited in the FaAA document. I cannot cite the specific page.

BY MR. STROUPE:

- And, to the best of your knowledge, Dr. Bush, these numbers are the result of a strain gauge rosette which was located in the fillet of the crankshaft at crank pin number five?
- A. To the best of my knowledge, that is the case, recognizing that I can only read what is here, and have not had an opportunity to digest the document.
- Q And do those strain gauge measurements, Dr. Bush, include all stresses, whether they be tensile, bending or torsional?

24 Ace-Federal Reporters, Inc. 25

21

22

2

3

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

25

A. Yes.

And thus, is it correct that you used all stresses in your fatigue analysis, as a result of utilizing the strain gauge data?

That's correct. As I indicated there, the small component of tension is buried in the strain gauge measurements in this instance.

MR. STROUPE: Judge Brenner, that's all of the questions I have on this subject. I would renew my request to be permitted to ask one or two questions of Dr. Bush with reference to the same exhibit, as to torsional stresses set fort in a particular table in that exhibit.

JUDGE BRENNER: Well, wait. I never stopped you from cross-examining Dr. Bush, so I don't know what you're talking about now. Nobody ever stopped you --

MR. STROUPE: I was going to another subject. You said you would be very careful to limit me to specifically the subject matter in this statement; and what I tried to indicate was that I would now like to cross-examine Dr. Bush with regard to torsional stresses as they are set forth in this exhibit, previously filed in this action.

JUDGE BRENNER: Nobody ever stopped you yesterday, while you had your opportunity for cross-examination.

Am I correct?

MR. STROUPE: That's correct.

24

Inc.

2

3

4

5 6

7

8 9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

JUDGE ERENNER: All right.

Dr. Bush, tell me, as simply as you can, how you know of your own knowledge that that figure of 29,800 psi which, I believe, you rounded to 30,000 in your testimony yesterday, is simply a combination of the bending and shear stresses. How do you know that, of your own knowledge?

THE WITNESS: Well, that would be resolved from the strain gauge data. And, as I indicated, since I had essentially no opportunity to read this, I would have to say it is more hearsay because I cannot equate it specifically to the strain gauge measurements shown here, the strain gauge measurements in the Failure Analysis documents and the values here.

JUDGE BRENNER: I'm sorry; I don't understand your answer.

How do you know, of your own knowledge, or what's the basis for your corrective statement this morning, as to just the part that that 29,800 psi represents -- that is, that it's a combination of the bending and shear stresses? What's your basis for knowing that?

THE WITNESS: Only in looking at the way the strain gauges are placed on there. They will be measuring -there will be a tensile component in there and a compressive component and a bending component; and then, also, it can be resolved into a torsional component. That's from the only one,

3

2

5

6

7

8 9

10

11

12

.13

14

16

17

18

20

End WRB 2

22

21

23

24

25

and I cannot equate the specific values thereto.

In other words, I would have to go back to the original values, look at the micro-inches of strain, et cetera, and I do not have -- the data may well be in this report, but if it is I haven't had an opportunity to see it.

JUDGE BRENNER: Have you read the proffered testimony of Paul R. Johnston, which is the subject of LILCO's motion dated March 8, 1985?

THE WITNESS: No.

JUDGE BRENNER: And it was your own independent realization, without prompting by anybody else, that that value, for the reasons you just told me, would represent a combination of the bending and shear stresses?

THE WITNESS: Well, I did discuss it yesterday because I realized --

JUDGE BRENNER: Who did you discuss it with?

THE WITNESS: I discussed it with Mr. Johnston.

I realized as soon as I stepped down that I had misrepresented the situation; and I wanted to clarify in my own mind, because I suddenly realized that that couldn't possibly be the correct tensile value.

B3

1 2

I would comment: I expected this to come up in cross-examination, frankly, and I would have responded yesterday, but it never did arise.

JUDGE BRENNER: Well, all right. Fine.

Witnesses can say they want to make a correction at any time; and as soon as they know they want to make a correction, that's the better time to do it. I state that as a general observation. You do not have to respond.

As I understand it, Mr. Stroupe, the further questions you were going to ask Dr. Bush are not related to the subject of this correction this morning?

MR. STROUPE: They are, I believe, related in the sense that the questions I would ask him refer to stresses upon the crankshaft that include torsionals, bending, shear — the very stresses I believe he is talking about this morning. Frankly, all I would want to do is ask him by having him look at one series of exhibits whether he is indeed able to determine that these stresses are linear.

JUDGE BRENNER: I think, as you candidly told me, it's also the same additional information that you would want to get into with your further testimony.

MR. STROUPE: That's correct.

JUDGE BRENNER: Let's take the whole thing up together and, depending on our ruling on your motion for reconsideration, when we all have the exhibits in front of us.

3

5

6

8

10

11

13

14

16

17

18

20

21

22

25

24

Ace-Federal Reporters, Inc.

We'll decide what to do at that time. To the extent we rule in your favor, if we do, then Dr. Bush would still be around for you to ask questions of him, too. And we'll decide what to do. I want to see the exhibits. I just don't have -- I'm trying to visualize what those exhibits look like, and I may be confusing them among all the exhibits I've looked at.

MR. STROUPE: I can present them to the Bench right now, if you'd --

JUDGE BRENNER: Well, I'd rather wait and just have -- be more deliberative about it; and then the parties by then will have had an opportunity to have looked at the exhibits, also. So we'll come back to the whole subject.

And we'll excuse Dr. Bush at this time.

(Witness Excused.)

JUDGE BRENNER: Off the record.

(Discussion off the record.)

JUDGE BRENNER: On the record.

MR. GODDARD: Judge Brenner, before we begin the panel on blocks, the Staff would like to state that, pursuant to the Board's direction, we have completely corrected, with all changes made, a copy of the Staff testimony. We have been unable locally to get it reproduced and served to the Board and the parties.

JUDGE BRENNER: We don't need it today. We're putting LILCO witnesses on right now. So you will have further

8 9

ce-Feder: Reporters, In

opportunity to take care of all that at the time the Staff comes on.

MR. STROUPE: We hope so.

JUDGE BRENNER: I want to make sure, Mr. Goddard, that the parties have the marked-up copy in advance, so that if there is any question you can resolve it before we get up here, because I want to avoid wasted effort.

MR. GODDARD: The markup on blocks, Judge Brenner, for the Staff is simply deletion of--

JUDGE BRENNER: Don't tell me now. I just want to make sure that we are all on the same wavelength and that it is all going to be in order.

I understand the theory. You want to take out everything related to cam gallery, but I don't know if you have any other changes. Just mark up the copies completely, including the changes annotated that you made on the crankshaft potion of that, and then we'll take care of it. But you don't have to do it until the Staff witnesses come back. Maybe we will get to them today. I don't know. Anything is possible.

All right. LILCO.

2630 03 01 2 WRBeb	1	Whereupon,
	2	CHARLES A. RAU,
	3	EDWARD J. YOUNGLING,
•	4	MILFORD M. SCHUSTER,
		트립스 경험 경험 경험 경험 전 등 이 전 등 이 경험 전 경험
	5	DUANE P. JOHNSON,
	6	and
	7	HARRY F. WACHOB
	8	resumed the stand and, having been previously duly sworn,
	9	were examined and testified further as follows:
	10	MR. ELLIS: Judge Brenner, the LILCO witness
	11	panel has been seated. We had made labels in anticipation
	12	of getting on earlier than today, and somehow or other, when
	13	we finally got on, the labels are back in the office. We
	14	are getting them quickly but if the Board wishes, I would
	15	like to proceed to introduce the panel.
	16	JUDGE BRENNER: Off the record.
	17	(Discussion off the record.)
	18	JUDGE BRENNER: Back on the record.
	19	DIRECT EXAMINATION
	20	BY MR. ELLIS:
	21	Q Gentlemen, I would like for you please to state
	22	for the record your name, your business affiliation, and

your business address, beginning, please, with Dr. Wachob.

I work for Failure Analysis Associates. The address is

(Witness Wachob) My name is Harry Frank Wachob.

23

24

25

A

- 1 2225 East Bay Shore Road, Palo Alto, California.
- 2 Would you also give your business position and
- 3 affiliation?
- 4 A (Witness Wachob) I am manager of the Materials
- 5 and Testing Laboratory.
- 6 Q Thank you.
- 7 Dr. Rau?
- 8 A (Witness Rau) My name is Charles Alfred Rau,
- 9 Junior. I am vice president and principal engineer of
- 10 Failure Analysis Associates. My business address is 2225
- 11 East Bay Shore Road, Palo Alto, California.
- 12 A (Witness Youngling) My name is Edward
- 13 J. Youngling. I am the manager of Nuclear Engineering for
- 14 the Long Island Lighting Company. My business address is
- 15 Shoreham Nuclear Power Station, Wading River, New York.
- 16 A (Witness Johnson) My name is Duane P. Johnson.
- 17 I am managing engineer at Failure Analysis Associates. My
- 18 business address is 2225 East Bay Shore Road, Palo Alto,
- 19 California.
- 20 A (Witness Schuster) My name is Milford
- 21 H. Schuster. I am employed by the Long Island Lighting
- 22 Company at the Shoreham Nuclear Power site in Wading River,
- 23 Long Island. And I am currently assigned to the Nuclear
- 24 Engineering Department.
- MR. ELLIS: Judge Brenner, all of these witnesses

- I believe -- I did not mention it earlier -- have testified
- 2 before and have been sworn.
- JUDGE BRENNER: That's right, and of course they
- 4 remain under oath or affirmation. And we can say welcome
- 5 back to all of them.
- 6 BY MR. ELLIS:
- 7 Q Gentlemen, do you have before you your prefiled
- 8 testimony entitled "Additional Cylinder Block Testimony of
- 9 Dr. Duane P. Johnson, Dr. Charles A. Rau, Milford
- 10 H. Schuster, Dr. Harry F. Wachob, and Edward J. Youngling on
- 11 behalf of Long Island Lighting Company, "including exhibits?
- 12 A (Witness Youngling) Yes, we do.
- 13 Q And do you also have before you a letter dated
- 14 February 7, 1985, to Messrs. Dynner and Perlis from me,
- 15 setting forth errata to that testimony?
- 16 A (Witness Youngling) Yes, we do.
- 17 Q All right.
- 18 Is the testimony entitled "Additional Cylinder
- 19 Block Testimony of Dr. Duane P. Johnson, Dr. Charles A. Rau,
- 20 Milford H. Schuster, Dr. Harry F. Wachob, and Edward
- 21 J. Youngling on behalf of Long Island Lighting Company,"
- 22 together with the exhibits and as corrected by the errata of
- 23 the February 7, 1985 letter true and correct to the best of
- 24 your knowledge and belief?
- Would each of you answer individually, please?

2522 22 24		28793
2630 03 04 1 WRBeb	1	A (Witness Wachob) Yes, it is.
	2	A (Witness Rau) Yes, it is.
	3	A (Witness Youngling) Yes, it is.
	4	A (Witness Johnson) Yes, it is.
	5	A (Witness Schuster) Yes, it is.
	6	Q And do each of you adopt it as your testimony in
	7	this proceeding?
	8	A (Witness Wachob) I do.
	9	A (Witness Rau) Yes, I do.
	10	A (Witness Youngling) Yes, I do.
	11	A (Witness Johnson) Yes, I do.
	12	A (Witness Schuster) I do.
	13	JUDGE BRENNER: Help me out, Mr. Ellis. Weren't
	14	you going to delete portions of this testimony?
	15	MR. ELUIS: The cam gallery portions?
	16	JUDGE BRENNER: Yes.
	17	MR. ELLIS: Yes, sir.
	18	JUDGE BRENNER: All the exhibits relate to that,
	19	and I can see why you may want to separate out the
	20	stipulation and get it in, although I am not sure it's
	21	essential. That's why when you started talking about all
	22	the exhibits and everything I was confused.
	23	MR. ELLIS: That's right, Judge Brenner. In the

portions that were prepared for the Reporter, we have not

yet gone through and lined out all of that testimony, and

24

26	30	03	05
1 WRBeb			D

- I apologize to the Board for that.
- JUDGE BRENNER: All right.
- Were you going to identify what we are not going
- 4 to enter into evidence?
- 5 MR. ELLIS: Yes, sir.
- 6 JUDGE BRENNER: I think the best thing is for you
- 7 to do that, and then for somebody to perform those deletions
- 8 very promptly so that the copy bound into the record matches
- 9 what in fact is being moved into evidence.
- MR. ELLIS: Yes, sir.
- JUDGE BRENNER: It's the same message I gave the
- 12 Staff about saving time.
- MR. ELLIS: Question and answer Number 3 on page
- 14 4, Number 3 running over to page 5;
- Page 13, starting with IV and extending through
- 16 page 25.
- 17 In addition, Exhibits B-65, 56 and 68 would no
- 18 longer be necessary in view of the resolution of the cam
- 19 gallery monitoring matter and the cam gallery itself.
- There will also be I think a reference to the cam
- 21 gallery on page 2 in the final paragraph that appears in the
- 22 answer on page 2.
- I believe with those deletions, Judge Brenner,
- 24 the remainder of the testimony will be moved into evidence.
- 25 JUDGE BRENNER: All right.

2630 03 07 1 WRBeb	1	JUDGE BRENNER: It begins: "The original EDG 103
	2	block experience"
	3	MR. ELLIS: I think that is not intended to be
	4	struck, Judge Brenner.
	5	JUDGE BRENNER: Here again this is why these
	6	things should be done in advance. I don't mean to seem
	7	unreasonable, but you could have talked about it and I
	8	believe probably done some editing on that sentence. I'm
	9	making some guesses here, but LILCO could keep in what it
	10	wanted to keep in and nevertheless delete the reference to
	11	the cam gallery.
	12	Do you want to leave the hours of operation in?
	13	Is that your problem, Mr. Ellis?
	14	MR. ELLIS: May I have a moment, Judge Brenner,
	15	please?
	16	(Pause.)
	17	
	18	
	19	
	20	
	21	
	22	
	23	
	24	

263	0	04	01
1	WR	Bbr	b

JUDGE BRENNER: If I can interrupt you for a

- 2 moment, Mr. Ellis, and then I will give you a moment,
- 3 perhaps what you might want to do -- I'm guessing, so I may
- 4 be wrong on this -- is to say the original EDG 103 block
- 5 experience included 30 hours at or above 110 percent of
- 6 nameplate load, and leave it like that.
- 7 MR. ELLIS: Yes, sir.
- JUDGE BRENNER: All right, sir. We will delete
- 9 the "which" for the sake of language; and then, for the sake
- 10 of substance, delete "demonstrated that cam gallery cracks
- 11 will not propagate", which is the last clause of the
- 12 sentence.
- MR. DYNNER: I have another question, and that is
- 14 that there are numerous references to cam gallery cracks on
- 15 pages 5 and 6 and 7. And it's out opinion that perhaps
- 16 those pages ought to be looked at, too, because the cam
- 17 gallery issue has been -- is no longer part of this
- 18 litigation, and I don't see what the use of all that
- 19 testimony about the cam gallery cracks would be.
- JUDGE BRENNER: Recall that yesterday we accepted
- 21 both parties' positions in approving the agreement on the
- 22 cam gallery; and part of the County's position was that no
- 23 findings would be made regarding the cam gallery cracks.
- 24 That remains the approved position, and perhaps
- 25 we could resolve it by reiterating that statement. It is

if you would like, before we start cross-examination I will

2630 04 03 2 WRBbrb	1	make the statement for the record, with respect to the
	2	blocks, as I had with respect to the crankshafts.
	3	JUDGE BRENNER: All right. Give me one moment.
	4	MR. DYNNER: Certainly.
	5	JUDGE BRENNER: Off the record.
	6	(Discussion off the record.)
	7	JUDGE BRENNER: On the record.
	8	What we will do at this point is admit the
	9	testimony of the LILCO panel of witnesses on the subject of
	10	additional cylinder block testimony, with the corrections
	11	and deletions that have been discussed on the record, and
	12	with the limitation we have identified to the extent there
	13	may still be some passing references to the cam gallery
	14	cracks.
	15	And we will immediately, at the same point in the
	16	transcript, immediately follow the testimony with the
	17	two-page stipulation dated January 14, 1985, and signed by
	18	counsel for all the parties, on the subject of the cam
	19	gallery cracks. Of course, that stipulation is led to and
	20	is referenced in the settlement of the cam gallery
	21	contention that we approved yesterday, and bound into the
	22	record yesterday.
	23	(The documents follow.)
	24	
	25	

HUNTON & WILLIAMS 2000 PENNSYLVANIA AVENUE. N.W. P.O. Box 19230 WASHINGTON, D.C. 20036 299 PARK AVENUE 707 EAST MAIN STREET P O. BOX 1835 NEW YORK. NEW YORK 10171 RICHMOND, VIRGINIA 23212 TELEX 754708 TELEPHONE 804-788-8200 TELEPHONE 202-955-1500 TWX 710-956-0061 8 8 4 T BUILDING P 0 BOX 109 FIRST VIRGINIA BANK TOWER P O BOX 3889 NORFOLK, VIRGINIA 23514 TELEPHONE 804-825-5501 TELEX 755628 TELEPHONE 9:9-828-9371 FIRST TENNESSEE BANK BUILDING P O BOX 951 February 7, 1985 KNOXVILLE. TENNESSEE 37901 4011 CHAIN BRIDGE ROAD TELEPHONE 615-637-4311 TELEPHONE 703-352-2200 FILE NO. DIRECT DIAL NO 202 985 Alan R. Dynner, Esq. Kirkpatrick & Lockhart 1900 M Street, N.W. Washington, D.C. 20036 Robert G. Perlis, Esq. U.S. Nuclear Regulatory Commission Washington, D.C. 20555 Dear Alan and Bob: This letter lists errata for LILCO's qualified load, additional block and crankshaft testimony. Errata Regarding Additional Crankshaft Testimony Page 2, line 22, the words "crankshafts were" should read "crankshaft was." Page 6, line 1, the words "Were the crankshafts" B . should read "Was the crankshaft." Page 8, line 15, the word "crankshafts" should read "crankshaft." Page 8, line 17, the words "crankshafts have" should D. read "crankshaft has." Errata Regarding Additional Block Testimony II. Page 4, answer 3, paragraph 3c, first sentence, delete the word "replacement" which appears at the end of the first and beginning of the second lines. Page 6, last line of answer 6, insert the word "during" in lieu of "before."

February 7, 1985 Page 2

> C. Page 9, delete the term "replacement" the first time it appears in the first sentence of the second paragraph.

III. Errata Regarding Diesel Generator Qualified Load Testimony

A. The portion of answer 2 on pages 1 and 2 is set forth fully below with the revisions underscored.

(Dawe) My current position, to which I was appointed in February, 1985, is Supervisor of Projects within the Nuclear Technologies and Licensing Division of Stone & Webster (SWEC). I am responsible for technical and administrative supervision of personnel assigned to SWEC headquarters projects, including field assignments.

I joined Stone & Webster in 1973 as an Engineer in the Licensing Group. In January 1974, I was assigned as Licensing Engineer for the Shoreham Nuclear Power Station (SNPS) under construction, and was Lead Licensing Engineer from 1976 to 1980. In this capacity, I was responsible for all licensing related activities for SNPS, including preparation of the Final Safety Analysis Report. From 1980 through 1984, I held the position of Supervisor of Project Licensing within the Licensing Division. My duties included assuring project awareness of regulatory requirements and developments, assuring proper and consistent application of SWEC licensing policies, and consulting with projects and clients on licensing issues. I have had additional assignments at Stone & Webster including development of company positions for NRC Regulatory Guides and Lead Licensing Engineer for the Special Projects Group of the Operations Services

February 7, 1985 Page 3

Division. I am also the Stone & Webster representative to, and participating member of, two subcommittees of the AIF Committee on Reactor Licensing and Safety.

- B. Page 5, eighth line from the bottom, insert "generators" in lieu of "operators."
- C. Page 16, third and fourth lines from the bottom, should be changed to read as follows: "approximately 22 minutes every 48 minutes during the operation of the diesel (at 3300 KW)..."
- D. Page 25, line 2, change "Revision 7" to "Revision 9."
- E. Page 25, lines 3-4, delete "(iii) SP 29.015.04, Revision 0, 'Loss of Coolant Accident Coincident With a Loss of Off-Site Power,' and change "(iv)" to "(iii)."
- F. Page 25, line 5, change "Revision 4" to "Revision 5."
- G. Page 25, second line of second full paragraph, change "LOOP/LOCA" to "LOOP" and change "SP 29.015.04" to "SP 29.015.01."
- H. Page 26, fourth line from bottom, insert "such as" for "for."
- I. Page 27, answer 22, third line, change "February 1, 1985" to "February 1985."
- J. Page 32, delete the last sentence on the page which reads "The CRD pumps cannot be restarted as long as a LOCA signal is present."
- K. Page 33, line 3 of answer 29, delete term "automatic."

HUNTON & WILLIAMS February 7, 1985 Page 4 Page 33, answer 29, fourth line, insert "3741.8 KW" in lieu of "3839.2 KW" and "3575.2 KW" in lieu of "3627.6 KW." Page 34, second and fifth lines, substitute "runout" for "design." M. Page 34, first line of last paragraph, insert the figure "999 KW" in lieu of "1022 KW." N. Page 34, last paragraph, line 3, insert "3707.9 KW" in lieu of "3867.3 KW" and delete the paren-0. thetical sentence which follows. Page 36, third line from bottom of first full P. paragraph, delete "to." If the County and Staff plan to submit testimony errata at the time of the hearing, it would be helpful if you would send it to us in advance of the hearing. Best wishes. Sincerely, T. S. Ellis, III & 75/403 cc: Service List

UNITED STATES OF AMERICA NUCLEAR RECULATORY COMMISSION

Before the Atomic Safety and Licensing Board

In the Matter of		
LONG ISLAND LIGHTING COMPANY	Docket No.	50-322(OL)
(Shoreham Nuclear Power Station,) Unit 1)		

0

0

ADDITIONAL CYLINDER BLOCK TESTIMONY OF DR. DUANE P. JOHNSON, DR. CHARLES A. RAU, JR., MILFORD H. SCHUSTER, DR. HARRY F. WACHOB AND EDWARD J. YOUNGLING ON BEHALF OF LONG ISLAND LIGHTING COMPANY

Testimony and Exhibits

TABLE OF CONTENTS

	Page
I.	Introduction1
II.	Confirmatory Testing And Post Endurance Run Block Inspections5
III.	Effect Of The 3300 KW Qualified Load10
***	Monitoring Of The Cam Gallery Cracks In The EDG 101 And 102 Blocks Is Unnecessary13 A. High Magnification Photomicrographs14 B. The Stipulation
-	G. Strain Gage Measurements

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

Before the Atomic Safety and Licensing Board

In the Matter of	
LONG ISLAND LIGHTING COMPANY	Docket No. 50-322 (OL
(Shoreham Nuclear Power Station,) Unit 1)	

ADDITIONAL CYLINDER BLOCK TESTIMONY OF DR. DUANE P. JOHNSON, DR. CHARLES A. RAU, JR., MILFORD H. SCHUSTER, DR. HARRY F. WACHOB AND EDWARD J. YOUNGLING ON BEHALF OF LONG ISLAND LIGHTING COMPANY

I. Introduction

- Please state your names and summarize your professional qualifications.
- A. (Johnson) My name is Dr. Duane P. Johnson. My professional qualifications are set forth in my previous testimony during this proceeding.
- (Rau) My name is Dr. Charles A. Rau, Jr. My professional qualifications are set forth in my previous testimony during this proceeding.
- (Schuster) My name is Milford H. Schuster. My professional qualifications are set forth in my previous testimony in this proceeding.
- (Wachob) My name is Dr. Harry F. Wachob. My professional qualifications are set forth in my previous testimony in this proceeding.

(Youngling) My name is Edward J. Youngling. My professional qualifications are set forth in my previous testimony in this proceeding.

2. What issues are addressed by this testimony?

0

0

0

A. (All) Among the topics addressed are the EDG 103 endurance run, the results of inspections on the block following the endurance run, and the effect of these inspections on Lilco's previous evaluations and conclusions.

Also addressed are the effect of operating the EDGs at the qualified load of 3300 KW, including the margins between demonstrated performance and that cumulative damage which a postulated LOOP/LOCA might involve.

to disqualify the blocks on the basis of the cam gallery cracks. However, it still contends that the cracks in the EDG 101 and 102 blocks should be monitored by placing wire strain gages across the cracks and by measuring the depths of the cracks before operation and at the first refueling outage. This testimony addresses whether there is any need to monitor the cam gallery cracks in the EDG 101 and 102 blocks in light of the high magnification photomicrographs, the x-ray crystallography and the strain gage test results.

- Please briefly summarize the conclusions reached in your testimony.
 - A. (All) Our conclusions are as follows:

0

0

- 1. Fluorescent magnetic particle inspections of the block top and eddy current inspections of stud holes on he block top of the EDG 103 replacement block at the conclusion of the endurance run detected no reportable indications. The absence of ligament or stud-to-stud cracks in the block top confirms our opinion that the design enhancements introduced in the EDG 103 replacement block are beneficial and that they have reduced the possibility of fatigue crack initiation. Furthermore, the additional operation of the replacement block at 3300 KW for more than 500 hours during the endurance run confirms that the replacement block has been adequately designed and tested. Clearly, it has proven its capacity to perform its intended function of providing emergency power during postulated accident conditions at Shoreham.
- 2. Operating the EDGs at the qualified load of 3300 KW produces lower cyclic stress in the block top and in the cam gallery than at higher loads. This reduces the possibility of fatigue crack initiation in the block top, and reduces the rate of any crack propagation should crack initiation occur. Further, cumulative damage analysis shows that, if a postulated LOOP/LOCA occurs, the EDGs will perform their intended function with even greater margin at the qualified load than at the higher loads previously analyzed.

0

3. It is not necessary to monitor the cam gallery cracks in the EDG 101 and 102 blocks by placing wire strain gages across the repair welds or by measuring the depth of the cracks with the TSI depth gage at any time prior to the first refueling outage because:

- a. The 550x magnification photomicrographs and the x-ray crystallography, combined with previous fractographic and metallographic examinations, demonstrate that cam gallery cracks up to 0.91 inch deep in the original EDG 103 block did not propagate in more than 1200 hours of operation, despite the severely degraded fatigue and fracture properties of that block material and the presence of cracked repair welds. Accordingly, the cracks in the EDG 101 and 102 blocks which have superior fatigue and fracture properties and smaller repair welds, will not propagate.
- b. Strain gage measurements made on the cam gallery of the EDG 103 replacement block prior to the endurance run demonstrate that the stresses perpendicular to the cam gallery crack indications (i.e., vertical) are fully compressive during EDG operation, including quick starts to 3300 KW and continuous operation at 3300 KW. Extrapolation of this data shows that the stresses remain fully compressive at 3500 and 3900 KW. Since fatigue cracks do not grow in fully compressive stress fields, the strain gage data confirms our prior opinion, based on physical examinations, calculations and fracture mechanics analyses, that regardless of the presence of any residual stresses, the cam gallery cracks in the EDGs have not propagated and will not propagate in the future.
- ment EDG 103 replacement block are directly applicable to fracture mechanics analyses of the cam gallery cracks in EDGs 101 and 102, they confirm that the cam gallery cracks in the EDG 101 and 102 blocks will not propagate even at loads up to and including 2900 KW. Further, the presence of any residual stresses will not affect the validity of the strain gage results. Residual stresses at the tip of any

cracks in the EDG 101 or 102 blocks which are assumed hypothetically for purposes of analysis to extend substantially below the repair welds would be yery small and compressive.

II. Confirmatory Testing and Post Endurance Run Block Inspections

- 4. What is the operating history of the EDG 103 replacement block?
- A. (Rau, Schuster, Wachob, Youngling) The EDG 103 replacement block was installed in June 1984. Since June, EDG 103 has been operated for more than 849 hours. Of these hours, 70 hours were at or above 3500 KW and more than 507 hours were at or about 3300 KW as indicated on the main control room kilowatt meter. A substantial portion of the hours placed on the EDG 103 replacement block occurred as a result of a 745 hour (107 loading cycles) confirmatory test. The endurance run portion of the confirmatory test was performed at the load level of 3300 KW, which is the qualified load for the Shoreham EDGs.
- 5. Was the EDG 103 replacement block inspected after the 745 hour confirmatory test?
- A. (Johnson, Rau, Schuster, Wachob) Yes, the cam gallery area and the block top region of the EDG 103 replacement block were inspected at the conclusion of the endurance run portion of the 745 hour confirmatory test. In accordance with the program approved by the NRC Staff, which is outlined in SNRC 1094, the block top region was examined using fluorescent magnetic particle and eddy current inspection techniques. The

inspection showed no ligament or stud-to-stud cracks. In addition, eddy current examination of the four stud holes between cylinders no. 4 and 5 confirmed that neither ligament cracks nor stud-to-stud cracks initiated at the block top or at any location on the stud hole surface between the block top and the bottom thread in the stud hole.

The cam gallery area of the EDG 103 replacement block was inspected at cam bearing saddles no. 2 and 8 using visual, magnifying glass, liquid penetrant and magnetic particle examination techniques. Small, discontinuous linear indications detected by liquid penetrant examination were evaluated with the TSI crack depth gage to measure their depth. The deepest indication recorded after the endurance run was 0.010 inch deep. The remaining indications were all 0.004 inch deep or less.

- 6. Will any of the cam gallery indications impair the ability of the EDG 103 replacement block to perform its intended function?
- A. (Rau, Wachob, Schuster, Youngling) Absolutely not. The indications evaluated after the completion of the endurance run showed no significant change from their condition at the time they were initially detected prior to the endurance run in October 1984. These indications are still not detectable visually without a magnifying glass, and they have been measured both before and after the endurance run to have no significant

depth. Furthermore, casting shrinkage cracks as deep as 0.91 inch in the original EDG 103 block did not propagate during more than 1200 hours of operation, including more than 400 hours of operation at or above 3500 KW, despite the severely degraded fatigue properties of the block material. Consequently, the very shallow indications in the EDG 103 replacement block, with its superior fracture and fatigue properties, will not impair the ability of EDG 103 to provide emergency power at Shoreham.

3

- 7. If the cam gallery indications in the EDG 103 replacement block have not changed, why are there some differences in the inspection reports before and after the endurance run?
- A. (Johnson, Rau, Schuster, Wachob) None of the cam gallery inspection reports show significantly different indications after the endurance run. Minor differences in mapping of the surface indications revealed by magnetic particle and liquid penetrant techniques before and after the endurance run are not significant. The insignificant differences result from the very shallow nature of the indications, minor differences in surface cleaning and preparation, and test techniques.

Similarly, minor variations in the depth of indications measured by the TSI crack depth gage are not significant. Some slight variation is expected in reported depths because they are within the accuracy of the TSI crack depth gage. In our opinion, when the visual, magnetic particle, liquid penetrant

and TSI depth gage inspections are analyzed as a whole, they indicate that no propagation of these indications has occurred during more than 500 hours of endurance testing on the EDG 103 replacement block.

8. What effect, if any, do the results of the inspections of the EDG 103 replacement block following the endurance run have on your opinion regarding the adequacy of its design and testing?

0

- (Rau, Wachob) The product enhancements incorporated A. into the EDG 103 replacement block have now been further tested by actual operation at Shoreham. The absence of any detectable ligament or stud-to-stud cracks in the block top after the endurance run confirms our opinion that the design enhancements introduced in the EDG 103 replacement block are beneficial. Since the EDG 101, 102 and original 103 blocks had initiated ligament cracks at approximately an equivalent number of operating hours as have now been placed on the EDG 103 replacement block without block top cracking, the design enhancements have reduced the possibility of fatigue crack initiation. Thus, the endurance run confirms our previous testimony, which was based on our review of the replacement block design and on our review of the R-5 test engine experience, that the replacement block has been adequately designed and tested.
- 9. Should the replacement block have been tested for 745 hours at or above 3300 KW to confirm its adequacy for nuclear service?

A. (Rau, Youngling) No. The 745 hour confirmatory test (10⁷ loading cycles) was performed primarily to evaluate the adequacy of the modified crankshaft. The County's contention with regard to the replacement block, and our testimony with respect to the replacement block, addressed whether it was an unproven design that was inadequately tested. Operation of the engine since block replacement for more than 849 hours, of which more than 577 hours were at or above 3300 KW, further substantiates the extensive R-5 test experience. This confirms our opinion that the design enhancements incorporated into the block are beneficial, and that the design is both proven and adequately tested.

Furthermore, testing the primary EDG 103 replacement block for 10⁷ loading cycles was not necessary in light of our cumulative damage analyses of the EDG 101 and 102 blocks. These prior analyses demonstrate that the blocks are capable of performing their intended function even though they have ligament cracks. Thus, testing the EDG 103 replacement block for more than 577 hours at or above 3300 KW without developing any detectable ligament or stud-to-stud cracks further demonstrates that the block is qualified for nuclear service.

^{10.} Since the EDG 103 replacement block has no ligament cracks, does it need to be inspected on the same basis as the EDG 101 and 102 blocks for stud-to-stud cracks?

A. (Rau, Wachob) No. In our original testimony, we stated that the EDG 103 replacement block should be inspected on the same basis as the EDG 101 and 102 blocks until sufficient operating service without ligament cracks had been obtained to increase the inspection intervals. The endurance run has placed enough hours on the replacement block without the development of ligament cracks to justify extending the inspection interval for that block.

The EDG 103 replacement block can now be operated without additional inspections for stud-to-stud cracks for combinations of load and time that produce less than the allowable fatigue damage index. In other words, operation may continue without further block top inspections until the fatigue damage index accrued is equal to one-third of the fatigue damage index demonstrated for the original EDG 103 benchmark period minus the fatigue damage index that would be required for one postulated LOOP/LOCA. Since it is anticipated that the EDG 103 replacement block will experience less than 100 hours of further operation before the end of the first fuel cycle, no additional block top inspections are necessary until the refueling outage.

0

III. Effect of the 3300 KW Qualified Load

- 11. What is the effect on the EDG blocks or operation at up to the qualified load of 3300 KW?
 - A. (Rau, Wachob) Operation of the EDGs at a maximum

load of 3300 KW rather than a maximum load of 3500 or 3900 KW will produce lower cyclic stresses in the block top and in the cam gallery. Specifically, operation of the engine at the lower load levels reduces the cylinder firing pressures, thermal strains, and vertical loads imposed on the head during cylinder firing. This results in a corresponding reduction in the loads transmitted to the block through the head studs and through contact with the liner and block top. As a result, the possibility of fatigue crack initiation in the block top is reduced, and, should crack initiation occur, the rate of any crack propagation will be slower.

- 12. The County contends that the qualified load might be exceeded for brief periods of time during EDG operation. If brief load excursions occur over 3300 KW, what effect, if any, will they have on the blocks?
- A. (Rau) We have previously testified about the effect of engine operation at 3500 and 3900 KW. Our cumulative damage analysis of the block tops demonstrated that the blocks would withstand with sufficient margin a LOOP/LOCA with a postulated load profile that included 0.2 hours at 3900 KW and 0.8 hours at 3500 KW.

0

0

Further, stresses in the cam gallery area will not increase significantly at power levels above 3300 KW. These stresses have been verified by the strain gage testing, which demonstrates that the vertical stresses remain fully compressive even when extrapolated to loading as high as 3900 KW.

Reliable operation at loads in excess of 3300 KW has also been verified by the operating experience of the EDGs. Despite hundreds of hours of operation above 3500 KW, including more than 25 hours each at or above 110% of nameplate load, EDG 101 and 102 have not developed stud-to-stud cracks. The original EDG 103 block experience, which included 30 hours at or above 110% of nameplate load, demonstrated that cam gallery cracks will not propagate. In addition, the EDG 103 replacement block has already experienced 70 hours of operation at or above 3500 KW. These are direct demonstrations of the blocks' ability to perform reliably at loads up to and including their overload rating for brief periods of time. Thus, both the analytical and the empirical evidence demonstrates that brief excursions over 3300 KW, should any occur, will not impair the ability of the EDGs to perform their intended function.

13. What is the load profile that the EDGs at Shoreham will experience should a LOOP/LOCA occur?

(3)

- A. (Youngling) The maximum emergency service load on any EDG is bounded by 3300 KW. A conservative LOOP/LOCA load profile would be 0.2 hours at 3300 KW, 0.8 hours at 3200 KW, and up to 167 hours at 2617 KW.
- 14. What effect, if any, does the reduced load profile have on the results or the conclusions of the cumulative damage analysis?
- A. (Rau) A postulated LOOP/LOCA resulting in a load profile of 0.2 hours at 3300 KW, 0.8 hours at 3200 KW and 167

0

)

0

hours at 2617 KW will produce less fatigue damage than the LOOP/LOCA load profile previously analyzed. Analyses of the damage accumulated by the original EDG 103 block during the test period from March 11 through April 14, 1984 demonstrates that at the actual load profile of the EDG 101, 102 and 103 engines, the blocks will withstand a postulated LOOP/LOCA with even greater margin.

- 15. Has FaAA performed additional cumulative damage analyses of the block top since the conclusion of the previous hearings?
- A. (Rau) Yes. As part of the preparation of the final generic block report, which was issued in December 1984, cumulative damage calculations were performed employing a refined determination of stresses from the strain gage testing. The additional cumulative damage calculations set forth in the final block report confirm our conclusion that the Shoreham blocks will perform their intended function with sufficient margin during a postulated LOOP/LOCA.

the EDG 101 and 102 Blocks is Unnecessary

- 16. Is monitoring of the cam gallery cracks in the EDG 101 and 102 blocks nesessary or justified?
- A. (Rau, Wachob) No. There is no need to monitor the cam gallery cracks prior to the scheduled maintenance interval at the first refueling outage. In addition to our previous calculations, and fractographic and metallographic

0

0

0

0

vaminations, we now have additional data which establishes that monitoring is not necessary or justified. First, photomicrographs taken of the weld shrinkage crack at/550x confirmed LNco's previous testimony that the cam gallery cracks in the original EDG 103 block were fabrication cracks that had not propagated during EDG operation. Second, /x-ray crystallographic analyses were performed on the oxide present on the cam gallery cracks in the original EDG 103 block which established that the oxide was primarily (85 percent) magnetite. As a result of these tests, the County has stipulated that the cracks in the EDG 101, 10% and original EDG 103 blocks have not propagated during or as a result of EDG operation. Finally, strain gage measurements made on the EDG 103 replacement block, which are applicable to fracture mechanics analyses of cracks in the EDG 101 and 102 blocks, establish that the cam gallery cracks will not propagate beneath the repair weld depth even considering the presence of residual stresses.

A. High Magnification Photomicrographs

17. Please explain in greater detail now the high magnification photomicrographs support your conclusion that monitoring is unnecessary.

A. (Rau, Wachob) In our previous testimony, at Tr. 26525-26, we discussed a series of photomicrographs taken from a metallographic cross-section of cam gallery bearing support to 7 of the original EDG 103 block. Two of these

what we have called the casting shrinkage crack. As shown in Exhibit B-63, these photomicrographs were taken at 100x and 500x magnification. Two more photomicrographs, depicted in County Exhibit S-4, were taken at 50x and 100x magnification of what we have called the weld shrinkage crack, which, as shown in Lilco Exhibit B-61, is directly adjacent to the casting shrinkage crack. However, as was discussed at Tr. 26525-26, no 500x photomicrograph was originally taken of the weld shrinkage crack.

At the meeting of the parties on November 20, 1984, Lilco agreed to take additional photomicrographs of the weld shrinkage crack at 500x magnification. (See Tr. 26990-91). Accordingly, two additional photomicrographs at 550x were taken of representative areas of the weld shrinkage crack in cam gallery bearing support no. 7. These photomicrographs are attached as Exhibit B-65. The locations where these photomicrographs were taken are shown in Lilco Exhibit B-66, which is a marked-up version of County Exhibit S-4.

The 550x photomicrographs confirm what the 100x photomicrograph in County Exhibit S-4 depicted, namely that the weld skrinkage crack surface has a very thin oxide which is markedly different from the uniformly thick (0.2 to 0.5 mils), wark oxide on the contiguous casting shrinkage crack depicted

of the casting shrinkage crack in Lilco Exhibit B-63 with the 550x photomicrographs in Lilco Exhibit B-65 shows the difference between the oxides present on the casting shrinkage crack and the weld shrinkage crack. The light gray appearance of the crack surface on the casting shrinkage crack is due to the presence of the thick oxide. The absence of a light gray layer on the weld shrinkage crack reveals that no thick oxide is present.

The significant differences between the photomicrographs confirms the opinion we expressed at Tr. 26469 that the casting shrinkage crack must have been formed before the weld shrinkage crack formed. The clear and pronounced difference between the thick, dark oxide on the casting shrinkage crack and the very thin oxide layer on the weld shrinkage crack indicates that the casting shrinkage crack formed during the fabrication process and did not propagate during EDG operation.

B. / The Stipulation

18. Please describe in greater detail how the x-ray crystallography and the Stipulation support your conclusion that monitoring is unnecessary.

A (Rau, Wachob, Youngling) As a result of the x-ray crystallography performed on a section of the cam gallery crack from bearing support no. 7 of the original EDG 103 block, which determined that the oxide layer on the crack was primarily (8%)

percent) magnetite, the parties have stipulated that the oxide, layer was formed at high temperatures at the time of the casting process and that the layer was not due to fretting corrosion or graphitic corrosion. The parties have also stipulated that this evidence supports the conclusion that the cam gallery cracks in the original EDG 103 block did not propagate during or as a result of EDG operation. Further, the parties have stipulated that the evidence justifies the conclusion that the cracks in the cam dellery areas of EDGs 101 and 102 formed during the casting process, and that this supports the conclusion that the cam gallery cracks in EDGs 101 and 102 did not propagate during or as a result of EDG operation. A copy of the Stipulation stating that Suffolk County and the State of New York do not seek to disqualify the use of the EDG 101, 102 or replacement EDG 103/blocks on the basis of the cam gallery cracks is attached as Exhibit B-67.

The Stipulation, which was based on the results of the x-ray crystallography, establishes that the cam gallery cracks in the EDG 101, 102 and original EDG 103 blocks have not propagated during more than a thousand hours of operation on each engine including hundreds of hours of operation at or above 3500 KW. Specifically, with respect to the original EDG 103 block, the x-ray crystallography and the Stipulation establishes that more than 1200 hours of operation, including more

propagation despite the severely degraded material of that block and the presence of large weld repairs with weld shrinkage cracks.

Based on this extensive operating experience, there is no reasonable engineering basis for concluding that cracks measured to be much smaller and shallower in the EDG 101 and 102 blocks will ever propagate, let alone propagate during the 100 hours or less of operation that the EDGs are anticipated to experience prior to the first refueling outage. Accordingly, there is no need to perform any monitoring or measuring of the cam gallery cracks prior to the first refueling outage. Mapping of the cracks at the maintenance interval scheduled during the first refueling outage is more than sufficient to confirm that there is no crack growth.

C. Strain Gage Measurements

- 19. Please describe the strain gage testing that was performed on the cam gallery of the EDG 10% replacement block.
- A. (Rau, Wachob, Schuster) Prior to the endurance run, strain gage measurements were made on the cam gallery of the EDG 103 replacement block at locations where cracks had been observed on the EDG 101, 102 and the original EDG 103 slocks.

 Prior to the installation of the strain gages on the EDG 103 replacement block, magnetic particle and liquid penetrant

fine, discontinuous linear indications that were reported by Lilco during its oral testimony.

Before installing the strain gages, through-bolts numbered 1, 2, 3, 7, 8 and 9, which are in the vicinity of cam bearing support saddles no. 2 and 8, were loosened. Then, strain gages, which included four full rectangular rosettes and two biaxial gages, were attached at six block locations as shown in Exhibit B-68, pages 1 and 5. After calibrating and zeroing the gages, the strain data were recorded as the through-bolts were tightened (torqued) in five increments up to the specified torque.

The strain gage data were recorded while the engine was brought to hot standby condition and quick started to 3300 KW. The EDG was run continuously at 3300 KW for approximately one hour, and then at lower load levels which were subsequently achieved by unloading the engine incrementally. At each power level, strain gage data was recorded after allowing a steady state operation.

20. Please describe the results of the strain gage testing.

(i.e., vertical) remain fully compressive at all operating conditions, including both fast starts to 3300 KW and steady starts

pressive stress that is introduced due to tightening of the through-bolts. Engine operation at load superimposes cyclic stresses on this steady compressive stress. However, the magnitudes of the cyclic stresses are less than the steady compressive stress. Therefore, the stresses remain fully compressive, thereby preventing crack propagation. The measured stresses perpendicular to the cam gallery indications are shown as a function of bolt torque and engine load in Exhibit B-68, pages 2-4 and 6-8.

- 21. Do the test results indicate whether the stresses perpendicular to the crack indications would remain compressive at higher engine loads?
- A. (Rau, Wachob) Yes. The test results have been extrapolated conservatively to engine operation at 3500 and at 3900 KW. The results indicate that the stresses remain fully compressive even at these loads.
- 22. Would the stresses remain fully compressive even during fast starts to 3900 KW?
- A. (Rau, Wachob) Yes. Fast starts do not introduce a significantly higher transient stress into the cam gallery as compared to steady operation at the same power levels. This is consistent with engineering analyses which indicate that transient thermal stresses introduced during fast starts will be insignificant in this region.

replacement block applicable to the cam gallery regions of the EDG 101 and 102 blocks?

A. (Rau, Wachob) Yes. The geometry of the cam callery is identical for each of the EDGs. Similarly, the compressive load imposed by the through-bolts is the same for each of the EDGs since the bolt torque specified is the same for each engine. Accordingly, in the absence of the repair welds and shrinkage cracks, strain gage measurements on the EDG 101 and 102 blocks would have been virtually identical to the measurements on the EDG 103 replacement block.

Although the EDG 101 and 102 blocks have repair welds and weld shrinkage cracks, the results of the strain gage measurements on the replacement block of EDG 103 are directly applicable to fracture mechanics analyses of cracks in the cam gallery regions of EDG 101 and 101. There is no indication that casting shrinkage cracks extend below the depth of the weld repairs in the EDG 101 or 102 blocks. Indeed, the evidence from the TSI depth gage is that no crack extends below the weld shrinkage crack. But if a casting shrinkage crack were present below the repair welds in the EDG 101 or 102 blocks, the strain gage measurements made on the replacement block of EDG 103 are directly applicable to the fracture mechanics analyses which show that such cracks would not propagate in operation. According—

Ty, the conclus on drawn from the EDG 103 strain gage data that

the cam gallery cracks are nonpropagating applies to the EDG.

101 and 102 blocks.

Based on the strain gage test results, would the presence of residual stresses affect your conclusion that cam gallery cracks will not propagate?

A. Rau, Wachob) No. Before the crack formed, any residual stresses that were present would have been tensile stresses at the cam gallery surface. These tensile stresses would have been balanced by compressive residual stresses beneath the cam gallery surface. The repair welding process and the formation of weld shrinkage ofacks has eliminated or reduced markedly the magnitude of any tensile residual stresses near the cam gallery surface. Correspondingly, it has reduced the magnitude of the balancing, subsurface compressive residual stresses. Consequently if a crack was hypothetically assumed to be present to a depth beyond the repair weld, the residual stresses near the crack tip would be negligibly small and compressive. Thus, any residual stresses existing at the present time will not enable crack extension during operation.

This analysis has been confirmed by physical observations of the original EDG 103 block after extensive operation. In the original EDG 103 block cam gallery, casting shrankage cracks extended substantially beyond the repair weld depth.

They did not propagate, however, during more than 1200 hours of peration, including more than 400 hours at or above 3500 KM.

block material and the presence of even larger repair we'ds.

25. Can tightening and loosening of the through-bolts cause sudden crack extension?

- A. (Rau, Wachob) No. During the course of the strain gage testing, the through-bolts in the vicinity of cam bearing supports no. 2 and 8 were fully loosened and subsequently retightened to the specified to que. No significant change in the surface crack indications: sulted. In addition, the through-bolts on the DG 101, 102 and the original EDG 103 blocks have also been loosened and retightened several times for required maintenance, with no indication of cam gallery crack extension. Since each of the existing Shoreham EDG blocks has already experienced through-bolt loosening and retightening, subsequent loosening and retightening will not produce crack extension, including "pop-in," of any cam gallery cracks.
- 26. The County contends that the EDO 101 and 102 cam gallery cracks should be monitored with wire gages because there is no reliable depth measurements of the cracks in these blocks. Do you agree?
- A. (Rau, Wachob) No. Cam gallery cracks in the EDG 101 and 202 blocks have been inspected visually and with fluorescent magnetic particle and liquid penetrant. These inspections revealed that the repair welds are smaller and the weld chrinkage cracks shorter and tighter on the surface than in the

the metallurgical analysis and mechanical testing which have shown superior mechanical properties in the EDG 101 and 102 blocks compared with the original EDG 103 block. Thus, all other factors being equal, both casting shrinkage and weld shrinkage cracks, if they form, will be shallower in the EDG 101 and 102 blocks than in the original EDG 103 block.

Crack depth measurements using the TSI depth gage have also indicated that the cracks in the EDG 101 block are much shallower than in the original EDG 103 block. The deepest crack in the EDG 101 block was measured to be 0.164 inch as compared to 0.91 inch in the original EDG 103 block. Thus, it is our opinion that the original casting shrinkage cracks were much shallower in the EDG 101 and 102 blocks and were completely ground out at the time of the repair weld.

Nevertheless, even if it is unrealistically assumed that casting shrinkage cracks in the EDG 101 and 102 blocks are as deep as those in the original EDG 103 block, there is no necessity to monitor the cracks because they will not grow. The evidence demonstrates clearly that the relatively large cracks in the original EDG 103 block with severely degraded material did not propagate. Similar cracks in the EDG 101 and 102 blocks, if they existed, would not propagate in the superior material of those blocks.

galleries of EDG 101 and 102 should be monitored because the repair welds are inadequate. Do you agree?

A (Rau, Wachob) No. The operating experience of the original BDG 103 block makes clear that the cracked weld repairs do not cause cam gallery crack propagation even in material with severely degraded fatigue resistance. Thus, the operating experience of the original EDG 103 block for over 1200 hours with cracked welds and without any cam gallery crack propagation shows that the presence of weld shrinkage cracks in the cam galleries of the EDG 101 and 102 blocks will not cause crack propagation.

Furthermore, since the strain gage measurements establish that the stresses in the cam gallery area of the EDGs remain fully compressive under load conditions up to the EDGs' overload design rating, it is clear that no crack propagation will occur in the future as a result of any anticipated operation regardless of the presence of cracked repair welds. Consequently, it is not necessary to conduct wire gage monitoring of the repair welds on the EDG 101 and 102 blocks or to measure the depth of the cracks in the EDG 101 and 102 blocks prior to the scheduled maintenance interval at the first refueling out

0

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

Before the Atomic Safety and Licensing Board

In the Matter of

LONG ISLAND LIGHTING COMPANY

(Shoreham Nuclear Power Station,)
Unit 1)

Docket No. 50-322(OL)

CYDINDER BLOCK EXHIBITS

ADDITIONAL CYLINDER BLOCK TESTIMONY OF DR. DUANE P. JOHNSON, DR. CHARLES A. RAU, JR., MILFORD H. SCHUSTER, DR. HARRY F. WACHOB AND EDWARD J. YOUNGLING ON BEHALF OF LONG ISLAND LIGHTING COMPANY

B-65

550x magnification photomicrographs of the weld shrinkage crack at face 1 of cam saddle no. 7 of the original EDG 103 block.

B-66

Mark-up of 100x magnification photomicrograph of the weld shrinkage crack at face 1 of cam saddle no. 7 of the original EDG 103 block.

B-67

Stipulation of the parties regarding cam gallery crack contention.

B-68

Strain gage measurements on cam gallery of replacement EDG 103 block.

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

Before the Atomic Safety and Licensing Board

In the Matter of		
LONG ISLAND LIGHTING COMPANY	Docket No.	50-322 (OL)
(Shoreham Nuclear Power Station, Unit 1)		

STIPULATION

The parties to this proceeding, by counsel, stipulate as follows:

ordered that a cam gallery crack from the original EDG 103 block be produced for analysis. As a result, analyses utilizing x-ray diffraction techniques have been performed on a cam gallery crack from the original EDG 103 block by a laboratory on behalf of Suffolk County. The test results confirm that the oxide layer on the cam gallery crack surface consists primarily of magnetite oxides (approximately 85%). This indicates that the oxide layer was formed at high temperatures during the time of the casting process and that these layers were not due to fretting corrosion or graphitic corrosion. This evidence supports the conclusion that the cam gallery cracks in the original EDG 103 block did not propagate during or as a result of operation.

- 2. The evidence of record indicates that the cracks in the cam gallery areas of EDGs 101 and 102 formed through the same process as the cam gallery cracks in the original EDG 103 block. Accordingly, the test results support the conclusion that the cam gallery cracks in EDGs 101 and 102 did not propagate during or as a result of EDG operation.
- disqualify the use of the blocks of EDGs 101 and 102 and the new block of EDG 103 on the basis of the existence of cam gallery cracks. However, Suffolk County reserves the right to contend and to litigate that the cracks should be monitored continuously using wire strain gages and that depth measurements should be taken prior to operation and at the first refueling outage, if Shoreham is licensed to operate.

Fabrian G. Palomino & Sesan Bright Counsel for State of New York Counsel for Suffolk County

Counsel for Long Island

Counsel for Nuclear Regulatory

Commission

A	6	3	0	0	4	0	3
1			WR	B	b	rb	

1

an instrument accuracy of 0.6 percent.

- MR. DYNNER: I object, Judge, because my question
- 3 is: what was the potential instrument error on the main
- 4 control room kilowatt meter and he is not being responsive
- 5 at all.
- JUDGE BRENNER: No, I think he is, because it's
- 7 part of the explanation; and if he doesn't make that
- 8 explanation then there will be the ambiguity that he is
- 9 talking about everything related to the --
- 10 MR. DYNNER: I was going to follow up by asking
- 11 him which hours were which. But I don't think he's being
- 12 responsive to my specific question at all.
- JUDGE BRENNER: Let him make the explanation.
- 14 think we'll get there faster in this case. If you're going
- 15 to get there anyway, I could not be assured, and neither
- 16 could the witness, that you were going to get there. And it
- 17 would have been potentially misleading, I think.
- 18 Go ahead.
- 19 WITNESS YOUNGLING: The remaining portion of
- 20 those hours which were taken during the endurance run on
- 21 diesel engine 103, were accumulated during the endurance
- 22 run, which utilized the main control room watt-hour meter as
- 23 the primary source of data accumulation.
- 24 As we testified earlier, that particular
- 25 instrument loop had an accuracy of 2.5 percent. That

25

So it is correct that your testimony is that the

28804 A630 04 05 potential instrument error for the main control room WRBbrb 1 kilowatt meter during this test was plus or minus 70 2 kilowatts; is that right? 3 (Witness Youngling): I'm saying that the 4 recorder loop accuracy is plus or minus 70 kw. But, as we 5 have previously testified, it is our feeling that the 6 7 instrument spends as much time above as below; and we feel that the mean value, as indicated by the kilowatt meter, is 8 representative of the loop load -- of the diesel generator 9 10 load. Now, of the 507 hours that are referred to in 11 0 that sentence, how many of those hours were run at 3300 12 13 kilowatts, as indicated by the main control room kilowatt 14 · meter? 15 (Witness Youngling): Mr. Dynner, I don't have 16 that number with me now. I'll have to get it for you at the 17 break. 18 In the next sentence, you refer to "A substantial 0 19 portion of the hours placed on the EDG-103 replacement block 20 occurred as the result of a 745-hour 10 to the 7th loading 21 cycle confirmatory test." 22 How many hours are you referring to in your term "a substantial portion"? 23

24

MR. DYNNER: Or the testimony, for that matter,

That's the number you want, is that right,

MR. DYNNER: That's what I was looking for. And

23

24

25

Mr. Dynner?

2630 05 03		28807
WRBmpb	1	I think the answer is that they don't know.
	2	WITNESS YOUNGLING: I can get you the number at
	3	the break.
	4	BY MR. DYNNER:
	5	Q When you refer in the next sentence to the
	6	endurance run portion of the confirmatory test, are you
	7	referring to the 525 hours that you just mentioned?
	8	A (Witness Youngling) Yes, I am.
	9	Q And were those 525 hours, was the load level
	10	during that confirmatory test indicated by the main control
	11	room kilowatt meter?
	12	A (Witness Youngling) As I previously testified
	13	this morning, the majority of the data points were taken off
	14	the control room meter. But there were some data points
	15	that were read off the watt hour test loop after
	16	confirmation of load on the watt hour meter. So some of the
	17	data was recorded off the more accurate loop.
	18	Q Can you quantify that in terms of the number of
	19	hours that were read off the data meter?
	20	A (Witness Youngling) No, I don't have that
	21	number.
	22	MR. DYNNER: I have no further questions.
	23	JUDGE BRENNER: That's why I was trying to get to
	24	the witnesses this morning; I knew what the approximate
	25	length of your cross plan was. I don't know if the other

The reason for that, of course, is, of course,

2630 05 05 2 WRBmpb	1	28809 that their testimony was filed after ours and we did not get
	2	a chance to respond.
	3	JUDGE BRENNER: We will allow that type of
	4	inquiry. We have allowed it before.
	5	MR. ELLIS: Thank you.
	6	JUDGE BRENNER: Maybe we should let you do that
	7	now to the extent it might affect our questions.
	8	MR. ELLIS: All right, sir. I'll be glad to go
	9	to it now.
	10	JUDGE BRENNER: All right.
	11	REDIRECT EXAMINATION
	12	BY MR. ELLIS:
	13	Q Gentlemen, turn, if you will, please, to the
	14	testimony of Mr. Bridenbaugh, dated January 25, 1985, on
	15	page two. Question four, Dr. Rau, states:
	16	"Do you believe that the cylindar
	17	blocks in EDG 101 and 102 are suitable
	18	for use at a reduced load of 3300 KW?"
	19	And the first paragraph of the answer states:
	20	"No. First, both of those blocks
	21	have ligament cracks. FaAA's own analysis
	22	predicts that both ligament and stud to
	23	stud cracks may initiate in those blocks
	24	even at the reduced load level of 3300 KW."

Dr. Rau, do you agree with that portion of answer

15

16

17

18

19

20

number four?

2 A (Witness Rau) No, Mr. Ellis, I do not.

3 Mr. Bridenbaugh has answered no to the question of whether

4 or not blocks of 101 and 102 are suitable for their intended

5 purpose at a reduced load of 3300. I disagree with his

6 statement, his answer no. I believe they are. And I

7 believe they are for a number of reasons.

In particular the cumulative damage analysis of
fatigue crack propagation of the block tops has indicated
that, independent of whether or not stud to stud cracks
would initiate at any power level -- whether it be 33 or 35
or any combination duty -- that there is a very substantial

13 margin which would prevent a crack, even if it were

14 initiated, from extending to a size of concern.

And in particular I previously testified that the EDG 101 and 102 blocks, even based on the very conservative cumulative damage analysis of crack propagation that we've done, could withstand 50 consecutive LOOP/LOCAs even at the 35-, 39-, 2600 design load profile which was addressed in the proceedings of last fall.

21 For that reason I disagree that initiation has 22 any relationship to the adequacy of the 101 or 102 blocks 23 with regard to the functionability or ability to perform 24 their intended function at 3300.

25 Q In your opinion, Dr. Rau, do you agree that

stud to stud cracks are likely to initiate in those blocks

- at load levels of 3300? 2
- (Witness Rau) No, Mr. Ellis, I do not believe 3
- 4 that stud to stud crack initiation is likely in those
- blocks. 5
- 6 The analyses that have been done of the
- 7 possibility of fatigue crack initiation are very
- conservative, as I have testified quite extensively 8
- 9 previously. And although they indicate the possibility that
- stud to stud cracks might initiate, the conservatism in that 10
- analysis leads me to believe that it is not likely that they 11
- 12 will.
- 13 I think further that the extensive operation that
- 14 the 101 and 102 blocks have seen at power levels at and
- 15 above 3500 KW, when converted, if you like, to an equivalent
- 16 number of hours at 3300 KW, suggests that these blocks have
- 17 already demonstrated a very substantial number of cycles --
- 18 again of the order of five-times-ten-to-the-sixth cycles --
- 19 an equivalent of 3300 KW without initiating stud to stud
- 20 cracks even after ligament cracks have been shown to be
- 21 present in the 101 and the 102 blocks.
- 22 So for that reason I don't believe it is likely
- 23 that we are going to initiate stud to stud cracks in those
- block tops. 24
- 25 All right. 0

initiate and that the cyclic stresses will decrease very

6

7

11

12

19

20

21

22

23

24

25

rapidly with distance from that sharp corner.

And for both reasons, that even if a crack were 2 to initiate in a circumferential area it would slow down and 3 it would arrest. And for that reason the implication that 4 initiation has any relevance whatsoever to the suitability 5

of the blocks, should it occur, I take disagreement with.

I also disagree with the statement that there

have been no tests which conclusively establish the absence 8 of cracks in either 101 or 102. I believe that there are 9 10 inspections -- in particular the ultrasonic inspections -which do conclusively indicate that there are no cracks in 101.

13 And I believe Dr. Johnson would like to comment 14 on that.

15 (Witness Schuster) Long Island Lighting Company has performed in excess of 100 examinations of the liner 16 17 landing and the block top areas of 101, 102 and 103 18 engines.

Specifically EDG 101 early in November of 1983, we performed a penetrant examination on cylindar number eight. At that point in time some industry experience was provided to us in regard to the possibility of circumferential indications in the cylindar block. So we performed a penetrant baseline on cylindar number eight on DG 101.

after it had been cut up. And further verification was then

Mr. Schuster, before you -- before Dr. Johnson

done by -- of our examinations by FaAA in California.

comments about the FaAA inspections, you referred to a

number of liquid penetrant inspections of the diesel

21

22

23

24

personnel with a minimum level two certification for the

baseline inspection, and the additional examinations and

examination certification in UT, MT, PT and RT, and had

extensive casting industry experience.

scrutinization was done by a level three who had level three

You omitted, though, from your answer,

Mr. Schuster, what was the result of the additional work on

the 101, DG 101. You mentioned ultrasonic that was done as

18

19

20

21

22

23

24

12

1.3

14

21

22

23

24

25

a result of the background.

A (Witness Schuster) The results of the ultrasonic examination were that there were no indications in that area of the block, in the land area of the block, specifically that notch where the liner landing face and ledge meet each other.

Incidentally, we also verified this procedure

again on DG 103 with a different inspector to verify the

original inspection because of questions that were raised as

a result of some of what is going on here, and verified that

that procedure was in fact valid.

Q Have any of the inspections, then, that you have described, Mr. Schuster, revealed any circumferential cracks on DG 101 and 102?

15 A (Witness Schuster) No, sir.

16 Q Dr. Johnson, do you agree with that second 17 paragraph of answer four? And give a basis for your answer, 18 please.

19 A (Witness Johnson) No, I do not agree with that 20 statement.

I do not believe there is any evidence that there are circumferential cracks in DG 101 and 102. We performed extensive UTs -- ultrasonic tests -- directed at detection of circumferential cracks in March of '84 after the 100 hour endurance run test on DG 101, and no circumferential cracks

2630 05 13 1 WRBmpb were detected. We have also performed penetrant tests directed at circumferential cracks. They were conducted both on DG 101 and 102 after the 100 hour endurance runs. And no circumferential cracks were detected.

1	Q	Gentlemen,	let's	turn	to	the	third	paragraph	of
							W 10 10 10 10 10 10 10 10 10 10 10 10 10		

2 Answer 4, and let me ask you, without reading it -- you may

3 read it for yourself -- whether you agree or disagree with

4 that.

15

16

17

18

19

20

21

22

23

24

25

Any member of the panel may answer.

6 A (Rau) Others may wish to answer, too, Mr. Ellis,

7 but I, for one, certainly strongly disagree with the

8 statements made by Mr. Bridenbaugh in his testimony, the

9 third paragraph in his answer to Question No. 4.

He states that Failure Analysis has not
undertaken any detailed crack propagation analyses, and I
have testified previously and will state again here that
Failure Analysis Associates has in fact done an analysis of
crack propagation in the block top.

The cumulative damage analysis, which we have testified about extensively, is in fact an analysis of fatigue crack propagation in the block top, and it does in fact show with a reasonable degree of scientific certainty that the block top cracks cannot and will not extend during a LOOP/LOCA to a size of concern, with a very substantial margin.

With regard to the circumferential crack area,
which Mr. Bridenbaugh suggests we haven't done a crack
propagation analysis of, we have in fact done all that
analysis which is necessary to reach with a reasonable

1 degree of scientific certainty a conclusion that those

2 circumferential cracks are of no concern because they will

3 not and cannot extend to a size to affect the function of

4 the EDG blocks.

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

In particular, the finite element stress analyses which we have done have indicated convincingly that the stresses which are very high right at that sharp corner between the counterbore, the cylinder, and the liner land where circumferential cracks were detected in the original 103 block with the degenerate Widmanstaetten graphite, those very high stresses very quickly drop off with distance away from that sharp corner; and through analyses of postulated hypothetical cracks which might extend in various directions from that sharp corner, our analyses have shown that the maximum stress will become compressive at depths less than four-tenths of an inch beneath that surface, and once the maximum stresses become compressive in conjunction with a reduced magnitude in the cyclic stresses any crack, should it initiate at that sharp corner, will slow down and will arrest.

There is absolutely no reason to do any specific, if you like, fracture mechanics analyses of crack progression beyond that point because it is simply going to show no crack progression.

25 A (Schuster) I would like to add that the results

of	the	inspections	on	the	block	top,	specifically	y for
-		was man me mu mass m				mer In 6	mhannan.	

2 stud-to-stud indications, the penetrant examinations, and

3 other examinations that were done on DG-101 and 102

4 indicated no stud-to-stud cracks, and those engine blocks

5 have over some 1200 hours of operation at all loads.

A (Rau) Could I add one more thing?

I noticed that Mr. Bridenbaugh in that same

paragraph you referenced also makes reference to ligament

crack area, which I don't think I have responded to

10 specifically.

I think it is appropriate to note that the finite element stress analyses that have been done at the block top region indicate that in the ligament area as well as in the stud-to-stud area that the steady stresses; the mean stresses also decrease very rapidly with distance beneath the top surface of the block, and in fact they become compressive on the ligament side of the stud as you progress down towards the thread area from the block top surface.

Similarly, to the stud-to-stud side of the stud hole and the block top, the cyclic stresses introduced by the cylinder firing also decrease in magnitude as you progress in distance from the block top down towards the threads, and in fact the magnitude of the cyclic stresses decreases very substantially as you move from the block top down to the inch and a half depth where the first thread

26	30	06	04
1	WF	Bbi	ır

appears on EDG-101 and 102 block tops.

- 2 For both those reasons, the ligament cracks are
- 3 also going to slow down and arrest, as in fact -- and this
- 4 in fact confirms the observations that have been made on the
- 5 EDG-101 and 102 that in fact the ligament cracks do slow
- 6 down and arrest at the liner land area.
- 7 Q What is your opinion with respect to whether
- 8 subsurface ligament cracks would initiate at the first
- 9 loaded thread in the stud hole?
- MR. DYNNER: Objection. There is nothing about
- 11 initiation. The question is about propagation.
- MR. ELLIS: That is correct, Judge Brenner. What
- 13 I was doing is the implication of the statement concerning
- 14 ligament cracks. I was simply taking the full implication
- 15 of that statement.
- JUDGE BRENNER: Well, I think I will overrule the
- 17 objection. I know we will overrule the objection for
- 18 Mr. Ellis' reason, and in addition, maybe we don't
- 19 understand what Mr. Bridenbaugh means by "develop," as he
- 20 uses that word in that paragraph, that the witnesses have
- 21 been focused on as a lead-up to this.
- So for completeness, because we might not learn
- 23 fully what he means, and for conservatism's sake I assume he
- 24 means initiation, also, for now.
- 25 Do you need the question again?

And although I haven't made a specific calculation of it, we are talking about hundreds and thousands of times more difficult to initiate a crack down

initiation of fatigue crack beneath the block top.

22

23

24

21

22

23

24

25

As the records of the eddy current examination I performed in the stud holes after the 100-hour endurance run show, there were large unmistakable crack indications down at least to 1.4 inches in both stud holes.

After the load excursion in the old DG-103, we have laboratory destructive tests, laboratory magnetic particle tests, penetrant tests, eddy current examination

2630 06 07 results, which all agree that the stud-to-stud crack in this WRBbur area after the load excursion do not extend to more than approximately three inches in this area. Dr. Johnson, did you review some specific data to support or confirm your opinion that you have just given me? (Johnson) The specific inspection report. Well, the DRQR report, Q-220, which clearly describes the magnitude of the signal, which is approximately five times the reference level down to the first thread, which is approximately 1.5 inches in both stud holes.

2630 07 02 1 WRBwrb

Dr. Johnson has testified that he has reviewed the

2 inspection reports and knows precisely that the depth of the

3 stud-to-stud crack between cylinders 4 and 5 was in fact

4 between 1.4 and 1.6 inches deep. That's the initial crack

5 size upon which our cumulative damage analysis is in part

6 based.

service.

In addition to that crack measurement there is also the measurement of the crack depth after the demonstration run -- that is, about 4/14 1984 -- when the original 103 block, or after which it was taken out of

The quantification of the crack depth in the stud-to-stud region at that time was made by a number of methods, including destructive metallurgical examination which confirmed that the depth after that demonstration period run was, in fact, 3 inches, maybe as little as 2.8 inches, but between 2.8 and 3 inches deep. That is below the block top surface.

That depth was confirmed by visual examination through the metallography -- that is, the visual examination. It was also measured by eddy current to be the same depth. It was measured by magnetic particle inspection to be the same depth. It was measured by liquid penetrant to be the same depth.

So there were four independent non-destructive and

- l destructive examinations which confirmed the depth of the
- 2 crack after the demonstration period on the original 103
- 3 block. And, in fact, the eddy current inspections of the
- 4 crack depth prior to the demonstration period, I believe
- 5 also confirmed by some ultrasonic inspections which were
- 6 consistent with that 1.5 or 1.4 to 1.6 inch crack depth
- 7 prior to the period.
- 8 And it is those two crack sizes which form, in
- 9 part, the input to the cumulative damage analysis of crack
- 10 progression which is benchmarked against the performance of
- 11 the original 103 block during that test period, 3/11 through
- 12 4/14 1984.
- 13 Q Well, Dr. Rau, is it your opinion that the
- 14 cumulative damage analysis -- Or, what is your opinion with
- 15 respect to whether the cumulative damage analysis was based
- 16 on adequately precise crack measurements? Was it or wasn't
- 17 it?
- 18 A (Witness Pau) It very definitely was, Mr. Ellis,
- 19 for the reasons I have just indicated. The crack size after
- 20 the endurance run was confirmed to be within 2.8 to 3 inches
- 21 deep by four independent methods, and the measurement
- 22 before has been confirmed by the eddy current and
- 23 ultrasonics to be within 1.4 to 1.6 inches deep. And
- 24 there's absolutely no concern whatsoever for the validity of
- 25 either one of those numbers within those ranges quoted.

Q Gentlemen, in that same answer Mr. Bridenbaugh states, and I'm paraphrasing, that the original analysis was inadequate -- referring to the cumulative damage analysis -- at 35, 39 and the same weaknesses exist at 33, because it was based on inadequate -- in part, based on inadequate crack propagation data.

Do you agree with that, gentlemen?

A (Witness Rau) No, Mr. Ellis; I strongly disagree with Mr. Bridenbaugh's testimony in that regard. He is implying that we do not have adequate fatigue crack propagation data upon which to perform our cumulative damage analysis of fatigue crack propagation. I disagree with his statement because it's clear that we do.

is, the benchmarked testing upon which the analysis in in part based -- we actually cut physical samples from the block top region of the original 103 block. It contained the same microstructure, the same degenerate Widmanstaetten graphite that was throughout the original 103 block. We made fatigue crack propagation measurements on that material cut from the same original 103 block. We measured the effect of variable cyclic stress amplitude, we measured the effect of variable steady, or mean stress on the rate of fatigue crack propagation on the original material cut from the old 103 block.

2

3

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

For that reason we have done a direct and precise measurement of the rate of fatigue crack propagation in the original 103 block material.

Now, to perform the cumulative damage analysis we also have measured, directly measured, the fatigue crack propagation rates in conventional gray cast iron without degenerate Widmanstaetten graphite.

Short of completely destroying the 101 and 102 blocks, and cutting material directly from them, we have done the best that anybody could possibly do with regard to quantifying the rate of fatigue crack propagation in typical gray cast iron of the ASTM A48-64 gray cast iron Class 40. We did that by cutting samples from a large casting made by TDI in an area where the wall thickness was approximately three inches, where the microstructure was confirmed to be conventional, or typical gray cast iron. We fabricated a laboratory specimen, we went to the laboratory and we measured on those specimens cut from the typical gray cast iron the effect of variable cyclic stress, of variable steady, or mean stress, and we did it on exactly the same basis we made the measurements of fatigue crack propagation on the original 103 block material with degenerate Widmanstaetten graphite.

So, as I said previously, short of literally cutting material actually precisely from 101 or 102, we have

JUDGE BRENNER: We're starting to get too

15

repetitious.

2 MR. ELLIS: Yes, sir.

various points in time.

- 3 BY MR. ELLIS:
- Q Gentlemen, finally, Mr. Bridenbaugh states that
 the original analysis was inadequate at 35 and 39, and the
 same weaknesses exist at 33, because it failed to account
 for possible variations in the rate of crack growth at
 various points in time.
- 9 Do you agree with that, Dr. Rau?
- 10 A (Witness Rau) No, Mr. Ellis, I do not.
- It's quite clear, once you understand the details
 of the cumulative damage analysis of fatigue crack
 propagation that it does, in fact, consider in a
 conservative fashion the variation in crack growth rate at

The original 103 block and the progression of the 16 17 stud-to-stud crack during the demonstration test period between 3/11 and 4/14 1984 in fact undergoes progression of 18 19 the stud-to-stud crack during that period over the crack size range which is the one used to benchmark the cumulative 20 damage analysis. And to the extent there are any 21 22 significant variations in crack progression over that time period, or over that distance of crack progression, that's 23 incorporated, if you like, automatically through the 24 25 behavior of the original 103 testing.

2630 07 08 1 WRBwrb	1	28832 I've indicated that in addition to that the
	2	analysis which we've performed is conservative, and it
	3	incorporates any possible variations in a conservative way.
	4	And what I mean by that is the following:
	5	The analysis which we did, the cumulative damage
	6	analysis of fatigue crack propagation in the block top, has
	7	not incorporated any effects of fatigue crack retardation
	8	that sometimes result as the result of variations in the
	9	load amplitude and sequencing of loads. And in particular,
	10	what happens I think Dr. Bush may have testified about
	11	this already: if there's a high load or stress which is
	12	subsequently followed by a lower load or stress, the fatigue
	13	crack progression at the lower load of stress will be
	14	retarded or slowed down if in fact it is preceded by a high
	15	load first, compared to what it would have been without that
	16	high load preceding the operation at the lower load.
	17	mh 6

The reason for which our cumulative damage analysis is conservative, it is that the postulated LOOP/LOCA load profile involved the highest demands, or loads, and therefore corresponding stresses in the block top area early in the LOOP/LOCA load profile, followed with subsequent operation at lower load levels.

So that if in fact the effects of variations in crack progression due to this high load followed by low load were to be incorporated explicitly in the cumulative damage

original 103, had been included in our analysis.

MR. ELLIS: Judge Brenner, that's all the

24

JUDGE BRENNER: This will take another moment or

JUDGE BRENNER: I don't even know if I've seen the

2630 07 12 last communication. But that doesn't matter. 1 WRBwrb I'll see if one or two questions will help solve it; and, if not, I'll abandon the whole subject in favor of the break. We can let the witnesses take a break now while we keep talking. This won't relate directly to their testimony.

Mr. Dynner, without the Board, just the parties?

Maybe I misunderstood. You see, I thought you

24

It just seems to me I can't be in a position to say that I

can do anything between now and Monday or now and Tuesday.

and hopefully we will be able to continue -- or to begin,

23

24

13

14

15

16

17

18

19

20

21

22

23

24

25

I should say -- discussions after we conclude this hearing

2 and keep the Board apprised if anything happens as a result

3 of those discussions, if they occur.

anything further.

JUDGE BRENNER: Well, I think it would be 4 5 reasonable -- unless you point out why it would be unreasonable from your point of view -- for us to require 6 7 the parties to have -- to begin the discussions that you 8 have said have not occurred between now and early next week 9 so that we could at least get a status report and then make 10 a more informed decision as to anything we might -- whether 11 there was anything we might say or do that could stimulate

Now, we might agree with you that at that point there is still nothing further for us to do, and we might well decide to do nothing, but I want to have that other opportunity, and it will be very convenient, since we are all going to be here next week, to work it out so that we can have the opportunity then.

MR. DYNNER: I would respectfully suggest that if the Board requires the parties to have discussions, that those discussions are probably not going to go anywhere. Discussions on settlement go someplace if the parties mutually decide that they have something to discuss and that there is movement on either side, but I don't think it will be appropriate for the Board to require discussion to take

	-				
1	D	la	C	6	

- 2 I would hope discussions would take place if
- 3 people's positions are such that they could have
- 4 discussions.
- 5 JUDGE BRENNER: I am confused again. You will
- 6 forgive me.
- 7 I thought you said you would be willing to
- 8 undertake discussions. That was my starting point. So my
- 9 only question is for us to force the timing a little better
- 10 than leaving the timing wide open, and that is all I thought
- Il was speaking to because you corrected my previous
- 12 misimpression and told me you were certainly willing to have
- 13 discussions.
- MR. DYNNER: I said we are willing to talk if
- 15 LILCO has something they want to talk to us about. I don't
- 16 think that discussions ought to be imposed by the Board, and
- 17 I don't think a timeframe for those discussions ought to be
- 18 imposed by the Board.
- I think at this stage in particular settlement
- 20 negotiations and discussions ought to be left to the
- 21 parties.
- JUDGE BRENNER: You are not communicating any
- 23 substantive thoughts to me, Mr. Dynner. I am not receiving
- 24 any, let's put it that way.
- 25 All right. Let's take a break. We will see if

2630 08 05		28841
1 WRBbur	1	we can do what we need to do by 11:15, and if we are not
	2	ready then, we will let you know.
	3	(Recess.)
	4	JUDGE BRENNER: Back on the record.
	5	We have reconsidered, at LILCO's request, and now
	6	supported by their written proffer, whether to allow LILCO
	7	to put in the "Proffered Testimony of Paul R. Johnston,"
	8	dated March 8, 1985.
	9	On reconsideration, we hold to our original
	10	ruling, for the reasons we gave on the record yesterday, not
	11	to admit the testimony. There is no need to repeat that.
	12	I will further point out the obvious, that to the
	13	extent there is information already existing in the record
	14	that the parties want to bring together in their proposed
	15	findings, they are entitled to do that.
	16	MR. ELLIS: Judge Brenner, maybe before the Board
	17	begins its questions
	18	JUDGE BRENNER: I have one other subject.
	19	Your subject was related to the testimony?
	20	MR. ELLIS: Yes, sir.
	21	JUDGE BRENNER: I am sorry. I had one other
	22	subject.
	23	With respect to settlement discussions, it is the
	24	Board's view that we would seek to require further
	24	board a view that we would seek to require further

25 discussions to take place as a follow-up to what has

about that much. Label that the "shape of the table"
discussions, to take place between now and Monday, and then
let us know, and I am sure the parties, with those goals in
mind, can come up with something.

Obviously, when the time comes for the parties to

Obviously, when the time comes for the parties to report back to us, the report may be that no further progress has been made, but....I am talking about the

24

1

12

13

14

15

16

17

18

19

20

21

22

23

ultimate report back to us.

We think that is consistent, or at least not 2 3 inconsistent, with anything the parties express so far. We are at least not discouraged by the fact that no party has 4 said absolutely there is no point in any further discussions 5 to take place, and having been through lengthy proceedings 6 already and having seen the parties' very successful results . 7 8 in at least holding discussions even when they do not reach fruition, we would have been surprised if any party had 9 10 taken that position. 11

So the parties that the parties -- at least we have confidence that the parties will continue to approach this matter as they have approached settlement matters in the past, and if no progress is made, that will be the result. But nevertheless, we are going to require that you try, and you tell us how best -- what type of framework that that could be done to best suit your mutual purposes.

Since we are not going to -- well, I don't think we will finish with this panel. If it looks like we are not going to finish with the panel, anyway, we probably would like to adjourn at about 11:50 to give us a little more time, but if it makes a difference between finishing and not finishing we have some flexibility.

Mr. Ellis, you wanted to raise a matter?

MR. ELLIS: Yes, sir, two things. With respect

2630 08 08 1 WRBbur	1	to the Board's ruling, the proffered testimony, is it the
	2	Board's practice to bind that in as offered but exclude it?
	3	And if so, I would ask that that be done.
	4	JUDGE BRENNER: Yes. We will make it an exhibit
	5	so as not to confuse the parties here to thinking it is in
	6	evidence.
	7	Thank you. I should have offered that. I guess
	8	I did yesterday and forgot to renew the offer today.
	9	I suppose we will give it a C exhibit number.
	10	MR. ELLIS: Yes, sir.
	11	JUDGE BRENNER: We believe, taking two lists,
	12	which may not be accurate, that we are up to C-43 for
	13	LILCO.
	14	Do you know?
	15	MR. ELLIS: I don't know, Judge. I will check
	16	that. I think that is correct, and we will supply four
	17	copies to the reporter marked as C-43.
	18	JUDGE BRENNER: All right. The "Proffered
	19	Testimony of Paul R. Johnston," dated March 8, 1985, which
	20	consists of three typewritten a cover page and three
	21	typewritten pages will be marked for identification as LILCO
	22	Exhibit C-43, and it has been rejected by the Board for the
	23	reasons indicated.
	24	(LILCO Exhibit C-43
	25	identified and rejected.)

2630 08 09 1 WRBbur	1	MR. ELLIS: The second point, Judge Brenner, is
	2	that Mr. Dynner had asked for some figures that
	3	Mr. Youngling said he would obtain at the break. He has
	4	those figures now and is prepared to give them if the Board
	5	considers this to be an appropriate time.
	6	JUDGE BRENNER: Fine.
	7	Mr. Youngling.
	8	WITNESS YOUNGLING: Judge Erenner, on page 5 of
	9	our testimony, Mr. Dynner asked me how many what
	10	percentage of the hours of the 745 hours that were
	11	accumulated during the 10-to-the-7 test were on the
	12	replacement 103 block.
	13	Of those 745 hours, 596 hours were on the
	14	replacement block.
	15	He also asked me, of the 507 hours cited in the
	16	fourth line of my testimony, how many of those hours were a
	17	3300 kw, and there were approximately 426 hours at 3300 kw.
	18	
	19	
	20	
	21	
	22	
	23	
	24	
	25	

2630 09 01 2 WRBeb	1	JUDGE BRENNER: Is that 426 of the 596?
2 WKDED	2	WITNESS YOUNGLING: Of the 507.
	3	MR. DYNNER: May I ask a question, Judge Brenner,
	4	of Mr. Youngling, with respect to the remainder? He said
	5	that 426 hours were at 3300, and I was going to ask him
	6	about the remainder between 426 and 507.
	7	WITNESS YOUNGLING: The remainder of those hours
	8	were at greater than 3300.
	9	JUDGE BRENNER: We will let you come back to it
	10	as part of your follow-up questions if you want, Mr. Dynner,
	11	if you think it is necessary to ask a question or two now so
	12	you can contemplate the answers, I will let you do that
	13	also.
	14	MR. DYNNER: Either way. I am confused now more
	15	than I was before. And I could ask some questions about
	16	this discrete area.
	17	JUDGE BRENNER: Go ahead.
	18	MR. DYNNER: Thank you, Judge.
	19	BY MR. DYNNER:
	20	Q Mr. Youngling, your testimony says more than 507
	21	hours were at or about 3300 kilowatts as indicated on the
	22	main control room kilowatt meter. You now said that 426
	23	hours were at 3300 kilowatte.

the main control room kilowatt meter?

24

25

Were those 426 at 3300 kilowatts as indicated on

3400 but you don't know precisely where. Is that right?

(Witness Youngling) I don't have the precise

24

25

A

2630 09 03 2 WRBeb	1	breakdown with me, no.
	2	Q My statement is correct then; is that correct?
	3	A (Witness Youngling) No, I know where they are.
	4	I don't have the breakdown with me.
	5	Q But my question is
	6	A (Witness Youngling) I'm sorry, Mr. Dynner.
	7	Q The 81 hours were somewhere between 33 and 34
	8	hundred. Is that right?
	9	A (Witness Youngling) Yes.
	10	Q Thank you.
	11	MR. DYNNER: I think that clears it up for me.
	12	Thank you, Judge.
	13	EXAMINATION BY THE BOARD
	14	BY JUDGE MORRIS:
	15	Q Dr. Rau, I have some questions. Mr. Ellis
	16	started you through Mr. Bridenbaugh's testimony, but he
	17	stopped before getting to question and answer 6. I will
	18	give you a minute to refresh your memory on what that answer
	19	was.
	20	(Pause.)
	21	Mr. Bridenbaugh states that:
	22	"The results of the endurance test do
	23	not disclose anything about the endurance limits
	24	of 101 and 102 blocks for a number of reasons,
	25	one that the cast iron of 103 has a tensile

As I think we have testified extensively

- 1 previously, it is my opinion that the design modifications
- 2 or improvements that were incorporated in the replacement
- 3 103 block, one of which is made reference to in
- 4 Mr. Bridenbaugh's testimony, would have the effect of
- 5 reducing the stresses and increasing the margin. And to
- 6 that extent I would expect the replacement 103 block top to
- 7 be even more reliable than the 101 and the 102 are.
- 8 Q It is my understanding, and correct me if I'm
- 9 wrong, that LILCO chose to run the endurance test on 103 so
- 10 that they could monitor the cracks in the cam gallery which
- If they felt was not a feasible thing to do on 101 and 102. Is
- 12 that correct?
- 13 A (Witness Youngling) Yes, Judge, that was
- 14 certainly one of the reasons that we chose the 103 engine,
- 15 yes.
- In addition, of course the major emphasis for the
- 17 test was to approve the crankshaft. And we also wanted to
- 18 put some hours on this new 103 block to give us rear surance
- 19 of its reliability.
- 20 A (Witness Rau) Judge Morris, I would just add
- 21 that it certainly was my recommendation to LILCO that in
- 22 fact the replacement 103 block was much more appropriate for
- 23 the cam gallery strain gage testing. And in fact, the 101
- 24 and 102 would have been very difficult to accomplish that
- 25 task and I recommended the testing be done on the

1

replacement 103 block for that reason	replacemen	t 103	block	for	that	reason.
---------------------------------------	------------	-------	-------	-----	------	---------

- 2 Q Was there any consideration that running an
 3 endurance test on either 101 or 102 might be damaging to
 4 those engines?
- 5 A (Witness Rau) Well, as I have indicated,
 6 Judge Morris, the reasons for selecting the replacement 103
 7 were primarily with the cam gallery testing.
- I think with regard to whether it would be
 damaging or not, I don't think that issue was even part of
 the consideration. It's my opinion that the testing with
 regard to the crankshaft wouldn't have mattered, whether
 they had done it on 101, 102 or 103.
- 13 I also am of the opinion that there wouldn't have 14 been anything gained by -- with regard to the block top 15 reliabili by doing the 10 to the 7 testing on 101 or 102, 16 the reason being that 101 and 102 already have ligament 17 cracks and the endurance testing is a test with regard to 18 crack initiation. And once you have cracks, obviously you 19 cannot confirm -- you are not going to get cracks by doing 20 the endurance test. And I really felt there would be 21 nothing gained by subsequent testing on 101 or 102 even if 22 in fact the cam gallery were not a dominant issue with 23 regard to which block to utilize.

24 BY JUDGE BRENNER:

25 Q Dr. Rau, wouldn't there have been information

would be the same as the shape of the S-N curve that we have

with regard to the crankshaft, but we have in fact produced

(Witness Rau) I don't know what you discussed

previously discussed with respect to the crankshaft?

22

23

24

- in one of our prior exhibits -- I don't remember the number
- 2 now -- but the actual S-N data measured for the original 103
- 3 cast iron material, and also representative S-N data for the
- 4 A4864 gray cast iron with typical microstructure.
- 5 Those were the most appropriate S-N curves.
- 6 If your question means to ask if there is a
- 7 certain number of cycles you can acquire on the block top
- 8 which would give you some information about whether you're
- 9 going to get stud-to-stud cracks initiated -- maybe I'm
- 10 misinterpreting--
- 11 Q That's a good question.
- 12 A (Witness Rau) Surely there is information gained
- 13 as you produce -- put cycles on the block top. Based on the
- 14 knee to which we have actually measured and seen in the
- 15 literature, I am not prepared to say that there is any
- 16 magical number at 10 to the 7 or 3 x 10 to the 6 or 5 x 10
- 17 to the 6.
- But certainly as you get more and more cycles on
- 19 without initiation of the stud-to-stud cracks and you
- 20 already have ligament cracks, you do gain some information
- 21 with regard to the conservatism that was in our analyses of
- 22 the block top once it contains ligament cracks.
- 23 And there is no question that the 101 and the 102
- 24 block tops have experienced a substantial amount of duty at
- 25 a range of power levels much of which is up in the 3500 kw

- 1 regime, which are equivalent to hundreds of hours at 35 and
- even larger hundreds of hours at 3300 kw. And these, as you
- 3 know, are equivalent to 5 x 10 to the 6.
- 4 They are less than the 740 that is required for
- 5 10 to the 7, but they are certainly well in excess of a
- 6 million cycles which those two blocks, that is, 101 and 102,
- 7 have experienced without initiating stud-to-stud cracks, but
- 8 already having ligament cracks.
- 9 However, I don't think you can draw definitive
- 10 conclusions from additional testing of 101 and 102 on this
- 11 basis because there is another mechanism of potential crack
- 12 initiation in the stud-to-stud region which we've testified
- 13 about previously.
- 14. Although you do gain some information with regard
- 15 to the high-cycle fatigue mode or potential mode of crack
- 16 initiation, you don't gain -- unless you run a lot of starts
- 17 and stops, you don't gain specific information with regard
- 18 to the potential low-cycle fatigue load of initiation of
- 19 stud-to-stud cracks.
- And for that reason, even if you were to run 5 x
- 21 10 to the 6, which we have done already, or to run 10 to the
- 22 7 cycles on 101 or 102 and show there is no stud-to-stud
- 23 cracks, you could not be convinced that you might not get a
- 24 stud-to-stud crack initiated on subsequent cycling or
- 25 testing of either of those engines.

2630 09 10 For that reason we have conservatively relied WRBeb upon the crack propagation to demonstrate the margin to meet its intended function during a LOOP/LOCA and although I believe that there is additional margin associated with crack initiation which might in fact preclude us ever initiating cracks in the stud-to-stud region, I don't rely upon that, nor do I rely upon the time it might take for a crack to grow from initiation up to a depth of 1.5 inches. These are additional conservatisms which we don't take credit for, which would further expand the margin which has been demonstrated by the cumulative damage analysis of fatigue crack propagation. 14.

		1	11-11	1		1-	+-		
- (2 1	know	METT'	Ter	me	ash	CO	make	Sure

2	Your analysis from your point of view has
3	conservatively assumed initiation of stud to stud cracks
4	where a block already has ligament cracks, correct?

Mour Honor, that those cracks extended to a depth of an inch and a half.

9 the 101 and the 102 block, in your view why do you not
10 believe you can point to that experience as a reasonable
11 assurance, in your professional opinion, that in fact stud
12 to stud cracks would not initiate in the 101 or the 102
13 blocks?

A (Witness Rau) I'm not sure, Judge Brenner, that
I couldn't. I just haven't attempted to do so because it's
not really necessary to do so, in my opinion, given the
enormous margins already demonstrated.

I think I have indicated that I do believe that it is in fact an indication that our initiation analyses, given the presence of a stud to stud crack, are in fact conservative. But in fact it is not so many cycles, and also given the possibility of the thermal stresses and the low cycle fatigue initiation, I don't choose to rely upon that evidence as definitive evidence that we will never get stud to stud cracks initiated.

0 811	4	
Q All righ	L	

1	Q All right.
2	Changing subjects slightly and this might be
3	you, Mr. Youngling, or perhaps you, Mr. Schuster, but
4	anybody can answer:
5	I can't locate the page right now, but I believe
6	in your testimony however by reference to another
7	document you talk about matters relating to future
8	surveillance or inspection of the blocks if operation is
9	permitted. That is, after an operating license.
10	Could you tell me precisely what LILCO is
11	committing to do in that regard? I believe you reference an
12	FaAA report rather than spelling it out.
13	A (Witness Youngling) Yes, Judge. The major
14	documents which will put in place the future testing on the
15	block consist of the commitments made through the DRQR
16	program and as implemented into the TDI owner's group the
17	TDI operating manual, which defines the preventive
18	maintenance program to be adopted by LILCO.
19	In addition, the Staff in their December SER on
20	the Shoreham engines has identified additional block
21	inspections that they are contemplating.
22	Now in detail, our commitment through the DRQR
23	program is to perform an eddy current inspection of the
24	block top between adjacent cylindars whenever the engine is
25	operated at 50 percent load or greater. If an indication is

inspection between two adjacent cylindar heads, although at

- this time we don't find that to be unreasonable. 1 Let me add, Judge Brenner, LILCO does have 2 confidence that the eddy current probe inspection, which is 3 to be done between two adjacent cylindar heads, will provide 4 us the same kind of information that this further NRC 5 inspection would provide. And that is our major reason in 6 not fully committing to it at this time. 7 Have you finished? 8 (Witness Youngling) Just one other point: 9 The eddy current inspection, of course, has to be 10 11 done between all cylindar heads whenever we run the engine at greater than 50 percent load, whereas the Staff 12 recommendation would just be looking at two adjacent heads. 13 Does the eddy current inspection frequency, then, 14 include at least monthly -- or let me state it differently: 15 16 Would it be performed every time the one hour run would be 17 performed? 18 (Witness Youngling) Yes, it would, Judge. Since the engine would be operated at greater than 50 percent load 19 during that one hour run, yes, the test would be performed, 20 the inspection would be performed. 21 JUDGE BRENNER: That's all the questions I have.
- 22
- What happened -- I should have stated it 23 expressly -- Judge Morris is not finished with his 24 questioning. He allowed me to ask some questions on a 25

I don't expect, in other words, to have to

JUDGE BRENNER: All right. I'm telling you what

Mr. Dynner tells me is he still intends to pursue the

written cross plan that I have; and I have my own estimate

as to how long that will take. So now we're going to

adjourn.

I did want to say one thing as a follow up to the last testimony regarding inspections:

I suppose it's understandable that LILCO may

still be thinking about certain matters. But to the extent

those matters may be pertinent to our findings on issues in

controversy, the time has come because we're going to close

the record next week.

MR. ELLIS: Yes, sir, we'll be prepared to give you a direct answer and a conclusive answer on those points next week.

20 JUDGE BRENNER: All right.

17

18

19

21

22

23

24

25

I think it might be helpful if we could get in writing -- no testimony, no explanation as to why it's a good idea or a bad idea, just in writing; I understand it's another document, but we're asking it to be pulled together -- precisely what the conditions for the inspection of the

1:30 p.m., Monday, 11 March 1985.)

above-entitled matter was recessed, to reconvene at

24

CERTIFICATE OF OFFICIAL REPORTER

This is to certify that the attached proceedings before the UNITED STATES NUCLEAR REGULATORY COMMISSION in the matter of:

NAME OF PROCEEDING: LONG ISLAND LIGHTING COMPANY

(Shoreham Nuclear Power Station)

DOCKET NO .:

50-322-OL

PLACE:

HAUPPAUGE, NEW YORK

DATE:

FRIDAY, MARCH 8, 1985

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission.

(TYPED)

WILLIAM R. BLOOM

Official Reporter

ACE-FEDERAL REPORTERS, INC. Reporter's Affiliation

(sigt William R. Gloon