

AMENDMENT 1 TO RESAR-SP/90 PDA MODULE 5, "REACTOR SYSTEM"

8412190290 841130
PDR ADOCK 05000601
K PDR

AMENDMENT 1 TO RESAR-SP/90 PDA MODULE 5, "REACTOR SYSTEM"

INSTRUCTION SHEET

Insert all pages behind QUESTIONS/ANSWERS tab.

- 490.1 The WAPWR fuel design has a new feature for those rods containing
4.2 integral fuel burnable absorber. Will the absorbing material melt during any operational transients before the fuel melting limit is exceeded?

RESPONSE:

The melting temperature of [], the absorbing material, exceeds +a,c that of UO₂, namely [] versus a maximum of 2800°C for +a,b,c UO₂. In addition the absorbing material is a [+a,c] so that its temperature will always be below the temperature of the coolest portion of the fuel. Hence, there are no transients, operational or accidental, where the temperature of the absorbing material approaches the melting point.

- 490.2 What is the limit and method used for creep collapse analysis for
4.2 WAPWR fuel rods? Since this is a new design, please provide pertinent information on the fuel densification limit and the initial fuel pressure of the fuel rods to assure no creep collapse occurs.

RESPONSE:

Even though the WAPWR is a new design, the current fuel rod analysis methodology described in WCAPs 8218, 8720 and 8377 continues to be applicable. With the exception of thicker clad, the WAPWR fuel rod is similar to that of 17x17 OFA or Vantage 5. Therefore, the densification and collapse modeling for WAPWR fuel remains the same as that given in these WCAPs. The clad flattening time for WAPWR is ≥45,000 EFPH for initial backfill pressure of [] psia or greater. +a,c

- 490.3 Provide analyses of combined seismic-and-LOCA loads on WAPWR fuel
4.2 assemblies to demonstrate the conformance to Appendix A of SRP 4.2.

RESPONSE:

The WAPWR fuel assembly seismic capability has been analyzed for proposed high seismic sites covering a wide spectrum of foundation

characteristics in Japan. This seismic analysis was based on the S2 earthquake which is equivalent to the Safe-Shutdown-Earthquake. The seismic response spectra used are conservative compared to site seismic characteristics for all U.S. nuclear plants.

The results of the seismic analysis show that the WAPWR fuel assembly structural integrity is maintained. Since the fuel assembly components are deformed elastically, a coolable geometry and control rod insertion capability are assured.

As for time fuel assembly response to LOCA loads, asymmetric blowdown loads resulting from large double-ended breaks in the main loop piping are not considered as part of the design bases for WAPWR. Analyses of the potential for pipe fracture from ductile rupture and unstable flow extension, materials tests to define tensile and toughness properties, and predictions of leak rates from postulated flaws will be prepared and subtitled as part of the RESAR-SP/90 FDA document. These analyses will be in accordance with the technical bases presented in the USNRC General Letter 84-04, "Safety Evaluation W Topical Reports Dealing with Elimination of Postulated Pipe Breaks in PWR Primary Main Loops," dated Feb. 1, 1984. As a result, the induced core plate motions will be small and the effect on the overall fuel assembly will be negligible. For a discussion of the pipe breaks considered as part of the WAPWR design bases, see Section 3.6 of RESAR-SP/90 PDA Module 7, "Structural/Equipment Design".

- 490.4 Describe plans for on-line fuel system monitoring and postirradiation
4.2 surveillance.

RESPONSE:

Methods and instrumentation for on-line fuel monitoring (e.g., coolant activity monitoring, etc.) are discussed in RESAR-SP/90 PDA Module 13, "Auxiliary Systems".

A routine fuel inspection program will be implemented on the irradiated and discharged initial WAPWR fuel during plant refueling outages. The program will involve visual examinations on a representative sample of assemblies from the first WAPWR fueled core at each refueling until this fuel is discharged. Visual observations will include, but not be limited to, crud buildup, rod bowing, grid strap conditions and inspections for potential missing components. Additional fuel inspections would be performed depending on the results of operational monitoring, including coolant activity, and the visual fuel inspections.

- 491.1 Past agreements with Westinghouse, going back as far as Robinson and
4.3 Indian Point 2 reviews, relating to X-Y plane xenon stability, have
been that specific tests would be performed to demonstrate stability
for reactor classes with significant, relevant new characteristics
such as core diameter or power density. This is the primary bases on
which assurances of stability have been accepted. Please indicate if
such tests will be carried out for WAPWR.

RESPONSE:

On the first plant built and ready for testing (i.e., prototype/
first-of-a-kind) Westinghouse will propose tests to determine the
stability of the plant with respect to axial and radial xenon
transients. These proposed tests will be documented in RESAR-SP/90
PDA Module 14, "Initial Test Program".

- 491.2 Discuss the effects of low radial leakage core-reflector design on
4.3 excore detection, particularly the SRM and axial distribution
measurements with the four segment power monitors. Also, we have not
as yet seen an uncertainty analysis topical report for the four
segment excore system. Is this report to be submitted? Will it
address low leakage configuration?

RESPONSE:

Assuming adequate signal strength, the ability to measure axial power
distribution is expected to be as good or better than the current
detector design, regardless of the type of the core-reflector design
employed. With regard to the SRM, it is concluded that the count rate
remains the same order of magnitude as that of current PWRs. Should
the count rate prove to be lower than expected, this can be remedied
by installing another available detector of higher sensitivity.

With regard to uncertainty analyses, this subject was addressed in
WCAP-10665(P)/10666(NP) sent to the NRC in September 1984. The
topical report does not address a low leakage configuration.

- 491.3 There have recently been some problems with current Westinghouse
15.4.1 reactors about Technical Specifications and the control rod withdrawal
at zero power event in modes 3, 4, or 5 because of differences between
Technical Specification allowed equipment operability and the analysis
which assumes two pumps in operation. How will this problem be
handled in WAPWR?

RESPONSE:

The current Westinghouse position on this question, explained in E. P. Rahe, Jr's letter to Mr. D. Eisenhut, "Number of Operating Reactor Coolant Pumps in Mode 3," NS-EPR-2935, July 9, 1984, applies to WAPWR. If this position is changed in the future, the revised position will also be applied to WAPWR.

492.1 You state on page 4.4-8 of WAPWR-RS "It was concluded from preliminary
4.4 evaluation of the data that the CHF characteristics of WAPWR fuel
assembly design are not significantly different from those of the
current 17x17 design, and can be described by the WRB-2 CHF
correlation."

Provide the data from your CHF tests which model the WAPWR fuel
assembly and give your analytic justification for the use of the 1.17
design criterion.

RESPONSE:

The WAPWR fuel assemblies use eight type "R" grids with mixing vanes
of the same design as the W 17x17 mixing vane. DNB testing of the
WAPWR typical and thimble cell geometries has been performed to
characterize the DNB performance of a WAPWR fuel assembly.
Evaluations of the data have been performed using the WRB-2 CHF
correlation, Reference 1, which was developed to predict the DNB
performance of W fuel designs which employ grids with the 17x17 type
of mixing vane design. The results of these evaluations indicate that
the WRB-2 correlation predicts the data well. Use of a 1.165 design
limit DNBR with the WRB-2 correlation is justified for the WAPWR fuel
assembly.

A description of the WAPWR DNB test program and the data evaluations
follows.

WAPWR DNB TEST PROGRAM

Test Geometries

The WAPWR DNB test program was conducted at the Columbia University
Heat Transfer Laboratory. Two 6x6 rod bundles were tested -- one with
all rods heated (typical cell) and one with the center four rods

replaced by an unheated thimble tube (thimble cell). Both rod bundles were full length and both used a cosine axial power distribution. Figures 1 and 2 show the typical and thimble cell bundle cross sections. The axial locations of the grids and the thermocouples used to detect DNB are shown in Figure 3, and Figure 4 shows the axial power profile.

The WAPWR DNB test bundles were tested over a wide range of fluid conditions:

Inlet pressure: 1500 - 2450 psia
Inlet mass velocity: $1.0 - 3.6 \times 10^6$ lbm/hr-ft²
Inlet temperature: 400 - 620°F

Test Procedure

The general procedures followed in conducting the WAPWR DNB test program were the same as those described in Reference 2.

DATA EVALUATIONS

The local fluid conditions for each test run were calculated using the THINC subchannel code. The measured critical heat flux for each data point was compared to the critical heat flux predicted by the WRB-2 CHF correlation. Tables 1 and 2 show the local conditions at the point of minimum DNBR for each run in the WAPWR typical and thimble cell data sets. Also shown for each run is the measured-to-predicted critical heat flux ratio at that location, as calculated by the WRB-2 correlation.

The average measured-to-predicted critical heat flux ratios for the WAPWR typical and thimble cell data sets are 0.9870 and 0.9899, respectively. It is apparent that the WRB-2 CHF correlation accurately predicts the DNB performance of the WAPWR fuel design.

CRITERION FOR DESIGN

The WAPWR DNB data sets have been incorporated into the database of the WRB-2 correlation. Table 3 shows the results of applying the WRB-2 CHF correlation to each of the data sets in the revised database.

For the design of Westinghouse reactor cores, the chosen criterion is that CHF will not occur at a 95 percent probability with a 95 percent confidence level. In order to meet this criterion, a limiting value of DNBR is determined by the method of Owen, Reference 3. Owen has prepared tables which give values of k_p such that at least a proportion P of the population is greater than $(\frac{M}{P})_{AVG}$ - $k_p s$ with confidence v where $(\frac{M}{P})_{AVG}$ and s are the sample mean and standard deviation, respectively. When this method was carried out using all 887 data points, the results indicated that a reactor core designed using the WRB-2 correlation could operate with a minimum DNBR of 1.165 and satisfy the design criterion.

REFERENCES

1. Davidson, S. L. (Ed.), "Reference Core Report -- Vantage 5 Fuel Assembly," WCAP-10444, December 1983.
2. Hill, K. W., Motley, F. E., Cadek, F. F., Wenzel, A. H., "Effect of 17x17 Fuel Assembly Geometry on DNB, WCAP-8296-P-A (Westinghouse Proprietary) and WCAP-8297-A (Non-proprietary), February 1975.
3. Owen, D. B., "Factors for One-Sided Tolerance Limits and for Variable sampling plans," SCR-607, March 1963.

TABLE 1

TEST RESULTS - 12.8 FOOT .408 INCH OD NONUNIFORM TEST SECTION TYPICAL CELL

RUN NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10E6 LBM/HR-SOFT)	LOCAL QUALITY (%)	LOCAL HEAT FLUX (X10E6 BTU/HR-SOFT)	(MEAS/ PRED)	ELEVATION FROM INLET (INCHES)	(MEAS/ PRED)	MEAS.
W2508									+ (b,c)
W2510									.9585
W2511									.8166
W2512									.8448
W2513									1.1081
W2514									1.1132
W2515									1.0386
W2516									.8985
W2517									1.0047
W2518									.8732
W2519									1.0460
W2520									1.0167
W2521									1.1384
W2522									1.1078
W2523									1.0589
W2524									.8875
W2525									1.0781
W2526									1.0752
W2527									1.0543
W2528									.8868
W2529									.8604
W2530									.8140
W2531									.8110
W2532									.8258
W2533									.8922
W2534									1.0310
W2535									1.0295
W2536									.8689
W2537									.8715
W2538									.8088
W2539									.8753

L = 12.8 FT
 DE = .4518 IN
 16 RODS 100%
 20 RODS 85%

ROD O.D. = .408 IN
 MIXING VANE GRIDS
 INNER ROD/OUTER ROD POWER = 1.1628

TABLE 1 (cont.) TEST RESULTS -12.8 FOOT .406 INCH OD NONUNIFORM TEST SECTION
TYPICAL CELL

RUN NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10 ⁶ LBM/HR-SQFT)	LOCAL QUALITY (%)	LOCAL HEAT FLUX (X10 ⁶ BTU/HR-SQFT)		ELEVATION FROM INLET (INCHES)	
					MEAS.	PRED.	PRED.	MEAS.
W2540								
W2541								
W2542								
W2543								
W2544								
W2545								
W2546								
W2547								
W2548								
W2549								
W2550								
W2551								
W2552								
W2553								
W2554								
W2555								
W2556								
W2557								
W2558								
W2559								
W2560								
W2561								
W2562								
W2563								
W2564								
W2565								
W2566								
W2567								
W2568								
W2569								

L = 12.8 FT
DE = .4518 IN
16 RODS 100%
20 RODS 86%

ROD O.D. = .406 IN
MIXING VANE GRIDS 17.5 IN SPACING
INNER ROD/OUTER ROD POWER = 1.1628

TABLE 1 (cont.) TEST RESULTS -12.8 FOOT .408 INCH OD NONUNIFORM TEST SECTION
TYPICAL CELL

RUN NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10 ⁶ LBM/HR-SQFT)	LOCAL QUALITY (%)	LOCAL HEAT FLUX (X10 ⁶ BTU/HR-SQFT)		ELEVATION FROM INLET (INCHES)	
					MEAS.	PRED.	PRED.	MEAS.
W2570	[+(b,c)		[+(b,c)
W2571					.8920			
W2572					.8845			
W2573					.9085			
W2574					.8884			
W2575					.8751			
W2576					1.0034			
W2577					.9419			
W2578					1.1063			
W2579					1.1187			
W2580					.9843			
W2581					.9089			
W2582					1.0363			
W2583					1.0829			
W2584					1.1358			
W2585					.9071			
W2586					1.0565			
W2587					.9138			
W2588					.9941			
W2589					.8323			
W2590					.9812			
W2592					.9875			
W2593					1.0092			
W2594					1.0416			
W2595					.9851			
W2597					.8445			
W2598	.9018							
W2600	1.0016							
W2601	1.0518							
W2602	1.0272							
								1.0343

L = 12.8 FT
DE = .4518 IN
16 RODS 100%
20 RODS 86%

ROD O.D. = .408 IN
MIXING VANE GRIDS 17.6 IN SPACING
INNER ROD/OUTER ROD POWER = 1.1628

TABLE 2. TEST RESULTS - 12.8 FOOT .406 INCH OD NONUNIFORM TEST SECTION COLD WALL CELL

RUN NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10 ⁶ LBM/HR-SQFT)	LOCAL QUALITY (X)	LOCAL HEAT FLUX (X10 ⁶ BTU/HR-SQFT)	(MEAS/PRED)	ELEVATION FROM INLET (INCHES)	(MEAS/PRED)
W2615								
W2616								
W2617								
W2618								
W2619								
W2620								
W2621								
W2622								
W2623								
W2624								
W2625								
W2626								
W2627								
W2628								
W2629								
W2630								
W2631								
W2632								
W2633								
W2634								
W2635								
W2636								
W2637								
W2638								
W2639								
W2640								
W2642								
W2643								
W2644								
W2646								

L = 12.8 FT
 DE = .4566 IN (LG THIN)
 .3315 IN (SM THIN)
 12 RODS 100%
 20 RODS 86%
 ROD O.D. = .406 IN
 MIXING VANE GRIDS 17.8 IN SPACING
 INNER ROD/OUTER ROD POWER = 1.1628

TABLE 2 (cont.) TEST RESULTS -12.8 FOOT .406 INCH OD NONUNIFORM TEST SECTION
COLD WALL CELL

RUN NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10 ⁶ LBM/HR-SOFT)	LOCAL QUALITY (X)	LOCAL HEAT FLUX (X10 ⁶ BTU/HR-SOFT)	(MEAS/PRED)	ELEVATION FROM INLET (INCHES)	(MEAS/PRED)	PRED. MEAS.
W2647									
W2648									
W2649									
W2650									
W2651									
W2652									
W2653									
W2654									
W2655									
W2658									
W2657									
W2658									
W2659									
W2660									
W2661									
W2662									
W2663									
W2664									
W2665									
W2666									
W2667									
W2668									
W2670									
W2671									
W2672									
W2673									
W2674									
W2675									
W2676									

L = 12.8 FT
 DE = .4568 IN (LG THIN)
 .3315 IN (SM THIN)
 12 RODS 100%
 20 RODS 86%
 MIX O.D. = .406 IN
 MIXING VANE GRIDS 17.5 IN SPACING
 INNER ROD/OUTER ROD POWER = 1.1628

TABLE 2 (cont.) TEST RESULTS -12.8 FOOT .406 INCH OD NONUNIFORM TEST SECTION
COLD WALL CELL

RUN NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10 ⁶ LBM/HR-SQFT)	LOCAL QUALITY (X)	LOCAL HEAT FLUX (X10 ⁶ BTU/HR-SQFT)	(MEAS/PRED)	ELEVATION FROM INLET (INCHES)	(MEAS/PRED)	MEAS.
W2677						1.0027			+(b,c)
W2678						.9881			
W2679						1.0094			
W2680						.9313			
W2681						1.0681			
W2682						.8753			
W2683						1.0091			
W2684						.7731			
W2685						.8166			
W2686						.9036			
W2687						1.0084			
W2688						.8869			
W2689						.8724			
W2690						.8670			
W2691						1.0124			
W2692						.8547			
W2693						.9480			
W2694						1.0365			
W2695						.9006			
W2696						.9595			
W2698						.8398			
W2699						1.0445			
W2701						.9788			
W2702						.8937			
W2703						.8881			
W2705						1.0086			
W2706						.9880			
W2707						.9904			
W2708						1.0334			
W2710						1.0134			

L = 12.8 FT
 DE = .4568 IN (LB THM)
 .3315 IN (SM THM)
 12 RODS 100%
 2C RODS 86%
 ROD O.D. = .406 IN
 MIXING VANE GRIDS 17.5 IN SPACING
 INNER ROD/OUTER ROD POWER = 1.1628

TABLE 2 (CONT.) TEST RESULTS -12.8 FOOT .406 INCH OD NONUNIFORM TEST SECTION
COLD WALL CELL


BLM NO.	INLET PRESSURE (PSIA)	INLET TEMP (F)	INLET MASS VELOCITY (X10 ⁶ LBM/HR-SQFT)	LOCAL QUALITY (%)	LOCAL HEAT FLUX (X10 ⁶ BTU/HR-SQFT)	MEAS. PRED.	ELEVATION FROM INLET (INCHES)	MEAS. PRED.
W2711						1.0317		
W2713						1.0481		
W2714						.8571		
W2715						.8938		
W2716						.8608		

L = 12.8 FT
 DE = .4568 IN (LG THM)
 MIXING VANE GRIDS 17.8 IN SPACING
 12 RODS 100%
 20 RODS 85%
 INNER ROD/OUTER ROD POWER = 1.1628


TABLE 3

WRB-2 CHF CORRELATION - STATISTICAL RESULTS

<u>Rod O.D.</u> (inch)	<u>L_h</u> (ft.)	<u>g_{sp}</u> (inch)	<u>Heat Flux</u> <u>Profile</u>	<u>Configuration</u>	<u>N</u>	<u>(M/P)</u>	<u>Sample</u> <u>Standard</u> <u>Deviation, S</u>
0.360	14	10	Cosine	TYP-5x5	51	0.9861	0.0758
0.360	14	10	Cosine	TYP-5x5	31	1.0097	0.0680
0.406	12.8	17.5	Cosine	TYP-6x6	98	0.9870	0.0704
0.406	12.8	17.5	Cosine	THM-6x6	95	0.9899	0.0723
0.360	14	20	Cosine	TYP-5x5	63	0.9961	0.0946
0.360	14	20	Cosine	THM-5x5	38	0.9832	0.0599
0.374	8	22	Uniform	TYP-5x5	67	1.0316	0.0897
0.374	14	22	Uniform	TYP-5x5	71	1.0095	0.0664
0.374	14	22	Cosine	TYP-5x5	74	0.9893	0.0822
0.374	14	22	Cosine	THM-5x5	70	0.9884	0.0775
0.374	8	26	Uniform	TYP-5x5	78	1.0198	0.0810
0.374	8	26	Uniform	THM-5x5	68	1.0398	0.1062
0.374	14	26	Uniform	TYP-5x5	73	0.9914	0.0823
				All Data	877	1.0014	0.0825




Dimensions in Inches




Rod Relative Power

FIGURE 1: WAPWR TYPICAL CELL BUNDLE CROSS SECTION



Timble Tube O.D.: 1.024 Inches



Rod Relative Power

FIGURE 2: WAPWR THIMBLE CELL BUNDLE CROSS SECTION





FIGURE 3: AXIAL LOCATION OF GRIDS AND THERMOCOUPLES
IN WAPWR DNB TEST BUNDLES

Q''_{LOC}/Q''_{AVG} LOCAL-TO-AVERAGE HEAT FLUX RATIO



+b,c

Z, Axial Distance From Beginning of Heated Length (Inches)

FIGURE 4 APWR DNB HEATER ROD AXIAL HEAT FLUX DISTRIBUTION

- 492.2 Provide the documentation required by NUREG-0737 Item II.F.2. The
4.4 response should be given item-by-item showing how your design complies
with each requirement. Clearly state where your design deviates from
the requirements and why such deviation is acceptable.

RESPONSE:

Inadequate core cooling instrumentation is considered to be part of
the reactor coolant system. Therefore, see RESAR-SP/90 PDA Module 4,
"Reactor Coolant System"; Subsection 4.4.6.5 for a description of this
instrumentation.