

## **Clarification Request for Additional Information**

**Docket No. 72-1040**

**Certificate of Compliance No. 1040**

**Amendment No. 4 to the HI-STORM UMAX Canister Storage System**

### **Chapter 6 – Shielding Evaluation**

6-1

#### **NRC Clarification:**

Holtec provided a supplemental response to RAI 6-1 on 12/20/2019 (ML20002A425) stating that it modified the dose rate in Section 5.3.4 of the CoC to be approximately 1.5 times the dose rate reported in the FSAR for both the standard and Version B lids. The staff summarized discussion from the previous clarification call held on 12/6/2019 (ML19345E201) and re-emphasized that a basis/justification for the Technical Specifications (TS) dose rate limits should be provided in the FSAR analysis for UMAX Amendment 4. Staff understands the justification and calculated dose rates in the FSAR (i.e., 66 mrem/hr for the standard lid and 22 mrem/hr for the Version B lid), but was not understanding the connection to the higher dose rate limits (i.e., 90 mrem/hr for the standard lid and 30 mrem/hr for the Version B lid) that Holtec had proposed for the TS. Holtec is planning to provide an additional supplemental response to RAI 6-1 to revise the proposed TS dose rate limits to match the dose rates calculated in the FSAR.

#### **Holtec Response:**

The dose limits in 5.3.4.a of the CoC Appendix A are revised to be 66 mrem/hr for the standard lid and 22 mrem/hr for the Version B lid. These are the same calculated dose rate values reported in the SAR Table 5.4.7 and supporting calculation packages.