



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 14, 1985

Docket No. 50-213
LS05-85-03-012

Mr. W. G. Council, Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Post Office Box 270
Hartford, Connecticut 06141

Dear Mr. Council:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION CONCERNING RESPONSES TO
GENERIC IMPLICATIONS OF SALEM ATWS EVENTS (GENERIC LETTER 83-28)

Re: Haddam Neck Plant

References: (1) W. G. Council letter to D. G. Eisenhower dated November 8, 1983
(2) W. G. Council letter to D. G. Eisenhower dated March 16, 1984

By references 1 and 2 above, Connecticut Yankee Atomic Power Company (CYAPCO) provided information in response to Generic Letter 83-28. The staff has completed a preliminary review to assess the completeness and adequacy of licensee responses to Generic Letter 83-28 Items 2.1, 2.2, 3.1.3, 3.2.3, 4.4 and 4.5. For the Haddam Neck Plant, your responses were found to be incomplete for Items 2.1, 2.2.2, 4.5.2 and 4.5.3. Brief descriptions of the deficiencies are given as guidelines for corrective action in the enclosed request for additional information. Efforts by Owners Groups, INPO and NSSS Vendors have been or are being made to produce generic responses that may be useful in meeting the requirements of Generic Letter 83-28 Items 2.1, 2.2.2 and 4.5.3. You may wish to contact your Owners Group or INPO regarding the applicability of such generic responses to Haddam Neck.

In order to preserve our present review schedule, the staff needs to have the supplementary information within 60 days for Items 2.1, 2.2.2, 4.5.2, and within 90 days for Item 4.5.3. Should you not be able to conform with this request, your licensing department should contact your Project Manager, Mr. F. Akstulewicz (301) 492-7215.

8503150463 850314
PDR ADOCK 05000213
P PDR

Mr. W. G. Council, Vice President - 2 -

March 14, 1985

This request for information was approved by the Office of Management and Budget under clearance number 3150-0011 which expires April 30, 1985. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management Room 3208, New Executive Office Building, Washington, D.C. 20503.

Sincerely,

Original signed by

John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#5 Reading
HThompson
CJamerson
FAkstulewicz
JZwolinski
OELD
LHarmon
EJordan
BGrimes
JPartlow
ACRS (10)
JHannon
DLasher
DBeckham
RAuluck
JStevens

DL:ORB#5
CJamerson:jb
3/12/85

DL:ORB#5
FAkstulewicz
3/13/85

X
DL:ORB#5
JZwolinski
3/14/85

SE01
DSW USE02

Mr. W. G. Council

- 3 -

March 14, 1985

cc

Gerald Garfield, Esquire
Day, Berry & Howard
Counselors at Law
City Place
Hartford, Connecticut 05103-3499

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental
Protection
State Office Building
Hartford, Connecticut 06106

Superintendent
Haddam Neck Plant
RDF #1
Post Office Box 127E
East Hampton, Connecticut 06424

John F. Opeka
Vice President, Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

State of Connecticut
Office of Policy and Management
ATTN: Under Secretary Energy
Division
80 Washington Street
Hartford, Connecticut 06106

U.S. Environmental Protection Agency
Region I Office
ATTN: Regional Radiation Representative
JFK Federal Building
Boston, Massachusetts 02203

Resident Inspector
Haddam Neck Nuclear Power Station
c/o U.S. NRC
East Haddam Post Office
East Haddam, Connecticut 06423

Dr. Thomas E. Murley, Regional Administrator
Nuclear Regulatory Commission, Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

REQUEST FOR ADDITIONAL INFORMATION FOR
HADDAM NECK RESPONSE TO GENERIC LETTER 83-28
DOCKET NO. 50-213

1. Item 2.1 (part 2) - Incomplete

Submit additional information describing the Haddam Neck vendor interface program for reactor trip system components. Information supplied should state how the program assures that vendor technical information is kept complete, current and controlled throughout the life of the plant and should also indicate how the program will be implemented at Haddam Neck.

2. Item 2.2.2 - Incomplete

Provide your evaluation of the NUTAC program and describe how it will be implemented at Haddam Neck. The staff found the NUTAC program fails to address the concern about establishing and maintaining an interface between all vendors of safety-related equipment and the utility. Accordingly Haddam Neck will need to supplement its response to address this concern. This additional information should describe how current procedures will be modified and new ones initiated to meet each element of item 2.2.2 concern.

3. Item 4.5.2 - Incomplete

Provide additional information on the operating history of the reactor trip breaker as requested by the staff on June 8, 1984.

4. Item 4.5.3 - Incomplete

Provide results of your review of existing or proposed intervals for on-line testing considering the concerns of 4.5.3.1 to 4.5.3.5 in the generic letter. Proposed Technical Specification changes resulting from this review shall be submitted for review.