

DMB-016

FEB 28 1985

Docket No. 50-313

Mr. John Griffin  
Senior Vice President  
of Energy Supply  
Arkansas Power and Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Dear Mr. Griffin:

We have reviewed your letter of December 14, 1984, concerning the Once Through Steam Generator Sleeved Tube Inspection for Arkansas Nuclear One, Unit 1. We have determined that we need additional information which is identified in the enclosure. We request your response within 30 days from receipt of this letter.

Sincerely,  
"John F. Stolz"  
John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

Enclosure:  
As Stated

cc: w/enclosure:  
See next page

DISTRIBUTION

- ~~Docket File~~
- NRC PDR
- L PDR
- ORR#4 Rdg
- HThompson
- OELD
- EJordan
- BGrimes
- JPartlow
- ACRS-10
- Gray File

- PIngram
- GVissing
- EBlackwood
- HOornstein
- BLiaw

ORR#4:DL  
GVissing;cr  
2/27/85

ORR#4:DL  
JStolz  
2/18/85

8503150513 850228  
PDR ADOCK 05000313  
PDR

Arkansas Power & Light Company

50-313, Arkansas Nuclear One, Unit 1

cc w/enclosure(s):

Mr. J. Ted Enos  
Manager, Licensing  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Mr. Frank Wilson  
Director, Division of Environmental  
Health Protection  
Department of Health  
Arkansas Department of Health  
4815 West Markham Street  
Little Rock, Arkansas 72201

Mr. James M. Levine  
General Manager  
Arkansas Nuclear One  
P. O. Box 608  
Russellville, Arkansas 72801

Mr. W. D. Johnson  
U.S. Nuclear Regulatory Commission  
P. O. Box 2090  
Russellville, Arkansas 72801

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220, 7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. Nicholas S. Reynolds  
Bishop, Liberman, Cook, Purcell & Reynolds  
1200 17th Street, NW  
Washington, DC 20036

Honorable Ermil Grant  
Acting County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801

Regional Radiation Representative  
EPA Region VI  
1201 Elm Street  
Dallas, Texas 75270

Mr. Robert Martin, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

REQUEST FOR ADDITIONAL INFORMATION CONCERNING  
OTSG SLEEVED TUBE INSPECTION FOR  
ARKANSAS NUCLEAR ONE, UNIT 1  
DOCKET NO. 50-313

1. Describe the research and development programs that AP&L will use to ensure that state of the art technology will be utilized in the inspection program for the sleeved tubes.
2. Discuss the anticipated problem areas in the inspection of the sleeves and describe work which will be done to mitigate these problem areas.
3. Provide the reference for the data cited in the attachment to your December 14, 1984, letter concerning the Babcock and Wilcox demonstration of the capabilities of the MIZ 18 system.