

March 7, 1985

Mr. James G. Keppler, Regional Administrator Office of Inspection and Enforcement Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137



Dear Mr. Keppler,

In accordance with Zion Station Technical Specification 4.3.1.B.5.A, the number of tubes plugged in each steam generator as a result of the most recent inspection is as follows:

Steam Generator		No. of Tubes Plugged
(A)	1RC100	10
(B)	1RC400	47
(C)	1RC200	10
(D)	1RC300	6

If there are any additional questions, please contact Mr. R.L. Sumners of my Technical Staff at Zion Station.

Sincerely,

K.L. Graesser Superintendent Zion Station

. h. Leraesser

KLG/jlm

cc: R. Fuerst

G. Pliml

K. Kofron

A. Miosi

W. Stone

R. Cascarano

Master File

8503210442 850307 PDR ADOCK 05000275 PDR