

E4C-082 Rev 1, CCN N-3 System Dynamic Voltages During DBAs

9606040034 960529  
PDR ADOCK 05000361  
P PDR

Southern California Edison Company  INTERIM CALCULATION CHANGE NOTICE (ICCN)/ CALCULATION CHANGE NOTICE (CCN)	CALC. NO. <b>E4C-082</b>	ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>1</b>	TOTAL NO. OF PAGES <b>453</b>
	BASE CALC. REV. <b>1</b>	UNIT <b>2 &amp; 3</b>	CCN CONVERSION : CCN NO. <b>CCN- 9</b>	CALC. REV. <b>1</b>
	CALCULATION SUBJECT : <p style="text-align: center;"><b>SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT</b></p>			
CALCULATION CROSS-INDEX <input checked="" type="checkbox"/> New/Updated index included <input type="checkbox"/> Existing index is complete	ENGINEERING SYSTEM NUMBER <b>1804</b>	PRIMARY STATION SYSTEM DESIGNATOR <b>PBA,PBB,PEA,PEB</b>	Q-CLASS <b>II</b>	
	CONTROLLED PROGRAM OR DATABASE IN ACCORDANCE WITH NES&L 41-5-1 <input checked="" type="checkbox"/> PROGRAM <input type="checkbox"/> DATA BASE	PROGRAM / DATABASE NAME (S) <input type="checkbox"/> ALSO, LISTED BELOW <p style="text-align: center;"><b>PSS/E</b></p>	VERSION/RELEASE NO.(S) <p style="text-align: right;"><b>19.0</b></p>	
<b>1. BRIEF DESCRIPTION OF ICCN / CCN:</b>				

THIS CCN (N-3) IS INTENDED TO VERIFY THE CAPABILITY OF ELECTRICAL AUXILIARY SYSTEM WHEN ESF LOADS ARE STARTED OUT OF SEQUENCE DUE TO A POSSIBLE OVERLAPPING OPERATION OF THEIR AGASTAT RELAY TIMER. THE ANALYSES INCLUDED IN THIS CCN (N-3) ARE IN ADDITION TO THE EXISTING ANALYSES IN THE BASE CALCULATION (E4C-082, REVISION 1). SEE NEXT SHEETS.

INITIATING DOCUMENT (DCP / MMP, FCN, OTHER) \_\_\_\_\_

*NCR*  
*10/6/94*  
~~PROJECT~~ NO. 93070031

REV. \_\_\_\_\_

**2. OTHER AFFECTED DOCUMENTS (CHECK AS APPLICABLE FOR CCN ONLY):**

YES

NO

OTHER AFFECTED DOCUMENTS EXIST AND ARE IDENTIFIED ON ATTACHED FORM 26-503.

**3. APPROVAL :**

DISCIPLINE / ESC : NEDO-ELECTRICAL

L. R. MURIEL / LRM 5/215  
ORIGINATOR (Print name/initial) PAX

*achadings*  
GS (Signature)

Other (Signature) \_\_\_\_\_

A. M. PATEL / AMP 51864  
IRE (Print name/initial) PAX

*KZ Johnson*  
NES&L DM (Signature)

10/24/94  
DATE

.. ASSIGNED SUPPLEMENT ALPHA DESIGNATOR : \_\_\_\_\_

CONVERSION TO CCN DATE 10/27/94

*Suzza Castillo*  
SCE CDM - SONGS

# CALCULATION CROSS-INDEX

ICCN NO./ PRELIM. CCN NO.      N-3	PAGE <u>2</u> OF <u>453</u>
---------------------------------------	-----------------------------

Calculation No. E4C-082 REV. 1

Sheet No. \_\_\_\_\_ CCN CONVERSION:  
CCN NO. CCN- 9

Calc. rev. number and responsible supervisor initials and date	INPUTS These interfacing calculations and / or document provide input to the subject calculation and if revised may require revision of the subject calculation.		OUTPUTS Results and conclusions of the subject calculation are used in these interfacing calculations and / or documents.		Does the output interface calc/ document require revision?	Identify output interface calc / document CCN, DCN, TCN / Rev. FIDCN, or tracking number
	Calc / Document No.	Rev. No.	Calc / Document No.	Rev. No.	YES / NO	
E4C-082 REV 1  <i>acm</i> 10/6/94	SO23-302-15-10 SO23-302-15-11 SO23-302-15-12 SO23-302-15-13 SO23-302-15-14	1 1 1 1 1	E4C-098 E4C-099	0 0	NO NO	
	DCP 2&3 6754.00SP DCP 2&3 6742.07SM  E4C-088 CCN 1 E4C-087 CCN 1	0 0  0 0				
	LOG ITEM BC-83-159 LOG ITEM BC-83-205		NOTE: The input documents shown in this form are additional items to the existing Calculation Cross Index.			

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. <i>N-3</i>	PAGE <i>3</i> OF <i>453</i>
---	-----------------------------

CCN CONVERSION CCN NO. CCN - <i>9</i>
--

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURTE <i>LRM</i>	<i>9-30-94</i>	A. M. PATEL <i>AMP</i>	<i>10-5-94</i>					

## TABLE OF CONTENTS

1.0 PURPOSE AND ACCEPTANCE CRITERIA:	SHEET NO.
1.1 PURPOSE.....	4
1.2 ACCEPTANCE CRITERIA.....	7
2.0 RESULTS, CONCLUSIONS AND RECOMMENDATION:	
2.1 RESULTS.....	8
2.2 CONCLUSIONS.....	132
2.3 RECOMMENDATION.....	137
3.0 ASSUMPTIONS.....	139
4.0 DESIGN INPUT.....	145
5.0 METHODOLOGY.....	146
TABLE 5.1 - ACCIDENT LOADING WITH SEQUENCE OVERLAPS.....	151
TABLE 5.2 - MOTOR OPERATED VALVES (MOV) DATA.....	170
TABLE 5.3 - MOTOR CONTROL CENTER LOAD SCHEDULE.....	183
TABLE 5.4 - EQUIVALENT MCC STARTING MOTOR INERTIA.....	214
6.0 REFERENCES.....	233
7.0 NOMENCLATURE.....	234
8.0 COMPUTATIONS.....	235
9.0 APPENDICES & ATTACHMENTS:	
9.1 APPENDICES.....	255
9.2 ATTACHMENTS.....	448
LAST PAGE.....	453

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>4</b> OF <b>453</b>
---	-----------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

## 1.0 PURPOSE AND ACCEPTANCE CRITERIA:

### 1.1 PURPOSE:

This CCN verifies the capability of electrical auxiliary system when ESF loads are started out of sequence due to a possible overlapping operation of their Agastat relay timer.

A. Data contained in the CCNs identified below are considered in the analyses for this electrical auxiliary system capability verification.

1. CCN 3. This CCN revises the 1500 KVA loadcenter transformer data to reflect the impedance of the replacement (spare) loadcenter transformer with the highest (worst case) impedance value.

The transformer data indicated in CCN 3 was based on the transformer specification provided by SCE to the vendor. This CCN (N-3) considers the transformer data which are based from the more accurate vendor test reports (References 6.2 through 6.6). The new parameters for the 1500 KVA loadcenter transformers are as follows:

Impedance = 10.18%  
X-R Ratio = 7.0  
Nominal Tap Voltage = 4155 Volts

2. CCN 5 (Unit 2) and CCN 6 (Unit 3). These CCNs revise the loading in the emergency diesel generator MCCs to reflect the new 2-HP motor for the Lube Oil Circulating Pumps/Auxiliary Turbocharger Pump. These changes support the plant modifications described in Design Change Package 2&3 6754.00SP (Reference 6.10).
3. CCN 7 (Unit 2) and CCN 8 (Unit 3). These CCNs reflect the addition of Component Cooling Water (CCW) Seismic Makeup Pumps P-1018 and P-1019. These changes support the plant modifications described in Design Change Package 2&3 6742.07SM (Reference 6.11).

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>5</b> OF <b>453</b>
---	-----------------------------

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

4. CCN 2 (Unit 2) and CCN 4 (Unit 3). These CCNs indicate that equipment hatch electric hoists 2Z028, 2Z029, 3Z028 and 3Z029 can be fed from their respective 480-V ESF Buses 2B04, 2B06, 3B04 and 3B06 via pressurizer heater panels 2BHP04, 2BHP08, 3BHP04 and 3BHP08. However, these loads have no bearing in these analyses because they are not operated during Mode 1 or during a design basis accident considered in these analyses.

B. In addition, this CCN includes the following changes and updates to the base calculation:

1. The new load inertia for the Control Room Emergency Air Conditioning Units E-418 and E-419 per Log Item BC-93-159 (Reference 6.8) to reflect the new (lower) values provided by the vendor (Reference 6.7, Attachment 9.2.1).
2. The new motor base (MBASE) for the Auxiliary Feedwater Pumps 2P141, 2P504, 3P141 and 3P504 is 0.6832 MVA per Calculations E4C-086, Rev. 0, CCN 1 and E4C-087, Rev. 0, CCN 1.
3. The single train operation of Component Cooling Water Pumps and Saltwater Cooling Pumps per Log Item BC-93-205 (Reference 6.9)
4. The change in the operating modes considered for the Dome Air Circulator Fans to cover the possibility of single train operation of these fans.
5. For systems containing a swing or redundant components, the load with the highest impedance feeder cable is selected as the starting load to obtain the most limiting voltage profile:

1. Component Cooling Water Pump 2P025 at 4-kV Bus 2A04
2. Component Cooling Water Pump 2P025 at 4-kV Bus 2A06
3. Component Cooling Water Pump 3P024 at 4-kV Bus 3A04
4. Component Cooling Water Pump 3P025 at 4-kV Bus 3A06
5. Saltwater Cooling Pump 2P307 at 4-kV Bus 2A04
6. Saltwater Cooling Pump 2P114 at 4-kV Bus 2A06
7. Saltwater Cooling Pump 3P307 at 4-kV Bus 3A04
8. Saltwater Cooling Pump 3P114 at 4-kV Bus 3A06

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 6 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-20-94	A. M. PATEL	10-5-94					

6. In cases where the 4-kV ESF buses are deenergized and transferred to the corresponding ESF buses of the companion unit, motor loads that are initially running during the normal plant operation are stopped and restarted when the tie breaker closes during bus transfer. In the base calculation, these loads continue to run rather than being stopped and restarted when the bus transfer occurs.

Completion and issuance of this CCN closes NEDOTRAK Item 93070031, Sub. 01, (Reference 6.1).

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	N-3	PAGE 7 OF 453
PRELIM. CCN NO.		CCN CONVERSION
		CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**1.2 ACCEPTANCE CRITERIA:**

- A. All ESF motor loads that are required to mitigate the consequences of a design basis accident should accelerate to their rated operating speeds under credible worst case loading conditions, and with these motor loads started out of sequence due to a possible overlapping operation of their Agastat relay timer.

The motor terminal voltage during the starting and accelerating period should be adequate such that the corresponding motor torque is constantly more than the load requires, allowing the motor to accelerate to its rated speed. Note that the torque developed by the motor at any speed is directly proportional to the square of the voltage and inversely proportional to the square of the frequency.

- B. At no time during the automatic sequencing period should the generator loading exceed the generator's 4700 KW rating or 5170 KW short time rating (each diesel generator unit in SONGS 2&3 can be loaded up to 5170 KW for 2 hours within a 24-hour period).

- C. The following acceptance criteria for the emergency diesel generators, based on Section C.1.4 of Regulatory Guide 1.9 (Reference 6.12) apply:

1. Each emergency diesel generator should be capable of starting and accelerating to rated speed all the required ESF loads in the required sequence.
2. At no time during the loading sequence should the frequency of the generator decrease to less than 95% of nominal (60 Hertz) nor the voltage decrease to less than 75% of nominal (4.36 KV).
3. The generator frequency should be restored to within 2% of nominal (60 Hertz) in less than 60% of each load-sequence interval for step load increase.
4. The generator voltage should be restored to within 10% of nominal (4.36 KV) within 60% of each load-sequence time interval.

- D. The acceleration times determined in these analyses should remain bounded by the existing motor protective device settings per Class 1E 4KV Protection Calculation E4C-098 (Reference 6.16) and Class 1E 480V Protection Calculation E4C-099 (Reference 6.17).



**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>8</b> OF <b>453</b>
---	-----------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-99					

**2.0 RESULTS, CONCLUSIONS AND RECOMMENDATION:**

**2.1 RESULTS:**

The results of the dynamic simulations are presented in the form of voltage profiles for the ESF buses and MCCs; voltage and speed/acceleration profiles for ESF motors; and voltage, frequency and power profiles for the emergency diesel generators. The dynamic profiles established by this CCN represent the bounding values for the ESF motors, buses and emergency diesel generators during a postulated design basis accident coincident with the worst case system voltages in the ESF buses.

Voltage is specified in per unit at 4.16 KV, 4.36 KV or 480 V base. The time scale is specified in seconds. Motor speed is specified in per unit slip. The generator power is specified in megawatts (MW) and frequency in per unit at 60-cycle.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO. /  
PRELIM. CCN NO. N-3 PAGE 9 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIE	9-30-94	A. M. PATEL	10-5-94					

**INTERPRETATION OF THE DYNAMIC VOLTAGE PROFILES**

Refer to the voltage profiles on the following pages. A time scale from t=0 to t=40 seconds is provided in the voltage profiles for the 4-KV buses, 480-V Buses and 480-V MCCs. Automatic sequencing of ESF loads occurs from time t=0 second.

The definition of time t=0 varies depending on the bus alignment considered in each case. In CASEs IIIAX and IIIAY t=0 is the time at which the emergency diesel generator output breakers close. This occurs after a delay from the initiation of the safety signal during which the emergency diesel generators start and come up to their rated speeds and voltages (normally within 10 seconds). In CASEs IVBX and IVBY, t=0 is the time when the tie breakers close.

At time t=0, the profiles show the voltage dip that occurs when the first load group starts. Other ESF loads are started out of sequence thereafter at t=2.5, t=7.5, t=12.5, t=17.5, t=27.5 and t=32.5 seconds.

The voltage profiles for emergency diesel generator CASEs IIIAX and IIIAY indicate a sharp increase in voltage (spike) when motors from the last sequenced load group approach their rated speeds. This condition is due to the fact that the generator must constantly adjust its power output to match the power demand of the motors while they start and accelerate to their rated speeds. As these motors attain their rated speeds, the power demand quickly diminishes, causing the generator to readjust to this change. However, the drop in motor power demand occurs quicker than the generator is able to compensate, resulting in a momentary surge in generator voltage. This generator response characteristic is normal and is expected during the starting and sequencing of motors supplied from their associated diesel generator.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>10</b> OF <b>453</b>
---	------------------------------

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL <i>LRM</i>	<i>9-30-94</i>	A. M. PATEL <i>AMP</i>	<i>10-5-94</i>					


**CASE IIIAX DYNAMIC PROFILES**



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RX\CHARNOUT\_111RX

CCN9


Sheet No. 11  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPW 9-30-94 IRE: RL 10-5-94



FRI, SEP 16 1994 14:02  
 2G002 (14.36-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RX\CHARNOUT\_111RX




FRI, SEP 16 1994 14:03  
 2G003 (14.36-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111A\XCHRMOUT\_111A

CCN 9


Sheet No. 12  
 Calc No: EAC-082 CCN N-5 Rev. 1  
 RE: CPM 9-30-94 IRE: RL 10-5-94



FRI, SEP 16 1994 14:03  
 2G002 POWER (MW)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111A\XCHRMOUT\_111A




FRI, SEP 16 1994 14:03  
 2G003 POWER (MW)



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119X\2CHANDOUT\_1119X

CCN9


Sheet No. 13  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CCN 9-30-94 IRE: RI 10-5-94



FRI, SEP 16 1994 14:03  
 2G002 FREQ DEVIATION




SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119X\2CHANDOUT\_1119X



FRI, SEP 16 1994 14:03  
 2G003 FREQ DEVIATION




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1118\XCH\ANOUT\_1118X



FRI, SEP 16 1994 14:03  
 BUS 2A04 (4.16-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1118\XCH\ANOUT\_1118X




FRI, SEP 16 1994 14:04  
 BUS 2A06 (4.16-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\1119X\CHANDOUT\_1119X

CCN 9


Sheet No. 15  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 14:04  
 BUS 2804 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\1119X\CHANDOUT\_1119X



FRI, SEP 16 1994 14:04  
 BUS 2806 (480-V BASE)






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111A\XCHAROUT\_111A.X

CCN 9


Sheet No. 16  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: Ad 10-5-94



FRI, SEP 16 1994 14:04  
 MCC 2BRA (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111A\XCHAROUT\_111A.X




FRI, SEP 16 1994 14:04  
 MCC 2BRB (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\X3\CHRNOUT\_111\X

CCN 9


Sheet No. 17  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: 1pm 9-20-94 IRE: 10-5-94



FRI, SEP 16 1994 14:04  
 MCC 2BD (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\X3\CHRNOUT\_111\X



FRI, SEP 16 1994 14:04  
 MCC 2BH (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1118X\CHRNOUT\_1118X



FRI, SEP 16 1994 14:04  
 MCC 2BE (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1118X\CHRNOUT\_1118X




FRI, SEP 16 1994 14:04  
 MCC 2BJ (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHANOOUT\_1119X

CCN9


Sheet No. 19  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:04  
 MCC 2BY (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHANOOUT\_1119X



FRI, SEP 16 1994 14:04  
 MCC 2BZ (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_1119\XCHRNOUT\_1119X



FRI, SEP 16 1994 14:04  
 MCC 80-U2 (1480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_1119\XCHRNOUT\_1119X




FRI, SEP 16 1994 14:04  
 MCC 85-U2 (1480-V BASE)



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119X\CHRMOUT\_1119X

CCN 9


Sheet No. 21  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:04  
 2P017



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119X\CHRMOUT\_1119X




FRI, SEP 16 1994 14:05  
 2P019



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_1119X\CHANDOUT\_1119X

CCN 9


Sheet No. 22  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: Ad 10-5-94



FRI, SEP 16 1994 14:05  
 2P191-A




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_1119X\CHANDOUT\_1119X



FRI, SEP 16 1994 14:05  
 2P191-B



SRM ONEPFE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTRACES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PFI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\XCHRNOUT\_1111X




FRI, SEP 16 1994 14:05

2P190



SRM ONEPFE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTRACES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PFI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\XCHRNOUT\_1111X




FRI, SEP 16 1994 14:05

2P192






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\XCHANDOUT\_1111.X




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\XCHANDOUT\_1111.X





SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\XCHAMOUT\_1111X




FRI, SEP 16 1994 14:05

25401



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\XCHAMOUT\_1111X




FRI, SEP 16 1994 14:05

25402




SAN ONOFPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHRNOUT\_1119X



FRI, SEP 16 1994 14:05  
 2P009



SAN ONOFPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHRNOUT\_1119X




FRI, SEP 16 1994 14:05  
 2P010



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_111A\XCHRNOUT\_111A.X

CCN 9


Sheet No. 27  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 9-30-94 IRE: pl 10-5-94



FRI, SEP 16 1994 14:05  
 P162-U2



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_111A\XCHRNOUT\_111A.X




FRI, SEP 16 1994 14:06  
 P160-U2



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1118\3CHANDOUT\_1118X

CCN 9


Sheet No. 28  
 Case No: E4C-082 CCN N-3 Rev. 1  
 RE: LPN 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 14:06  
 2P015



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1118\3CHANDOUT\_1118X




FRI, SEP 16 1994 14:06  
 2P016



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHRNOUT\_1119X

CCN 9

Sheet No. 29  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: dl 10-5-94




FRI, SEP 16 1994 14:06

2A071



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHRNOUT\_1119X



FRI, SEP 16 1994 14:06


2A072




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHARNOUT\_1119X

CCN 9

Sheet No. 30  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CRM 9-30-94 IRE: AL 10-5-94




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\XCHARNOUT\_1119X






SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PIT INTERACTIVE PLOTTING PROGRAM - PSSPLT  
FILE: C:\CASE\_1119\XCHANNOUT\_1119X



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PIT INTERACTIVE PLOTTING PROGRAM - PSSPLT  
FILE: C:\CASE\_1119\XCHANNOUT\_1119X








SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTT INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_111\X3\CHANNOUT\_1111\X

CCN 9

Sheet No. 32  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: AL 10-5-94




FRI, SEP 16 1994 14:07  
 2P012



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTT INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_111\X3\CHANNOUT\_1111\X

CCN 9

Sheet No. 32  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: AL 10-5-94




FRI, SEP 16 1994 14:07  
 2P013



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1119\XCHAMOUT\_1119X

CCN 9


Sheet No. 33  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 9-20-94 IRE: R1 10-5-94



FRI, SEP 16 1994 14:07  
 2P025-A




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1119\XCHAMOUT\_1119X



FRI, SEP 16 1994 14:08  
 2P025-B




SAB QUOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111R\CHANNOUT\_111R



FRI, SEP 16 1994 14:08  
 2A274




SAB QUOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111R\CHANNOUT\_111R




FRI, SEP 16 1994 14:08  
 2A276



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\AXJCMANOUT\_111\AX



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\AXJCMANOUT\_111\AX






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CRSE\_1119X\CHANNOUT\_1119X

CCN 9


Sheet No. 36  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: al 10-5-94



FRI, SEP 16 1994 14:08  
 2E550



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CRSE\_1119X\CHANNOUT\_1119X




FRI, SEP 16 1994 14:08  
 2E547



SAR DOWDRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\111RX\CHANDOUT\_111RX

CCN 9


Sheet No. 37  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: R 10-5-94



FRI, SEP 16 1994 14:08  
 25546



SAR DOWDRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\111RX\CHANDOUT\_111RX




FRI, SEP 16 1994 14:08  
 25549



SMOYRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119X\CHRMOUT\_1119X

CCN 9


Sheet No. 38  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: DL 10-5-94



FRI, SEP 16 1994 14:08  
 2P307



SMOYRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119X\CHRMOUT\_1119X



FRI, SEP 16 1994 14:09  
 2P114




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1119X\CHARTOUT\_1119X

CCN 9

Sheet No. 39

Case No: E4C-082 CCN N-3 Rev. 1

RE: Cpm 9-30-94 IRE: bl 10-5-94




FRI, SEP 16 1994 14:09

2P141



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1119X\CHARTOUT\_1119X




FRI, SEP 16 1994 14:09

2P504





SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\111RX\CHANDOUT\_111RX




FRI, SEP 16 1994 14:09

E336-U2



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\111RX\CHANDOUT\_111RX



FRI, SEP 16 1994 14:09


E335-U2



SMN OMOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_111\X3\CHRNOUT\_111\X

LEN 9


Sheet No. 41  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: DL 10-5-94



FRI, SEP 16 1994 14:09  
 2P018-B



SMN OMOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_111\X3\CHRNOUT\_111\X



FRI, SEP 16 1994 14:10  
 2P018-B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <i>N-3</i>	PAGE <i>42</i> OF <i>453</i>
CCN CONVERSION CCN NO. CCN - <i>9</i>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURTE <i>LRM</i>	<i>9-30-94</i>	A. M. PATEL <i>AM</i>	<i>10-5-94</i>					


**CASE IIIAY DYNAMIC PROFILES**



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111AY\CHARNOUT\_111AY

CCN 9


Sheet No. 43  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: RL 10-5-94



FRI, SEP 16 1994 14:27  
 20002 (4.36-KV BASE)



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111AY\CHARNOUT\_111AY




FRI, SEP 16 1994 14:28  
 20003 (4.36-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11187\CHNR001\_11187

CCN 9


Sheet No. 44  
 Calc No: 54C-082 CCN N-3 Rev. 1  
 RE: Crem 9-30-94 IRE: dl 10-5-94



FRI, SEP 16 1994 14:28  
 2G002 POWER (MW)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11187\CHNR001\_11187




FRI, SEP 16 1994 14:28  
 2G003 POWER (MW)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\RYJCHRNOUT\_1111.RY

CCN 9


Sheet No. 45  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:28  
 2G002 FREQ DEVIATION




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\RYJCHRNOUT\_1111.RY



FRI, SEP 16 1994 14:28  
 2G003 FREQ DEVIATION




SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11181\JCHANNOUT\_11181



FRI, SEP 16 1994 14:28  
**BUS 2A04 (4.16-KV BASE)**



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11181\JCHANNOUT\_11181




FRI, SEP 16 1994 14:28  
**BUS 2A06 (4.16-KV BASE)**



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: E.CASE\_111RY3CHANOUT\_111RY

CCN 9


Sheet No. 47  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: DL 10-5-94



FRI, SEP 16 1994 14:29  
 BUS 2804 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: E.CASE\_111RY3CHANOUT\_111RY




FRI, SEP 16 1994 14:29  
 BUS 2806 (480-V BASE)






SAW ONEPFE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
FILE: C:\CASE\111RY\CHANDOUT\_111RY



FRI, SEP 16 1994 14:29  
MCC 2BRA (480-V BASE)




SAW ONEPFE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
FILE: C:\CASE\111RY\CHANDOUT\_111RY



FRI, SEP 16 1994 14:29  
MCC 2BRB (480-V BASE)




SMN ONEFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_111\RY2CHRNOUT\_111.RY



FRI, SEP 16 1994 14:29  
 MCC 2BD (480-V BASE)



SMN ONEFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_111\RY2CHRNOUT\_111.RY




FRI, SEP 16 1994 14:29  
 MCC 2BH (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_111\RYCHMOUT\_111.RY

CCN 9


Sheet No. 50  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: BL 10-5-94



FRI, SEP 16 1994 14:29  
 MCC 2BE (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_111\RYCHMOUT\_111.RY




FRI, SEP 16 1994 14:29  
 MCC 2BJ (480-V BASE)



SAB OROFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11181\DC\MANOUT\_11181

CCN 9


Sheet No. 51  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPW 9-30-94 IRE: Rel 10-5-94



FRI, SEP 16 1994 14:29  
 MCC 2BY (480-V BASE)



SAB OROFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11181\DC\MANOUT\_11181




FRI, SEP 16 1994 14:29  
 MCC 2BZ (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11197\CHRNOUT\_11197

CCN 9

Sheet No. 52  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Upm 9-30-94 IRE: Aut 10-5-94




FRI, SEP 16 1994 14:29

MCC BQ-U2 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11197\CHRNOUT\_11197



FRI, SEP 16 1994 14:29


MCC BS-U2 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11\AT\CHRNOUT\_111.RY

*CCN 9*


Sheet No. 53  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 9-30-94 IRE: PL 10-5-94



FRI, SEP 16 1994 14:29  
 2P017



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11\AT\CHRNOUT\_111.RY




FRI, SEP 16 1994 14:30  
 2P019



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES, INC. - PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\YCHANDOUT\_111AY

CCN 9


Sheet No. 54  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: Rel 10-5-94



FRI, SEP 16 1994 14:30  
 2P191 - B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES, INC. - PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\YCHANDOUT\_111AY




FRI, SEP 16 1994 14:30  
 2P191 - B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., P35/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\2CHNOUT\_1119Y

CCN 9


Sheet No. 55  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 14:30  
 2P190



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., P35/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\2CHNOUT\_1119Y



FRI, SEP 16 1994 14:30  
 2P192






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\RYJCHRNOUT\_111.RY

CCN 9


Sheet No. 56  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:30  
 2E399



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\RYJCHRNOUT\_111.RY




FRI, SEP 16 1994 14:30  
 2E400



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1118\JCHANDOUT\_1118Y

CCN 9


Sheet No. 57  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:30  
 2E401



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1118\JCHANDOUT\_1118Y




FRI, SEP 16 1994 14:30  
 2E402



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RY\CHRNOUT\_111RY

CCN 9


Sheet No. 58  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 930-94 IRE: 10-5-94



FRI, SEP 16 1994 14:30  
 2F009




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RY\CHRNOUT\_111RY



FRI, SEP 16 1994 14:30  
 2F010




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RY2\HANDOUT\_111RY



FRI, SEP 16 1994 14:31  
**P162-U2**



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RY2\HANDOUT\_111RY




FRI, SEP 16 1994 14:31  
**P160-U2**



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111AY\CHANDOUT\_111AY

CCN 9


Sheet No. 60  
 Calc No: E4C-0P2 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: PL 10-5-94



FRI, SEP 16 1994 14:31  
 2F012



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111AY\CHANDOUT\_111AY




FRI, SEP 16 1994 14:31  
 2F013



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11191\CHRNOUT\_11191

CCN 9


Sheet No. 61  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CRW 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:31  
 29015



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11191\CHRNOUT\_11191




FRI, SEP 16 1994 14:31  
 29016



SRN DOWDRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11191\3CHANOUT\_11191

CCN 9


Sheet No. 62  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:31  
 25550



SRN DOWDRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11191\3CHANOUT\_11191




FRI, SEP 16 1994 14:32  
 25547



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\2CHANDOUT\_1119Y

CCN 9


Sheet No. 63  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: PL 10-5-94



FRI, SEP 16 1994 14:32  
 2E546



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\2CHANDOUT\_1119Y



FRI, SEP 16 1994 14:32  
 2E549






SAN ONOFPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111AY\CHARNOUT\_111AY

CCN 9

Sheet No. 64  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: RL 10-5-94




FRI, SEP 16 1994 14:32

2A071



SAN ONOFPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111AY\CHARNOUT\_111AY



FRI, SEP 16 1994 14:32


2A072



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RY\CHANDOUT\_111RY

CCN 9


Sheet No. 65  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 !RE: Ad 10-5-94



FRI, SEP 16 1994 14:32  
 E418-U2



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111RY\CHANDOUT\_111RY




FRI, SEP 16 1994 14:32  
 E419-U2



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\3CHANO\OUT\_1119

CCN 9


Sheet No. 66  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: Red 10-5-94



FRI, SEP 16 1994 14:32  
 2A074



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1119\3CHANO\OUT\_1119




FRI, SEP 16 1994 14:32  
 2A073



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111A7\CHNOUT\_111A7

CCN9


Sheet No. 67  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Gen 9-30-94 IRE: pl 10-5-94



FRI, SEP 16 1994 14:32  
 2P025-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111A7\CHNOUT\_111A7




FRI, SEP 16 1994 14:33  
 2P025-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\RYCHMOUT\_111AY

CCN 9


Sheet No. 68  
 Case No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:33  
 2P307



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_111\RYCHMOUT\_111AY




FRI, SEP 16 1994 14:33  
 2P114



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., P55/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\1111\CHARTOUT\_1111.RY

CCN 9


Sheet No. 69  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 14:33  
 2A274



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., P55/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\1111\CHARTOUT\_1111.RY



FRI, SEP 16 1994 14:33  
 2A276




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11197\CHANNOUT\_11197

CCN 9

Sheet No. 70

Calc No: E4C-082 CCN N-3 Rev. 1


RE: LPM 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 14:33  
 2A275



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11197\CHANNOUT\_11197




FRI, SEP 16 1994 14:33  
 2A277



SABONOFF NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\JCHRNOUT\_1111AY

CCN 9


Sheet No. 71  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 14:33  
 2P141



SABONOFF NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1111\JCHRNOUT\_1111AY



FRI, SEP 16 1994 14:34  
 2P504






SRM DNGRFE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11191\DC\HARDOUT\_11191

CCN 9


Sheet No. 72  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: Ad 12-5-94



FRI, SEP 16 1994 14:34  
 E336-U2



SRM DNGRFE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_11191\DC\HARDOUT\_11191




FRI, SEP 16 1994 14:34  
 E335-U2



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., P/SSE RELEASE 19.0  
 P/TI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\11191\3CHANDOUT\_11191

CCN 9


Sheet No. 73  
 Case No: EAC-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: RI 12-5-94



FRI, SEP 16 1994 14:34  
 2P018-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., P/SSE RELEASE 19.0  
 P/TI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\11191\3CHANDOUT\_11191



FRI, SEP 16 1994 14:35  
 2P018-B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 74 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
 CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-99					


**CASE IVBX DYNAMIC PROFILES**



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1\VBX\CHANDOUT\_1.VBX

CCN 9

Sheet No. 75  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CRM 9-30-94 IRE: RI 10-5-94




FRI, SEP 16 1994 15:19

BUS 3A04 (4.16-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1\VBX\CHANDOUT\_1.VBX



FRI, SEP 16 1994 15:19


BUS 3A06 (4.16-KV BASE)



SRM ONE/RE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\1V8X\CHANO1\_1V8X

CCN9


Sheet No. 76  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: DL 10-5-94



FRI, SEP 16 1994 15:19  
 BUS 3B04 (480-V BASE)



SRM ONE/RE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\1V8X\CHANO1\_1V8X




FRI, SEP 16 1994 15:19  
 BUS 3B06 (480-V BASE)



SRM ONOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTRGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PFI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: E.CASE\_IVBXJCHANDOUT\_IVBX

CCN 9


Sheet No. 77  
 Calc No: ETC-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: REL 10-5-94



FRI, SEP 16 1994 15:20  
 MCC 3BRA (480-V BASE)



SRM ONOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTRGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PFI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: E.CASE\_IVBXJCHANDOUT\_IVBX




FRI, SEP 16 1994 15:20  
 MCC 3BRB (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\IBX\CHRNOUT\_1\IBX

CCN 9


Sheet No. 78  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: PL 10-5-94



FRI, SEP 16 1994 15:20  
 MCC 3BD (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\IBX\CHRNOUT\_1\IBX




FRI, SEP 16 1994 15:20  
 MCC 3BH (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX

CCN 9


Sheet No. 79  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: Bl 10-5-94



FRI, SEP 16 1994 15:20  
 MCC 3BE (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX



FRI, SEP 16 1994 15:20  
 MCC 3BJ (480-V BASE)






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_LVBOX\CHANDOUT\_LVBOX

CCN 9


Sheet No. 80  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: AD 10-5-94




FRI, SEP 16 1994 15:20  
 MCC 3BY (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_LVBOX\CHANDOUT\_LVBOX





FRI, SEP 16 1994 15:20  
 MCC 3BZ (480-V BASE)



  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1V8X\CHANDUT\_1V8X

FRI, SEP 16 1994 15:20  
MCC BQ-U3 (480-V BASE)




  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1V8X\CHANDUT\_1V8X

FRI, SEP 16 1994 15:20  
MCC BS-U3 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVB\XCHANDOUT\_IVB




FRI, SEP 16 1994 15:20

3P017



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVB\XCHANDOUT\_IVB



FRI, SEP 16 1994 15:20


3P019



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1V BX

CCN 9


Sheet No. 83  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: R 10-5-94



FRI, SEP 16 1994 15:20  
 3P024



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1V BX




FRI, SEP 16 1994 15:21  
 3P025-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1VBX

CCN 9


Sheet No. 84  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: dl 10-5-94



FRI, SEP 16 1994 15:21  
 3P307



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1VBX




FRI, SEP 16 1994 15:21  
 3P114



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_1\VBX\JCHRNOUT\_1.VBX

CCN 9


Sheet No. 85  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: dl 10-5-94



FRI, SEP 16 1994 15:21  
 3P191-A



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_1\VBX\JCHRNOUT\_1.VBX




FRI, SEP 16 1994 15:21  
 3P191-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVB\XCHANDOUT\_IVB

CCN 9


Sheet No. 86  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 15:21  
 3P190



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVB\XCHANDOUT\_IVB




FRI, SEP 16 1994 15:21  
 3P192



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1VBOX\CHANNOUT\_1VBOX

CCN 9


Sheet No. 87  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: dl 10-5-94



FRI, SEP 16 1994 15:21  
 3F300



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1VBOX\CHANNOUT\_1VBOX




FRI, SEP 16 1994 15:21  
 3F400






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_IVBX\CHNHOUT\_IVBX



FRI, SEP 16 1994 15:21

3E401



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_IVBX\CHNHOUT\_IVBX

FRI, SEP 16 1994 15:22


3E402



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTT INTERACTIVE PLOTTING PROGRAM - PSS/PT  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX

CCN 9

Sheet No. 89  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 12-5-94




FRI, SEP 16 1994 15:22

3A071



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTT INTERACTIVE PLOTTING PROGRAM - PSS/PT  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX



FRI, SEP 16 1994 15:22


3A072



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_1\VBX\CHAMOUT\_1VBX

CCN 9


Sheet No. 90  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 15:22  
 3A074




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_1\VBX\CHAMOUT\_1VBX



FRI, SEP 16 1994 15:22  
 3A073




SRN DOWFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVBX\CHANDOUT\_IVBX



FRI, SEP 16 1994 15:22  
 3P009



SRN DOWFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVBX\CHANDOUT\_IVBX




FRI, SEP 16 1994 15:22  
 3P010



SAN DIEGO NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PII  
 FILE: C:\CRSE\1V8X\CHANDOUT\_1V8X

CCN 9


Sheet No. 92  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: Pol 10-5-94



FRI, SEP 16 1994 15:22  
 P162-U3



SAN DIEGO NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PII  
 FILE: C:\CRSE\1V8X\CHANDOUT\_1V8X




FRI, SEP 16 1994 15:22  
 P160-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_IVB\XCHRMOUT\_IVB\X

CCN 9


Sheet No. 93  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: dl 10-5-94



FRI, SEP 16 1994 15:22  
 3P015




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_IVB\XCHRMOUT\_IVB\X



FRI, SEP 16 1994 15:23  
 3P016



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
FILE: C:\CASE\_1\B9XJCHMOU1\_1V9X




FRI, SEP 16 1994 15:23

E418-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
FILE: C:\CASE\_1\B9XJCHMOU1\_1V9X



FRI, SEP 16 1994 15:23


E419-U3



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CRSE\1V8X\CHRMOUT\_1V8X

CCN9


Sheet No. 95  
 Calc No: ETC-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: RP 10-5-94



FRI, SEP 16 1994 15:23  
 3P012



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CRSE\1V8X\CHRMOUT\_1V8X



FRI, SEP 16 1994 15:24  
 3P013






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\VBX\CHRMOUT\_1VBX

CCN 9

Sheet No. 96  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: PL 10-5-94




FRI, SEP 16 1994 15:24

3A274



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\VBX\CHRMOUT\_1VBX



FRI, SEP 16 1994 15:24


3A276



SRM ONEOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVB\X3CHRNOUT\_IVB\X

CCN 9


Sheet No. 67  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: Ad 10-5-94



FRI, SEP 16 1994 15:24  
 3A275





SRM ONEOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_IVB\X3CHRNOUT\_IVB\X



FRI, SEP 16 1994 15:24  
 3A277



SRM ONE/RE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTRGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX




SRM ONE/RE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTRGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
 FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1\VBX\CHNOUT\_1.VBX

CCN 9


Sheet No. 99  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: AD 10-5-94



FRI, SEP 16 1994 15:24  
 3E546



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLI  
 FILE: C:\CASE\_1\VBX\CHNOUT\_1.VBX




FRI, SEP 16 1994 15:24  
 3E546



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPL1  
 FILE: C:\CASE\_IVB\XCHRNOUT\_IVB.X

CCN 9

Sheet No. 100  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: BL 10-5-94




FRI, SEP 16 1994 15:24

3P141



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPL1  
 FILE: C:\CASE\_IVB\XCHRNOUT\_IVB.X



FRI, SEP 16 1994 15:25


3P504



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\198X\CHANDOUT\_1V8X

CCN 9

Sheet No. 101  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 930-94 IRE: AL 10-5-94




FRI, SEP 16 1994 15:25

E336-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\198X\CHANDOUT\_1V8X





FRI, SEP 16 1994 15:25

E335-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
FILE: C:\CASE\_1\VBX\CHRNOUT\_1.VBX

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>103</b> OF <b>453</b>
CCN CONVERSION		CCN NO. CCN - <b>9</b>

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>CPM</i> 9-30-99	A. M. PATEL	10-5-99					

CASE IVBY DYNAMIC PROFILES






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B7\CHANNOUT\_1\B7

CCN 9


Sheet No. 104  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPW 9-30-94 IRE: H 10-5-94



FRI, SEP 16 1994 15:42  
 BUS 3A04 (4.16-KV BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B7\CHANNOUT\_1\B7




FRI, SEP 16 1994 15:43  
 BUS 3A06 (4.16-KV BASE)



SMN DOWFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSS/PLI  
 FILE: C:\CASE\_LVBV\JCHANDOUT\_LVBV

CCN 9


Sheet No. 105  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: RL 10-5-94



FRI, SEP 16 1994 15:43  
 BUS 3B04 (480-V BASE)



SMN DOWFIRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSS/PLI  
 FILE: C:\CASE\_LVBV\JCHANDOUT\_LVBV




FRI, SEP 16 1994 15:43  
 BUS 3B06 (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB\JCHAMOUT\_L\VB\

CCN 9

Sheet No. 106  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: RL 10-5-94



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB\JCHAMOUT\_L\VB\






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_L\B7\CHANDOUT\_L\B7

CCN 9


Sheet No. 107  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LEM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 15:43  
 MCC 3BD (480-V BASE)




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_L\B7\CHANDOUT\_L\B7



FRI, SEP 16 1994 15:43  
 MCC 3BH (480-V BASE)


CCN 9


Sheet No. 108  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Perm 9-30-94 IRE: Rel 10-5-94



FRI, SEP 16 1994 15:43


MCC 3BE (480-V BASE)

  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB7\CHANNOUT\_L\VB7



FRI, SEP 16 1994 15:43

MCC 3BJ (480-V BASE)


  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB7\CHANNOUT\_L\VB7



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_LV81\JCHRNOUT\_LV81

CCN 9


Sheet No. 109  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: RL 10-5-94



FRI, SEP 16 1994 15:44  
 MCC 3BY (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_LV81\JCHRNOUT\_LV81




FRI, SEP 16 1994 15:44  
 MCC 3BZ (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1\BY3\CHARNOUT\_1\BY3

CCN 9


Sheet No. 110  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: UPM 9-30-94 IRE: PL 10-5-94



FRI, SEP 16 1994 15:44  
 MCC 80-U3 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\1\BY3\CHARNOUT\_1\BY3




FRI, SEP 16 1994 15:44  
 MCC 85-U3 (480-V BASE)



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_1\B7\3\CHRNOUT\_1\B7

CCN 9


Sheet No. 111  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: RP 10-5-94



FRI, SEP 16 1994 15:44  
 3P017



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\_1\B7\3\CHRNOUT\_1\B7



FRI, SEP 16 1994 15:44  
 3P019






SMOONRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BYJCHANDOUT\_1\BY

CCN 9


Sheet No. 112  
 Calc No: EAC-082 CCN N-3 Rev. 1  
 RE: CRM A-30-94 IRE: PL 10-5-94



FRI, SEP 16 1994 15:44  
 3P024



SMOONRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BYJCHANDOUT\_1\BY




FRI, SEP 16 1994 15:44  
 3P025-B



SMN DUPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BY2\CHANOVT\_1.VBY

CCN 9

Sheet No. 113  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: And 10-5-94




FRI, SEP 16 1994 15:44

3P307



SMN DUPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BY2\CHANOVT\_1.VBY



FRI, SEP 16 1994 15:44


3P114



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PII  
 FILE: C:\CASE\_LVB\YJCHANDOUT\_LVB\Y

CCN 9


Sheet No. 119  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: RL 10-5-94



FRI, SEP 16 1994 15:44  
 3P191-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PII  
 FILE: C:\CASE\_LVB\YJCHANDOUT\_LVB\Y




FRI, SEP 16 1994 15:44  
 3P191-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_LVB\YCHRNOUT\_LVB1

CCN 9


Sheet No. 115  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 15:45  
 3P190



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_LVB\YCHRNOUT\_LVB1




FRI, SEP 16 1994 15:45  
 3P192



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BYJCHANDOUT\_1.VBY

CCN 9

Sheet No. 116  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: DL 10-5-94




FRI, SEP 16 1994 15:45

3E399



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BYJCHANDOUT\_1.VBY




FRI, SEP 16 1994 15:45

3E400



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BY3\CHRNOUT\_1.VBY




FRI, SEP 16 1994 15:45

3E401



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\BY3\CHRNOUT\_1.VBY




FRI, SEP 16 1994 15:45

20543



SRM ONOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
FILE: C:\CASE\_IVBY\JCHANDOUT\_IVBY




FRI, SEP 16 1994 15:45

3A071



SRM ONOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
PTI INTERACTIVE PLOTTING PROGRAM - PSS/PTI  
FILE: C:\CASE\_IVBY\JCHANDOUT\_IVBY



FRI, SEP 16 1994 15:45


3A072



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLOT  
 FILE: C:\CASE\_1\B7\CHANDOUT\_1\B7

CCN 9


Sheet No. 119  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: RL 10-5-94



3A074



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PVI INTERACTIVE PLOTTING PROGRAM - PSSPLOT  
 FILE: C:\CASE\_1\B7\CHANDOUT\_1\B7



3A073






SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_LVBY\CHANNOUT\_LVBY

CCN 9


Sheet No. 120  
 Case No: EAC-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: Rel 10-5-94



FRI, SEP 16 1994 15:45  
 3P009



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_LVBY\CHANNOUT\_LVBY




FRI, SEP 16 1994 15:46  
 3P010



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\IVBY\CHANNOUT\_IVBY

CCN9


Sheet No. 121  
 Calc No: ETC-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 01 10-5-94



FRI, SEP 16 1994 15:46  
 P162-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSS/PLT  
 FILE: C:\CASE\IVBY\CHANNOUT\_IVBY




FRI, SEP 16 1994 15:46  
 P160-U3



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPL1  
 FILE: C:\CASE\1VBYJCHANDOUT\_1VBY

CCN 9


Sheet No. 122  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 15:46  
 3P015



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPL1  
 FILE: C:\CASE\1VBYJCHANDOUT\_1VBY




FRI, SEP 16 1994 15:47  
 3P016



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B71\CHANDOUT\_1\B71

CEN 9


Sheet No. 123  
 Calc No: E4C-082 CEN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 10-5-94



FRI, SEP 16 1994 15:47  
 E418-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B71\CHANDOUT\_1\B71




FRI, SEP 16 1994 15:47  
 E419-U3



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB\YCH\ANOUT\_L\VB\Y

CCN 9

Sheet No. 124  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: bl 10-5-94




FRI, SEP 16 1994 15:46

3P012



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB\YCH\ANOUT\_L\VB\Y



FRI, SEP 16 1994 15:46


3P013




SRN ONOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\B7Y1CHRNOUT\_1.VBY

CCN 9

Sheet No. 125  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: 10-5-94



SRN ONOFFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\B7Y1CHRNOUT\_1.VBY






SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B1\YCHRNOUT\_1\B1

CCN 9


Sheet No. 126  
 Calc No: EAC-D82 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: AL 10-5-94



FRI, SEP 16 1994 15:48  
 3A275



SAN ONOFRÉ NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 P11 INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B1\YCHRNOUT\_1\B1




FRI, SEP 16 1994 15:48  
 3A277



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: E.CASE\_1V812CHANNOUT\_1V8Y

CCN 9

Sheet No. 127  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LRM 9-30-94 IRE: DL 10-5-94




FRI, SEP 16 1994 15:47

3E550



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: E.CASE\_1V812CHANNOUT\_1V8Y




FRI, SEP 16 1994 15:47

3E547





SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PII  
 FILE: C:\CASE\_1\VB\3\CHANDOUT\_1.VB




FRI, SEP 16 1994 15:47

3E546



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSS/PII  
 FILE: C:\CASE\_1\VB\3\CHANDOUT\_1.VB




FRI, SEP 16 1994 15:47

3E549



SRM ONDRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB7\CHRNOUT\_1.VB7




FRI, SEP 16 1994 15:48

3P141



SRM ONDRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_L\VB7\CHRNOUT\_1.VB7



FRI, SEP 16 1994 15:48


3P504



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_LVBY\CHANDOUT\_LVBY

CCN 9


Sheet No. 130  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: Al 10-5-94



FRI, SEP 16 1994 15:48  
 E336-U3




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC.: PSS/E RELEASE 19.0  
 PII INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CRSE\_LVBY\CHANDOUT\_LVBY



FRI, SEP 16 1994 15:49  
 E335-U3




SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B7\3CHNOUT\_1.VBY



FRI, SEP 16 1994 15:49  
 3P018-B



SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT  
 POWER TECHNOLOGIES INC., PSS/E RELEASE 19.0  
 PTI INTERACTIVE PLOTTING PROGRAM - PSSPLT  
 FILE: C:\CASE\_1\B7\3CHNOUT\_1.VBY



FRI, SEP 16 1994 15:49  
 3P018-B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>132</b> OF <b>453</b>
---	-------------------------------

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURTEL <i>LRM</i>	<i>9-30-99</i>	A. M. PATEL <i>AP</i>	<i>10-5-99</i>					

**2.2 CONCLUSIONS:**

A. In response to Acceptance Criteria Section 1.2.A, the results of these analyses demonstrate that all ESF motor loads can successfully accelerate to their rated speeds without spurious tripping of their associated circuit breakers, when fed from either the switchyard (CASEs IVBX and IVBY) or the emergency diesel generators (CASEs IIIAX and IIIAY), under the following conditions:

1. Maximum loading.
2. Minimum system voltages.
3. Out-of-sequence starting of ESF loads.

Successful acceleration of ESF motors to their rated speeds indicate that the calculated voltage at the motor terminals are adequate to maintain a corresponding motor torque higher than the load torque requirement.

The following Tables 2.1 and 2.2 show the time (seconds) it would take for each motor to accelerate to its rated speed from standstill. The first column indicates the redundant motor loads. The second column shows the longest acceleration time expected when these redundant motor loads are started out of sequence when powered from the emergency diesel generators. The third column shows the longest acceleration time when these motors are started out of sequence when powered from the offsite power supply (switchyard).

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>133</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

**TABLE 2.1 - UNIT 2 ESF MOTORS OUT-OF-SEQUENCE ACCELERATION TIME**

UNIT 2	FED FROM EDG	FED FROM SWITCHYARD
4-KV MOTOR LOADS		
CONTAINMENT SPRAY PUMP 2P012/2P013	0.87	0.87
AUXILIARY FEEDWATER PUMP 2P141/2P504	3.30	5.00
COMPONENT COOLING WATER PUMP 2P024/2P025/2P026	0.73	0.80
LOW PRESSURE SAFETY INJECTION PUMP 2P015/2P016	0.87	0.87
HIGH PRESSURE SAFETY INJECTION PUMP 2P017/2P018/2P019	1.07	1.40
SALTWATER COOLING PUMP 2P112/2P113/2P114/2P307	0.57	0.53
AUXILIARY BUILDING EMERGENCY CHILLER E335/E336	0.50	0.50
480-V LOADCENTER MOTOR LOADS		
CHARGING PUMP 2P190/2P191/2P192	0.80	1.07
DOMESTIC AIR CIRCULATOR FAN 2A071/2A072/2A073/2A074	5.42	7.50
CONTAINMENT EMERGENCY FAN 2E399/2E400/2E401/2E402	3.20	5.07
CONTROL ROOM EMERGENCY AC UNIT E418/E419	4.12	5.85
480-V MCC MOTOR LOADS		
EDG BUILDING EMERGENCY FAN 2A274/2A275/2A276/2A277	3.85	5.00
EDG RADIATOR FAN 2E546/2E547/2E549/2E550	1.52	2.20
SPENT FUEL PUMP 2P009/2P010	0.80	1.07
CONTROL BLDG EMERGENCY CHILLED WATER PUMP 2P160/2P162	0.53	1.07

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>134</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**TABLE 2.2 - UNIT 3 ESF MOTORS OUT-OF-SEQUENCE ACCELERATION TIME**

UNIT 3	FED FROM EDG	FED FROM SWITCHYARD
<b>4-KV MOTOR LOADS</b>		
CONTAINMENT SPRAY PUMP 3P012/3P013	0.87	0.87
AUXILIARY FEEDWATER PUMP 3P141/3P504	3.30	5.00
COMPONENT COOLING WATER PUMP 3P024/3P025/3P026	0.73	0.80
LOW PRESSURE SAFETY INJECTION PUMP 3P015/3P016	0.87	0.87
HIGH PRESSURE SAFETY INJECTION PUMP 3P017/3P018/3P019	1.07	1.40
SALTWATER COOLING PUMP 3P112/3P113/3P114/3P307	0.57	0.53
AUXILIARY BUILDING EMERGENCY CHILLER E335/E336	0.50	0.50
<b>480-V LOADCENTER MOTOR LOADS</b>		
CHARGING PUMP 3P190/3P191/3P192	0.80	1.07
DOME AIR CIRCULATOR FAN 3A071/3A072/3A073/3A074	5.42	7.50
CONTAINMENT EMERGENCY FAN 3E399/3E400/3E401/3E402	3.20	5.07
CONTROL ROOM EMERGENCY AC UNIT E418/E419	4.12	5.85
<b>480-V MCC MOTOR LOADS</b>		
EDG BUILDING EMERGENCY FAN 3A274/3A275/3A276/3A277	3.85	5.00
EDG RADIATOR FAN 3E546/3E547/3E549/3E550	1.52	2.20
SPENT FUEL PUMP 3P009/3P010	0.80	1.07
CONTROL BLDG EMERGENCY CHILLED WATER PUMP 3P160/3P162	0.53	1.07

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 135 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

- B. In response to Acceptance Criteria Section 1.2.B, loading profiles for the emergency diesel generators show that the steady state loading in each generator is within its 4700 KW rating. The momentary power surges above the 4700 KW rating during automatic sequencing are acceptable because each diesel generator unit is capable of being loaded to 5170 KW for 2 hours within 24-hour period.
- C. In response to Acceptance Criteria Section 1.2.C.1, results of the dynamic simulations performed for the emergency diesel generators demonstrate that each emergency diesel generator is capable of starting and accelerating their respective ESF loads to their rated speeds at their designated sequence. See Table 2.1 and 2.2 above.
- D. In response to Acceptance Criteria Section 1.2.C.2, results of the dynamic simulations performed for the emergency diesel generators indicate that the minimum generator frequency throughout the duration of automatic sequencing is no less than 98.8% of the nominal (60 Hertz), which is above the minimum limit of 95% nominal required by Regulatory Guide 1.9, and the corresponding minimum generator voltage is no less than 78% of the nominal voltage (4.36 KV), which is above the minimum limit of 75% nominal.
- E. Acceptance Criteria Section 1.2.C.3 requires that the generator frequency be restored to within 2% of nominal (60 Hertz) in less than 60% of each load-sequence interval for step load increase. Since the minimum generator frequency throughout the duration of automatic sequence is 98.8% per Section 2.2.D above, the frequency criterion of Section 1.2.C.3 is correspondingly satisfied.
- F. Acceptance Criteria Section 1.2.C.4 requires that the generator voltage be restored to 10% of nominal (4.36 KV) within 60% of each load-sequence time interval. Based on the results of dynamic simulations performed for the emergency diesel generators, full recovery to nominal voltage is achieved in less than 60% of each loading sequence.
- G. In response to Acceptance Criteria 1.2.D, results of these analyses were reviewed against Calculations E4C-098 (Reference 6.16) and E4C-099 (Reference 6.17). Based on these reviews, the acceleration times determined in these analyses, per Tables 2.1 and 2.2 above, remain bounded by the existing motor protective device settings per Class 1E 4KV Protection Calculation E4C-098 (Reference 6.16) and Class 1E 480V Protection Calculation E4C-099 (Reference 6.17).



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>136</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

- H. The multiple starting of Saltwater Cooling Pumps, Component Cooling Water Pumps and Dome Air Circulator Fans during the dynamic simulation for single train operation insures that the results of these analyses are bounding for all operating modes of these loads when the auxiliary system is fed from the offsite power supply.
- I. For systems which have swing or redundant components, the starting of load with the highest impedance feeder cable insures that the results of these analyses are bounding and are applicable to any of the redundant components.
- J. In cases where the 4-kV ESF buses are deenergized and transferred to the corresponding ESF buses of the companion unit (CASEs IVBX and IVBY), motor loads that are initially running during the normal plant operation are stopped and restarted when the tie breaker closes during bus transfer. This insures that the resulting voltage profiles established by this CCN for these cases are bounding. The results of the analyses performed for these cases are acceptable.
- K. The post accident steady state voltage in some cases may not recover to 90% of the motor rated voltage per ANSI Standard C50.41-1982 (Reference 6.18). However, this condition is rare because the corresponding switchyard voltage considered in these analyses is based on the expected minimum of 218 KV at the switchyard which could occur only when all the Units in San Onofre are off-line during summer peak loading conditions. In most cases this minimum switchyard voltage (218 KV) would not persist for an indefinite period since it is normal for the Edison Energy Control Center to reconfigure the 230-KV system and restore the system voltage to within normal (230 KV). For specifics, see System Operating Bulletin No. 17 (Reference 6.19). A more severe instability in the grid causing extreme degradation of voltage below 218 KV would cause the auxiliary system to be powered from the emergency diesel generators. Detailed analyses of the effect of post accident steady state voltages on the running motor loads are addressed in Calculation E4C-090 (Reference 6.15).
- L. This CCN does not impact any relevant provisions of the SONGS 2&3 Technical Specifications, Updated Final Safety Analysis Report and Design Bases Documentation.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 137 OF 453

CCN CONVERSION  
CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIE	9-30-94	A. M. PATEL	10-5-94					

**2.3 RECOMMENDATION:**

None identified. No further action is required by this CCN.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO. / PRELIM. CCN NO. N-3 PAGE 138 OF 453

CCN CONVERSION  
 CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEV <i>LM</i>	9-30-94	A. M. PATEL <i>AP</i>	10-5-94					

THIS PAGE INTENTIONALLY LEFT BLANK

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO. / PRELIM. CCN NO. N-3 PAGE 139 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**3.0 ASSUMPTIONS:**

- 3.1 All assumptions established in the base calculation are applicable to this CCN.
- 3.2 This CCN considers the most limiting impedance value for the new 1500 KVA loadcenter transformers based on the vendor test reports (References 6.2 through 6.6). This limiting impedance value is used in all ESF loadcenter transformers to allow their replacement without exceeding the bounds of these analyses.
- 3.3 This CCN considers only the analyses performed in the base calculation for CASE IIIA, when fed from the emergency diesel generators, and CASE IVB, when fed from the offsite power supply. These cases are chosen for this CCN because they represent the most limiting conditions (minimum voltage and maximum loading) for dynamic simulations. This will ensure that the results of these analyses are bounding.
- 3.4 Motor Control Center Loading Assumptions:
  - A. MCC load data, except MOVs, are taken from Calculations E4C-086 and E4C-087 (References 6.13 and 6.14). The equivalent KW and KVAR values for the MOVs are determined in Table 5.2 based on their horsepower rating and typical power factor and efficiency of 60% and 70% respectively, per Litorque Publication SEL-17 (Attachment 9.2.2). MCC load schedules are shown in Table 5.3.

MCC loads are lumped and classified as follows:

- 1. Initial Condition Equivalent Load - This equivalent load is a constant KVA load consisting of both static and motor loads at steady state running condition. These loads are considered operating prior to the initiation of accident signal.
- 2. Accident Condition Equivalent Motor Load - This equivalent load is the starting motor load representative of all ESF motors that are required for accident mitigation. For conservatism, these motors are assumed to start at Sequence 1 or at t=0 second and include motors that would continue to run after the completion of automatic sequencing. Motor Operated Valves (MOVs) are assumed to operate during the entire dynamic simulation, regardless of their position when the safety signal is received.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>140</b> OF <b>453</b>
-----------	----------------------------	-------------------------------

CCN CONVERSION	CCN NO. CCN - <b>9</b>
----------------	------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

3. Accident Condition Equivalent Static And Running Load - This equivalent load is a constant KVA load consisting of both static and motor loads at steady state running condition. It represents all the static and motor loads that are continuously running through the entire sequencing period.

B. Based on Calculations E4C-086 and E4C-087 (References 6.13 and 6.14) a load margin of 5 KVA for the equivalent static load and 15 HP margin for the equivalent starting motor load are provided in each of the ESF MCCs for future load addition.

The corresponding calculations for the MCC equivalent loading are shown in Sections 8.3 through 8.20. The results of these calculations are shown in Tables 3.1 and 3.2.

C. The equivalent inertia constant for the starting lumped MCC motor model is based on the total inertia of the individual motors. Inertia values used in the CMOTOR models for the lumped MCC motors are typical values from Calculations E4C-086 and E4C-087 (References 6.13 and 6.14). Inertia values for each motor is determined based on the size and rating of the motor. The corresponding inertia ratio is taken from Table 1, "Load Characteristics Of Various Machines", in the Motor Application and Maintenance Handbook (Reference 6.20). Inertia ratio for each motor is determined based on the type of motor application. Accordingly, the inertia ratio for fans and the 15 HP margin discussed in Section 3.4.B (above) is assumed at 25. The inertia ratio for compressors is assumed at 8 and the inertia ratio for pumps and MOVs is assumed at 1.

Inertia constants used in the CMOTOR models are determined per Section 5.8 of the base calculation. The corresponding calculations are shown in Table 5.4 and the results of these calculations are shown in Table 3.3 below.

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>141</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**TABLE 3.1 - MCC EQUIVALENT LOADS**

MCC	PSS/E BUS NUMBER	INITIAL CONDITION EQUIV. LOADS		ACCIDENT CONDITION EQUIV. STATIC LOADS	
		P (MW)	Q (MVAR)	P (MW)	Q (MVAR)
2BRA	23403	0.00850	0.00526	0.00850	0.00526
2BD	23407	0.04586	0.00928	0.00850	0.00526
2BE	23414	0.08944	0.06408	0.08944	0.06408
2BY	23415	0.11821	0.07427	0.11248	0.07808
BQ	23417	0.07591	0.04579	0.07591	0.04579
2BRB	23603	0.00850	0.00526	0.00850	0.00526
2BH	23605	0.04586	0.00928	0.00850	0.00526
2BJ	23607	0.07924	0.05776	0.07924	0.05776
2BZ	23614	0.09305	0.06040	0.12438	0.08390
BS	23618	0.01233	0.00763	0.04263	0.02343
3BRA	33403	0.00850	0.00526	0.00850	0.00526
3BD	33407	0.04586	0.00928	0.00850	0.00526
3BE	33414	0.08944	0.06408	0.08944	0.06408
3BY	33415	0.11821	0.07427	0.11248	0.07808
BQ	33417	0.07591	0.04579	0.07591	0.04579
3BRB	33603	0.00850	0.00526	0.00850	0.00526
3BH	33605	0.04586	0.00928	0.00850	0.00526
3BJ	33607	0.07924	0.05776	0.07924	0.05776
3BZ	33614	0.09291	0.06040	0.12438	0.08390
BS	33618	0.01233	0.00763	0.04263	0.02343

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 142 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**TABLE 3.2 - MCC EQUIVALENT MOTOR LOADS**

MCC	PSS/E BUS NUMBER	ACCIDENT CONDITION EQUIVALENT MOTOR LOADS		
		Mbase (MVA)	P (MW)	Q (MVAR)
2BRA	22403	0.01756	0.01445	0.00997
2BD	22407	0.02279	0.01829	0.01360
2BE	22414	0.06785	0.04503	0.05076
2BY	22415	0.10244	0.08615	0.05542
BQ	22417	0.05149	0.04362	0.02736
2BRB	22603	0.01756	0.01445	0.00997
2BH	22605	0.02279	0.01829	0.01360
2BJ	22607	0.06777	0.04498	0.05069
2BZ	22614	0.06445	0.04996	0.04071
B5	22618	0.05149	0.04362	0.02736
3BRA	32403	0.01756	0.01445	0.00997
3BD	32407	0.02279	0.01829	0.01360
3BE	32414	0.06931	0.04591	0.05193
3BY	32415	0.10244	0.08615	0.05542
BQ	32417	0.05149	0.04362	0.02736
3BRB	32603	0.01756	0.01445	0.00997
3BH	32605	0.02279	0.01829	0.01360
3BJ	32607	0.06776	0.04497	0.05068
3BZ	32614	0.06749	0.05183	0.04322
B5	32618	0.05149	0.04362	0.02736

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. **N-3** PAGE **143** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL <i>pm</i>	9-30-94	A. M. PATEL <i>AP</i>	10-5-94					

**TABLE 3.3 - MCC EQUIVALENT MOTOR INERTIA CONSTANTS**

MCC	BUS NUMBER	EQUIVALENT INERTIA CONSTANT
2BRA	22403	1.467
2BD	22407	1.045
2BE	22414	0.586
2BY	22415	0.595
BQ	22417	1.041
2BRB	22603	1.467
2BH	22605	1.045
2BJ	22607	0.590
2BZ	22614	0.892
BS	22618	1.041
3BRA	32403	1.467
3BD	32407	1.045
3BE	32414	0.575
3BY	32415	0.595
BQ	32417	1.041
3BRB	32603	1.467
3BH	32605	1.045
3BJ	32607	0.590
3BZ	32614	0.868
BS	32618	1.041



**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 144 OF 453

CCN CONVERSION CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIE <i>LRM</i>	<u>9-30-74</u>	A. M. PATEL <i>AMP</i>	<u>10-5-74</u>					

THIS PAGE INTENTIONALLY LEFT BLANK

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. **N-3** PAGE **145** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**4.0 DESIGN INPUT:**

- 4.1 Except for the following changes and updates, all design inputs considered in the base calculation are applicable to this CCN.
- 4.2 The new load inertia for the Control Room Emergency Air Conditioning Units E-418 and E-419 is 272 lb-ft<sup>2</sup> to reflect the new inertia values provided by the vendor (Reference 6.7, Attachment 9.2.1). The corresponding calculation for inertia constant is shown in Section 8.21.
- 4.3 The new motor base (MBASE) for the Auxiliary Feedwater Pumps 2P141, 2P504, 3P141 and 3P504 is 0.6832 MVA per Calculations E4C-086, Rev. 0, CCN 1 and E4C-087, Rev. 0, CCN 2.
- 4.4 Per Section 3.2, these analyses consider the most limiting impedance value of the replacement 1500 KVA loadcenter transformers at nominal tap. The X-R ratio and the nominal tap voltage are bounding values applicable to all in-service and replacement 1500 KVA loadcenter transformers. The new parameters considered for the 1500 KVA loadcenter transformers are shown below and are based on the (bounding) vendor test reports (S023-302-15-11-1, Reference 6.3).

Impedance = 10.18%  
X-R Ratio = 7.0  
Nominal Tap Voltage = 4155 Volts

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 146 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**5.0 METHODOLOGY:**

- 5.1 This CCN follows the same methodology in the base calculation except for the following:
- 5.2 For the purpose of simplifying the analysis for sequence overlaps, only the most limiting cases in the base calculation are considered in this CCN. The most limiting cases are chosen on the basis of maximum loading and minimum voltage at the buses and MCCs under consideration.

In the case where the ESF buses are fed from their respective emergency diesel generators, only CASE IIIA (Unit 2) is considered. Two sub-cases of CASE IIIA are established, i.e., CASE IIIAX and CASE IIIAY, to cover all possible out-of-sequence starting times of ESF load groups during automatic sequencing. See Section 5.8 below for case description.

In the case where the ESF buses are fed from the offsite power supply, only CASE IVBT (Unit 3) is considered. Two sub-cases of CASE IVBT are established, i.e., CASE IVBX and CASE IVBY, to cover all possible out-of-sequence starting times of ESF load groups during automatic sequencing. See Section 5.8 below for case description.

To insure that the results of these analyses bound all possible operating conditions, the more conservative MCC 2BD main feeder parameters are considered for MCC 3BD main feeder in CASEs IVBX and IVBY.

- 5.3 The results of these dynamic simulations are shown in the form of voltage profiles for all buses, MCCs, and motor loads. For motor loads, speed profiles are also shown. These voltage and speed profiles are the bounding profiles established for this CCN.
- 5.4 In order to address the single train operation of the Component Cooling Water (CCW) Pumps, Saltwater Cooling (SWC) Pumps and Dome Air Circulator Fans (one Pump or one Fan running in anyone train) in the dynamic simulations, they are started in the first load group and restarted again at their designated starting sequence. This will result in the voltage profiles that are bounding and applicable in all modes of plant operations.

Single train operation of these loads does not affect the existing analyses for CASEs IIIAX and IIIAY where the loads are shed and then restarted at their designated sequence.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>147</b> OF <b>453</b>
CCN CONVERSION		CCN NO. CCN - <b>9</b>

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-20-94	A. M. PATEL	10-5-94					

5.5 For systems containing a swing or redundant components, the load with the highest impedance feeder cable is selected as the starting load to obtain the most limiting voltage profile:

1. Component Cooling Water Pump 2P025 at 4-kV Bus 2A04
2. Component Cooling Water Pump 2P025 at 4-kV Bus 2A06
3. Component Cooling Water Pump 3P024 at 4-kV Bus 3A04
4. Component Cooling Water Pump 3P025 at 4-kV Bus 3A06
5. Saltwater Cooling Pump 2P307 at 4-kV Bus 2A04
6. Saltwater Cooling Pump 2P114 at 4-kV Bus 2A06
7. Saltwater Cooling Pump 3P307 at 4-kV Bus 3A04
8. Saltwater Cooling Pump 3P114 at 4-kV Bus 3A06

5.6 These analyses consider the new inertia constant calculated in Section 8.0 for the Control Room Emergency Air Conditioning Units E-418 and E-419 to reflect the new (lower) inertia values provided by the vendor (References 6.7). Likewise, these analyses consider the new Motor Base (MBASE) for the Auxiliary Feedwater Pumps P141 and P504 per Section 1.1.B.2.

5.7 Results of the power flow solution for the initial steady state condition (t=0) and post accident steady state condition (t=40) are shown in Appendices 9.1.3 through 9.1.6. They are shown in both one-line output format and the "traditional" power flow output format.

5.8 The following cases are developed for this CCN to establish the new bounding voltage and speed profiles for all ESF motors, buses and MCCs when these loads are started out of sequence:

**I. Powered From Emergency Diesel Generators**

- a. **CASE IIIAX** - This case considers the Unit 2 ESF buses when supplied from their dedicated emergency diesel generators during a postulated design basis accident in Unit 2 coincident with a loss of offsite power. ESF loads are started per load schedule in Table 5.1.
- b. **CASE IIIAY** - This case is the same as CASE IIIAX except for the starting times of ESF loads. See Table 5.1.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. **N-3** PAGE **148** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL <i>LM</i>	9-30-94	A. M. PATEL <i>AP</i>	10-5-94					

**II. Powered From Offsite Power Supply**

- c. **CASE IVBTX** - This case considers the bus alignment where the Unit 3 4-KV ESF buses are tied to the corresponding Unit 2, 4-KV ESF buses with the Unit 2 Reserve Auxiliary Transformers 2XR1 and 2XR2 inoperable. All the ESF loads are supplied from the Unit 2 Main Transformer 2XM via Unit Auxiliary Transformer 2XU1. Loading for the associated non-ESF buses is determined per Table 3.1 in the base calculation. A design basis accident is postulated in Unit 3 while Unit 2 is in Mode 5 or 6 with its ESF loads running at steady state due to a spurious accident signal postulated in the Unit 2. ESF loads are started per load schedule in Table 5.1.
- d. **CASE IVBTY** - This case is the same as CASE IVBTX except for the starting times of ESF loads. See Table 5.1.

5.9 The following are the PSS/E files associated with each case analyzed in this CCN:

a. **CASE IIIAX:**

- Directory - DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX]
- LF-1\_IIIAX.SAV - Initial Condition Power Flow Saved Case.
- LF-2\_IIIAX.SAV - Post Accident Condition Power Flow Saved Case.
- SNAP\_IIIAX.SNP - Dynamic Simulation Snapshot.
- CHANOUT\_IIIAX.BIN - Channel Output.

b. **CASE IIIAY:**

- Directory - DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAY]
- LF-1\_IIIAY.SAV - Initial Condition Power Flow Saved Case.
- LF-2\_IIIAY.SAV - Post Accident Condition Power Flow Saved Case.
- SNAP\_IIIAY.SNP - Dynamic Simulation Snapshot.
- CHANOUT\_IIIAY.BIN - Channel Output.

c. **CASE IVBX:**

- Directory - DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]
- LF-1\_IVBX.SAV - Initial Condition Power Flow Saved Case.
- LF-2\_IVBX.SAV - Post Accident Condition Power Flow Saved Case.
- SNAP\_IVBX.SNP - Dynamic Simulation Snapshot.
- CHANOUT\_IVBX.BIN - Channel Output.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>49</b> OF <b>453</b>
CCN CONVERSION CCN NO. CCN - <b>9</b>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

d. CASE IVBY:

- Directory - DKB200: [MURIEL.E4C-082-AGA.CASE IVBY]
- LF-1\_IVBY.SAV - Initial Condition Power Flow Saved Case.
- LF-2\_IVBY.SAV - Post Accident Condition Power Flow Saved Case.
- SNAP\_IVBY.SNP - Dynamic Simulation Snapshot.
- CHANOUT\_IVBY.BIN - Channel Output.

5.10 Validation of the PSS/E program was performed by manual calculation. The manual calculation and the corresponding computer simulation (benchmark/test case) were documented in the Design Calculation DC-3128, Rev. 0 (Reference 6.21). Validation is performed by comparing the results (plots) of the original benchmark/test case run with the latest rerun. Comparison of plots from the latest rerun with corresponding plots from the original benchmark/test case shows identical results. This verifies the integrity of the PSS/E program. See Appendix 9.1.7 for these plots. PSS/E is controlled by Installation Report No. PC004R00.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./  
 PRELIM. CCN NO. N-3 PAGE 150 OF 453

CCN CONVERSION  
 CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL <i>LRM</i>	9-30-94	A. M. PATEL <i>AP</i>	10-5-94					

THIS PAGE INTENTIONALLY LEFT BLANK

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>151</b> OF <b>453</b>
CCN CONVERSION CCN NO. CCN - <b>9</b>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-032 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>CLM</i> 9-30-94	A. M. PATEL	<i>AP</i> 10-5-94					

**TABLE 5.1**

Postulated Accident Loading With Sequence Overlaps



SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

CCN 9

ORIGINATOR: Lpm  
 IRE: and

SHEET NO. 152  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1

CASE III.AX : UNIT 2 ESF LOAD SCHEDULE FOR UNIT 2 DBA FED FROM EMERGENCY DIESEL GENERATOR

PAGE 1

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)									POST ACC
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
4-KV BUS 2A04												
Cntmt Spray Pump P012	2403	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
AFW Pump P141	2404	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
CCW Pump P024	2405	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2406	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P015	2407	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P017	2408	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018*	2409	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P112	2410	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P307	2411	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON
Aux Bldg Chiller E336	2412	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Non-IE UPS*	2416	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
Loadcenter 2B04	2420	-	-	-	-	-	-	-	-	-	-	-
4-KV BUS 2A06												
AFW Pump P504	2603	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Cntmt Spray Pump P013	2604	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
CCW Pump P026	2605	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2606	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P016	2607	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P019	2608	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018*	2609	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P113	2610	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P114	2611	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON
Aux Bldg Chiller E335	2612	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Loadcenter 2B06	2620	-	-	-	-	-	-	-	-	-	-	-

\*Additional loads that are started manually during post accident steady state conditions.

E082SEQX.WK1

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lpm  
 DATE: 9-30-94  
 SHEET NO. 153  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE III.AX : UNIT 2 ESF LOAD SCHEDULE FOR UNIT 2 DBA FED FROM EMERGENCY DIESEL GENERATOR

PAGE 2

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B04												
Press Htr E615-E618**	21402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 2BRA	21403	-	-	-	-	-	-	-	-	-	-	-
2BRA Lumped Motor	22403	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRA Lumped Static	23403	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	21405	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E145 Panel	21406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BD (DG-MCC)	21407	-	-	-	-	-	-	-	-	-	-	-
2BD Lumped Motor	22407	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BD Lumped Static	23407	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A274	24412	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A275	24413	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Radiator Fan E550	24421	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Radiator Fan E546	24422	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Dome Air Circ A071	21409	OFF*	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E399	21410	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E401	21411	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P190	21413	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BE	21414	-	-	-	-	-	-	-	-	-	-	-
2BE Lumped Motor	22414	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BE Lumped Static	23414	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BY	21415	-	-	-	-	-	-	-	-	-	-	-
2BY Lumped Motor	22415	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BY Lumped Static	23415	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P009	24434	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC {Q}	21417	-	-	-	-	-	-	-	-	-	-	-
BQ Lumped Motor	22417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BQ Lumped Static	23417	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P162	24417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC Unit E416	21418	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Stdby Dome Air Circ A074	21419	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON

\* Temporarily deenergized during transition to Emergency Diesel Generator power

E082SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lem  
 IRE: Red

CCN 9  
 SHEET NO. 154  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE III.AX : UNIT 2 ESF LOAD SCHEDULE FOR UNIT 2 DBA FED FROM EMERGENCY DIESEL GENERATOR

PAGE 3

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)									POST ACC
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B06												
Pre Htr E627-E629/E622**	21602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 2BRB	21603	-	-	-	-	-	-	-	-	-	-	-
2BRB Lumped Motor	22603	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRB Lumped Static	23603	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BH (DG-MCC)	21605	-	-	-	-	-	-	-	-	-	-	-
2BH Lumped Motor	22605	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BH Lumped Static	23605	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E547	24606	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Radiator Fan E549	24607	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A276	24611	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A277	24612	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
H2 Recomb E146 Panel	21606	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BJ	21607	-	-	-	-	-	-	-	-	-	-	-
2BJ Lumped Motor	22607	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BJ Lumped Static	23607	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A072	21609	OFF*	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E400	21610	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E402	21611	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P192	21613	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BZ	21614	-	-	-	-	-	-	-	-	-	-	-
2BZ Lumped Motor	22614	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BZ Lumped Static	23614	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P010	24622	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC E419	21615	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	21617	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BS	21618	-	-	-	-	-	-	-	-	-	-	-
BS Lumped Motor	22618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BS Lumped Static	23618	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P160	24618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Stdby Dome Air Circ A073	21619	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON

\* Temporarily deenergized during transition to Emergency Diesel Generator power

E0825EQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lpm  
 IRE: Paul

SHEET NO. 155  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE III.AY : UNIT 2 ESF LOAD SCHEDULE FOR UNIT 2 DBA FED FROM EMERGENCY DIESEL GENERATOR

PAGE 4

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
4-KV BUS 2A04												
Cntmt Spray Pump P012	2403	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
AFW Pump P141	2404	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON
CCW Pump P024	2405	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2406	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON
Lo Press S I Pump P015	2407	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P017	2408	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018*	2409	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P112	2410	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P307	2411	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON
Aux Bldg Chiller E336	2412	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Non-1E UPS*	2416	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
Loadcenter 2B04	2420	-	-	-	-	-	-	-	-	-	-	-
4-KV BUS 2A06												
AFW Pump P504	2603	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON
Cntmt Spray Pump P013	2604	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
CCW Pump P026	2605	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2606	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON
Lo Press S I Pump P016	2607	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P019	2608	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018*	2609	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P113	2610	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P114	2611	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON
Aux Bldg Chiller E335	2612	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Loadcenter 2B06	2620	-	-	-	-	-	-	-	-	-	-	-

\*Additional loads that are started manually during post accident steady state conditions.

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

CCN 9

ORIGINATOR: Lpm  
 IRE: RJ  
 SHEET NO. 156  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE III.AY : UNIT 2 ESF LOAD SCHEDULE FOR UNIT 2 DBA FED FROM EMERGENCY DIESEL GENERATOR

PAGE 5

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)									POST ACC
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B04												
Press Htr E615-E618**	21402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 2BRA	21403	-	-	-	-	-	-	-	-	-	-	-
2BRA Lumped Motor	22403	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRA Lumped Static	23403	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	21405	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E145 Panel	21406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BD (DG-MCC)	21407	-	-	-	-	-	-	-	-	-	-	-
2BD Lumped Motor	22407	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BD Lumped Static	23407	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A274	24412	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON
EDG Bldg Fan A275	24413	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON
Radiator Fan E550	24421	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E546	24422	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A071	21409	OFF*	OFF*	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E399	21410	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E401	21411	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P190	21413	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BE	21414	-	-	-	-	-	-	-	-	-	-	-
2BE Lumped Motor	22414	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BE Lumped Static	23414	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BY	21415	-	-	-	-	-	-	-	-	-	-	-
2BY Lumped Motor	22415	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BY Lumped Static	23415	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P009	24434	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BQ	21417	-	-	-	-	-	-	-	-	-	-	-
BQ Lumped Motor	22417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BQ Lumped Static	23417	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P162	24417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC Unit E418	21418	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Stdby Dome Air Circ A074	21419	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON

\* Temporarily deenergized during transition to Emergency Diesel Generator power

E082SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

CCN 9

ORIGINATOR: Lpm  
 IRE: Ad

SHEET NO. 157  
 DATE: 9-20-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE III.AY : UNIT 2 ESF LOAD SCHEDULE FOR UNIT 2 DBA FED FROM EMERGENCY DIESEL GENERATOR

PAGE 6

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B06												
Pre Htr E627-E629/E622**	21602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 2BRB	21603	-	-	-	-	-	-	-	-	-	-	-
2BRB Lumped Motor	22603	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRB Lumped Static	23603	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BH (DG-MCC)	21605	-	-	-	-	-	-	-	-	-	-	-
2BH Lumped Motor	22605	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BH Lumped Static	23605	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E547	24606	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E549	24607	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A276	24611	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON
EDG Bldg Fan A277	24612	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON
H2 Recomb E146 Panel	21606	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BJ	21607	-	-	-	-	-	-	-	-	-	-	-
2BJ Lumped Motor	22607	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BJ Lumped Static	23607	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A072	21609	OFF*	OFF*	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E400	21610	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E402	21611	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P192	21613	OFF*	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BZ	21614	-	-	-	-	-	-	-	-	-	-	-
2BZ Lumped Motor	22614	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BZ Lumped Static	23614	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P010	24622	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC E419	21615	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	21617	OFF*	RESTART	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BS	21618	-	-	-	-	-	-	-	-	-	-	-
BS Lumped Motor	22618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BS Lumped Static	23618	OFF*	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P160	24618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Stdby Dome Air Circ A073	21619	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON

\* Temporarily deenergized during transition to Emergency Diesel Generator power

\*\*Additional loads that are started manually during post accident steady state conditions.

E082SEQX.WK1

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

CCN 9  
 SHEET NO. 158  
 DATE: 9-30-91  
 DATE: 10-5-94

ORIGINATOR: Lpm  
 IRE: Rd

TABLE 5.1 Contd...

CASE IV.BX: UNIT 2 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
4-KV BUS 2A04												
Cntmt Spray Pump P012	2403	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
AFW Pump P141	2404	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
CCW Pump P024	2405	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2406	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P015	2407	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P017	2408	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018	2409	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P112	2410	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P307	2411	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Aux Bldg Chiller E336	2412	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Non-1E UPS	2416	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Loadcenter 2B04	2420	-	-	-	-	-	-	-	-	-	-	-
4-KV BUS 2A06												
AFW Pump P504	2603	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Spray Pump P013	2604	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
CCW Pump P026	2605	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2606	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P016	2607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P019	2608	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018	2609	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P113	2610	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P114	2611	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Aux Bldg Chiller E335	2612	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Loadcenter 2B06	2620	-	-	-	-	-	-	-	-	-	-	-

\*DBA in Unit 3, Post Accident Loading in Unit 2.

CCH 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCH N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: CPM  
 IRE: BJ  
 SHEET NO. 159  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BX: UNIT 2 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B04												
Press Htr E615-E618	21402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BRA	21403	-	-	-	-	-	-	-	-	-	-	-
2BRA Lumped Motor	22403	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRA Lumped Static	23403	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	21405	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E145 Panel	21406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BD (DG-MCC)	21407	-	-	-	-	-	-	-	-	-	-	-
2BD Lumped Motor	22407	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BD Lumped Static	23407	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A274	24412	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A275	24413	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E550	24421	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E546	24422	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A071	21409	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E399	21410	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E401	21411	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P190	21413	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BE	21414	-	-	-	-	-	-	-	-	-	-	-
2BE Lumped Motor	22414	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BE Lumped Static	23414	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BY	21415	-	-	-	-	-	-	-	-	-	-	-
2BY Lumped Motor	22415	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BY Lumped Static	23415	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P009	24434	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BQ	21417	-	-	-	-	-	-	-	-	-	-	-
BQ Lumped Motor	22417	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
BQ Lumped Static	23417	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Chilled Wtr Pump P162	24417	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Control Rm AC Unit E418	21418	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Dome Air Circ A074	21419	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.



CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lpm  
 IRE: Red

SHEET NO. 160  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BX: UNIT 2 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 9

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B06												
Press Htr E627-E629/E622	21602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BRB	21603	-	-	-	-	-	-	-	-	-	-	-
2BRB Lumped Motor	22603	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRB Lumped Static	23603	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BH (DG-MCC)	21605	-	-	-	-	-	-	-	-	-	-	-
2BH Lumped Motor	22605	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BH Lumped Static	23605	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E547	24606	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E549	24607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A276	24611	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A277	24612	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E146 Panel	21606	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BJ	21607	-	-	-	-	-	-	-	-	-	-	-
2BJ Lumped Motor	22607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BJ Lumped Static	23607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A072	21609	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E400	21610	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E402	21611	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P192	21613	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BZ	21614	-	-	-	-	-	-	-	-	-	-	-
2BZ Lumped Motor	22614	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BZ Lumped Static	23614	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P010	24622	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC E419	21615	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Charging Pump P191	21617	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BS	21618	-	-	-	-	-	-	-	-	-	-	-
BS Lumped Motor	22618	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
BS Lumped Static	23618	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Chilled Wtr Pump P160	24618	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Dome Air Circ A073	21619	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: LRM  
 IRE: RL  
 SHEET NO. 161  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BX: UNIT 3 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 10

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
4-KV BUS 3A04												
Aux Bldg Chiller E336	3402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Cntmt Spray Pump P012	3403	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
AFW Pump P141	3404	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
CCW Pump P024***	3405	OFF	START	ON	ON	START	ON	ON	ON	ON	ON	ON
CCW Pump P025	3406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Lo Press S I Pump P015	3407	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P017	3408	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018**	3409	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P112	3410	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P307***	3411	OFF	START	ON	ON	ON	START	ON	ON	ON	ON	ON
Non-1E UPS**	3412	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
Loadcenter 3804	3417	-	-	-	-	-	-	-	-	-	-	-
4-KV BUS 3A06												
Aux Bldg Chiller E335	3602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Cntmt Spray Pump P013	3604	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
CCW Pump P026	3605	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025***	3606	OFF	START	ON	ON	START	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P016	3607	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P019	3608	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018**	3609	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P113	3610	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P114***	3611	OFF	START	ON	ON	ON	START	ON	ON	ON	ON	ON
AFW Pump P504	3612	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Loadcenter 3806	3619	-	-	-	-	-	-	-	-	-	-	-

\*DBA in Unit 3, Post Accident Loading in Unit 2.

E082SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

\*\*\*Restarted during sequencing to simulate starting of these motors at their designated starting times.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: CPM  
 IRE: Red  
 SHEET NO. 162  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BX: UNIT 3 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 11

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 3B04												
Press Htr E615-E618**	31402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 3BRA	31403	-	-	-	-	-	-	-	-	-	-	-
3BRA Lumped Motor	32403	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BRA Lumped Static	33403	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	31405	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E145 Panel	31406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 3BD (DG-MCC)	31407	-	-	-	-	-	-	-	-	-	-	-
3BD Lumped Motor	32407	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BD Lumped Static	33407	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A274***	34412	OFF	OFF	OFF	OFF	START	START	START	ON	ON	ON	ON
EDG Bldg Fan A275***	34413	OFF	OFF	OFF	OFF	START	START	START	ON	ON	ON	ON
Radiator Fan E550	34421	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Radiator Fan E546	34422	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Dome Air Circ A071***	31409	OFF	START	START	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E399	31410	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E401	31411	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P190	31413	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BE	31414	-	-	-	-	-	-	-	-	-	-	-
3BE Lumped Motor	32414	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BE Lumped Static	33414	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BY	31415	-	-	-	-	-	-	-	-	-	-	-
3BY Lumped Motor	32415	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BY Lumped Static	33415	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P009	34434	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BQ	31417	-	-	-	-	-	-	-	-	-	-	-
BQ Lumped Motor	32417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BQ Lumped Static	33417	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P162	34417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC Unit E418	31418	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A074***	31419	OFF	START	START	ON	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

E082SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

\*\*\*Restarted to simulate all possible starting times.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

SHEET NO. 163  
 ORIGINATOR: UPM  
 DATE: 9-30-94  
 IRE: RL  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BX: UNIT 3 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 3B06												
Press Htr E627-E630**	31602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 3BRB	31603	-	-	-	-	-	-	-	-	-	-	-
3BRB Lumped Motor	32603	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BRB Lumped Static	33603	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BH (DG-MCC)	31605	-	-	-	-	-	-	-	-	-	-	-
3BH Lumped Motor	32605	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BH Lumped Static	33605	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E547	34606	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
Radiator Fan E549	34607	OFF	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A276***	34611	OFF	OFF	OFF	OFF	START	START	START	ON	ON	ON	ON
EDG Bldg Fan A277***	34612	OFF	OFF	OFF	OFF	START	START	START	ON	ON	ON	ON
H2 Recomb E146 Panel	31606	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 3BJ	31607	-	-	-	-	-	-	-	-	-	-	-
3BJ Lumped Motor	32607	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BJ Lumped Static	33607	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A072***	31609	OFF	START	START	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E400	31610	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E402	31611	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P192	31613	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BZ	31614	-	-	-	-	-	-	-	-	-	-	-
3BZ Lumped Motor	32614	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BZ Lumped Static	33614	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P010	34622	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC Unit E419	31615	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	31617	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BS	31618	-	-	-	-	-	-	-	-	-	-	-
BS Lumped Motor	32618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BS Lumped Static	33618	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P160	34618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A073***	31619	OFF	START	START	ON	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

\*\*Additional loads that are started manually during post accident steady state conditions.

\*\*\*Restarted to simulate all possible starting times.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lpm  
 IRE: RL

SHEET NO. 164  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BY: UNIT 2 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
4-KV BUS 2A04												
Cntmt Spray Pump P012	2403	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
AFW Pump P141	2404	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
CCW Pump P024	2405	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2406	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P015	2407	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P017	2408	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018	2409	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P112	2410	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P307	2411	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Aux Bldg Chiller E336	2412	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Non-1E UPS	2416	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Loadcenter 2B04	2420	-	-	-	-	-	-	-	-	-	-	-
4-KV BUS 2A06												
AFW Pump P504	2603	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Spray Pump P013	2604	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
CCW Pump P026	2605	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025	2606	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Lo Press S I Pump P016	2607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P019	2608	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018	2609	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P113	2610	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P114	2611	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Aux Bldg Chiller E335	2612	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Loadcenter 2B06	2620	-	-	-	-	-	-	-	-	-	-	-

\*DBA in Unit 3, Post Accident Loading in Unit 2.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Gen  
 IRE: Red  
 SHEET NO. 165  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BY: UNIT 2 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 14

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B04												
Press Htr E615-E618	21402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BRA	21403	-	-	-	-	-	-	-	-	-	-	-
2BRA Lumped Motor	22403	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRA Lumped Static	23403	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	21405	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E145 Panel	21406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BD (DG-MCC)	21407	-	-	-	-	-	-	-	-	-	-	-
2BD Lumped Motor	22407	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BD Lumped Static	23407	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A274	24412	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A275	24413	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E550	24421	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E546	24422	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A071	21409	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E399	21410	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E401	21411	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P190	21413	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BE	21414	-	-	-	-	-	-	-	-	-	-	-
2BE Lumped Motor	22414	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BE Lumped Static	23414	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BY	21415	-	-	-	-	-	-	-	-	-	-	-
2BY Lumped Motor	22415	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BY Lumped Static	23415	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P009	24434	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BQ	21417	-	-	-	-	-	-	-	-	-	-	-
BQ Lumped Motor	22417	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
BQ Lumped Static	23417	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Chilled Wtr Pump P162	24417	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Control Rm AC Unit E418	21418	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Dome Air Circ A074	21419	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

SHEET NO. 166  
 ORIGINATOR: UPM  
 DATE: 9-30-94  
 IRE: Red  
 DATE: 10-5-94

TABLE 5.1 Contd...

CASE IV.BY: UNIT 2 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 15

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 2B06												
Press Htr E627-E629/E622	21602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BRB	21603	-	-	-	-	-	-	-	-	-	-	-
2BRB Lumped Motor	22603	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BRB Lumped Static	23603	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BH (DG-MCC)	21605	-	-	-	-	-	-	-	-	-	-	-
2BH Lumped Motor	22605	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BH Lumped Static	23605	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E547	24606	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E549	24607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A276	24611	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A277	24612	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E146 Panel	21606	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 2BJ	21607	-	-	-	-	-	-	-	-	-	-	-
2BJ Lumped Motor	22607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BJ Lumped Static	23607	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A072	21609	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E400	21610	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E402	21611	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P192	21613	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 2BZ	21614	-	-	-	-	-	-	-	-	-	-	-
2BZ Lumped Motor	22614	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
2BZ Lumped Static	23614	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P010	24622	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC E419	21615	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Charging Pump P191	21617	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BS	21618	-	-	-	-	-	-	-	-	-	-	-
BS Lumped Motor	22618	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
BS Lumped Static	23618	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Chilled Wtr Pump P160	24618	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Dome Air Circ A073	21619	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lpm  
 IRE: Red  
 SHEET NO. 167  
 DATE: 9-30-94  
 DATE: 10-5-99

TABLE 5.1 Contd...

CASE IV.BY: UNIT 3 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 16

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)									POST ACC
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
4-KV BUS 3A04												
Aux Bldg Chiller E336	3402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Cntmt Spray Pump P012	3403	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
AFW Pump P141	3404	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON
CCW Pump P024***	3405	OFF	START	ON	ON	ON	START	ON	ON	ON	ON	ON
CCW Pump P025	3406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Lo Press S I Pump P015	3407	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P017	3408	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018**	3409	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P112	3410	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P307***	3411	OFF	START	ON	ON	ON	START	ON	ON	ON	ON	ON
Non-IE UPS**	3412	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
Loadcenter 3B04	3417	-	-	-	-	-	-	-	-	-	-	-
4-KV BUS 3A06												
Aux Bldg Chiller E335	3602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON
Cntmt Spray Pump P013	3604	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
CCW Pump P026	3605	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
CCW Pump P025***	3606	OFF	START	ON	ON	ON	START	ON	ON	ON	ON	ON
Lo Press S I Pump P016	3607	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P019	3608	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Hi Press S I Pump P018**	3609	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START
SWC Pump P113	3610	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
SWC Pump P114***	3611	OFF	START	ON	ON	ON	START	ON	ON	ON	ON	ON
AFW Pump P504	3612	OFF	OFF	OFF	OFF	OFF	OFF	OFF	START	ON	ON	ON
Loadcenter 3B06	3619	-	-	-	-	-	-	-	-	-	-	-

\*DBA in Unit 3, Post Accident Loading in Unit 2.

E0B2SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

\*\*\*Restarted during sequencing to simulate starting of these motors at their designated starting times.



CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: Lpm  
 IRE: Rd  
 SHEET NO. 168  
 DATE: 9-30-94  
 DATE: 10-5-99

TABLE 5.1 Contd...

CASE IV.BY: UNIT 3 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 17

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)								POST ACC	
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 3B04												
Press Htr E615-E618**	31402	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 3BRA	31403	-	-	-	-	-	-	-	-	-	-	-
3BRA Lumped Motor	32403	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BRA Lumped Static	33403	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	31405	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
H2 Recomb E145 Panel	31406	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 3BD (DG-MCC)	31407	-	-	-	-	-	-	-	-	-	-	-
3BD Lumped Motor	32407	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BD Lumped Static	33407	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A274***	34412	OFF	OFF	OFF	OFF	OFF	START	START	START	START	ON	ON
EDG Bldg Fan A275***	34413	OFF	OFF	OFF	OFF	OFF	START	START	START	START	ON	ON
Radiator Fan E550	34421	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E546	34422	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A071***	31409	OFF	START	ON	START	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E399	31410	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E401	31411	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P190	31413	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BE	31414	-	-	-	-	-	-	-	-	-	-	-
3BE Lumped Motor	32414	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BE Lumped Static	33414	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BY	31415	-	-	-	-	-	-	-	-	-	-	-
3BY Lumped Motor	32415	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BY Lumped Static	33415	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P009	34434	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BQ	31417	-	-	-	-	-	-	-	-	-	-	-
BQ Lumped Motor	32417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BQ Lumped Static	33417	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P162	34417	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC Unit E418	31418	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A074***	31419	OFF	START	ON	START	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

E082SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

\*\*\*Restarted to simulate all possible starting times.

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

ORIGINATOR: LPM  
 IRE: And

SHEET NO. 169  
 DATE: 9-30-94  
 DATE: 10-5-94

CCN 9

TABLE 5.1 Contd...

CASE IV.BY: UNIT 3 ESF LOAD SCHEDULE FOR DBA IN BOTH UNITS - FED FROM 2XU1\*

PAGE 18

EQUIPMENT	PSSE BUS #	INIT COND	Agastat Time Delay Relay Operating Times (seconds)									POST ACC
			0	2.5	7.5	12.5	17.5	22.5	27.5	32.5		
480-V BUS 3B06												
Press Htr E627-E630**	31602	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON
MCC 3BRB	31603	-	-	-	-	-	-	-	-	-	-	-
3BRB Lumped Motor	32603	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BRB Lumped Static	33603	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BH (DG-MCC)	31605	-	-	-	-	-	-	-	-	-	-	-
3BH Lumped Motor	32605	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BH Lumped Static	33605	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E547	34606	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Radiator Fan E549	34607	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
EDG Bldg Fan A276***	34611	OFF	OFF	OFF	OFF	OFF	START	START	START	START	ON	ON
EDG Bldg Fan A277***	34612	OFF	OFF	OFF	OFF	OFF	START	START	START	START	ON	ON
H2 Recomb E146 Panel	31606	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
MCC 3BJ	31607	-	-	-	-	-	-	-	-	-	-	-
3BJ Lumped Motor	32607	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BJ Lumped Static	33607	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A072***	31609	OFF	START	ON	START	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E400	31610	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Cntmt Emergency Fan E402	31611	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Charging Pump P192	31613	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC 3BZ	31614	-	-	-	-	-	-	-	-	-	-	-
3BZ Lumped Motor	32614	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
3BZ Lumped Static	33614	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Spent Fuel Pump P010	34622	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Control Rm AC Unit E419	31615	OFF	OFF	OFF	START	ON	ON	ON	ON	ON	ON	ON
Charging Pump P191	31617	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
MCC BS	31618	-	-	-	-	-	-	-	-	-	-	-
BS Lumped Motor	32618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
BS Lumped Static	33618	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chilled Wtr Pump P160	34618	OFF	START	ON	ON	ON	ON	ON	ON	ON	ON	ON
Dome Air Circ A073***	31619	OFF	START	ON	START	ON	ON	ON	ON	ON	ON	ON

\*DBA in Unit 3, Post Accident Loading in Unit 2.

E082SEQX.WK1

\*\*Additional loads that are started manually during post accident steady state conditions.

\*\*\*Restarted to simulate all possible starting times.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 170 OF 453

CCN CONVERSION  
CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>LM</i> 9-30-94	A. M. PATEL	<i>AM</i> 10-5-99					

<p><b>TABLE 5.2</b></p> <p>Motor Operated Valve (MOV) Data</p>
--

CCN 9

SONGS 2 AND 3  
CALCULATION NO. E4C-082, REV 1, CCN N-3  
SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: UPM  
IRE: And  
SHEET NO. 171  
DATE: 9-30-94  
DATE: 10-5-99

TABLE 5.2

UNIT 2 TRAIN A MOV MOTOR PARAMETERS

PAGE 1

M O V	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 2BRA -				
2HV-4763: P141 Discharge Bypass	-	0.750	1.44	1.91
2HV-0396: Shutdown Cooling Control	SMB-1	1.000	1.91	2.55
2HV-8161: Shutdown Cooling Bypass Control	SMB-1	2.600	4.98	6.64
2HV-8163: LPSI Pump P016 Mini Recirculation	SMB-000	0.670	1.28	1.71

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

E082MOV.WK1

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: Cpm  
 IRE: Red  
 SHEET NO. 172  
 DATE: 9-30-94  
 DATE: 10-5-99

TABLE 5.2 Contd...

UNIT 2 TRAIN A MOV MOTOR PARAMETERS

PAGE 2

M O V	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 2BE -				
2HV-4713: AFW To Steam Generator Control	SMB-000	0.130	0.25	0.33
2HV-9334: SI Tank Drain To RWST	SMB-00	1.330	2.55	3.40
2HV-9350: SI Tank T007 To RC Loop 1B	SB-1	5.300	10.15	13.53
2HV-9360: SI Tank T009 To RC Loop 2A	SB-1	5.300	10.15	13.53
2HV-9325: Lo Pressure SI Header To RC Loop 1B	SMB-1	2.600	4.98	6.64
2HV-9328: Lo Pressure SI Header To RC Loop 2A	SMB-1	2.600	4.98	6.64
2HV-9201: Auxiliary Spray To Pressurizer	SMB-000	0.330	0.63	0.84
2HV-9327: Hi Pressure SI Header To RC Loop 1B	SMB-00	0.700	1.34	1.79
2HV-9330: Hi Pressure SI Header To RC Loop 2A	SMB-00	0.700	1.34	1.79
2HV-6223: CCW Containment Inlet Isolation	SMB-000	0.330	0.63	0.84
2HV-9324: Hi Pressure SI Header To RC Loop 1A	SMB-00	0.700	1.34	1.79
2HV-9333: Hi Pressure SI Header To RC Loop 2B	SMB-00	0.700	1.34	1.79
2HV-9337: Shutdown Flow From RC Loop 2	SB-4	9.900	18.96	25.28
2HV-0516: RC Drain Tank Containment Isolation	SMB-000	0.125	0.24	0.32
2HV-7512: Containment Isol RC Drain To Radwaste	SMB-000	0.125	0.24	0.32
2HV-9367: Shutdown Heat Exch To Spray Header 1	SMB-00	1.300	2.49	3.32
2HV-0514: Quench Tk Vap Sample Containment Isol	SMB-000	0.125	0.24	0.32
2HV-5803: Containment Sump To Radwaste Sump	SMB-000	0.125	0.24	0.32
2HV-9949: Containment Purge Inlet	SMB-0	3.200	6.13	8.17
2HV-9305: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
2HV-4731: AFW To Steam Generator E089 Isolation	-	1.000	1.91	2.55
2HV-8150: Shutdown Cooling Sys Heat Exch Outlet	SMB-1	1.000	1.91	2.55
2HV-8152: Shutdown Cooling Sys Heat Exch Inlet	SMB-1	2.600	4.98	6.64
2HV-6366: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2HV-6367: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2HV-6236: CCW Non-Critical Containment Isol	SMB-000	0.330	0.63	0.84
2HV-6370: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2HV-6371: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
CALCULATION NO. E4C-082, REV 1, CCN N-3  
SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: CPM  
IRE: RL  
SHEET NO. 173  
DATE: 9-30-94  
DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 2 TRAIN A MOV MOTOR PARAMETERS

MOV	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 2BY -				
2HV-9306: Safety Injection Pump Miniflow	SMB-00	0.330	0.63	0.84
2HV-9307: Safety Injection Pump Miniflow	SMB-00	0.330	0.63	0.84
2HV-9247: BA Pumps To Charging Pump Suction	SMB-00	0.700	1.34	1.79
2HV-9379: Shutdown Cooling Flow To LPSI	SB-0	3.200	6.13	8.17
2HV-9353: Shutdown Cooling Warm-Up	SMB-00	0.170	0.33	0.43
2HV-9303: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
2HV-9420: Hi Pressure SI Header To RC Loop 2	SMB-00	0.670	1.28	1.71
2HV-6497: Saltwater From CCM Heat Exchanger	SMB-00	1.000	1.91	2.55
2HV-9300: Radwaste East Outlet	SB-1	5.300	10.15	13.53

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
CALCULATION NO. E4C-082, REV 1, CCN N-3  
SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: Lpm  
IRE: Aut

SHEET NO. 174  
DATE: 9-30-94  
DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 2 TRAIN B MOV MOTOR PARAMETERS		PAGE 4		
MOV	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 2BRB -				
2HV-4762: AFW Pump P504 Discharge	-	0.750	1.44	1.91
2HV-8160: Shutdown Cooling Heat Exch Bypass	SMB-1	1.000	1.91	2.55
2HV-8162: LPSI Pump P015 Mini Recirculation	SMB-000	0.700	1.34	1.79

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

EOB2MOV.WK1

CC19

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: LPm SHEET NO. 175  
 IRE: Red DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 2 TRAIN B MOV MOTOR PARAMETERS

PAGE 5

MOV	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 2BJ -				
2HV-9339: Shutdown Flow From RC Loop 2	SB-4	9.900	18.96	25.28
2HV-9340: SI Tank T008 To RC Loop 1A	SB-1	5.300	10.15	13.53
2HV-9370: SI Tank T010 To RC Loop 2B	SB-1	5.300	10.15	13.53
2HV-9347: SI Pump Minimum Recirculation	SMB-00	0.330	0.63	0.84
2HV-9322: Lo Pressure SI Header To RC Loop 1A	SMB-1	2.600	4.98	6.64
2HV-9331: Lo Pressure SI Header To RC Loop 2B	SMB-1	2.600	4.98	6.64
2HV-9348: SI Pump Minimum Recirculation	SMB-00	0.330	0.63	0.84
2HV-9323: Hi Pressure SI Header To RC Loop 1A	SMB-00	0.700	1.34	1.79
2HV-9332: Hi Pressure SI Header To RC Loop 2B	SMB-00	0.700	1.34	1.79
2HV-9217: RCP Bleed Off To VCT	SMB-000	0.125	0.24	0.32
2HV-9326: Hi Pressure SI Header To RC Loop 1B	SMB-00	0.700	1.34	1.79
2HV-9329: Hi Pressure SI Header To RC Loop 2A	SMB-00	0.700	1.34	1.79
2HV-7258: Containment Isol SI Tank Vent Header	SMB-000	0.125	0.24	0.32
2HV-0508: RC Hot Leg Sample Containment Isol	SMB-000	0.330	0.63	0.84
2HV-0517: RC Hot Leg Sample Containment Isol	SMB-000	0.330	0.63	0.84
2HV-9368: Shutdown Heat Exch To Spray Header 2	SMB-00	1.300	2.49	3.32
2HV-0510: Press Vapor Sample Containment Isol	SMB-000	0.333	0.64	0.85
2HV-0512: Press Surge Line Liquid Sample Isol	SMB-000	0.333	0.64	0.85
2HV-9950: Containment Purge Outlet	SMB-0	3.200	6.13	8.17
2HV-9917: H2 Purge Exhaust Inlet	SMB-000	0.125	0.24	0.32
2HV-9946: H2 Purge Supply Unit Discharge	SMB-000	0.125	0.24	0.32
2HV-9302: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
2HV-9304: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
2HV-6211: CCW To Containment	SMB-000	0.330	0.63	0.84
2HV-6368: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2HV-6369: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2HV-6216: CCW From Containment	SMB-000	0.330	0.63	0.84
2HV-6372: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2HV-6373: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
2LV-0227C: RWT Outlet To Charging Pump Header	SMB-00	0.700	1.34	1.79
2HV-9900: Containment Norm Cooling Supply Isol	SMB-000	0.330	0.63	0.84
2HV-9971: Containment Norm Cooling Return Isol	SMB-000	0.330	0.63	0.84

\*Based on 60% PF and 70% EFF. See Section 3.4.a.



CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN W-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: Urm  
 IRE: And

SHEET NO. 176  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 2 TRAIN B MOV MOTOR PARAMETERS

MOV	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 2B2 -				
2HV-4712: AFW Pump P504 Discharge Control	SMB-000	0.125	0.24	0.32
2HV-5686: Firewater Containment Isolation	SMB-000	0.125	0.24	0.32
2LV-0227B: VCT Drain Return	SMB-00	0.700	1.34	1.79
2HV-9235: BA Tank T072 To Chrging Pump Suction	SMB-00	0.700	1.34	1.79
2HV-9240: BA Tank T071 To Chrging Pump Suction	SMB-00	0.700	1.34	1.79
2HV-4714: AFW To Steam Generator E088 Isolation	-	1.000	1.91	2.55
2HV-9336: Shutdown Cooling Flow To LPSI	SMB-1	2.600	4.98	6.64
2HV-9359: Shutdown Cooling Warm-Up	SMB-00	0.170	0.33	0.43
2HV-9301: Radwaste West Outlet	SB-1	5.300	10.15	13.53
2HV-6495: Saltwater From CCW Heat Exchanger	SMB-00	1.000	1.91	2.55
2TV-9267: RC Regen Heat Exchanger Isolation	SB-00	1.000	1.91	2.55
2HV-8151: Shutdown Cooling Heat Exch Outlet	SMB-1	1.000	1.91	2.55
2HV-8153: Shutdown Cooling Heat Exch Inlet	SMB-1	2.600	4.98	6.64
2HV-9434: Hi Pressure SI To RC Loop 1	SMB-00	0.700	1.34	1.79

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: Lpm  
 IRE: and

CCN 9  
 SHEET NO. 177  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 3 TRAIN A MOV MOTOR PARAMETERS

PAGE 7

MOV	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 3BRA -				
3HV-4763: AFW Pump P141 Discharge Bypass	-	0.750	1.44	1.91
3HV-0396: Shutdown Cooling Control	SMB-1	1.000	1.91	2.55
3HV-8161: Shutdown Cooling Bypass Control	SMB-1	2.600	4.98	6.64
3HV-8163: LPSI Pump P016 Mini Recirculation	SMB-000	0.700	1.34	1.79

\*Based on 80% PF and 70% EFF. See Section 3.4.a.

E082MOV.WK1

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: CPM SHEET NO. 178  
 DATE: 9-30-94  
 IRE: Paul DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 3 TRAIN A MOV MOTOR PARAMETERS

PAGE 8

M O V	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 3BE -				
3HV-4713: AFW To Steam Generator Control	SMB-000	0.130	0.25	0.33
3HV-9334: SI Tank Drain To RWSY	SMB-00	1.330	2.55	3.40
3HV-9350: SI Tank T007 To RC Loop 1B	SB-1	5.300	10.15	13.53
3HV-9360: SI Tank T009 To RC Loop 2A	SB-1	5.300	10.15	13.53
3HV-9325: Lo Pressure SI Header To RC Loop 1B	SB-1	2.600	4.98	6.64
3HV-9328: Lo Pressure SI Header To RC Loop 2A	SB-1	2.600	4.98	6.64
3HV-9201: Auxiliary Spray To Pressurizer	SMB-000	0.330	0.63	0.84
3HV-9327: Hi Pressure SI Header To RC Loop 1B	SMB-00	0.700	1.34	1.79
3HV-9330: Hi Pressure SI Header To RC Loop 2A	SMB-00	0.700	1.34	1.79
3HV-6223: CCW Containment Inlet Isolation	SMB-000	0.330	0.63	0.84
3HV-9324: Hi Pressure SI Header To RC Loop 1A	SMB-00	0.700	1.34	1.79
3HV-9333: Hi Pressure SI Header To RC Loop 2B	SMB-00	0.700	1.34	1.79
3HV-9337: Shutdown Flow From RC Loop 2	SB-4	9.900	18.96	25.28
3HV-0516: RC Drain Tank Containment Isolation	SMB-000	0.125	0.24	0.32
3HV-7512: Containment Isol RC Drain To Radwaste	SMB-000	0.130	0.25	0.33
3HV-9367: Shutdown Heat Exch To Spray Header 1	SMB-00	1.300	2.49	3.32
3HV-0514: Quench Tk Vap Sample Containment Isol	SMB-000	0.125	0.24	0.32
3HV-5803: Containment Sump To Radwaste Sump	SMB-000	0.330	0.63	0.84
3HV-9949: Containment Purge Inlet	SMB-0	3.200	6.13	8.17
3HV-9305: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
3HV-4731: AFW To Steam Generator E089 Isolation	-	1.250	2.39	3.19
3HV-8150: Shutdown Cooling Sys Heat Exch Outlet	SMB-1	1.000	1.91	2.55
3HV-8152: Shutdown Cooling Sys Heat Exch Inlet	SMB-1	2.600	4.98	6.64
3HV-6366: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3HV-6367: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3HV-6236: CCW Non-Critical Containment Isol	SMB-000	0.330	0.63	0.84
3HV-6370: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3HV-6371: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

E082MOV.WK1

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: CPM  
 IRE: Paul  
 SHEET NO. 179  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 3 TRAIN A MOV MOTOR PARAMETERS

PAGE 9

M O V	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 3BY -				
3HV-9306: Safety Injection Pump Miniflow	SMB-00	0.330	0.63	0.84
3HV-9307: Safety Injection Pump Miniflow	SMB-00	0.330	0.63	0.84
3HV-9247: BA Pumps To Chrging Pump Suction	SMB-00	0.700	1.34	1.79
3HV-9379: Shutdown Cooling Flow To LPSI	SB-0	3.200	6.13	8.17
3HV-9353: Shutdown Cooling Warm-Up	SMB-00	1.900	3.64	4.85
3HV-9303: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
3HV-9420: Hi Pressure SI Header To RC Loop 2	SMB-00	0.700	1.34	1.79
3HV-6497: Saltwater From CCW Heat Exchanger	SMB-00	1.000	1.91	2.55
3HV-9300: Radwaste East Outlet	SB-1	5.200	9.96	13.28

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

E082MOV.WK1

CCN 9

SONGS 2 AND 3  
CALCULATION NO. E4C-082, REV 1, CCN N-3  
SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: LPm SHEET NO. 180  
DATE: 9-30-94  
IRE: RL DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 3 TRAIN B MOV MOTOR PARAMETERS

MOV	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 3BRB -				
3HV-4762: AFW Pump P504 Discharge	-	0.750	1.44	1.91
3HV-8160: Shutdown Cooling Heat Exch Bypass	SMB-1	1.000	1.91	2.55
3HV-8162: LPSI Pump P015 Mini Recirculation	SMB-000	0.700	1.34	1.79

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: LRM SHEET NO. 181  
 DATE: 9-30-94  
 IRE: RL DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 3 TRAIN B MOV MOTOR PARAMETERS

M O V	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 3BJ -				
3HV-9339: Shutdown Flow From RC Loop 2	SB-4	9.900	18.96	25.28
3HV-9340: SI Tank T008 To RC Loop 1A	SB-1	5.200	9.96	13.28
3HV-9370: SI Tank T010 To RC Loop 2B	SB-1	5.300	10.15	13.53
3HV-9347: SI Pump Minimum Recirculation	SMB-000	0.330	0.63	0.84
3HV-9322: Lo Pressure SI Header To RC Loop 1A	SMB-1	2.600	4.98	6.64
3HV-9331: Lo Pressure SI Header To RC Loop 2B	SMB-1	2.600	4.98	6.64
3HV-9348: SI Pump Minimum Recirculation	SMB-00	0.330	0.63	0.84
3HV-9323: Hi Pressure SI Header To RC Loop 1A	SMB-00	0.700	1.34	1.79
3HV-9332: Hi Pressure SI Header To RC Loop 2B	SMB-00	0.700	1.34	1.79
3HV-9217: RCP Bleed Off To VCT	SMB-000	0.125	0.24	0.32
3HV-9326: Hi Pressure SI Header To RC Loop 1B	SMB-00	0.700	1.34	1.79
3HV-9329: Hi Pressure SI Header To RC Loop 2A	SMB-00	0.700	1.34	1.79
3HV-7258: Containment Isol SI Tank Vent Header	SMB-000	0.130	0.25	0.33
3HV-0508: RC Hot Leg Sample Containment Isol	SMB-000	0.330	0.63	0.84
3HV-0517: RC Hot Leg Sample Containment Isol	SMB-000	0.330	0.63	0.84
3HV-9368: Shutdown Heat Exch To Spray Header 2	SMB-00	1.300	2.49	3.32
3HV-0510: Press Vapor Sample Containment Isol	SMB-000	0.330	0.63	0.84
3HV-0512: Press Surge Line Liquid Sample Isol	SMB-000	0.330	0.63	0.84
3HV-9950: Containment Purge Outlet	SMB-0	3.200	6.13	8.17
3HV-9917: H2 Purge Exhaust Inlet	SMB-000	0.125	0.24	0.32
3HV-9946: H2 Purge Supply Unit Discharge	SMB-000	0.130	0.25	0.33
3HV-9302: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
3HV-9304: Containment Emergency Sump Outlet	SMB-00	0.700	1.34	1.79
3HV-6211: CCW To Containment	SMB-000	0.330	0.63	0.84
3HV-6368: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3HV-6369: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3HV-6216: CCW From Containment	SMB-000	0.330	0.63	0.84
3HV-6372: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3HV-6373: CCW To Emergency Cooling Unit	SB-00S	1.900	3.64	4.85
3LV-0227C: RWT Outlet To Chrging Pump Header	SMB-00	0.700	1.34	1.79
3HV-9900: Containment Norm Cooling Supply Isol	SMB-000	0.330	0.63	0.84
3HV-9971: Containment Norm Cooling Return Isol	SMB-000	0.330	0.63	0.84

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCM N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING A DBA

RE: Lpm SHEET NO. 182  
 IRE: And DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.2 Contd...

UNIT 3 TRAIN B MOV MOTOR PARAMETERS

PAGE 12

M O V	SIZE	HP	EQUIV KW*	EQUIV KVAR*
- MCC 3B2 -				
3HV-4712: AFW Pump P504 Discharge Control	SMB-000	0.125	0.24	0.32
3HV-5686: Firewater Containment Isolation	SMB-000	0.130	0.25	0.33
3LV-0227B: VCT Drain Return	SMB-00	0.700	1.34	1.79
3HV-9235: BA Tank T072 To Charging Pump Suction	SMB-00	0.700	1.34	1.79
3HV-9240: BA Tank T071 To Charging Pump Suction	SMB-00	0.700	1.34	1.79
3HV-4714: AFW To Steam Generator E088 Isolation	-	2.000	3.83	5.11
3HV-9336: Shutdown Cooling Flow To LPSI	SMB-1	2.600	4.98	6.64
3HV-9359: Shutdown Cooling Warm-Up	SMB-00	0.170	0.33	0.43
3HV-9301: Radwaste West Outlet	SB-1	5.300	10.15	13.53
3HV-6495: Saltwater From CCW Heat Exchanger	SMB-00	1.000	1.91	2.55
3TV-9267: RC Regen Heat Exchanger Isolation	SB-00	1.000	1.91	2.55
3HV-8151: Shutdown Cooling Heat Exch Outlet	SMB-1	1.000	1.91	2.55
3HV-8153: Shutdown Cooling Heat Exch Inlet	SMB-1	2.600	4.98	6.64
3HV-9434: Hi Pressure SI To RC Loop 1	SMB-00	0.670	1.28	1.71

\*Based on 60% PF and 70% EFF. See Section 3.4.a.

E082MOV.WK1

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>183</b> OF <b>453</b>
CCN CONVERSION CCN NO. CCN - <b>9</b>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>LM</i> 9-30-94	A. M. PATEL	<i>AS</i> 10-5-94					

**TABLE 5.3**

Motor Control Center Load Schedule



SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Uem SHEET NO. 184  
 DATE: 9-30-94  
 IRE: Del DATE: 10-5-94

TABLE 5.3

UNIT 2 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BRA													
HV-4763: P141 Disch Valve Bypass	2BRA05	1.44	1.91	OFF	CLOSE	0.00	0.00	-	-	1.44	1.91	-	-
HV-0396: Shutdown Cooling Ctrl Valve	2BRA13	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8161: Shutdown Clg Bypass Ctrl Vlv	2BRA15	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8163: LPSI Pump P016 Min Recrc Vlv	2BRA16	1.28	1.71	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Panel 2Q074 15KVA Xfmr 2T074	2BRA22	4.25	2.63	ON	ON	-	-	4.25	2.63	-	-	4.25	2.63
MCC 2BRA EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	4.25	2.63				
MCC 2BRA EQUIVALENT LOADING ON ACCIDENT CONDITION										1.44	1.91	4.25	2.63

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

CCN 9



SONGS 2 AND 3

CALCULATION NO. E4C-082, REV 1, CCN N-3

SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm SHEET NO. 186  
 DATE: 9-30-94  
 IRE: Paul DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BE													
Fuel Handling Airborne Monitor RT7822	2BE02	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Fuel Handling Bldg Emergency Htr E464	2BE03	28.70	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
Battery Charger D3 (125V) B003	2BE04	66.49	49.87	ON	ON	-	-	66.49	49.87	-	-	66.49	49.87
HV-4713: AFW To Steam Gen Control	2BE06	0.25	0.33	OFF	OPEN	0.00	0.00	-	-	0.25	0.33	-	-
HV-9334: SI Tank Drain To RWST	2BE09	2.55	3.40	OFF	CLOSE	0.00	0.00	-	-	2.55	3.40	-	-
HV-9350: SI Tank T007 To RC Loop 1B	2BE10	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9360: SI Tank T009 To RC Loop 2A	2BE11	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9325: Lo Press SI Hdr To RC Loop 1B	2BE14	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9328: Lo Press SI Hdr To RC Loop 2A	2BE15	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9201: Aux Spray To Pressurizer	2BE17	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9327: Hi Press SI Hdr To RC Loop 1B	2BE18	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9330: Hi Press SI Hdr To RC Loop 2A	2BE19	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-6223: CCW Cntmt Inlet Isol Valve	2BE21	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9324: Hi Press SI Hdr To RC Loop 1A	2BE22	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9333: Hi Press SI Hdr To RC Loop 2B	2BE23	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9337: Shutdown Flow From RC Loop 2	2BE25	18.96	25.28	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-0516: RC Drain Tank Cntmt Isol Vlv	2BE26	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-7512: Cntmt Isol RC Drain To Rdwst	2BE27	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-9367: Shtdwn Ht Exch To Spray Hdr 1	2BE29	2.49	3.32	OFF	OPEN	0.00	0.00	-	-	2.49	3.32	-	-

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1. CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm SHEET NO. 187  
 DATE: 9-30-94  
 IRE: RL DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BE Contd...													
HV-0514: Quench Tk Vap Smp1 Cntmt Iso1	2BE30	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-5803: Cntmt Sump To Radwaste Sump	2BE31	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-9949: Containment Purge Inlet	2BE33	6.13	8.17	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9305: Cntmt Emerg Sump Outlet	2BE35	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-4731: AFW To Steam Gen E089 Iso1	2BE36	1.91	2.55	OFF	OPEN	0.00	0.00	-	-	1.91	2.55	-	-
HV-8150: Shtdwn Clg Sys Ht Exch Outlet	2BE38	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8152: Shtdwn Clg Sys Ht Exch Inlet	2BE39	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Containment Airborne Monitor RT7804	2BE41	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Boric Acid Make-up Heat Trace Pnl L266	2BE42	15.30	9.48	ON	ON	-	-	15.30	9.48	-	-	15.30	9.48
HV-6366: CCW To Emergency Cooling Unit	2BE44	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6367: CCW To Emergency Cooling Unit	2BE45	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
HV-6236: CCW Non-Critical Cntmt Iso1	2BE46	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-6370: CCW To Emergency Cooling Unit	2BE47	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6371: CCW To Emergency Cooling Unit	2BE48	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
Post Accident Cleanup Unit Heater E652	2BE49	3.80	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
Vital Bus Backup Panel 2Q063	2BE51	21.25	13.17	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
MCC 2BE EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	85.19	61.45				
MCC 2BE EQUIVALENT LOADING ON ACCIDENT CONDITION										32.02	42.70	85.19	61.45

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

CCN9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm SHEET NO. 188  
 DATE: 9-30-94  
 IRE: Red DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BY													
Battery Charger D1	2BY03	66.49	49.87	ON	ON	-	-	66.49	49.87	-	-	66.49	49.87
Intake Structure Cooling Fan A370	2BY07	3.18	2.14	OFF	START	0.00	0.00	-	-	3.18	2.14	-	-
Intake Structure Cooling Fan A373	2BY08	3.18	2.14	OFF	START	0.00	0.00	-	-	3.18	2.14	-	-
HV-9306: Safety Inject Pump Mini Flow	2BY09	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
CCW Seismic Make-Up Pump P1018	2BY10	6.58	4.25	OFF	ON	0.00	0.00	-	-	-	-	6.58	4.25
Boric Acid Makeup Emergency ACU E439	2BY11	0.97	1.02	OFF	START	0.00	0.00	-	-	0.97	1.02	-	-
Boric Acid Makeup Emergency ACU E440	2BY12	0.97	1.02	OFF	START	0.00	0.00	-	-	0.97	1.02	-	-
HV-9307: Safety Inject Pump Mini Flow	2BY13	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Boric Acid Makeup Pump P174***	2BY14	20.81	11.23	ON	ON	20.81	11.23	-	-	20.81	11.23	-	-
Boric Acid Makeup Pump P175	2BY15	20.81	11.23	OFF	START	0.00	0.00	-	-	20.81	11.23	-	-
HV-9247: BA Pumps To Chrg Pump Suction	2BY16	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
Control Room Essential Lighting**	2BY19	4.25	2.63	OFF	ON	-	-	0.00	0.00	-	-	4.25	2.63
Charging Pump Area Emergency ACU E437	2BY20	0.48	0.51	OFF	START	0.00	0.00	-	-	0.48	0.51	-	-
Charging Pump Area Emergency ACU E438	2BY21	0.97	1.02	OFF	START	0.00	0.00	-	-	0.97	1.02	-	-
Control Room Cabinet Emerg ACU E424	2BY22	6.58	4.25	OFF	START	0.00	0.00	-	-	6.58	4.25	-	-
EPPM Panel 2L411 (NON-1E)	2BY23	0.43	0.26	OFF	ON	-	-	0.00	0.00	-	-	0.43	0.26
Safety Equip Bldg Emergency ACU E417	2BY24	5.26	3.40	OFF	START	0.00	0.00	-	-	5.26	3.40	-	-
Safety Equip Bldg Emergency ACU E517	2BY25	0.87	0.75	OFF	START	0.00	0.00	-	-	0.87	0.75	-	-

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

\*\*CAN BE FED FROM TRAIN B (2BZ11).

\*\*\*RESTARTED AFTER THE LOSS OF BUS VOLTAGE CONDITION.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm SHEET NO. 189  
 DATE: 9-30-94  
 IRE: Red DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BY Contd...													
HV-9379: Shutdown Cooling Flow To LPSI	2BY26	6.13	8.17	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9353: Shutdown Cooling Warm-Up Vlv	2BY27	0.33	0.43	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9303: Containment Emerg Sump Outlet	2BY28	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9420: Hi Press SI Hdr To RC Loop 2	2BY29	1.28	1.71	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
CCW Bldg Pump Room Emergency ACU E453	2BY30	0.68	0.71	OFF	START	0.00	0.00	-	-	0.68	0.71	-	-
CCW Bldg Pump Room Emergency ACU E454	2BY31	0.74	0.77	OFF	START	0.00	0.00	-	-	0.74	0.77	-	-
OTSC Computer Inverter Assy 2Y010	2BY33	12.75	7.90	OFF	ON	-	-	0.00	0.00	-	-	12.75	7.90
Spent Fuel Pool Pump P009	2BY34	C MOTOR MODEL											
HV-6497: Saltwater From CCW Heat Exchg	2BY35	1.91	2.55	OFF	OPEN	0.00	0.00	-	-	1.91	2.55	-	-
Feedwater Pump Room Fan A394	2BY36	4.39	2.83	OFF	START	0.00	0.00	-	-	4.39	2.83	-	-
Fuel Handling Bldg Emergency ACU E441	2BY37	0.77	0.81	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Fuel Handling Bldg Accident ACU E370	2BY38	40.53	26.18	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Lo Press SI Pump P015 Encl Heaters	2BY39-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Hi Press SI Pump P017 Encl Heaters	2BY39-B	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Hi Press SI Pump P018 Encl Heaters**	2BY39-C	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
SWC Pump P112 Enclosure Heaters	2BY39-D	0.40	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
SWC Pump P307 Enclosure Heaters	2BY39-E	0.40	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.40	0.00

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

\*\*CAN BE FED FROM TRAIN B (2BZ37-B).

CCN 9

RE: LPm  
 IRE: And

SHEET NO. 190  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BY Contd...													
Fuel Bldg Acc ACU E370 Encl Heaters	2BY39-F	0.33	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.33	0.00
Spray Chem Add Pump P020 Encl Heaters	2BY39-G	0.14	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
AFW Pump P141 Enclosure Heaters	2BY39-H	0.66	0.00	ON	OFF	-	-	0.66	0.00	-	-	0.00	0.90
Containment Spray Pump P012 Encl Htrs	2BY40-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E399 Encl Heaters	2BY40-B	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Boric Acid Makeup Pump P174 Encl Htrs	2BY40-C	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Boric Acid Makeup Pump P175 Encl Htrs	2BY40-D	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Charging Pump P191 Enclosure Htrs**	2BY40-E	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E401 Encl Heaters	2BY40-F	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Charging Pump P190 Enclosure Heaters	2BY40-G	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
HV-9300: RWST East Outlet	2BY41	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	0.00	0.00
Motor & Strip Heater Panel 2Q039	2BY42	17.00	10.54	ON	ON	-	-	17.00	10.54	0.00	0.00	-	-
MCC 2BY EQUIVALENT LOADING ON INITIAL CONDITION						20.81	11.23	93.15	60.41				
MCC 2BY EQUIVALENT LOADING ON ACCIDENT CONDITION										73.14	47.36	108.23	75.45

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.  
 \*\*CAN BE FED FROM TRAIN B (2BZ38-G).

LPm





SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Uran SHEET NO. 192  
 DATE: 9-30-94  
 IRE: Ad DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BRB													
HV-4762: AFW Pump P504 Disch Valve	2BRB05	1.44	1.91	OFF	CLOSE	0.00	0.00	-	-	1.44	1.91	-	-
HV-8160: Shutdown Clg Ht Exch Bypass	2BRB15	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8162: LPSI Pump P015 Mini Recirc	2BRB16	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Panel 2Q075	2BRB22	4.25	2.63	ON	ON	-	-	4.25	2.63	-	-	4.25	2.63
MCC 2BRB EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	4.25	2.63				
MCC 2BRB EQUIVALENT LOADING ON ACCIDENT CONDITION										1.44	1.91	4.25	2.63

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm  
 IRE: And  
 SHEET NO. 193  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BH													
Diesel Fuel Transf Pump P094 Encl Htrs	2BH03-A	0.25	0.00	ON	OFF	-	-	0.25	0.00	-	-	0.00	0.00
Diesel Fuel Transf Pump P095 Encl Htrs	2BH03-B	0.25	0.00	ON	OFF	-	-	0.25	0.00	-	-	0.00	0.00
Diesel Radiator Fan E547 Encl Heaters	2BH03-C	0.77	0.00	ON	OFF	-	-	0.77	0.00	-	-	0.00	0.00
Diesel Radiator Fan E549 Encl Heaters	2BH03-D	0.77	0.00	ON	OFF	-	-	0.77	0.00	-	-	0.00	0.00
Diesel Radiator Fan E547	2BH06	CMOTOR MODEL											
Diesel Radiator Fan E549	2BH07	CMOTOR MODEL											
Diesel Fuel Transfer Pump P095	2BH08	0.73	0.76	OFF	START	0.00	0.00	-	-	0.73	0.76	-	-
Diesel Fuel Transfer Pump P094	2BH09	0.73	0.76	OFF	START	0.00	0.00	-	-	0.73	0.76	-	-
Diesel Bldg Emergency Supply Fan A276	2BH11	CMOTOR MODEL											
Diesel Bldg Emergency Supply Fan A277	2BH12	CMOTOR MODEL											
Diesel Generator Space Heater EG003	2BH17	1.50	0.00	ON	OFF	-	-	1.50	0.00	-	-	0.00	0.00
Diesel Generator Immersion Heater E656	2BH22	15.00	0.00	ON	OFF	-	-	15.00	0.00	-	-	0.00	0.00
Diesel Generator Immersion Heater E657	2BH23	15.00	0.00	ON	OFF	-	-	15.00	0.00	-	-	0.00	0.00
DG Lube Oil/Turbocharger P998/P1017**	2BH24	1.91	2.01	ON	ON	1.91	2.01	-	-	1.91	2.01	-	-
DG Lube Oil/Turbocharger P999/P1016**	2BH25	1.91	2.01	ON	ON	1.91	2.01	-	-	1.91	2.01	-	-
Strip Heater Panel 2Q023	2BH26	4.25	2.63	ON	ON	-	-	4.25	2.63	-	-	4.25	2.63
MCC 2BH EQUIVALENT LOADING ON INITIAL CONDITION						3.82	4.02	37.79	2.63				
MCC 2BH EQUIVALENT LOADING ON ACCIDENT CONDITION								5.28	5.54	4.25	2.63		

\*REFERENCE: CALCULATION E4C-086, REV 0.  
 \*\*RESTARTED AFTER THE LOSS OF BUS VOLTAGE CONDITION.

CCN 9

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BJ													
HV-9339: Shutdown Flow From RC Loop 2	2BJ05	18.96	25.28	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9340: SI Tank T008 To RC Loop 1A	2BJ06	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9370: SI Tank T010 To RC Loop 2B	2BJ07	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9347: SI Pump Minimum Recirculation	2BJ09	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9322: Lo Press SI Hdr To RC Loop 1A	2BJ10	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9331: Lo Press SI Hdr To RC Loop 2B	2BJ11	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9348: SI Pump Minimum Recirculation	2BJ13	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9323: Hi Press SI Hdr To RC Loop 1A	2BJ14	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9332: Hi Press SI Hdr To RC Loop 2B	2BJ15	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9217: RCP Bleed Off To VC	2BJ17	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-9326: Hi Press SI Hdr To RC Loop 1B	2BJ18	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9329: Hi Press SI Hdr To RC Loop 2A	2BJ19	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-7258: Cntmt Isol SI Tank Int Hdr	2BJ21	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-0508: RC Hot Leg Sample Cntmt Isol	2BJ22	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-0517: RC Hot Leg Sample Cntmt Isol	2BJ23	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9368: Shtdm Ht Exch To Spray Hdr 2	2BJ25	2.49	3.32	OFF	OPEN	0.00	0.00	-	-	2.49	3.32	-	-
HV-0510: Pressr Vapor Smp1 Cntmt Isol	2BJ26	0.64	0.85	OFF	CLOSE	0.00	0.00	-	-	0.64	0.85	-	-
HV-0512: Pressr Surge Ln Liq Smp1 Isol	2BJ27	0.64	0.85	OFF	CLOSE	0.00	0.00	-	-	0.64	0.85	-	-
HV-9950: Containment Purge Outlet	2BJ29	6.13	8.17	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9917: H2 Purge Exhaust Inlet	2BJ30	0.24	0.32	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-

\*REFERENCE: TABLE 5.2.

*CPM 9*

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm SHEET NO. 195  
 DATE: 9-30-94  
 IRE: RL DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BJ Contd...													
HV-9946: H2 Purge Supply Unit Disch	2BJ31	0.24	0.32	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9302: Cntmt Emergency Sump Outlet	2BJ33	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9304: Cntmt Emergency Sump Outlet	2BJ34	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6211: CCW To Containment	2BJ35	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-6368: CCW To Emergency Cooling Unit	2BJ37	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6369: CCW To Emergency Cooling Unit	2BJ38	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
HV-6216: CCW From Containment	2BJ39	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-6372: CCW To Emergency Cooling Unit	2BJ41	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6373: CCW To Emergency Cooling Unit	2BJ42	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
LV-0227C: RWT Outlet To Chrg Pump Hdr	2BJ43	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
Fuel Handling Vent Air Monitor RT7823	2BJ44	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Fuel Handling Bldg Emergency Htr E465	2BJ45	32.30	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
Battery Charger D4	2BJ46	66.49	49.87	ON	ON	-	-	66.49	49.87	-	-	66.49	49.87
HV-9900: Cntmt Normal Clg Supply Isol	2BJ47	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9971: Cntmt Normal Clg Return Isol	2BJ48	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
Containmet Airborne Monitor RT7807	2BJ49	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Boric Acid Make-up Heat Trace Pnl L267	2BJ50	5.10	3.16	ON	ON	-	-	5.10	3.16	-	-	5.10	3.16
Vital Bus Backup Panel 2Q062	2BJ51	21.25	13.17	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
MCC 2BJ EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	74.99	55.13				
MCC 2BJ EQUIVALENT LOADING ON ACCIDENT CONDITION										31.97	42.63	74.99	55.13

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

CCN 9



TABLE 5.3 Contd...

UNIT 2 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BZ Contd...													
Safety Equip Bldg Emergency ACU E416	2BZ24	5.46	3.67	OFF	START	0.00	0.00	-	-	5.46	3.67	-	-
Safety Equip Bldg Emergency ACU E445	2BZ25	0.87	0.75	OFF	START	0.00	0.00	-	-	0.87	0.75	-	-
HV-9336: Shutdown Cooling Flow To LPSI	2BZ26	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9359: Shutdown Cooling Warm-Up Vlv	2BZ27	0.33	0.43	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9301: RWST West Outlet	2BZ28	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
CCW Bldg Pump Room Emergency ACU E455	2BZ29	0.74	0.77	OFF	START	0.00	0.00	-	-	0.74	0.77	-	-
Safety Equip Bldg Emergency ACU E518	2BZ30	0.87	0.91	OFF	START	0.00	0.00	-	-	0.87	0.91	-	-
HV-6495: Saltwater From CCW Heat Exch	2BZ31	1.91	2.55	OFF	OPEN	0.00	0.00	-	-	1.91	2.55	-	-
TV-9267: RC Regen Heat Exchanger Isol	2BZ32	1.91	2.55	OFF	CLOSE	0.00	0.00	-	-	1.91	2.55	-	-
Fuel Handling Bldg Emergency ACU E442	2BZ33	0.77	0.81	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Fuel Handling Bldg Accident ACU E371	2BZ34	40.53	26.18	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8151: Shtdm Clg Heat Exch Outlet	2BZ35	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8153: Shtdm Clg Heat Exch Inlet	2BZ36	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Lo Press SI Pump P016 Encl Heaters	2BZ37-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Hi Press SI Pump P018 Encl Htrs**	2BZ37-B	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Hi Press SI Pump P019 Encl Heaters	2BZ37-C	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
SWC Pump P113 Enclosure Heaters	2BZ37-D	0.40	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

\*\*CAN BE FED FROM TRAIN A (2BY39-C).

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: UPM SHEET NO. 198  
 DATE: 9-30-94  
 IRE: DL DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 2 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 2BZ Contd...													
SWC Pump P114 Enclosure Heaters	2BZ37-E	0.40	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.40	0.00
Fuel Bldg Acc ACU E371 Enc1 Heaters	2BZ37-F	0.33	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.33	0.00
AFW Pump P504 Enclosure Heaters	2BZ37-H	0.66	0.00	ON	OFF	-	-	0.66	0.00	-	-	0.00	0.00
Spray Chem Addn Pump P021 Enc1 Heater	2BZ37-I	0.14	0.00	ON	OFF	-	-	0.14	0.00	-	-	0.00	0.00
Containment Spray Pump P013 Enc1 Htrs	2BZ38-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E400 Enc1 Heaters	2BZ38-B	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E402 Enc1 Heaters	2BZ38-C	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Charging Pump P192 Enclosure Heaters	2BZ38-E	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Chrg Pump P191 Enclosure Heaters**	2BZ38-G	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
HV-9434: H1 Press SI To RC Loop 1	2BZ39	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Motor & Strip Heater Panel 2Q041	2BZ40	12.75	7.90	ON	ON	-	-	12.75	7.90	-	-	12.75	7.90
MCC 2BZ EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	88.80	57.77				
MCC 2BZ EQUIVALENT LOADING ON ACCIDENT CONDITION										36.95	32.65	120.13	81.27

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-086, REV 0, FOR OTHER LOADS.

\*\*CAN BE FED FROM TRAIN A (2BY40-E).

LOW 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCM N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: UPM SHEET NO. 199  
 DATE: 9-30-94  
 IRE: And DATE: 10-5-94

TABLE 5.3 Contd...

COMMON TRAIN B ESF LOAD SCHEDULE - SONGS 2 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER BS**													
Control Room Airborne Monitor RT7825	BS03	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Control Bldg Emerg Vent Elect Htr E296	BS04	4.80	0.00	OFF	ON	-	-	0.00	0.00	-	-	4.80	0.00
Chiller E335 Pumpout W309A	BS05	1.86	1.45	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Battery Room Emerg Exhaust Fan U2 A174	BS07	2.55	1.71	OFF	START	0.00	0.00	-	-	2.55	1.71	-	-
ESF Switchgear Room Emerg ACU U2 E257	BS08	7.68	4.55	OFF	START	0.00	0.00	-	-	7.68	4.55	-	-
Control Room Emergency Supply Fan A206	BS09	5.04	2.99	OFF	START	0.00	0.00	-	-	5.04	2.99	-	-
Fire Act & Det Ctrl Dist Pnl 2L-414***	BS11	12.75	7.90	OFF	ON	-	-	0.00	0.00	-	-	12.75	7.90
Fire Act & Det Ctrl Dist Pnl 3L-414***	BS12	12.75	7.90	OFF	ON	-	-	0.00	0.00	-	-	12.75	7.90
Battery Room Emerg Exhaust Fan U3 A174	BS14	2.55	1.71	OFF	START	0.00	0.00	-	-	2.55	1.71	-	-
ESF Switchgear Room Emerg ACU U3 E257	BS15	7.68	4.55	OFF	START	0.00	0.00	-	-	7.68	4.55	-	-
Chiller E335 Oil Pump P444	BS16	1.45	1.24	OFF	START	0.00	0.00	-	-	1.45	1.24	-	-
Ctrl Bldg Chiller Rm Supply Fan A054	BS18	2.73	1.83	OFF	START	0.00	0.00	-	-	2.73	1.83	-	-
Ctrl Bldg Chiller Rm Exhaust Fan A055	BS19	0.93	0.72	OFF	START	0.00	0.00	-	-	0.93	0.72	-	-
Ctrl Bldg Emerg Chilled Wtr Pump P160	BS20												
Strip Heater Panel Q035	BS22	6.38	3.95	ON	ON	-	-	6.38	3.95	-	-	6.38	3.95
MCC BS EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	8.08	5.00				
MCC BS EQUIVALENT LOADING ON ACCIDENT CONDITION								30.61	19.30	38.38	26.80		

\*REFERENCE: CALCULATION E4C-086, REV 0.  
 \*\*POWERED FROM EITHER UNIT 2 OR UNIT 3.  
 \*\*\*NON-CLASS 1E.

6009



SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm SHEET NO. 200  
 DATE: 9-30-94  
 IRE: Phil DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BRA													
HV-4763: AFW Pump P141 Disch Valve	3BRA05	1.44	1.91	OFF	CLOSE	0.00	0.00	-	-	1.44	1.91	-	-
HV-0396: Shutdown Cooling Ctrl Valve	3BRA13	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8161: Shutdown Clg Bypass Ctrl Vlv	3BRA15	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8163: LPSI Pump P016 Min Recrc Vlv	3BRA16	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Panel 3Q074	3BRA22	4.25	2.63	ON	ON	-	-	4.25	2.63	-	-	4.25	2.63
MCC 3BRA EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	4.25	2.63				
MCC 3BRA EQUIVALENT LOADING ON ACCIDENT CONDITION								1.44	1.91	4.25	2.63		

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.

CCN 9



SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

SHEET NO. 202  
 RE: Lpm DATE: 9-30-94  
 IRE: And DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BE													
Fuel Handling Vent Air Monitor RT7822	3BE02	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Fuel Handling Bldg Emergency Htr E464	3BE03	28.70	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
Battery Charger D3, B003	3BE04	66.49	49.87	ON	ON	-	-	66.49	49.87	-	-	66.49	49.87
HV-4713: AFW To Steam Gen Control	3BE06	0.25	0.33	OFF	OPEN	0.00	0.00	-	-	0.25	0.33	-	-
HV-9334: SI Tank Drain To RWST	3BE09	2.55	3.40	OFF	CLOSE	0.00	0.00	-	-	2.55	3.40	-	-
HV-9350: SI Tank T007 To RC Loop 1B	3BE10	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9360: SI Tank T009 To RC Loop 2A	3BE11	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9325: Lo Press SI Hdr To RC Loop 1B	3BE14	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9328: Lo Press SI Hdr To RC Loop 2A	3BE15	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9201: Aux Spray To Pressurizer	3BE17	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9327: Hi Press SI Hdr To RC Loop 1B	3BE18	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9330: Hi Press SI Hdr To RC Loop 2A	3BE19	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-6223: CCW Cntmt Inlet Isol Valve	3BE21	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9324: Hi Press SI Hdr To RC Loop 1A	3BE22	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9333: Hi Press SI Hdr To RC Loop 2B	3BE23	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9337: Shutdown Flow From RC Loop 2	3BE25	18.96	25.28	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-0516: RC Drain Tank Cntmt Isol Vlv	3BE26	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-7512: Cntmt Isol RC Drain To Rdwst	3BE27	0.25	0.33	OFF	CLOSE	0.00	0.00	-	-	0.25	0.33	-	-
HV-9367: Shtdwn Ht Exch To Spray Hdr 1	3BE29	2.49	3.32	OFF	OPEN	0.00	0.00	-	-	2.49	3.32	-	-

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.

*CCN 9*

RE: Uem  
 IRE: And

SHEET NO. 203  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KV	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BE Contd...													
HV-0514: Quench Tk Vap Smp1 Cntmt Iso1	3BE30	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-5803: Cntmt Sump To Radwaste Sump	3BE31	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9949: Containment Purge Inlet	3BE33	6.13	8.17	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9305: Cntmt Emergency Sump Outlet	3BE35	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-4731: AFW To Steam Gen E089 Iso1	3BE36	2.39	3.19	OFF	OPEN	0.00	0.00	-	-	0.00	0.00	-	-
HV-8150: Shtdwn Clg Sys Ht Exch Outlet	3BE38	1.91	2.55	OFF	OFF	0.00	0.00	-	-	2.39	3.19	-	-
HV-8152: Shtdwn Clg Sys Ht Exch Inlet	3BE39	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Containment Airborne Monitor RT7804	3BE41	1.70	1.05	ON	ON	-	-	1.70	1.05	0.00	0.00	-	-
Boric Acid Make-up Heat Trace Pnl L266	3BE42	15.30	9.48	ON	ON	-	-	15.30	9.48	-	-	15.30	9.48
HV-6366: CCW To Emergency Cooling Unit	3BE44	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6367: CCW To Emergency Cooling Unit	3BE45	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
HV-6236: CCW Non-Critical Cntmt Iso1	3BE46	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-6370: CCW To Emergency Cooling Unit	3BE47	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6371: CCW To Emergency Cooling Unit	3BE48	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	0.00	0.00	-	-
Post Accident Cleanup Unit Heater E652	3BE49	3.80	0.00	OFF	OFF	-	-	0.00	0.00	3.64	4.85	-	-
Vital Bus Backup Panel 3Q063	3BE51	21.25	13.17	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
MCC 3BE EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	85.19	61.45				
MCC 3BE EQUIVALENT LOADING ON ACCIDENT CONDITION										32.90	43.87	85.19	61.45

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.

DEN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: LPM SHEET NO. 204  
 DATE: 9-30-94  
 IRE: DL DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BY													
Battery Charger D1, B001	3BY03	66.49	49.87	ON	ON	-	-	66.49	49.87	-	-	66.49	49.87
Intake Structure Cooling Fan A370	3BY07	3.18	2.14	OFF	START	0.00	0.00	-	-	3.18	2.14	-	-
Intake Structure Cooling Fan A373	3BY08	3.18	2.14	OFF	START	0.00	0.00	-	-	3.18	2.14	-	-
HV-9306: Safety Inject Pump Mini Flow	3BY09	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
CCW Seismic Make-Up Pump P1018	3BY10	6.58	4.25	OFF	ON	0.00	0.00	-	-	-	-	6.58	4.25
Boric Acid Makeup Emergency ACU E439	3BY11	0.97	1.02	OFF	START	0.00	0.00	-	-	0.97	1.02	-	-
Boric Acid Makeup Emergency ACU E440	3BY12	0.97	1.02	OFF	START	0.00	0.00	-	-	0.97	1.02	-	-
HV-9307: Safety Inject Pump Mini Flow	3BY13	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Boric Acid Makeup Pump P174***	3BY14	20.81	11.23	ON	ON	20.81	11.23	-	-	20.81	11.23	-	-
Boric Acid Makeup Pump P175	3BY15	20.81	11.23	OFF	START	0.00	0.00	-	-	20.81	11.23	-	-
HV-9247: BA Pumps To Chrg Pump Suction	3BY16	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
Cont Rm Essential Lighting 3LP35**	3BY19	4.25	2.63	OFF	ON	-	-	0.00	0.00	-	-	4.25	2.63
Charging Pump Area Emergency ACU E437	3BY20	0.48	0.51	OFF	START	0.00	0.00	-	-	0.46	0.51	-	-
Charging Pump Area Emergency ACU E438	3BY21	0.97	1.02	OFF	START	0.00	0.00	-	-	0.97	1.02	-	-
Control Room Cabinet Emerg ACU E427	3BY22	6.58	4.25	OFF	START	0.00	0.00	-	-	6.58	4.25	-	-
EPPM Panel 3L411 (NON-1E)	3BY23	0.43	0.26	OFF	ON	-	-	0.00	0.00	-	-	0.43	0.26
Safety Equip Bldg Emergency ACU E417	3BY24	5.26	3.40	OFF	START	0.00	0.00	-	-	5.26	3.40	-	-
Safety Equip Bldg Emergency ACU E517	3BY25	0.87	0.75	OFF	START	0.00	0.00	-	-	0.87	0.75	-	-

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.  
 \*\*CAN BE FED FROM TRAIN B (3BZ11).  
 \*\*\*RESTARTED AFTER THE LOSS OF BUS VOLTAGE CONDITION.

6209



RE: LPN  
 IRE: Paul

SHEET NO. 206  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN A ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BY Contd...													
Fuel Bldg Acc ACU E370 Enc1 Heaters	3BY39-F	0.33	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.33	0.00
AFW Pump P141 Enclosure Heaters	3BY39-H	0.66	0.00	ON	OFF	-	-	0.66	0.00	-	-	0.00	0.00
Containment Spray Pump P012 Enc1 Htrs	3BY40-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E399 Enc1 Heaters	3BY40-B	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Boric Acid Makeup Pump P174 Enc1 Htrs	3BY40-C	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Boric Acid Makeup Pump P175 Enc1 Htrs	3BY40-D	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Chrg Pump P191 Enclosure Heaters**	3BY40-E	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E401 Enc1 Heaters	3BY40-F	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Charging Pump P190 Enclosure Heaters	3BY40-G	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
HV-9300: RWST East Outlet	3BY41	9.96	13.28	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Motor & Strip Heater Panel 3Q039	3BY42	17.00	10.54	ON	ON	-	-	17.00	10.54	-	-	17.00	10.54
MCC 3BY EQUIVALENT LOADING ON INITIAL CONDITION						20.81	11.23	93.15	60.41				
MCC 3BY EQUIVALENT LOADING ON ACCIDENT CONDITION								73.14	47.36	108.23	75.45		

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.

\*\*CAN BE FED FROM TRAIN B (3BZ38-G).

LPN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCM N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: UPM SHEET NO. 207  
 DATE: 9-30-94  
 IRE: Aut DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BRB													
HV-4762: AFW Pump P504 Disch Valve	3BRB05	1.44	1.91	OFF	CLOSE	0.00	0.00	-	-	1.44	1.91	-	-
HV-8160: Shutdown Clg Ht Exch Bypass	3BRB15	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8162: LPSI Pump P015 Mini Recirc Panel 3Q075	3BRB16 3BRB22	1.34 4.25	1.79 2.63	OFF ON	OFF ON	0.00 -	0.00 -	- 4.25	- 2.63	0.00 -	0.00 -	- 4.25	- 2.63
MCC 3BRB EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	4.25	2.63				
MCC 3BRB EQUIVALENT LOADING ON ACCIDENT CONDITION								1.44	1.91	4.25	2.63		

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.

CCM 9



SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Uem  
 IRE: Paul  
 SHEET NO. 208  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BH													
Diesel Fuel Transf Pump P094 Encl Htrs	3BH03-A	0.25	0.00	ON	OFF	-	-	0.25	0.00	-	-	0.00	0.00
Diesel Fuel Transf Pump P095 Encl Htrs	3BH03-B	0.25	0.00	ON	OFF	-	-	0.25	0.00	-	-	0.00	0.00
Diesel Radiator Fan E547 Encl Heaters	3BH03-C	0.77	0.00	ON	OFF	-	-	0.77	0.00	-	-	0.00	0.00
Diesel Radiator Fan E549 Encl Heaters	3BH03-D	0.77	0.00	ON	OFF	-	-	0.77	0.00	-	-	0.00	0.00
Diesel Radiator Fan E547	3BH06	CMOTOR MODEL											
Diesel Radiator Fan E549	3BH07	CMOTOR MODEL											
Diesel Fuel Transfer Pump P095	3BH08	0.73	0.76	OFF	START	0.00	0.00	-	-	0.73	0.76	-	-
Diesel Fuel Transfer Pump P094	3BH09	0.73	0.76	OFF	START	0.00	0.00	-	-	0.73	0.76	-	-
Diesel Bldg Emergency Supply Fan A276	3BH11	CMOTOR MODEL											
Diesel Bldg Emergency Supply Fan A277	3BH12	CMOTOR MODEL											
Diesel Generator Space Heater EG003	3BH17	1.50	0.00	ON	OFF	-	-	1.50	0.00	-	-	0.00	0.00
Diesel Generator Immersion Heater E656	3BH22	15.00	0.00	ON	OFF	-	-	15.00	0.00	-	-	0.00	0.00
Diesel Generator Immersion Heater E657	3BH23	15.00	0.00	ON	OFF	-	-	15.00	0.00	-	-	0.00	0.00
DG Lube Oil/Turbocharger P998/P1017**	3BH24	1.91	2.01	ON	ON	1.91	2.01	-	-	1.91	2.01	-	-
DG Lube Oil/Turbocharger P999/P1015**	3BH25	1.91	2.01	ON	ON	1.91	2.01	-	-	1.91	2.01	-	-
Strip Heater Panel 3Q023	3BH26	4.25	2.63	ON	ON	-	-	4.25	2.63	-	-	4.25	2.63
MCC 3BH EQUIVALENT LOADING ON INITIAL CONDITION						3.82	4.02	37.79	2.63				
MCC 3BH EQUIVALENT LOADING ON ACCIDENT CONDITION								5.28	5.54	4.25	2.63		

CCN 9

\*REFERENCE: CALCULATION E4C-087, REV 0.  
 \*\*RESTARTED AFTER THE LOSS OF BUS VOLTAGE CONDITION.

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm  
 DATE: 9-30-94  
 IRE: Red  
 SHEET NO. 209  
 DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BJ													
HV-9339: Shutdown Flow From RC Loop 2	3BJ05	18.96	25.28	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9340: SI Tank T008 To RC Loop 1A	3BJ06	9.96	13.28	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9370: SI Tank T008 To RC Loop 2B	3BJ07	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9347: SI Pump Minimum Recirculation	3BJ09	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9322: Lo Press SI Hdr To RC Loop 1A	3BJ10	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9331: Lo Press SI Hdr To RC Loop 2B	3BJ11	4.98	6.64	OFF	OPEN	0.00	0.00	-	-	4.98	6.64	-	-
HV-9348: SI Pump Minimum Recirculation	3BJ13	0.63	0.84	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9323: Hi Press SI Hdr To RC Loop 1A	3BJ14	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9332: Hi Press SI Hdr To RC Loop 2B	3BJ15	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9217: RCP Bleed Off To VCT	3BJ17	0.24	0.32	OFF	CLOSE	0.00	0.00	-	-	0.24	0.32	-	-
HV-9326: Hi Press SI Hdr To RC Loop 1B	3BJ18	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-9329: Hi Press SI Hdr To RC Loop 2A	3BJ19	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
HV-7258: Cntmt iso1 SI Tank Vent Hdr	3BJ21	0.25	0.33	OFF	CLOSE	0.00	0.00	-	-	0.25	0.33	-	-
HV-0508: RC Hot Leg Sample Cntmt Iso1	3BJ22	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-0517: RC Hot Leg Sample Cntmt Iso1	3BJ23	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9368: Shtdwn Ht Exch To Spray Hdr 2	3BJ25	2.49	3.32	OFF	OPEN	0.00	0.00	-	-	2.49	3.32	-	-
HV-0510: Pressr Vapor Smp1 Cntmt Iso1	3BJ26	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-0512: Pressr Surge Ln Liq Smp1 Iso1	3BJ27	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9950: Containment Purge Outlet	3BJ29	6.13	8.17	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9917: H2 Purge Exhaust Inlet	3BJ30	0.24	0.32	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-

\*REFERENCE: TABLE 5.2.

*Handwritten signature*

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BJ Contd...													
HV-9946: H2 Purge Supply Unit Disch	3BJ31	0.25	0.33	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9302: Cntmt Emergency Sump Outlet	3BJ33	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9304: Cntmt Emergency Sump Outlet	3BJ34	1.34	1.79	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6211: CCW To Containment	3BJ35	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-6368: CCW To Emergency Cooling Unit	3BJ37	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6369: CCW To Emergency Cooling Unit	3BJ38	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
HV-6216: CCW From Containment	3BJ39	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-6372: CCW To Emergency Cooling Unit	3BJ41	3.64	4.85	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-6373: CCW To Emergency Cooling Unit	3BJ42	3.64	4.85	OFF	OPEN	0.00	0.00	-	-	3.64	4.85	-	-
LV-0227C: RWT Outlet To Chrg Pump Hdr	3BJ43	1.34	1.79	OFF	OPEN	0.00	0.00	-	-	1.34	1.79	-	-
Fuel Handling Vent Air Monitor RT7823	3BJ44	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Fuel Handling Bldg Emergency Htr E465	3BJ45	32.30	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
Battery Charger D4, B004	3BJ46	66.49	49.87	ON	ON	-	-	66.49	49.87	-	-	66.49	49.87
HV-9900: Cntmt Normal Clg Supply Isol	3BJ47	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
HV-9971: Cntmt Normal Clg Return Isol	3BJ48	0.63	0.84	OFF	CLOSE	0.00	0.00	-	-	0.63	0.84	-	-
Containmet Airborne Monitor RT7807	3BJ49	1.70	1.05	ON	ON	-	-	1.70	1.05	-	-	1.70	1.05
Boric Acid Make-up Heat Trace Pnl L267	3BJ50	5.10	3.16	ON	ON	-	-	5.10	3.16	-	-	5.10	3.16
Vital Bus Backup Panel 3Q062	3BJ51	21.25	13.17	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00
MCC 3BJ EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	74.99	55.13				
MCC 3BJ EQUIVALENT LOADING ON ACCIDENT CONDITION										31.96	42.62	74.99	55.13

CCN 9

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.



TABLE 5.3 Contd...

UNIT 3 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	S T A T U S		I N I T I A L C O N D I T I O N				A C C I D E N T C O N D I T I O N L O A D S			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BZ Contd...													
Safety Equip Bldg Emergency ACU E416	3BZ24	5.46	3.67	OFF	START	0.00	0.00	-	-	5.46	3.67	-	-
Safety Equip Bldg Emergency ACU E445	3BZ25	0.87	0.75	OFF	START	0.00	0.00	-	-	0.87	0.75	-	-
HV-9336: Shutdown Cooling Flow To LPSI	3BZ26	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9350: Shutdown Cooling Warm-Up Vlv	3BZ27	0.33	0.43	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-9301: RWST West Outlet	3BZ28	10.15	13.53	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
CCW Bldg Pump Room Emergency ACU E455	3BZ29	0.68	0.71	OFF	START	0.00	0.00	-	-	0.68	0.71	-	-
Safety Equip Bldg Emergency ACU E518	3BZ30	0.87	0.91	OFF	START	0.00	0.00	-	-	0.87	0.91	-	-
HV-6495: Saltwater From CCW Heat Exch	3BZ31	1.91	2.55	OFF	OPEN	0.00	0.00	-	-	1.91	2.55	-	-
TV-9267: RC Regen Heat Exchanger Isol	3BZ32	1.91	2.55	OFF	CLOSE	0.00	0.00	-	-	1.91	2.55	-	-
Fuel Handling Bldg Emergency ACU E442	3BZ33	0.77	0.81	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Fuel Handling Bldg Accident ACU E371	3BZ34	40.53	26.18	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8151: Shtdwn Clg Heat Exch Outlet	3BZ35	1.91	2.55	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
HV-8153: Shtdwn Clg Heat Exch Inlet	3BZ36	4.98	6.64	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Lo Press SI Pump P016 Enc1 Heaters	3BZ37-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Hi Press SI Pump P018 Enc1 Heaters**	3BZ37-B	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Hi Press SI Pump P019 Enc1 Heaters	3BZ37-C	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
SWC Pump P113 Enclosure Heaters	3BZ37-D	0.40	0.00	OFF	OFF	-	-	0.00	0.00	-	-	0.00	0.00

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.  
 \*\*CAN BE FED FROM TRAIN A (3BY39-C).

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: LRM SHEET NO. 2/3  
 DATE: 9-30-94  
 IRE: Red DATE: 10-5-94

TABLE 5.3 Contd...

UNIT 3 MCC TRAIN B ESF LOAD SCHEDULE - SONGS 3 DESIGN BASIS EVENTS

EQUIPMENT	BREAKER	EQUIV KW*	EQUIV KVAR*	STATUS		INITIAL CONDITION				ACCIDENT CONDITION LOADS			
				INITIAL COND	ACC COND	MOTOR LOAD		STATIC LOAD		STARTING MOTOR		STATIC+RUNNING	
						KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
MOTOR CONTROL CENTER 3BZ Contd...													
SWC Pump P114 Enclosure Heaters	3BZ37-E	0.40	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.40	0.00
Fuel Bldg Acc ACU E371 Enc1 Heaters	3BZ37-F	0.33	0.00	OFF	ON	-	-	0.00	0.00	-	-	0.33	0.00
AFW Pump P504 Enclosure Heaters	3BZ37-H	0.66	0.00	ON	OFF	-	-	0.66	0.00	-	-	0.00	0.00
Containment Spray Pump P013 Enc1 Htrs	3BZ38-A	2.00	0.00	ON	OFF	-	-	2.00	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E400 Enc1 Heaters	3BZ38-B	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Cntmt Bldg Emerg ACU E402 Enc1 Heaters	3BZ38-C	0.26	0.00	ON	OFF	-	-	0.26	0.00	-	-	0.00	0.00
Charging Pump P192 Enclosure Heaters	3BZ38-E	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
Chrg Pump P191 Enclosure Heaters**	3BZ38-G	0.12	0.00	ON	OFF	-	-	0.12	0.00	-	-	0.00	0.00
HV-9434: HI Press SI To RC Loop 1	3BZ39	1.28	1.71	OFF	OFF	0.00	0.00	-	-	0.00	0.00	-	-
Motor & Strip Heater Panel 3Q041	3BZ40	12.75	7.90	ON	ON	-	-	12.75	7.90	-	-	12.75	7.90
MCC 3BZ EQUIVALENT LOADING ON INITIAL CONDITION						0.00	0.00	88.66	57.77				
MCC 3BZ EQUIVALENT LOADING ON ACCIDENT CONDITION								38.82	35.16	120.13	81.27		

\*REFERENCE: TABLE 5.2 FOR MOVs, CALCULATION E4C-087, REV 0, FOR OTHER LOADS.  
 \*\*CAN BE FED FROM TRAIN A (3BY40-E).

629

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>214</b> OF <b>453</b>
---	-------------------------------

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>LM</i> 9-30-94	A. M. PATEL	<i>AP</i> 10-5-94					

**TABLE 5.4**

Equivalent MCC Starting Motor Inertia

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN M-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm SHEET NO. 215  
 DATE: 9-30-94  
 IRE: Rac DATE: 10-5-94

TABLE 5.4

UNIT 2 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

PAGE 1

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BRA								
HV-4763: P141 Disch Valve Bypass	0.750	0.055	1.000	0.055	0.110	0.60	0.70	1.3321
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					32.610			16.640
EQUIVALENT MCC 2BRA INERTIA CONSTANT								1.467

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-086, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.



CCN9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCM W-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: CCM SHEET NO. 216  
 IRE: IRE DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BD								
DG Lube Oil/Turbocharger P996/P1015	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
DG Lube Oil/Turbocharger P997/P1014	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
Diesel Fuel Transfer Pump P093	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
Diesel Fuel Transfer Pump P096	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					33.028			23.660
EQUIVALENT MCC 2BD INERTIA CONSTANT								1.045

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-086, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm  
 IRE: Real  
 SHEET NO. 217  
 DATE: 9-20-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BE								
HV-4713: AFW To Steam Gen Control	0.130	0.055	1.000	0.055	0.110	0.60	0.70	0.2309
HV-9334: SI Tank Drain To RWST	1.330	0.060	1.000	0.060	0.120	0.60	0.70	2.3623
HV-9325: Lo Press SI Hdr To RC Loop 1B	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9328: Lo Press SI Hdr To RC Loop 2A	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9327: Hi Press SI Hdr To RC Loop 1B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9330: Hi Press SI Hdr To RC Loop 2A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-6223: CCW Cntmt Inlet Isol Valve	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-9324: Hi Press SI Hdr To RC Loop 1A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9333: Hi Press SI Hdr To RC Loop 2B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-0516: RC Drain Tank Cntmt Isol Vlv	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-7512: Cntmt Isol RC Drain To Rdwst	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-9367: Shtdm Ht Exch To Spray Hdr 1	1.300	0.060	1.000	0.060	0.120	0.60	0.70	2.3090
HV-0514: Quench Tk Vap SmpI Cntmt Isol	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-5803: Cntmt Sump To Radwaste Sump	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-4731: AFW To Steam Gen E089 Isol	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
HV-6367: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
HV-6236: CCW Non-Critical Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6371: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					35.208			45.006
EQUIVALENT MCC 2BE INERTIA CONSTANT								0.586

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-086, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN M-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm  
 IRE: Sal  
 SHEET NO. 218  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BY								
Intake Structure Cooling Fan A370	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Intake Structure Cooling Fan A373	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Boric Acid Makeup Emergency ACU E439	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Boric Acid Makeup Emergency ACU E440	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Boric Acid Makeup Pump P174	25.000	2.380	1.000	2.380	4.760	0.88	0.86	24.6432
Boric Acid Makeup Pump P175	25.000	2.380	1.000	2.380	4.760	0.88	0.86	24.6432
HV-9247: BA Pumps To Chrg Pump Suction	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
Charging Pump Area Emergency ACU E437	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Charging Pump Area Emergency ACU E438	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Control Room Cabinet Emerg ACU E424	7.500	0.620	8.000	4.960	5.580	0.84	0.85	7.8361
Safety Equip Bldg Emergency ACU E417	7.500	0.620	8.000	4.960	5.580	0.84	0.85	7.8361
Safety Equip Bldg Emergency ACU E517	1.500	0.060	8.000	0.480	0.540	0.76	0.77	1.9122
CCW Bldg Pump Room Emergency ACU E453	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
CCW Bldg Pump Room Emergency ACU E454	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
HV-6497: Saltwater From CCW Heat Exchg	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
Feedwater Pump Room Fan A394	7.250	0.620	25.000	15.500	16.120	0.84	0.85	7.5749
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					89.150			112.159
EQUIVALENT MCC 2BY INERTIA CONSTANT								0.595

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-086, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN M-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Urm  
 IRE: Red  
 SHEET NO. 219  
 DATE: 9-30-94  
 DATE: 10-5-99

TABLE 5.4 Contd...

COMMON TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC BQ								
Battery Room Emerg Exhaust Fan U2 A173	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
ESF Switchgear Room Emerg ACU U2 E255	10.000	0.770	8.000	6.160	6.930	0.86	0.85	10.2052
Control Room Emergency Supply Fan A207	10.000	0.770	25.000	19.250	20.020	0.86	0.85	10.2052
Battery Room Emerg Exhaust Fan U3 A173	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
ESF Switchgear Room Emerg ACU U3 E255	10.000	0.770	8.000	6.160	6.930	0.86	0.85	10.2052
Chiller E336 Oil Pump P445	1.500	0.060	1.000	0.060	0.120	0.76	0.77	1.9122
Cntrl Bldg Chiller Rm Supply Fan A053	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Cntrl Bldg Chiller Rm Exhaust Fan A056	2.000	0.077	25.000	1.925	2.002	0.79	0.80	2.3608
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					92.682			66.638
EQUIVALENT MCC BQ INERTIA CONSTANT								1.041

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-086, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm SHEET NO. 220  
 IRE: Paul DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

PAGE 6

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BRB								
2HV-4762: AFW Pump P504 Disch Valve	0.750	0.055	1.000	0.055	0.110	0.60	0.70	1.3321
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					32.610			16.640
EQUIVALENT MCC 2BRB INERTIA CONSTANT								1.467

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-086, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: CPM  
 IRE: R.P.  
 SHEET NO. 221  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BH								
Diesel Fuel Transfer Pump P095	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
Diesel Fuel Transfer Pump P094	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
DG Lube Oil/Turbocharger P998/P1017	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
DG Lube Oil/Turbocharger P999/P1016	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					33.028			23.660
EQUIVALENT MCC 2BH INERTIA CONSTANT								1.045

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-086, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: CPM SHEET NO. 222  
 IRE: And DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BJ								
HV-9322: Lo Press SI Hdr To RC Loop 1A	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9331: Lo Press SI Hdr To RC Loop 2B	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9323: Hi Press SI Hdr To RC Loop 1A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9332: Hi Press SI Hdr To RC Loop 2B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9217: RCP Bleed Off To VCT	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-9326: Hi Press SI Hdr To RC Loop 1B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9329: Hi Press SI Hdr To RC Loop 2A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-7258: Cntmt Isol SI Tank Vent Hdr	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-0508: RC Hot Leg Sample Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-0517: RC Hot Leg Sample Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-9368: Shtdwn Ht Exch To Spray Hdr 2	1.300	0.060	1.000	0.060	0.120	0.60	0.70	2.3090
HV-0510: Pressr Vapor Smpl Cntmt Isol	0.333	0.055	1.000	0.055	0.110	0.60	0.70	0.5915
HV-0512: Pressr Surge Ln Liq Smpl Isol	0.333	0.055	1.000	0.055	0.110	0.60	0.70	0.5915
HV-6211: CCW To Containment	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6369: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
HV-6216: CCW From Containment	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6373: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
LV-0227C: RWT Outlet To Chrg Pump Hdr	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9900: Cntmt Normal Cig Supply Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-9971: Cntmt Normal Cig Return Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					35.418			44.963
EQUIVALENT MCC 2BJ INERTIA CONSTANT								0.590

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-086, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm  
 IRE: Rd  
 SHEET NO. 223  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 2 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 2BZ								
HV-4712: AFW Pump P504 Disch Control	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
Intake Structure Cooling Fan A371	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Intake Structure Cooling Fan A372	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
HV-5686: Firewater Contmt Isolation	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
LV-0227B: VCT Drain Return	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9235: BA Tk T072 To Chrg Pump Suct	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9240: BA Tk T071 To Chrg Pump Suct	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
Feedwater Pump Rm Fan A443	7.250	0.620	25.000	15.500	16.120	0.84	0.85	7.5749
Charging Pump Area Emergency ACU E435	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Charging Pump Area Emergency ACU E436	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Control Room Cabinet Emerg ACU E423	7.500	0.620	8.000	4.960	5.580	0.84	0.85	7.8361
HV-4714: AFW To E088 Isolation	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
Safety Equip Bldg Emergency ACU E416	5.000	0.310	8.000	2.480	2.790	0.83	0.82	5.4805
Safety Equip Bldg Emergency ACU E445	1.500	0.060	8.000	0.480	0.540	0.76	0.77	1.9122
CCW Bldg Pump Room Emergency ACU E455	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Safety Equip Bldg Emergency ACU E518	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
HV-6495: Saltwater From CCW Heat Exch	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
TV-9267: RC Regen Heat Exchanger Isol	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					76.510			64.191
EQUIVALENT MCC 2BZ INERTIA CONSTANT								0.892

EOB2WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-086, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.



CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN M-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: UPM  
 IRE: Red  
 SHEET NO. 224  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

COMMON TRAIN B MCC EQUIVALENT INERTIA CONSTANT PAGE 10

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC BS								
Battery Room Emerg Exhaust Fan U2 A174	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
ESF Switchgear Room Emerg ACU U2 E257	10.000	0.770	8.000	6.160	6.930	0.86	0.85	10.2052
Control Room Emergency Supply Fan A206	10.000	0.770	25.000	19.250	20.020	0.86	0.85	10.2052
Battery Room Emerg Exhaust Fan U3 A174	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
ESF Switchgear Room Emerg ACU U3 E257	10.000	0.770	8.000	6.160	6.930	0.86	0.85	10.2052
Chiller E335 Oil Pump P444	1.500	0.060	1.000	0.060	0.120	0.76	0.77	1.9122
Ctrl Bldg Chiller Rm Supply Fan A054	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Ctrl Bldg Chiller Rm Exhaust Fan A055	2.000	0.077	25.000	1.925	2.002	0.79	0.80	2.3608
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					92.682			66.638
EQUIVALENT MCC BS INERTIA CONSTANT								1.041

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-086, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN W-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: CPM  
 IRE: Ent  
 SHEET NO. 225  
 DATE: 9-30-94  
 DATE: 10-5-99

TABLE 5.4 Contd...

UNIT 3 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BRA								
HV-4763: P141 Disch Bypass	0.750	0.055	1.000	0.055	0.110	0.60	0.70	1.3321
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					32.610			16.640
EQUIVALENT MCC 3BRA INERTIA CONSTANT								1.467

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-087, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCM N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm  
 IRE: Paul  
 SHEET NO. 226  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 3 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BD								
DG Lube Oil/Turbocharger P996/P1015	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
DG Lube Oil/Turbocharger P997/P1014	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
Diesel Fuel Transfer Pump P093	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
Diesel Fuel Transfer Pump P096	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					33.028			23.660
EQUIVALENT MCC 3BD INERTIA CONSTANT								1.045

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-087, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN W-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: LRM  
 IRE: Rue  
 SHEET NO. 227  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 3 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BE								
HV-4713: AFW To Steam Gen Control	0.130	0.055	1.000	0.055	0.110	0.60	0.70	0.2309
HV-9334: SI Tank Drain To RWST	1.330	0.060	1.000	0.060	0.120	0.60	0.70	2.3623
HV-9325: Lo Press SI Hdr To RC Loop 1B	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9328: Lo Press SI Hdr To RC Loop 2A	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9327: Hi Press SI Hdr To RC Loop 1B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9330: Hi Press SI Hdr To RC Loop 2A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-6223: CCW Cntmt Inlet Isol Valve	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-9324: Hi Press SI Hdr To RC Loop 1A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9333: Hi Press SI Hdr To RC Loop 2B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-0516: RC Drain Tank Cntmt Isol Vlv	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-7512: Cntmt Isol RC Drain To Rdwst	0.130	0.055	1.000	0.055	0.110	0.60	0.70	0.2309
HV-9367: Shtdwn Ht Exch To Spray Hdr 1	1.300	0.060	1.000	0.060	0.120	0.60	0.70	2.3090
HV-0514: Quench Tk Vap SmpI Cntmt Isol	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-5803: Cntmt Sump To Radwaste Sump	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-4731: AFW To Steam Gen E089 Isol	1.250	0.060	1.000	0.060	0.120	0.60	0.70	2.2202
HV-6367: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
HV-6236: CCW Non-Critical Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6371: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					35.218			45.823
EQUIVALENT MCC 3BE INERTIA CONSTANT								0.575

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-087, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Urem  
 IRE: Red  
 SHEET NO. 228  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 3 TRAIN A MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BY								
Intake Structure Cooling Fan A370	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Intake Structure Cooling Fan A373	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Boric Acid Makeup Emergency ACU E439	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Boric Acid Makeup Emergency ACU E440	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Boric Acid Makeup Pump P174	25.000	2.380	1.000	2.380	4.760	0.88	0.86	24.6432
Boric Acid Makeup Pump P175	25.000	2.380	1.000	2.380	4.760	0.88	0.86	24.6432
HV-9247: BA Pumps To Chrg Pump Suction	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
Charging Pump Area Emergency ACU E437	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Charging Pump Area Emergency ACU E438	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Control Room Cabinet Emerg ACU E427	7.500	0.620	8.000	4.960	5.580	0.84	0.85	7.8361
Safety Equip Bldg Emergency ACU E417	7.500	0.620	8.000	4.960	5.580	0.84	0.85	7.8361
Safety Equip Bldg Emergency ACU E517	1.500	0.060	8.000	0.480	0.540	0.76	0.77	1.9122
CCW Bldg Pump Room Emergency ACU E453	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
CCW Bldg Pump Room Emergency ACU E454	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
HV-6497: Saltwater From CCW Heat Exchg	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
Feedwater Pump Room Fan A394	7.250	0.620	25.000	15.500	16.120	0.84	0.85	7.5749
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					89.150			112.159
EQUIVALENT MCC 3BY INERTIA CONSTANT								0.595

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-087, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN M-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Uem SHEET NO. 229  
 IRE: Paul DATE: 9-30-94  
 DATE: 10-5-99

TABLE 5.4 Contd...

UNIT 3 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

PAGE 15

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BRB								
2HV-4762: AFW Pump P504 Disch Bypass	0.750	0.055	1.000	0.055	0.110	0.60	0.70	1.3321
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					32.610			16.640
EQUIVALENT MCC 3BRB INERTIA CONSTANT								1.467

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-087, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Upm SHEET NO. 230  
 IRE: Red DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 3 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

PAGE 16

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BH								
Diesel Fuel Transfer Pump P095	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
Diesel Fuel Transfer Pump P094	1.000	0.055	1.000	0.055	0.110	0.69	0.77	1.4041
DG Lube Oil/Turbocharger P998/P1017	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
DG Lube Oil/Turbocharger P999/P1016	2.000	0.077	1.000	0.077	0.154	0.69	0.78	2.7722
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					33.028			23.660
EQUIVALENT MCC 3BH INERTIA CONSTANT								1.045

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-087, Rev. 0.

CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm  
 IRE: Rul  
 SHEET NO. 231  
 DATE: 9-30-94  
 DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 3 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTOR	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3BJ								
HV-9322: Lo Press SI Hdr To RC Loop 1A	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9331: Lo Press SI Hdr To RC Loop 2B	2.600	0.210	1.000	0.210	0.420	0.60	0.70	4.6181
HV-9323: Hi Press SI Hdr To RC Loop 1A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9332: Hi Press SI Hdr To RC Loop 2B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9217: RCP Bleed Off To VCT	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
HV-9326: Hi Press SI Hdr To RC Loop 1B	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9329: Hi Press SI Hdr To RC Loop 2A	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-7258: Cntmt Isol SI Tank Vent Hdr	0.130	0.055	1.000	0.055	0.110	0.60	0.70	0.2309
HV-0508: RC Hot Leg Sample Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-0517: RC Hot Leg Sample Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-9368: Shtdwn Ht Each To Spray Hdr 2	1.300	0.060	1.000	0.060	0.120	0.60	0.70	2.3090
HV-0510: Pressr Vapor Smpl Cntmt Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-0512: Pressr Surge Ln Liq Smpl Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6211: CCW To Containment	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6369: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
HV-6216: CCW From Containment	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-6373: CCW To Emergency Cooling Unit	1.900	0.077	1.000	0.077	0.154	0.60	0.70	3.3748
LV-0227C: RWT Outlet To Chrg Pump Hdr	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9900: Cntmt Normal Clg Supply Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
HV-9971: Cntmt Normal Clg Return Isol	0.330	0.055	1.000	0.055	0.110	0.60	0.70	0.5861
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					35.418			44.961
EQUIVALENT MCC 3BJ INERTIA CONSTANT								0.590

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF are taken from Calculation E4C-087, Rev. 0.



CCN 9

SONGS 2 AND 3  
 CALCULATION NO. E4C-082, REV 1, CCN N-3  
 SUBJECT: SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

RE: Lpm SHEET NO. 232  
 DATE: 9-30-94  
 IRE: Rud DATE: 10-5-94

TABLE 5.4 Contd...

UNIT 3 TRAIN B MCC EQUIVALENT INERTIA CONSTANT

STARTING MOTORS	HP	MOTOR INERTIA	INERTIA RATIO	LOAD INERTIA	TOTAL INERTIA	PF	EFF	RATED KVA
MCC 3B2								
HV-4712: AFW Pump P504 Disch Control	0.125	0.055	1.000	0.055	0.110	0.60	0.70	0.2220
Intake Structure Cooling Fan A371	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
Intake Structure Cooling Fan A372	5.000	0.310	25.000	7.750	8.060	0.83	0.82	5.4805
HV-5686: Firewater Cntmt Isolation	0.130	0.055	1.000	0.055	0.110	0.60	0.70	0.2309
LV-02278: VCT Drain Return	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9235: BA Tk T072 To Chrg Pump Suct	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
HV-9240: BA Tk T071 To Chrg Pump Suct	0.700	0.055	1.000	0.055	0.110	0.60	0.70	1.2433
Feedwater Pump Rm Fan A443	7.250	0.620	25.000	15.500	16.120	0.84	0.85	7.5749
Charging Pump Area Emergency ACU E435	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Charging Pump Area Emergency ACU E436	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Control Room Cabinet Emerg ACU E426	7.500	0.620	8.000	4.960	5.580	0.84	0.85	7.8361
HV-4714: AFW To E088 Isolation	2.000	0.077	1.000	0.077	0.154	0.60	0.70	3.5524
Safety Equip Bldg Emergency ACU E416	5.000	0.310	8.000	2.480	2.790	0.83	0.82	5.4805
Safety Equip Bldg Emergency ACU E445	1.500	0.060	8.000	0.480	0.540	0.76	0.77	1.9122
CCW Bldg Pump Room Emergency ACU E455	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
Safety Equip Bldg Emergency ACU E518	1.000	0.055	8.000	0.440	0.495	0.69	0.77	1.4041
HV-6495: Saltwater From CCW Heat Exch	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
TV-9267: RC Regen Heat Exchanger Isol	1.000	0.055	1.000	0.055	0.110	0.60	0.70	1.7762
Margin for future load growth	15.000	1.250	25.000	31.250	32.500	0.85	0.86	15.3078
TOTAL INERTIA & RATED KVA					76.554			65.977
EQUIVALENT MCC 3B2 INERTIA CONSTANT								0.868

E082WK2.WK1

- NOTE: 1. Refer to Section 3.4.c.  
 2. LOAD INERTIA is equivalent to MOTOR INERTIA x INERTIA RATIO.  
 3. PF and EFF, except for MOVs, are taken from Calculation E4C-087, Rev. 0.  
 4. MOV PF and EFF are 60% and 70% respectively. See Section 3.4.a.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>233</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

**6.0 REFERENCES:**

This CCN adds the following reference documents in the Reference Section (Section 6.0) of the base calculation. The specified reference numbers are arbitrarily assigned and are applicable to this CCN only. It does not replace the corresponding reference numbers in the base calculation:

- 6.1 NEDOTRAK Item No. 93070031 - Operability Of Emergency Diesel Generators Due To Load Sequence Overlapping Condition Per Information Notice IN 92-77.
- 6.2 Vendor Document S023-302-15-10-1 - Report of Transformer Tests, Purchase Order #6V2D001, Shop Order #24-34274S01.
- 6.3 Vendor Document S023-302-15-11-1 - Report of Transformer Tests, Purchase Order #6V2D001, Shop Order #24-34274S02.
- 6.4 Vendor Document S023-302-15-12-1 - Report of Transformer Tests, Purchase Order #6V2D001, Shop Order #24-34274S03.
- 6.5 Vendor Document S023-302-15-13-1 - Report of Transformer Tests, Purchase Order #6V2D001, Shop Order #24-3274S04.
- 6.6 Vendor Document S023-302-15-14-1 - Report of Transformer Tests, Purchase Order #6V2D001, Shop Order #24-3274S05.
- 6.7 FAX transmittal from Daniel R. Otto of Joy Technologies Inc. to Bill Lennartz of SCE, dated May 11, 1993 (Attachment 9.2.1).
- 6.8 Log Item BC-93-159 - New Inertia Data For E-418/E-419.
- 6.9 Log Item BC-93-205 - Single Train Operations Of Saltwater Cooling and Component Cooling Water Pumps.
- 6.10 DCP No. 2&3 6754.00SP, Rev. 0 - Pre-Lubrication Modification, Units 2&3 Diesel Generator Lube Oil System.
- 6.11 DCP No. 2&3 6742.07SM, Rev. 0 - CCW System Seismic Makeup Upgrade.
- 6.12 Regulatory Guide 1.9, Revision 3, July 1993 - Selection, Design, Qualification And Testing Of Emergency Diesel Generator Units Used As Class 1E Onsite Electric Power Systems At Nuclear Power Plants.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>234</b> OF <b>453</b>
CCN CONVERSION CCN NO. CCN - <b>9</b>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

- 6.13 Calculation E4C-086, Rev. 0 - SONGS 2 BECAP and PSS/E Data Development And Documentation.
- 6.14 Calculation E4C-087, Rev. 0 - SONGS 3 BECAP and PSS/E Data Development And Documentation.
- 6.15 Calculation E4C-090, Rev. 1 - SONGS 2&3 Auxiliary System Voltage Regulation.
- 6.16 Calculation E4C-098, Rev. 0 - SONGS 2&3 4-KV Switchgear Protective Relay Setting Calculations.
- 6.17 Calculation E4C-099, Rev. 0 - SONGS 2&3 Safety Related 480-V Power Circuit Breaker Settings.
- 6.18 ANSI Standard C50.41-1982 - American National Standard for Polyphase Induction Motors for Power Generating Stations.
- 6.19 System Operating Bulletin No. 17, Revised June 11, 1990, and Appendix Applying to San Onofre, Revised May 9, 1986.
- 6.20 Motor Application and Maintenance Handbook by Robert W Smeaton, Published by McGraw-Hill Book Co., San Francisco 1969.
- 6.21 Calculation DC-3128, Rev. 0 - SONGS 1 PTI Program Verification.

**7.0 NOMENCLATURE:**

All applicable items in the Nomenclature Section of the base calculation is valid for this CCN.

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. **N-3** PAGE **235** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

**8.0 COMPUTATIONS:**

**8.1 SONGS 2 LOADCENTER TRANSFORMER 2B04X & 2B06X EQUIVALENT CIRCUIT:**

Reference: Section 4.4

$$Z_{GIVEN} = 10.18 \% \text{ at } 1.5 \text{ MVA Base}$$

$$X/R = 7.0$$

Nominal Tap Voltage = 4155 V

$$Z_{GIVEN} = 0.0144 + j0.1008 \text{ P.U. at } 1.5 \text{ MVA Base}$$

$$Z_{INPUT} = Z_{GIVEN} \times \frac{MVA_{NEW}}{MVA_{OLD}} = (0.0144 + j0.1008) \times \frac{10}{1.5}$$

$$Z_{INPUT} = 0.096 + j0.672 \text{ P.U. at } 10 \text{ MVA Base}$$

$$\text{Transformation Ratio (Input)} = 4155/4160 = 0.9988$$

**8.2 SONGS 3 LOADCENTER TRANSFORMER 3B04X & 3B06X EQUIVALENT CIRCUIT:**

Reference: Section 4.4

$$Z_{GIVEN} = 10.18 \% \text{ at } 1.5 \text{ MVA Base}$$

$$X/R = 7.0$$

Nominal Tap Voltage = 4155 V

$$Z_{GIVEN} = 0.0144 + j0.1008 \text{ P.U. at } 1.5 \text{ MVA Base}$$

$$Z_{INPUT} = Z_{GIVEN} \times \frac{MVA_{NEW}}{MVA_{OLD}} = (0.0144 + j0.1008) \times \frac{10}{1.5}$$

$$Z_{INPUT} = 0.096 + j0.672 \text{ P.U. at } 10 \text{ MVA Base}$$

$$\text{Transformation Ratio (Input)} = 4155/4160 = 0.9988$$

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. **N-3** PAGE **236** OF **453**

CCN CONVERSION  
CCN NO. CCN - **9**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.3 MOTOR CONTROL CENTER 2BRA EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j0.00 KVA  
 Initial Condition Equivalent Static Load\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Initial Condition Equivalent Load = 8.50 + j5.26 KVA

Initial Condition Equivalent P = 0.00850 MW  
 Initial Condition Equivalent Q = 0.00526 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 1.44 + j1.91 KVA  
 15 HP Allowance\*\* = 13.01 + j8.06 KVA  
 Total Starting Motor Load = 14.45 + j9.97 KVA  
 = 17.56 / 34.60° KVA

Starting Motor MBASE = 0.01756 (MVA)  
 Starting Motor Equivalent P = 0.01445 MW  
 Starting Motor Equivalent Q = 0.00997 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Accident Condition Equivalent Load = 8.50 + j5.26 KVA

Accident Condition Equivalent P = 0.00850 MW  
 Accident Condition Equivalent Q = 0.00526 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>237</b> OF <b>453</b>
CCN CONVERSION		CCN NO. <b>CCN - 9</b>

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.4 MOTOR CONTROL CENTER 2BD EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 3.82 + j4.02 KVA  
 Initial Condition Equivalent Static Load\* = 37.79 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Initial Condition Equivalent Load = 45.86 + j9.28 KVA

Initial Condition Equivalent P = 0.04586 MW  
 Initial Condition Equivalent Q = 0.00928 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 5.28 + j 5.54 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 18.29 + j 13.60 KVA  
 = 22.79 /36.63° KVA

Starting Motor MBASE = 0.02279 (MVA)  
 Starting Motor Equivalent P = 0.01829 MW  
 Starting Motor Equivalent Q = 0.01360 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Accident Condition Equivalent Load = 8.50 + j5.26 KVA

Accident Condition Equivalent P = 0.00850 MW  
 Accident Condition Equivalent Q = 0.00526 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO. / PRELIM. CCN NO. **N-3** PAGE **238** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.5 MOTOR CONTROL CENTER 2BE EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j 0.00 KVA  
 Initial Condition Equivalent Static Load\* = 85.19 + j61.45 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 89.44 + j64.08 KVA

Initial Condition Equivalent P = 0.08944 MW  
 Initial Condition Equivalent Q = 0.06408 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 32.02 + j42.70 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 45.03 + j50.76 KVA  
 = 67.85 /48.42° KVA

Starting Motor MBASE = 0.06785 (MVA)  
 Starting Motor Equivalent P = 0.04503 MW  
 Starting Motor Equivalent Q = 0.05076 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 85.19 + j61.45 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 89.44 + j64.08 KVA

Accident Condition Equivalent P = 0.08944 MW  
 Accident Condition Equivalent Q = 0.06408 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>239</b> OF <b>453</b>
---	-------------------------------

CCN CONVERSION CCN NO. CCN -	<b>9</b>
---------------------------------	----------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-99					

**8.6 MOTOR CONTROL CENTER 2BY EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 20.81 + j11.23 KVA  
 Initial Condition Equivalent Static Load\* = 93.15 + j60.41 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 118.21 + j74.27 KVA

Initial Condition Equivalent P = 0.11821 MW  
 Initial Condition Equivalent Q = 0.07427 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 73.14 + j47.36 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 86.15 + j55.42 KVA  
 = 102.44 /32.75° KVA

Starting Motor MBASE = 0.10244 (MVA)  
 Starting Motor Equivalent P = 0.08615 MW  
 Starting Motor Equivalent Q = 0.05542 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 108.23 + j75.45 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 112.48 + j78.08 KVA

Accident Condition Equivalent P = 0.11248 MW  
 Accident Condition Equivalent Q = 0.07808 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 290 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
 CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.7 MOTOR CONTROL CENTER BQ EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j 0.00 KVA  
 Initial Condition Equivalent Static Load\* = 71.66 + j43.16 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 75.91 + j45.79 KVA

Initial Condition Equivalent P = 0.07591 MW  
 Initial Condition Equivalent Q = 0.04579 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 30.61 + j19.30 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 43.62 + j27.36 KVA  
 = 51.49 / 32.10° KVA

Starting Motor MBASE = 0.05149 (MVA)  
 Starting Motor Equivalent P = 0.04362 MW  
 Starting Motor Equivalent Q = 0.02736 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 71.66 + j43.16 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 75.91 + j45.79 KVA

Accident Condition Equivalent P = 0.07591 MW  
 Accident Condition Equivalent Q = 0.04579 MVAR

\*From TABLE 5.3

\*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <i>N-3</i>	PAGE <i>241</i> OF <i>453</i>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <i>9</i>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>9-30-94</i>	A. M. PATEL	<i>10-5-94</i>					

**8.8 MOTOR CONTROL CENTER 2BRB EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j0.00 KVA  
 Initial Condition Equivalent Static Load\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Initial Condition Equivalent Load = 8.50 + j5.26 KVA

Initial Condition Equivalent P = 0.00850 MW  
 Initial Condition Equivalent Q = 0.00526 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 1.44 + j1.91 KVA  
 15 HP Allowance\*\* = 13.01 + j8.06 KVA  
 Total Starting Motor Load = 14.45 + j9.97 KVA  
 = 17.56 /34.60° KVA

Starting Motor MBASE = 0.01756 (MVA)  
 Starting Motor Equivalent P = 0.01445 MW  
 Starting Motor Equivalent Q = 0.00997 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Accident Condition Equivalent Load = 8.50 + j5.26 KVA

Accident Condition Equivalent P = 0.00850 MW  
 Accident Condition Equivalent Q = 0.00526 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./	N-3	PAGE 242 OF 453
PRELIM. CCN NO.		
CCN CONVERSION		
CCN NO.	CCN - 9	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

### 8.9 MOTOR CONTROL CENTER 2BH EQUIVALENT LOADS:

#### A. INITIAL CONDITION EQUIVALENT LOAD:

$$\begin{aligned}
 \text{Initial Condition Equivalent Motor Load}^* &= 3.82 + j4.02 \text{ KVA} \\
 \text{Initial Condition Equivalent Static Load}^* &= 37.79 + j2.63 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j2.63 \text{ KVA} \\
 \text{Total Initial Condition Equivalent Load} &= 45.86 + j9.28 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Initial Condition Equivalent P} &= 0.04586 \text{ MW} \\
 \text{Initial Condition Equivalent Q} &= 0.00928 \text{ MVAR}
 \end{aligned}$$

#### B. EQUIVALENT STARTING MOTOR LOAD:

$$\begin{aligned}
 \text{Equivalent Starting Motor Load}^* &= 5.28 + j 5.54 \text{ KVA} \\
 \text{15 HP Allowance}^{**} &= 13.01 + j 8.06 \text{ KVA} \\
 \text{Total Starting Motor Load} &= 18.29 + j13.60 \text{ KVA} \\
 &= 22.79 \angle 36.63^\circ \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Starting Motor MBASE} &= 0.02279 \text{ (MVA)} \\
 \text{Starting Motor Equivalent P} &= 0.01829 \text{ MW} \\
 \text{Starting Motor Equivalent Q} &= 0.01360 \text{ MVAR}
 \end{aligned}$$

#### C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:

$$\begin{aligned}
 \text{Accident Condition Static &\& Running Loads}^* &= 4.25 + j2.63 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j2.63 \text{ KVA} \\
 \text{Total Accident Condition Equivalent Load} &= 8.50 + j5.26 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Accident Condition Equivalent P} &= 0.00850 \text{ MW} \\
 \text{Accident Condition Equivalent Q} &= 0.00526 \text{ MVAR}
 \end{aligned}$$

\*From TABLE 5.3

\*\*Reference: Section 3.4.B

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO. / PRELIM. CCN NO. **N-3** PAGE **213** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

**8.10 MOTOR CONTROL CENTER 2BJ EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j 0.00 KVA  
 Initial Condition Equivalent Static Load\* = 74.99 + j55.13 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 79.24 + j57.76 KVA

Initial Condition Equivalent P = 0.07924 MW  
 Initial Condition Equivalent Q = 0.05776 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 31.97 + j42.63 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 44.98 + j50.69 KVA  
 = 67.77 / 48.42° KVA

Starting Motor MBASE = 0.06777 (MVA)  
 Starting Motor Equivalent P = 0.04498 MW  
 Starting Motor Equivalent Q = 0.05069 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 74.99 + j55.13 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 79.24 + j57.76 KVA

Accident Condition Equivalent P = 0.07924 MW  
 Accident Condition Equivalent Q = 0.05776 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>244</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>LM</i> 9-30-99	A. M. PATEL	<i>AM</i> 10-5-99					

**8.11 MOTOR CONTROL CENTER 2BZ EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j 0.00 KVA  
 Initial Condition Equivalent Static Load\* = 88.80 + j57.77 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 93.05 + j60.40 KVA

Initial Condition Equivalent P = 0.09305 MW  
 Initial Condition Equivalent Q = 0.06040 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 36.95 + j32.65 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 49.96 + j40.71 KVA  
 = 64.45 /39.17° KVA

Starting Motor MBASE = 0.06445 (MVA)  
 Starting Motor Equivalent P = 0.04996 MW  
 Starting Motor Equivalent Q = 0.04071 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 120.13 + j81.27 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 124.38 + j83.90 KVA

Accident Condition Equivalent P = 0.12438 MW  
 Accident Condition Equivalent Q = 0.08390 MVAR

\* From TABLE 5.3      \*\* Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>245</b> OF <b>453</b>
CCN CONVERSION		CCN NO. <b>CCN - 9</b>

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.12 MOTOR CONTROL CENTER BS EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j0.00 KVA  
 Initial Condition Equivalent Static Load\* = 8.08 + j5.00 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Initial Condition Equivalent Load = 12.33 + j7.63 KVA

Initial Condition Equivalent P = 0.01233 MW  
 Initial Condition Equivalent Q = 0.00763 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 30.61 + j19.30 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 43.62 + j27.36 KVA  
 = 51.49 /32.10° KVA

Starting Motor MBASE = 0.05149 (MVA)  
 Starting Motor Equivalent P = 0.04362 MW  
 Starting Motor Equivalent Q = 0.02736 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 38.38 + j20.80 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 42.63 + j23.43 KVA

Accident Condition Equivalent P = 0.04263 MW  
 Accident Condition Equivalent Q = 0.02343 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	N-3	PAGE 246 OF 453
PRELIM. CCN NO.		
CCN CONVERSION		
CCN NO.	CCN -	9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.13 MOTOR CONTROL CENTER 3BRA EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j0.00 KVA  
 Initial Condition Equivalent Static Load\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Initial Condition Equivalent Load = 8.50 + j5.26 KVA

Initial Condition Equivalent P = 0.00850 MW  
 Initial Condition Equivalent Q = 0.00526 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 1.44 + j1.91 KVA  
 15 HP Allowance\*\* = 13.01 + j8.06 KVA  
 Total Starting Motor Load = 14.45 + j9.97 KVA  
 = 17.56 / 34.60° KVA

Starting Motor MBASE = 0.01756 (MVA)  
 Starting Motor Equivalent P = 0.01445 MW  
 Starting Motor Equivalent Q = 0.00997 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Accident Condition Equivalent Load = 8.50 + j5.26 KVA

Accident Condition Equivalent P = 0.00850 MW  
 Accident Condition Equivalent Q = 0.00526 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	N-3	PAGE 247 OF 453
PRELIM. CCN NO.		
CCN CONVERSION		
CCN NO.	CCN -	9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.14 MOTOR CONTROL CENTER 3RD EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

$$\begin{aligned}
 \text{Initial Condition Equivalent Motor Load}^* &= 3.82 + j4.02 \text{ KVA} \\
 \text{Initial Condition Equivalent Static Load}^* &= 37.79 + j2.63 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j2.63 \text{ KVA} \\
 \text{Total Initial Condition Equivalent Load} &= 45.86 + j9.28 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Initial Condition Equivalent P} &= 0.04586 \text{ MW} \\
 \text{Initial Condition Equivalent Q} &= 0.00928 \text{ MVAR}
 \end{aligned}$$

**B. EQUIVALENT STARTING MOTOR LOAD:**

$$\begin{aligned}
 \text{Equivalent Starting Motor Load}^* &= 5.28 + j 5.54 \text{ KVA} \\
 \text{15 HP Allowance}^{**} &= 13.01 + j 8.06 \text{ KVA} \\
 \text{Total Starting Motor Load} &= 18.29 + j13.60 \text{ KVA} \\
 &= 22.79 \angle 36.63^\circ \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Starting Motor MBASE} &= 0.02279 \text{ (MVA)} \\
 \text{Starting Motor Equivalent P} &= 0.01829 \text{ MW} \\
 \text{Starting Motor Equivalent Q} &= 0.01360 \text{ MVAR}
 \end{aligned}$$

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

$$\begin{aligned}
 \text{Accident Condition Static &\& Running Loads}^* &= 4.25 + j2.63 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j2.63 \text{ KVA} \\
 \text{Total Accident Condition Equivalent Load} &= 8.50 + j5.26 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Accident Condition Equivalent P} &= 0.00850 \text{ MW} \\
 \text{Accident Condition Equivalent Q} &= 0.00526 \text{ MVAR}
 \end{aligned}$$

\*From TABLE 5.3      \*\*Reference: Section 3.4.B



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 248 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.15 MOTOR CONTROL CENTER 3BE EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

$$\begin{aligned} \text{Initial Condition Equivalent Motor Load}^* &= 0.00 + j 0.00 \text{ KVA} \\ \text{Initial Condition Equivalent Static Load}^* &= 85.19 + j61.45 \text{ KVA} \\ \text{5 KVA Allowance}^{**} &= 4.25 + j 2.63 \text{ KVA} \\ \text{Total Initial Condition Equivalent Load} &= 89.44 + j64.08 \text{ KVA} \end{aligned}$$

$$\begin{aligned} \text{Initial Condition Equivalent P} &= 0.08944 \text{ MW} \\ \text{Initial Condition Equivalent Q} &= 0.06408 \text{ MVAR} \end{aligned}$$

**B. EQUIVALENT STARTING MOTOR LOAD:**

$$\begin{aligned} \text{Equivalent Starting Motor Load}^* &= 32.90 + j43.87 \text{ KVA} \\ \text{15 HP Allowance}^{**} &= 13.01 + j 8.06 \text{ KVA} \\ \text{Total Starting Motor Load} &= 45.91 + j51.93 \text{ KVA} \\ &= 69.31 \angle 48.52^\circ \text{ KVA} \end{aligned}$$

$$\begin{aligned} \text{Starting Motor MBASE} &= 0.06931 \text{ (MVA)} \\ \text{Starting Motor Equivalent P} &= 0.04591 \text{ MW} \\ \text{Starting Motor Equivalent Q} &= 0.05193 \text{ MVAR} \end{aligned}$$

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

$$\begin{aligned} \text{Accident Condition Static &\& Running Loads}^* &= 85.19 + j61.45 \text{ KVA} \\ \text{5 KVA Allowance}^{**} &= 4.25 + j 2.63 \text{ KVA} \\ \text{Total Accident Condition Equivalent Load} &= 89.44 + j64.08 \text{ KVA} \end{aligned}$$

$$\begin{aligned} \text{Accident Condition Equivalent P} &= 0.08944 \text{ MW} \\ \text{Accident Condition Equivalent Q} &= 0.06408 \text{ MVAR} \end{aligned}$$

\*From TABLE 5.3

\*\*Reference: Section 3.4.B

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>249</b> OF <b>453</b>
CCN CONVERSION		<b>9</b>
CCN NO. CCN -		

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.16 MOTOR CONTROL CENTER 3BY EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 20.81 + j11.23 KVA  
 Initial Condition Equivalent Static Load\* = 93.15 + j60.41 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 118.21 + j74.27 KVA

Initial Condition Equivalent P = 0.11821 MW  
 Initial Condition Equivalent Q = 0.07427 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 73.14 + j47.36 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 86.15 + j55.42 KVA  
 = 102.44 /32.75° KVA

Starting Motor MBASE = 0.10244 (MVA)  
 Starting Motor Equivalent P = 0.08615 MW  
 Starting Motor Equivalent Q = 0.05542 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 108.23 + j75.45 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 112.48 + j78.08 KVA

Accident Condition Equivalent P = 0.11248 MW  
 Accident Condition Equivalent Q = 0.07808 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>250</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

### 8.17 MOTOR CONTROL CENTER 3BRB EQUIVALENT LOADS:

#### A. INITIAL CONDITION EQUIVALENT LOAD:

$$\begin{aligned}
 \text{Initial Condition Equivalent Motor Load}^* &= 0.00 + j0.00 \text{ KVA} \\
 \text{Initial Condition Equivalent Static Load}^* &= 4.25 + j2.63 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j2.63 \text{ KVA} \\
 \text{Total Initial Condition Equivalent Load} &= 8.50 + j5.26 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Initial Condition Equivalent P} &= 0.00850 \text{ MW} \\
 \text{Initial Condition Equivalent Q} &= 0.00526 \text{ MVAR}
 \end{aligned}$$

#### B. EQUIVALENT STARTING MOTOR LOAD:

$$\begin{aligned}
 \text{Equivalent Starting Motor Load}^* &= 1.44 + j1.91 \text{ KVA} \\
 \text{15 HP Allowance}^{**} &= 13.01 + j8.06 \text{ KVA} \\
 \text{Total Starting Motor Load} &= 14.45 + j9.97 \text{ KVA} \\
 &= 17.56 \angle 34.60^\circ \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Starting Motor MBASE} &= 0.01756 \text{ (MVA)} \\
 \text{Starting Motor Equivalent P} &= 0.01445 \text{ MW} \\
 \text{Starting Motor Equivalent Q} &= 0.00997 \text{ MVAR}
 \end{aligned}$$

#### C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:

$$\begin{aligned}
 \text{Accident Condition Static &\& Running Loads}^* &= 4.25 + j2.63 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j2.63 \text{ KVA} \\
 \text{Total Accident Condition Equivalent Load} &= 8.50 + j5.26 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Accident Condition Equivalent P} &= 0.00850 \text{ MW} \\
 \text{Accident Condition Equivalent Q} &= 0.00526 \text{ MVAR}
 \end{aligned}$$

\* From TABLE 5.3

\*\* Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 251 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**8.18 MOTOR CONTROL CENTER 3BH EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 3.82 + j4.02 KVA  
 Initial Condition Equivalent Static Load\* = 37.79 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Initial Condition Equivalent Load = 45.86 + j9.28 KVA

Initial Condition Equivalent P = 0.04586 MW  
 Initial Condition Equivalent Q = 0.00928 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 5.28 + j 5.54 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 18.29 + j13.60 KVA  
 = 22.79 /36.63° KVA

Starting Motor MBASE = 0.02279 (MVA)  
 Starting Motor Equivalent P = 0.01829 MW  
 Starting Motor Equivalent Q = 0.01360 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 4.25 + j2.63 KVA  
 5 KVA Allowance\*\* = 4.25 + j2.63 KVA  
 Total Accident Condition Equivalent Load = 8.50 + j5.26 KVA

Accident Condition Equivalent P = 0.00850 MW  
 Accident Condition Equivalent Q = 0.00526 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>252</b> OF <b>453</b>
CCN CONVERSION		CCN NO. CCN - <b>9</b>

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

**8.19 MOTOR CONTROL CENTER 3BJ EQUIVALENT LOADS:**

**A. INITIAL CONDITION EQUIVALENT LOAD:**

Initial Condition Equivalent Motor Load\* = 0.00 + j 0.00 KVA  
 Initial Condition Equivalent Static Load\* = 74.99 + j55.13 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Initial Condition Equivalent Load = 79.24 + j57.76 KVA

Initial Condition Equivalent P = 0.07924 MW  
 Initial Condition Equivalent Q = 0.05776 MVAR

**B. EQUIVALENT STARTING MOTOR LOAD:**

Equivalent Starting Motor Load\* = 31.96 + j42.62 KVA  
 15 HP Allowance\*\* = 13.01 + j 8.06 KVA  
 Total Starting Motor Load = 44.97 + j50.68 KVA  
 = 67.76 /48.42° KVA

Starting Motor MBASE = 0.06776 (MVA)  
 Starting Motor Equivalent P = 0.04497 MW  
 Starting Motor Equivalent Q = 0.05068 MVAR

**C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:**

Accident Condition Static & Running Loads\* = 74.99 + j55.13 KVA  
 5 KVA Allowance\*\* = 4.25 + j 2.63 KVA  
 Total Accident Condition Equivalent Load = 79.24 + j57.76 KVA

Accident Condition Equivalent P = 0.07924 MW  
 Accident Condition Equivalent Q = 0.05776 MVAR

\*From TABLE 5.3      \*\*Reference: Section 3.4.B

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./	PRELIM. CCN NO. <b>N-3</b>	PAGE <b>253</b> OF <b>453</b>
CCN CONVERSION		CCN NO. CCN - <b>9</b>

Project or DCP/MMP SONGS 2 & 3 Calc. No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. FATEL	10-5-94					

## 8.20 MOTOR CONTROL CENTER 3BZ EQUIVALENT LOADS:

### A. INITIAL CONDITION EQUIVALENT LOAD:

$$\begin{aligned}
 \text{Initial Condition Equivalent Motor Load}^* &= 0.00 + j 0.00 \text{ KVA} \\
 \text{Initial Condition Equivalent Static Load}^* &= 88.66 + j 57.77 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j 2.63 \text{ KVA} \\
 \text{Total Initial Condition Equivalent Load} &= 92.91 + j 60.40 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Initial Condition Equivalent P} &= 0.09291 \text{ MW} \\
 \text{Initial Condition Equivalent Q} &= 0.06040 \text{ MVAR}
 \end{aligned}$$

### B. EQUIVALENT STARTING MOTOR LOAD:

$$\begin{aligned}
 \text{Equivalent Starting Motor Load}^* &= 38.82 + j 35.16 \text{ KVA} \\
 \text{15 HP Allowance}^{**} &= 13.01 + j 8.06 \text{ KVA} \\
 \text{Total Starting Motor Load} &= 51.83 + j 43.22 \text{ KVA} \\
 &= 67.49 \angle 39.82^\circ \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Starting Motor MBASE} &= 0.06749 \text{ (MVA)} \\
 \text{Starting Motor Equivalent P} &= 0.05183 \text{ MW} \\
 \text{Starting Motor Equivalent Q} &= 0.04322 \text{ MVAR}
 \end{aligned}$$

### C. ACCIDENT CONDITION EQUIVALENT STATIC & RUNNING LOADS:

$$\begin{aligned}
 \text{Accident Condition Static &\& Running Loads}^* &= 120.13 + j 81.27 \text{ KVA} \\
 \text{5 KVA Allowance}^{**} &= 4.25 + j 2.63 \text{ KVA} \\
 \text{Total Accident Condition Equivalent Load} &= 124.38 + j 83.90 \text{ KVA}
 \end{aligned}$$

$$\begin{aligned}
 \text{Accident Condition Equivalent P} &= 0.12438 \text{ MW} \\
 \text{Accident Condition Equivalent Q} &= 0.08390 \text{ MVAR}
 \end{aligned}$$

\* From TABLE 5.3

\*\* Reference: Section 3.4.B

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 254 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-99					

**8.21 CONTROL ROOM EMERGENCY AC UNITS E418 & E419 INERTIA CONSTANT:**

Given:  $WK^2_{LOAD} = 272 \text{ LB-FT}^2$  (Reference: Sections 4.2)

$WK^2_{MOTOR} = 57 \text{ LB-FT}^2$

Motor Rated KVA = 140.22 KVA

$WK^2_{LOAD+MOTOR} = 329 \text{ LB-FT}^2$

$$H^* = \frac{0.231 \times WK^2_{LOAD+MOTOR} \times (RPM_{SYN})^2 \times 10^{-6}}{\text{Rated KVA}}$$

$$H = \frac{0.231 \times 329 \times 1800^2 \times 10^{-6}}{140.22}$$

H = 1.75607

\* See Section 5.8 of the base calculation.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <i>N-3</i>	PAGE <i>255</i> OF <i>453</i>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <i>9</i>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>9-30-94</i>	A. M. PATEL	<i>10-5-94</i>					

**9.0 APPENDICES AND ATTACHMENTS:**

**9.1 APPENDICES:**

- 9.1.1 NETWORK DATA.....SHEET 256
- 9.1.2 DYNAMIC SIMULATION DATA.....SHEET 278
- 9.1.3 CASE IIIAX - LOAD FLOW SOLUTION RESULTS.....SHEET 338
- 9.1.4 CASE IIIAY - LOAD FLOW SOLUTION RESULTS.....SHEET 358
- 9.1.5 CASE IVBX - LOAD FLOW SOLUTION RESULTS.....SHEET 378
- 9.1.6 CASE IVBY - LOAD FLOW SOLUTION RESULTS.....SHEET 411
- 9.1.7 PSS/E VALIDATION.....SHEET 444



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>256</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<i>LRM</i> 9-30-94	A. M. PATEL	<i>AMP</i> 10-5-94					

**APPENDIX 9.1.1**

**Network Data**

BUSES							GENERATION AREAS ZONES SYSTEM				
TOTAL	PQ<0.	PQ=0.	PE/E	PE/Q	SWING	OTHER	PLANTS	MACHS	USED	USED	BASE
199	146	40	0	0	1	12	5	5	1	1	10.0
AC BRANCHES							MULTI-SECTION		DC LINES		
TOTAL	RXB	RX	RXT	RX=0.	IN	OUT	LINES	SECTIONS	2-TERM	N-TERM	
204	0	84	80	40	186	18	0	0	0	0	

TOTAL GENERATION	PQLOAD	I LOAD	Y LOAD	SHUNTS	CHARGING	LOSSES	SWING
MW	91.7	91.0	0.0	0.0	0.0	0.7	91.7
MVAR	63.6	54.3	0.0	0.0	0.0	9.3	63.6

TOTAL SYSTEM MISMATCH = 0.01 MVA X-----AT BUS-----X X-----SWING-----X  
 LARGEST BUS MISMATCH = 0.00 MVA 4 2XR2\* 4.36 1 SYSTEM 230  
 HIGH VOLTAGE = 1.0003 PU 14 2XR2X 4.16  
 LOW VOLTAGE = 0.8381 PU 31407 3BD 0.48

THRSZ  
0.000100  
 X-----SOLV MSLV-----X X-FNSL NSOL-X X-----TYSL-----X BLOW PQ  
 ACCP ACCQ ACCM TOL ITER ACCN TOL ITER ACCTY TOL ITER UP BRAK  
 1.600 1.600 1.000 0.00010 100 1.00 0.100 20 1.000 0.000010 20 3.0 0.70

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: LPM 9-30-94 IRE: RD 10-5-94  
 Sheet No. 257

CCN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

THU, SEP 15 1994 14:47  
WORST  
MISMATCHES

BUS#	NAME	BSKV	MW	MVAR	MVA
4	2XR2*	4.36	0.00	0.00	0.00

Calc No: E4C-082 CCN N-3 Rev: 1  
Sheet No. 258  
RE: LPW 9-30-94 RE: AL 10-5-94

CCN9

PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS/E  
 SAN ONOPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

THU, SEP 15 1994 14:47  
 BUS DATA

BUS#	NAME	BSKV	CODE	VOLT	ANGLE	FLOAD	QLOAD	S	H	U	N	T	AREA	ZONE
1	SYSTEM	230	3	0.9478	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
2	2XR1*	4.36	1	0.9717	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
3	2XR1Y	4.16	1	0.9682	-4.0	17.0	10.5	0.0	0.0	0.0	1	1		
4	2XR2*	4.36	1	0.9717	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
5	2XR2Y	4.16	1	0.9682	-4.0	17.0	10.5	0.0	0.0	0.0	1	1		
6	3XR1*	4.36	1	0.9695	-0.2	0.0	0.0	0.0	0.0	0.0	1	1		
7	3XR1Y	4.16	1	0.9683	-3.9	17.0	10.5	0.0	0.0	0.0	1	1		
8	3XR2*	4.36	1	0.9691	-0.2	0.0	0.0	0.0	0.0	0.0	1	1		
9	3XR2Y	4.16	1	0.9637	-4.3	17.0	10.5	0.0	0.0	0.0	1	1		
12	2XR1X	4.16	1	0.9991	-1.7	0.0	0.0	0.0	0.0	0.0	1	1		
14	2XR2X	4.16	1	1.0003	-1.6	0.0	0.0	0.0	0.0	0.0	1	1		
16	3XR1X	4.16	1	0.9968	-1.9	0.0	0.0	0.0	0.0	0.0	1	1		
18	3XR2X	4.16	1	0.9970	-1.9	0.0	0.0	0.0	0.0	0.0	1	1		
24	2A04	4.16	1	0.9962	-1.8	0.0	0.0	0.0	0.0	0.0	1	1		
26	2A06	4.16	1	0.9970	-1.7	0.0	0.0	0.0	0.0	0.0	1	1		
34	3A04	4.16	1	0.9939	-2.0	0.0	0.0	0.0	0.0	0.0	1	1		
36	3A06	4.16	1	0.9937	-2.0	0.0	0.0	0.0	0.0	0.0	1	1		
41	2XMS	22.0	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
44	2XU1Y	4.16	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
45	2XU1*	4.36	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
46	2XU1X	4.16	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
51	3XMS	22.0	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
54	3XU1Y	4.16	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
55	3XU1*	4.36	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
56	3XU1X	4.16	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
214	2B04	0.48	1	0.9156	-7.7	0.0	0.0	0.0	0.0	0.0	1	1		
216	2B06	0.48	1	0.9254	-7.1	0.0	0.0	0.0	0.0	0.0	1	1		
314	3B04	0.48	1	0.9126	-8.0	0.0	0.0	0.0	0.0	0.0	1	1		
316	3B06	0.48	1	0.9215	-7.4	0.0	0.0	0.0	0.0	0.0	1	1		
2403	2P012	4.16	1	0.9957	-1.8	0.3	0.2	0.0	0.0	0.0	1	1		
2404	2P141	4.16	1	0.9946	-1.8	0.7	0.3	0.0	0.0	0.0	1	1		
2405	2P024	4.16	1	0.9958	-1.8	0.5	0.3	0.0	0.0	0.0	1	1		
2406	2P025-A	4.16	1	0.9956	-1.8	0.5	0.3	0.0	0.0	0.0	1	1		
2407	2P015	4.16	1	0.9957	-1.8	0.4	0.2	0.0	0.0	0.0	1	1		
2408	2P017	4.16	1	0.9957	-1.8	0.4	0.2	0.0	0.0	0.0	1	1		
2409	2P018-A	4.16	1	0.9957	-1.8	0.4	0.2	0.0	0.0	0.0	1	1		
2410	2P112	4.16	1	0.9956	-1.8	0.3	0.2	0.0	0.0	0.0	1	1		
2411	2P307	4.16	1	0.9956	-1.8	0.3	0.2	0.0	0.0	0.0	1	1		
2412	E336-U2	4.16	1	0.9953	-1.8	0.5	0.3	0.0	0.0	0.0	1	1		
2413	2G002	4.36	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
2416	2T014	4.16	1	0.9959	-1.8	0.1	0.1	0.0	0.0	0.0	1	1		
2420	2B04X	4.16	1	0.9959	-1.8	0.0	0.0	0.0	0.0	0.0	1	1		
2603	2P504	4.16	1	0.9956	-1.8	0.7	0.3	0.0	0.0	0.0	1	1		
2604	2P013	4.16	1	0.9965	-1.7	0.3	0.2	0.0	0.0	0.0	1	1		
2605	2P026	4.16	1	0.9965	-1.7	0.5	0.3	0.0	0.0	0.0	1	1		
2606	2P025-B	4.16	1	0.9963	-1.7	0.5	0.3	0.0	0.0	0.0	1	1		
2607	2P016	4.16	1	0.9964	-1.7	0.4	0.2	0.0	0.0	0.0	1	1		
2608	2P019	4.16	1	0.9965	-1.7	0.4	0.2	0.0	0.0	0.0	1	1		
2609	2P018-B	4.16	1	0.9965	-1.7	0.4	0.2	0.0	0.0	0.0	1	1		
2610	2P113	4.16	1	0.9965	-1.7	0.3	0.2	0.0	0.0	0.0	1	1		
2611	2P114	4.16	1	0.9964	-1.7	0.3	0.2	0.0	0.0	0.0	1	1		
2612	E335-U2	4.16	1	0.9961	-1.7	0.5	0.3	0.0	0.0	0.0	1	1		
2613	2G003	4.36	4	1.0000	0.0	0.0	0.0	0.0	0.0	0.0	1	1		
2620	2B06X	4.16	1	0.9966	-1.7	0.0	0.0	0.0	0.0	0.0	1	1		
3402	E336-U3	4.16	1	0.9933	-2.0	0.5	0.3	0.0	0.0	0.0	1	1		
3403	3P012	4.16	1	0.9934	-2.0	0.3	0.2	0.0	0.0	0.0	1	1		

Calc No: E4C-082 Sheet No. 259  
 RE: LPW 9-30-94 IRE: RL 10-5-94  
 Rev. 1

CCN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
 SAN ONOPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

THU, SEP 15 1994 14:47  
 BUS DATA

BUS#	NAME	BSKV	CODE	VOLT	ANGLE	PLOAD	QLOAD	S	H	U	N	T	AREA	ZONE
3404	3P141	4.16	1	0.9924	-2.0	0.7	0.3	0.0	0.0	1	1			
3405	3P024	4.16	1	0.9932	-2.0	0.5	0.3	0.0	0.0	1	1			
3406	3P025-A	4.16	1	0.9932	-2.0	0.5	0.3	0.0	0.0	1	1			
3407	3P015	4.16	1	0.9933	-2.0	0.4	0.2	0.0	0.0	1	1			
3408	3P017	4.16	1	0.9933	-2.0	0.4	0.2	0.0	0.0	1	1			
3409	3P018-A	4.16	1	0.9933	-2.0	0.4	0.2	0.0	0.0	1	1			
3410	3P112	4.16	1	0.9933	-2.0	0.3	0.2	0.0	0.0	1	1			
3411	3P307	4.16	1	0.9932	-2.0	0.3	0.2	0.0	0.0	1	1			
3412	3T014	4.16	1	0.9936	-2.0	0.1	0.1	0.0	0.0	1	1			
3413	3G002	4.36	4	1.0000	0.0	0.0	0.0	0.0	0.0	1	1			
3417	3B04X	4.16	1	0.9934	-2.0	0.0	0.0	0.0	0.0	1	1			
3602	E335-U3	4.16	1	0.9931	-2.0	0.5	0.3	0.0	0.0	1	1			
3604	3P013	4.16	1	0.9932	-2.0	0.3	0.2	0.0	0.0	1	1			
3605	3P026	4.16	1	0.9932	-2.0	0.5	0.3	0.0	0.0	1	1			
3606	3P025-B	4.16	1	0.9932	-2.0	0.5	0.3	0.0	0.0	1	1			
3607	3P016	4.16	1	0.9932	-2.0	0.4	0.2	0.0	0.0	1	1			
3608	3P019	4.16	1	0.9932	-2.0	0.4	0.2	0.0	0.0	1	1			
3609	3P018-B	4.16	1	0.9933	-2.0	0.4	0.2	0.0	0.0	1	1			
3610	3P113	4.16	1	0.9933	-2.0	0.3	0.2	0.0	0.0	1	1			
3611	3P114	4.16	1	0.9931	-2.0	0.3	0.2	0.0	0.0	1	1			
3612	3P504	4.16	1	0.9920	-2.0	0.7	0.3	0.0	0.0	1	1			
3613	3G003	4.36	4	1.0000	0.0	0.0	0.0	0.0	0.0	1	1			
3619	3B06X	4.16	1	0.9933	-2.0	0.0	0.0	0.0	0.0	1	1			
21402	2E61M	0.48	1	0.9045	-8.5	0.2	0.0	0.0	0.0	1	1			
21403	2BRA	0.48	1	0.9152	-7.8	0.0	0.0	0.0	0.0	1	1			
21405	2P191-A	0.46	1	0.9454	-7.7	0.1	0.0	0.0	0.0	1	1			
21406	2E145	0.48	1	0.8820	-8.5	0.1	0.0	0.0	0.0	1	1			
21407	2BD	0.48	1	0.8414	-9.1	0.0	0.0	0.0	0.0	1	1			
21409	2A071	0.46	1	0.9343	-7.4	0.1	0.0	0.0	0.0	1	1			
21410	2E399	0.46	1	0.9435	-7.7	0.1	0.0	0.0	0.0	1	1			
21411	2E401	0.46	1	0.9410	-7.7	0.1	0.0	0.0	0.0	1	1			
21413	2P190	0.46	1	0.9463	-7.7	0.1	0.0	0.0	0.0	1	1			
21414	2BE	0.48	1	0.9128	-7.8	0.0	0.0	0.0	0.0	1	1			
21415	2BY	0.48	1	0.9124	-7.9	0.0	0.0	0.0	0.0	1	1			
21417	BQ-U2	0.48	1	0.9130	-7.8	0.0	0.0	0.0	0.0	1	1			
21418	E418-U2	0.46	1	0.9232	-7.6	0.1	0.1	0.0	0.0	1	1			
21419	2A074	0.46	1	0.9291	-7.4	0.1	0.0	0.0	0.0	1	1			
21602	2E62N	0.48	1	0.9127	-7.9	0.2	0.0	0.0	0.0	1	1			
21603	2BRB	0.48	1	0.9252	-7.1	0.0	0.0	0.0	0.0	1	1			
21605	2BH	0.48	1	0.8684	-8.1	0.0	0.0	0.0	0.0	1	1			
21606	2E146	0.48	1	0.8889	-7.9	0.1	0.0	0.0	0.0	1	1			
21607	2BJ	0.48	1	0.9227	-7.1	0.0	0.0	0.0	0.0	1	1			
21609	2A072	0.46	1	0.9424	-6.7	0.1	0.0	0.0	0.0	1	1			
21610	2E490	0.46	1	0.9490	-7.0	0.1	0.0	0.0	0.0	1	1			
21611	2E402	0.46	1	0.9423	-7.0	0.1	0.0	0.0	0.0	1	1			
21613	2P192	0.46	1	0.9521	-7.0	0.1	0.0	0.0	0.0	1	1			
21614	2BZ	0.48	1	0.9236	-7.1	0.0	0.0	0.0	0.0	1	1			
21615	E419-U2	0.46	1	0.9591	-7.1	0.1	0.1	0.0	0.0	1	1			
21617	2P191-B	0.46	1	0.9514	-7.0	0.1	0.0	0.0	0.0	1	1			
21618	BS-U2	0.48	1	0.9223	-7.1	0.0	0.0	0.0	0.0	1	1			
21619	2A073	0.46	1	0.9355	-6.6	0.1	0.0	0.0	0.0	1	1			
22403	2BRA-M	0.48	1	0.9152	-7.8	0.0	0.0	0.0	0.0	1	1			
22407	2BD-M	0.48	1	0.8414	-9.1	0.0	0.0	0.0	0.0	1	1			
22414	2BE-M	0.48	1	0.9128	-7.8	0.0	0.1	0.0	0.0	1	1			
22415	2BY-M	0.48	1	0.9124	-7.9	0.1	0.1	0.0	0.0	1	1			
22417	BQ-U2-M	0.48	1	0.9130	-7.8	0.0	0.0	0.0	0.0	1	1			

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Pen 9-30-94 IRE: As 10-5-94

Sheet No. 260

CCN 9

SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3

BUS DATA

E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

BUS#	NAME	BSKV	CODE	VOLT	ANGLE	PLOAD	QLOAD	S	H	U	T	AREA	ZONE
22603	2BRB-M	0.48	1	0.9252	-7.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
22605	2BH-M	0.48	1	0.8684	-8.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
22607	2BJ-M	0.48	1	0.9227	-7.1	0.0	0.0	0.1	0.0	0.0	0.0	1	1
22614	2BZ-M	0.48	1	0.9236	-7.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
22618	BS-U2-M	0.48	1	0.9223	-7.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
23403	2BRA-S	0.48	1	0.9152	-7.8	0.0	0.0	0.0	0.0	0.0	0.0	1	1
23407	2BD-S	0.48	1	0.8414	-9.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
23414	2BE-S	0.48	1	0.9128	-7.8	0.1	0.1	0.0	0.0	0.0	0.0	1	1
23418	2BY-S	0.48	1	0.9124	-7.9	0.1	0.1	0.0	0.0	0.0	0.0	1	1
23417	BQ-U2-S	0.48	1	0.9130	-7.8	0.1	0.0	0.0	0.0	0.0	0.0	1	1
23603	2BRB-S	0.48	1	0.9252	-7.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
23605	2BH-S	0.48	1	0.8684	-8.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
23607	2BJ-S	0.48	1	0.9227	-7.1	0.1	0.1	0.0	0.0	0.0	0.0	1	1
23614	2BZ-S	0.48	1	0.9236	-7.1	0.1	0.1	0.0	0.0	0.0	0.0	1	1
23618	BS-U2-S	0.48	1	0.9223	-7.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24412	2A274	0.46	1	0.8747	-9.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24413	2A275	0.46	1	0.8717	-8.9	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24417	P162-U2	0.46	1	0.9398	-7.5	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24421	2E550	0.46	1	0.8713	-8.9	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24422	2E546	0.46	1	0.8720	-8.9	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24434	2P009	0.46	1	0.9389	-7.6	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24606	2E547	0.46	1	0.9098	-8.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24607	2E549	0.46	1	0.9001	-7.9	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24611	2A276	0.46	1	0.9031	-8.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24612	2A277	0.46	1	0.9005	-8.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24618	P160-U2	0.46	1	0.9561	-7.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
24622	2P010	0.46	1	0.9504	-6.9	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31402	3E61N	0.48	1	0.9016	-8.7	0.2	0.0	0.0	0.0	0.0	0.0	1	1
31403	3BRA	0.48	1	0.9123	-8.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31405	3P191-A	0.46	1	0.9406	-7.9	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31406	3E145	0.48	1	0.8880	-8.5	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31407	3BD	0.48	1	0.8381	-9.3	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31409	3A071	0.46	1	0.9298	-7.6	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31410	3E399	0.46	1	0.9406	-7.9	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31411	3E401	0.46	1	0.9386	-7.9	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31413	3P190	0.46	1	0.9433	-7.9	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31414	3BE	0.48	1	0.9105	-8.0	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31415	3BY	0.48	1	0.9104	-8.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31417	BQ-U3	0.48	1	0.9039	-8.1	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31418	E418-U3	0.46	1	0.9142	-7.8	0.1	0.1	0.0	0.0	0.0	0.0	1	1
31419	3A074	0.46	1	0.9244	-7.5	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31602	3E62N	0.48	1	0.9091	-8.2	0.2	0.0	0.0	0.0	0.0	0.0	1	1
31603	3BRB	0.48	1	0.9212	-7.4	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31605	3BH	0.48	1	0.8649	-8.4	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31606	3E146	0.48	1	0.8854	-8.2	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31607	3BJ	0.48	1	0.9186	-7.4	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31609	3A072	0.46	1	0.9359	-7.0	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31610	3E400	0.46	1	0.9445	-7.3	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31611	3E402	0.46	1	0.9374	-7.2	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31613	3P192	0.46	1	0.9480	-7.3	0.2	0.0	0.0	0.0	0.0	0.0	1	1
31614	3BZ	0.48	1	0.9196	-7.4	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31615	E419-U3	0.46	1	0.9499	-7.3	0.1	0.1	0.0	0.0	0.0	0.0	1	1
31617	3P191-B	0.46	1	0.9480	-7.3	0.1	0.0	0.0	0.0	0.0	0.0	1	1
31618	BS-U3	0.48	1	0.9154	-7.5	0.0	0.0	0.0	0.0	0.0	0.0	1	1
31619	3A073	0.46	1	0.9304	-6.9	0.1	0.0	0.0	0.0	0.0	0.0	1	1
32403	3BRA-M	0.48	1	0.9123	-8.0	0.0	0.0	0.0	0.0	0.0	0.0	1	1

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 RE: Ad 10-5-94

Sheet No. 261

CAN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

THU, SEP 15 1994 14:47  
 BUS DATA

BUS#	NAME	BSKV	CODE	VOLT	ANGLE	PLOAD	QLOAD	S	H	U	N	T	AREA	ZONE
32407	3BD-M	0.48	1	0.8381	-9.3	0.0	0.0	0.0	0.0	1	1			
32414	3BE-M	0.48	1	0.9105	-8.0	0.0	0.1	0.0	0.0	1	1			
32415	3BY-M	0.48	1	0.9104	-8.0	0.1	0.1	0.0	0.0	1	1			
32417	BQ-U3-M	0.48	1	0.9039	-8.1	0.0	0.0	0.0	0.0	1	1			
32603	3BRB-M	0.48	1	0.9212	-7.4	0.0	0.0	0.0	0.0	1	1			
32605	3BH-M	0.48	1	0.8649	-8.4	0.0	0.0	0.0	0.0	1	1			
32607	3BJ-M	0.48	1	0.9186	-7.4	0.0	0.1	0.0	0.0	1	1			
32614	3BZ-M	0.48	1	0.9196	-7.4	0.1	0.0	0.0	0.0	1	1			
32618	BS-U3-M	0.48	1	0.9154	-7.5	0.0	0.0	0.0	0.0	1	1			
33403	3BRA-S	0.48	1	0.9123	-8.0	0.0	0.0	0.0	0.0	1	1			
33407	3BD-S	0.48	1	0.8331	-9.3	0.0	0.0	0.0	0.0	1	1			
33414	3BE-S	0.48	1	0.9105	-8.0	0.1	0.1	0.0	0.0	1	1			
33415	3BY-S	0.48	1	0.9104	-8.0	0.1	0.1	0.0	0.0	1	1			
33417	BQ-U3-S	0.48	1	0.9039	-8.1	0.1	0.0	0.0	0.0	1	1			
33603	3BRB-S	0.48	1	0.9212	-7.4	0.0	0.0	0.0	0.0	1	1			
33605	3BH-S	0.48	1	0.8649	-8.4	0.0	0.0	0.0	0.0	1	1			
33607	3BJ-S	0.48	1	0.9186	-7.4	0.1	0.1	0.0	0.0	1	1			
33614	3BZ-S	0.48	1	0.9196	-7.4	0.1	0.1	0.0	0.0	1	1			
33618	BS-U3-S	0.48	1	0.9154	-7.5	0.0	0.0	0.0	0.0	1	1			
34412	3A274	0.46	1	0.8714	-9.3	0.0	0.0	0.0	0.0	1	1			
34413	3A275	0.46	1	0.8681	-9.2	0.0	0.0	0.0	0.0	1	1			
34417	P162-U3	0.46	1	0.9302	-7.8	0.0	0.0	0.0	0.0	1	1			
34421	3E550	0.46	1	0.8675	-9.1	0.0	0.0	0.0	0.0	1	1			
34422	3E546	0.46	1	0.8687	-9.2	0.0	0.0	0.0	0.0	1	1			
34434	3P009	0.46	1	0.9382	-7.8	0.0	0.0	0.0	0.0	1	1			
34606	3E547	0.46	1	0.8968	-8.2	0.0	0.0	0.0	0.0	1	1			
34607	3E549	0.46	1	0.8964	-8.2	0.0	0.0	0.0	0.0	1	1			
34611	3A276	0.46	1	0.8999	-8.3	0.0	0.0	0.0	0.0	1	1			
34612	3A277	0.46	1	0.8965	-8.2	0.0	0.0	0.0	0.0	1	1			
34618	P160-U3	0.46	1	0.9489	-7.3	0.0	0.0	0.0	0.0	1	1			
34622	3P010	0.46	1	0.9453	-7.2	0.0	0.0	0.0	0.0	1	1			

Calc No: E4C-082 Sheet No. 262  
 RE: PM 990-99 IRE: PL 10-5-94  
 CCN N-3 Rev. 1

CCN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E THU, SEP 15 1994 14:47  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 SWITCHED  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA SHUNT DATA  
BUS# MOD VHI VLO SHUNT X-----X X-----X X-----X X-----X REMOTE

\* HOME \*

Calc No: <u>E4C-082</u>	Sheet No. <u>263</u>
RE: <u>CPM 9-30-94</u>	Rev. <u>1</u>
IRE: <u>AL 10-5-94</u>	

LEN 9



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E THU, SEP 15 1994 14:47  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 GENERATING  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA PLANT DATA

BUS#	NAME	BSKV	COD	MCNS	PGEN	QGEN	QMAX	QMIN	VSCHED	VACT.	REMO	PCT	Q
1	SYSTEM	230	3	1	91.7	63.6	9999.0-9999.0	0.9478	0.9478				
2413	2G002	4.36	4	1	0.0	0.0	0.0	0.0	1.0000	1.0000			
2613	2G003	4.36	4	1	0.0	0.0	0.0	0.0	1.0000	1.0000			
3413	3G002	4.36	4	1	0.0	0.0	0.0	0.0	1.0000	1.0000			
3613	3G003	4.36	4	1	0.0	0.0	0.0	0.0	1.0000	1.0000			

Calc No: E4C-082 CCN N-3 Rev. 1 Sheet No. 264  
 RE: PM 9-30-94 RE: 10-5-94

CCN9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E THU, SEP 15 1994 14:47  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 GENERATOR  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA UNIT DATA

BUS#	NAME	BSKV	COD	ID	ST	PGEN	QGEN	QMAX	QMIN	PMAX	PMIN	MBASE	Z	S	O	R	C	E	X	T	R	A	N	GENTAP
1	SYSTEM	230	3	1	1	92	64	9999-9999	9999-9999	10	0.0000	0.0011												
2413	2G002	4.36	4	1	0	0	0	4	0	9999-9999	6	0.0000	0.1070											
2613	2G003	4.36	4	1	0	0	0	4	0	9999-9999	6	0.0000	0.1070											
3413	3G002	4.36	4	1	0	0	0	4	0	9999-9999	6	0.0000	0.1070											
3613	3G003	4.36	4	1	0	0	0	4	0	9999-9999	6	0.0000	0.1070											

Calc No: E4C-082 Sheet No. 265  
 RE: from 9-30-94 IRE: AL 10-5-94  
 CCA N-3 Rev. 1

CCN9

CCN9

Sheet No. 266  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: LPM 9-30-94 IRE: Feb 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAS ONOFF NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA  
THU, SEP 15 1994 14:47  
BRANCH DATA

FROM	TO	CKT NAME	NAME	LINE R	LINE X	CHRGING	TP	ST	RATA	RATB	RATC
1*	2	1 SYSTEM	2XR1*	0.0000	0.0003	0.0000	F	1	0	0	0
1*	4	1 SYSTEM	2XR2*	0.0000	0.0003	0.0000	F	1	0	0	0
1*	6	1 SYSTEM	3XR1*	0.0001	0.0015	0.0000	F	1	0	0	0
1*	8	1 SYSTEM	3XR2*	0.0001	0.0018	0.0000	F	1	0	0	0
1	41*	1 SYSTEM	2XMS	0.0000	0.0010	0.0000	T	0	0	0	0
1	51*	1 SYSTEM	3XMS	0.0000	0.0010	0.0000	T	0	0	0	0
2	3*	1 2XR1*	2XR1Y	0.0017	0.0372	0.0000	T	1	0	0	0
2	12*	1 2XR1*	2XR1X	0.0022	0.0467	0.0000	T	1	0	0	0
4	5*	1 2XR2*	2XR2Y	0.0017	0.0372	0.0000	T	1	0	0	0
4	14*	1 2XR2*	2XR2X	0.0022	0.0467	0.0000	T	1	0	0	0
6	7*	1 3XR1*	3XR1Y	0.0017	0.0355	0.0000	T	1	0	0	0
6	16*	1 3XR1*	3XR1X	0.0022	0.0464	0.0000	T	1	0	0	0
8	9*	1 3XR2*	3XR2Y	0.0018	0.0382	0.0000	T	1	0	0	0
8	18*	1 3XR2*	3XR2X	0.0023	0.0477	0.0000	T	1	0	0	0
12*	24	1 2XR1X	2A04	0.0026	0.0039	0.0000	T	1	0	0	0
14*	26	1 2XR2X	2A06	0.0031	0.0048	0.0000	T	1	0	0	0
16*	34	1 3XR1X	3A04	0.0026	0.0040	0.0000	T	1	0	0	0
18*	36	1 3XR2X	3A06	0.0031	0.0047	0.0000	T	1	0	0	0
24*	34	1 2A04	3A04	0.0014	0.0017	0.0000	T	1	0	0	0
24	44*	1 2A04	2XU1Y	0.0031	0.0047	0.0000	T	1	0	0	0
24*	2403	1 2A04	2P012	0.0110	0.0083	0.0000	T	1	0	0	0
24*	2404	1 2A04	2P141	0.0176	0.0132	0.0000	T	1	0	0	0
24*	2405	1 2A04	2P024	0.0068	0.0051	0.0000	T	1	0	0	0
24*	2406	1 2A04	2P025-A	0.0097	0.0073	0.0000	T	1	0	0	0
24*	2407	1 2A04	2P015	0.0103	0.0078	0.0000	T	1	0	0	0
24*	2408	1 2A04	2P017	0.0104	0.0079	0.0000	T	1	0	0	0
24*	2409	1 2A04	2P018-A	0.0098	0.0074	0.0000	T	1	0	0	0
24*	2410	1 2A04	2P112	0.0118	0.0089	0.0000	T	1	0	0	0
24*	2411	1 2A04	2P307	0.0130	0.0097	0.0000	T	1	0	0	0
24*	2412	1 2A04	E336-U2	0.0140	0.0105	0.0000	T	1	0	0	0
24	2413*	1 2A04	2G002	0.0087	0.0106	0.0000	T	0	0	0	0
24*	2416	1 2A04	2T014	0.0015	0.0139	0.0000	T	1	0	0	0
24*	2420	1 2A04	2B04X	0.0015	0.0012	0.0000	T	1	0	0	0
26*	36	1 2A06	3A06	0.0011	0.0013	0.0000	T	0	0	0	0
26	46*	1 2A06	2XU1X	0.0032	0.0049	0.0000	T	0	0	0	0
26*	2603	1 2A06	2P504	0.0149	0.0112	0.0000	T	1	0	0	0
26*	2604	1 2A06	2P013	0.0104	0.0079	0.0000	T	1	0	0	0
26*	2605	1 2A06	2P026	0.0065	0.0049	0.0000	T	1	0	0	0
26*	2606	1 2A06	2P025-B	0.0098	0.0074	0.0000	T	1	0	0	0
26*	2607	1 2A06	2P016	0.0097	0.0073	0.0000	T	1	0	0	0
26*	2608	1 2A06	2P019	0.0088	0.0067	0.0000	T	1	0	0	0
26*	2609	1 2A06	2P018-B	0.0087	0.0065	0.0000	T	1	0	0	0
26*	2610	1 2A06	2P113	0.0095	0.0072	0.0000	T	1	0	0	0
26*	2611	1 2A06	2P114	0.0119	0.0090	0.0000	T	1	0	0	0
26*	2612	1 2A06	E335-U2	0.0123	0.0093	0.0000	T	1	0	0	0
26	2613*	1 2A06	2G003	0.0063	0.0077	0.0000	T	0	0	0	0
26*	2620	1 2A06	2B06X	0.0015	0.0012	0.0000	T	0	0	0	0
34	54*	1 3A08	3XU1Y	0.0031	0.0047	0.0000	T	0	0	0	0
34*	3402	1 3A04	E336-U3	0.0081	0.0061	0.0000	T	0	0	0	0
34*	3403	1 3A04	3P012	0.0102	0.0077	0.0000	T	0	0	0	0
34*	3404	1 3A04	3P141	0.0166	0.0125	0.0000	T	0	0	0	0
34*	3405	1 3A04	3P024	0.0101	0.0076	0.0000	T	0	0	0	0
34*	3406	1 3A04	3P025-A	0.0096	0.0072	0.0000	T	0	0	0	0
34*	3407	1 3A04	3P015	0.0104	0.0078	0.0000	T	0	0	0	0
34*	3408	1 3A04	3P017	0.0112	0.0084	0.0000	T	0	0	0	0
34*	3409	1 3A04	3P018-A	0.0096	0.0073	0.0000	T	0	0	0	0

CCN 9

Sheet No. 267  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: Upr 9-30-94 IRE: PL 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAM OROFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA  
THU, SEP 15 1994 14:47  
BRANCH DATA

FROM	TO	CKT	NAME	LINE R	LINE I	CHRGING	TP	ST	RATA	RATB	RATC	RATD
34*	3410	1	3A04	3P112	0.0110	0.0083	0.0000	1	0	0	0	0
34*	3411	1	3A04	3P307	0.0132	0.0099	0.0000	1	0	0	0	0
34*	3412	1	3A04	3P014	0.0142	0.0107	0.0000	1	0	0	0	0
34	3413*	1	3A04	3G002	0.0060	0.0073	0.0000	T	0	0	0	0
34*	3417	1	3A04	3B04X	0.0022	0.0016	0.0000	1	0	0	0	0
36	56*	1	3A06	3XU1X	0.0032	0.0049	0.0000	0	0	0	0	0
36*	3602	1	3A06	E335-U3	0.0087	0.0065	0.0000	1	0	0	0	0
36*	3604	1	3A06	3P013	0.0107	0.0081	0.0000	1	0	0	0	0
36*	3605	1	3A06	3P026	0.0072	0.0055	0.0000	1	0	0	0	0
36*	3606	1	3A06	3P025-B	0.0077	0.0058	0.0000	1	0	0	0	0
36*	3607	1	3A06	3P016	0.0099	0.0074	0.0000	1	0	0	0	0
36*	3608	1	3A06	3P019	0.0086	0.0065	0.0000	1	0	0	0	0
36*	3609	1	3A06	3P018-B	0.0079	0.0059	0.0000	1	0	0	0	0
36*	3610	1	3A06	3P113	0.0088	0.0066	0.0000	1	0	0	0	0
36*	3611	1	3A06	3P114	0.0115	0.0086	0.0000	1	0	0	0	0
36*	3612	1	3A06	3P504	0.0190	0.0143	0.0000	1	0	0	0	0
36	3613*	1	3A06	3G003	0.0063	0.0077	0.0000	T	0	0	0	0
36*	3619	1	3A06	3B05X	0.0017	0.0012	0.0000	1	0	0	0	0
41*	45	1	2XMS	2XU1*	0.0000	0.0007	0.0000	F	0	0	0	0
44*	45	1	2XU1Y	2XU1*	0.0021	0.0399	0.0000	F	0	0	0	0
45	46*	1	2XU1*	2XU1X	0.0021	0.0399	0.0000	T	0	0	0	0
51*	55	1	3XMS	3XU1*	0.0000	0.0007	0.0000	F	0	0	0	0
54*	55	1	3XU1Y	3XU1*	0.0021	0.0399	0.0000	F	0	0	0	0
55	56*	1	3XU1*	3XU1X	0.0021	0.0399	0.0000	T	0	0	0	0
214	2420*	1	2B04	2B04X	0.0960	0.6720	0.0000	T	1	0	0	0
214*	21402	1	2B04	2E61N	0.4985	0.5265	0.0000	1	0	0	0	0
214*	21403	1	2B04	2BBA	0.1055	0.1114	0.0000	1	0	0	0	0
214	21405*	1	2B04	2P191-A	1.1325	0.6523	0.0000	T	1	0	0	0
214*	21406	1	2B04	2E145	3.9484	1.4658	0.0000	1	0	0	0	0
214*	21407	1	2B04	2BD	1.7456	1.8436	0.0000	1	0	0	0	0
214	21409*	1	2B04	2A071	2.6447	0.9818	0.0000	T	1	0	0	0
214	21410*	1	2B04	2E399	1.2311	0.6910	0.0000	T	1	0	0	0
214	21411*	1	2B04	2E401	1.4868	0.8345	0.0000	T	1	0	0	0
214	21413*	1	2B04	2P190	1.0428	0.5853	0.0000	T	1	0	0	0
214*	21414	1	2B04	2BE	0.1021	0.1078	0.0000	1	0	0	0	0
214*	21415	1	2B04	2BY	0.0601	0.1117	0.0000	1	0	0	0	0
214*	21417	1	2B04	BQ-U2	0.1021	0.1078	0.0000	1	0	0	0	0
214	21418*	1	2B04	E418-U2	1.7020	0.9553	0.0000	T	1	0	0	0
214	21419*	1	2B04	2A074	3.2645	1.2119	0.0000	T	1	0	0	0
216	2620*	1	2B06	2B06X	0.0960	0.6720	0.0000	T	1	0	0	0
216*	21602	1	2B06	2E52N	0.5785	0.6109	0.0000	1	0	0	0	0
216*	21603	1	2B06	2BRB	0.0630	0.0665	0.0000	1	0	0	0	0
216*	21605	1	2B06	2BH	1.3866	1.4645	0.0000	1	0	0	0	0
216*	21606	1	2B06	2E146	4.3170	1.6027	0.0000	1	0	0	0	0
216*	21607	1	2B06	2BJ	0.1055	0.1114	0.0000	1	0	0	0	0
216	21609*	1	2B06	2A072	2.9279	1.0870	0.0000	T	1	0	0	0
216	21610*	1	2B06	2E400	1.7290	0.9794	0.0000	T	1	0	0	0
216	21611*	1	2B06	2E402	2.4051	1.3499	0.0000	T	1	0	0	0
216	21613*	1	2B06	2P192	1.5473	0.8685	0.0000	T	1	0	0	0
216*	21614	1	2B06	2BZ	0.0462	0.0859	0.0000	1	0	0	0	0
216	21615*	1	2B06	E419-U2	0.3504	0.2202	0.0000	T	1	0	0	0
216	21617*	1	2B06	2P191-B	1.6168	0.9242	0.0000	T	1	0	0	0
216*	21618	1	2B06	BS-U2	0.2178	0.2300	0.0000	1	0	0	0	0
216	21619*	1	2B06	2A073	3.7667	1.3984	0.0000	T	1	0	0	0
314	3417*	1	3B04	3B04X	0.0960	0.6720	0.0000	T	1	0	0	0
314*	31402	1	3B04	3E61N	0.4934	0.5211	0.0000	1	0	0	0	0

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E THU, SEP 15 1994 14:47  
 SAR ONOPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 BRANCH DATA  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

FROM	TO	CKT	NAME	NAME	LINE R	LINE X	CHRGING	TP	ST	RATA	RATB	RATC
314*	31403	1	3B04	3BRA	0.0851	0.0898	0.0000		1	0	0	0
314	31405*	1	3B04	3P191-A	1.3253	0.7439	0.0000	T	1	0	0	0
314*	31406	1	3B04	3E145	2.9119	1.0810	0.0000		1	0	0	0
314*	31407	1	3B04	3BD	1.7456	1.8436	0.0000		1	0	0	0
314	31409*	1	3B04	3A071	2.7997	1.0394	0.0000	T	1	0	0	0
314	31410*	1	3B04	3E399	1.2109	0.6797	0.0000	T	1	0	0	0
314	31411*	1	3B04	3E401	1.4128	0.7930	0.0000	T	1	0	0	0
314	31413*	1	3B04	3P190	1.0226	0.5740	0.0000	T	1	0	0	0
314*	31414	1	3B04	3BE	0.0749	0.0791	0.0000		1	0	0	0
314*	31415	1	3B04	3BY	0.0416	0.0773	0.0000		1	0	0	0
314*	31417	1	3B04	BQ-U3	0.3301	0.3486	0.0000		1	0	0	0
314	31418*	1	3B04	E418-U3	1.9913	1.1177	0.0000	T	1	0	0	0
314	31419*	1	3B04	3A074	3.4408	1.2774	0.0000	T	1	0	0	0
316	3619*	1	3B06	3B06X	0.0960	0.6720	0.0000	T	1	0	0	0
316*	31602	1	3B06	3E62N	0.5615	0.5930	0.0000		1	0	0	0
316*	31603	1	3B06	3BRB	0.0681	0.0719	0.0000		1	0	0	0
316*	31605	1	3B06	3BH	1.3713	1.4483	0.0000		1	0	0	0
316*	31606	1	3B06	3E146	4.2529	1.5789	0.0000		1	0	0	0
316*	31607	1	3B06	3BJ	0.1123	0.1186	0.0000		1	0	0	0
316	31609*	1	3B06	3A072	3.2057	1.1901	0.0000	T	1	0	0	0
316	31610*	1	3B06	3E400	1.7659	0.9912	0.0000	T	1	0	0	0
316	31611*	1	3B06	3E402	2.4757	1.3896	0.0000	T	1	0	0	0
316	31613*	1	3B06	3P192	1.5473	0.8685	0.0000	T	1	0	0	0
316*	31614	1	3B06	3BZ	0.0462	0.0859	0.0000		1	0	0	0
316	31615*	1	3B06	E419-U3	0.6262	0.3751	0.0000	T	1	0	0	0
316	31617*	1	3B06	3P191-B	1.5473	0.8685	0.0000	T	1	0	0	0
316*	31618	1	3B06	BS-U3	0.4151	0.4384	0.0000		1	0	0	0
316	31619*	1	3B06	3A073	3.8682	1.4361	0.0000	T	1	0	0	0
21403*	22403	1	2BRA	2BRA-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21403*	23403	1	2BRA	2BRA-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21407*	22407	1	2BD	2BD-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21407*	23407	1	2BD	2BD-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21407	24412*	1	2BD	2A274	0.5272	0.0961	0.0000	T	1	0	0	0
21407	24413*	1	2BD	2A275	1.0033	0.1828	0.0000	T	1	0	0	0
21407	24421*	1	2BD	2E550	1.4454	0.2634	0.0000	T	1	0	0	0
21407	24422*	1	2BD	2E546	1.3094	0.2386	0.0000	T	1	0	0	0
21414*	22414	1	2BE	2BE-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21414*	23414	1	2BE	2BE-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21415*	22415	1	2BY	2BY-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21415*	23415	1	2BY	2BY-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21415	24434*	1	2BY	2P009	4.4724	0.8150	0.0000	T	1	0	0	0
21417*	22417	1	BQ-U2	BQ-U2-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21417*	23417	1	BQ-U2	BQ-U2-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21417	24417*	1	BQ-U2	P162-U2	3.9792	0.7252	0.0000	T	1	0	0	0
21603*	22603	1	2BRB	2BRB-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21603*	23603	1	2BRB	2BRB-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21605*	22605	1	2BH	2BH-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21605*	23605	1	2BH	2BH-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21605	24606*	1	2BH	2E547	1.1904	0.2169	0.0000	T	1	0	0	0
21605	24607*	1	2BH	2E549	1.3604	0.2479	0.0000	T	1	0	0	0
21605	24611*	1	2BH	2A276	0.4932	0.0899	0.0000	T	1	0	0	0
21605	24612*	1	2BH	2A277	0.9183	0.1673	0.0000	T	1	0	0	0
21607*	22607	1	2BJ	2BJ-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21607*	23607	1	2BJ	2BJ-S	0.0000	0.0001	0.0000	Z	1	0	0	0
21614*	22614	1	2BZ	2BZ-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21614*	23614	1	2BZ	2BZ-S	0.0000	0.0001	0.0000	Z	1	0	0	0

Calc No: E4C-082 CN N-3 Rev. 1  
 RE: Pen 9-30-94 IRE: AP 10-5-94  
 Sheet No. 268

CEN 9

CCN9

Sheet No. 269  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: Upm 9-30-94 IRE: 10-5-98

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

TRU, SEP 15 1994 14:47  
BRANCH DATA

FROM	REV	TO	CTY	NAME	LINE R	LINE X	CHRGING	TP	ST	RATA	RATB	RATC
21614	24622*	1	282	2P010	4.5914	0.8367	0.0000	T	1	0	0	0
21618*	22618	1	BS-U2	BS-U2-M	0.0000	0.0001	0.0000	Z	1	0	0	0
21618*	23618	1	BS-U2	BS-U2-S	0.0030	0.0001	0.0000	Z	1	0	0	0
21618	24618*	1	RS-U2	P160-U2	1.9726	0.3595	0.0000	T	1	0	0	0
31403*	32403	1	3B2A	3BRA-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31403*	33403	1	3B2A	3BRA-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31407*	32407	1	3B2D	3BD-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31407*	33407	1	3B2D	3BD-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31407	34412*	1	3B2D	3A274	0.4932	0.0899	0.0000	T	1	0	0	0
31407	34413*	1	3B2D	3A275	1.0203	0.1859	0.0000	T	1	0	0	0
31407	34421*	1	3B2D	3E550	1.5135	0.2758	0.0000	T	1	0	0	0
31407	34422*	1	3B2D	3E546	1.2584	0.2293	0.0000	T	1	0	0	0
31414*	32414	1	3B2E	3BE-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31414*	33414	1	3B2E	3BS-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31415*	32415	1	3B2Y	3BY-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31415*	33415	1	3B2Y	3BY-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31415	34434*	1	3B2Y	3F009	3.9962	0.7283	0.0000	T	1	0	0	0
31417*	32417	1	BQ-U3	BQ-U3-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31417*	33417	1	BQ-U3	BQ-U3-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31417	34417*	1	BQ-U3	P162-U3	3.9792	0.7252	0.0000	T	1	0	0	0
31603*	32603	1	3B2R	3BRB-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31603*	33603	1	3B2R	3BRB-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31605*	32605	1	3B2H	3BH-M	6.0030	0.0001	0.0000	Z	1	0	0	0
31605*	33605	1	3B2H	3BH-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31605	34606*	1	3B2H	3E547	1.2584	0.2293	0.0000	T	1	0	0	0
31605	34607*	1	3B2H	3E549	1.3604	0.2479	0.0000	T	1	0	0	0
31605	34611*	1	3B2H	3A276	0.4251	0.0775	0.0000	T	1	0	0	0
31605	34612*	1	3B2H	3A277	0.9693	0.1766	0.0000	T	1	0	0	0
31607*	32607	1	3B2J	3BJ-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31607*	33607	1	3B2J	3BJ-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31614*	32614	1	3B2Z	3BZ-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31614*	33614	1	3B2Z	3BZ-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31614	34622*	1	3B2Z	3P010	4.8805	0.8894	0.0000	T	1	0	0	0
31618*	32618	1	BS-U3	BS-U3-M	0.0000	0.0001	0.0000	Z	1	0	0	0
31618*	33618	1	BS-U3	BS-U3-S	0.0000	0.0001	0.0000	Z	1	0	0	0
31618	34618*	1	BS-U3	P160-U3	1.9726	0.3595	0.0000	T	1	0	0	0

FROM	TO	CKT	TP	RATIO	ANGLE	RG	CONT	RMAX	RMIN	VMAX	VMIN	STEP	TAB
1	2	1	F	0.9750	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
1	4	1	F	0.9750	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
1	6	1	F	0.9750	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
1	8	1	F	0.9750	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
1	41	1	T	0.9727	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
1	51	1	T	0.9727	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
2	3	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
2	12	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
4	5	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
4	14	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
6	7	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
6	16	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
8	9	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
8	18	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
24	2413	1	T	0.9541	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
26	2613	1	T	0.9541	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
34	3413	1	T	0.9541	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
36	3613	1	T	0.9541	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
41	45	1	F	0.9500	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
44	45	1	F	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
45	46	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
51	55	1	F	0.9500	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
54	55	1	F	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
55	56	1	T	1.0481	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	2420	1	T	0.9988	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21405	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21409	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21410	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21411	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21413	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21418	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
214	21419	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	2620	1	T	0.9988	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21609	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21610	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21611	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21613	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21615	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21617	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
216	21619	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	3417	1	T	0.9988	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31405	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31409	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31410	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31411	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31413	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31418	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
314	31419	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	3619	1	T	0.9988	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31609	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31610	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31611	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31613	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31615	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31617	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
316	31619	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: *CPM 9-30-94* IRE: *RL 10-5-94*  
 Sheet No. 270

*CCN 9*

FROM	TO	CKT	TP	RATIO	ANGLE	RG	CONT	RMAX	RMIN	VMAX	VMIN	STEP	TAB
21407	24412	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21407	24413	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21407	24421	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21407	24422	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21415	24434	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21417	24417	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21605	24606	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21605	24607	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21605	24611	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21605	24612	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21614	24622	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
21618	24618	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31407	34412	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31407	34413	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31407	34421	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31407	34422	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31415	34434	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31417	34417	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31605	34606	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31605	34607	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31605	34611	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31605	34612	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31614	34622	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	
31618	34618	1	T	1.0435	0.00	1	0	1.5000	0.5100	1.5000	0.5100	0.00625	

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPW 9-30-94 IRE: PL 10-5-94  
 Sheet No. 271

2029



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E      THU, SEP 15 1994 14:47  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3      LINE SHUNT DATA  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA  
X-----FROM-----X X-----TO-----X CKT    LINE G,B (FROM)    LINE G,B (TO) ST

\* NONE \*

Calc No:	<u>E4C-082</u>	CCN	<u>N-3</u>	Rev.	<u>1</u>	Sheet No.	<u>272</u>
RE:	<u>LPW</u>	<u>9-30-94</u>	IRE:	<u>DL</u>	<u>10-5-94</u>		

GEN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAN ONOPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

THU, SEP 15 1994 14:47  
DC LINE DATA

\* NONE \*

Calc No:	<u>E4C-082</u>	CCN	<u>N-3</u>	Sheet No.	<u>273</u>
RE:	<u>Open 9-30-94</u>	REV.	<u>1</u>		
		IRE:	<u>Ad 10-5-94</u>		

*Can 9*

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E THU, SEP 15 1994 14:47  
 SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 AREA DATA  
 E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA  
 X-- AREA --X X----- AREA SWING -----X X--- DESIRED ---X

BUS#	NAME	BSKV	PGEN	PMAX	PMIN	INTERCHANGE	TOLER	BUSES
1	0					0.0	10.0	199
SUMMATION:						0.0		

Calc No: E4C-082 Sheet No. 274  
 RE: CCN N-3 Rev. 1  
 RE: PM 9-30-94 RE: AL 10-5-94

*CCN 9*

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-682, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA

THU, SEP 15 1994 14:47  
TRANSFORMER 2  
CORRECTION DATA

\* NONE \*

Calc No:	<u>E4C-082</u>	Sheet No.	<u>275</u>
RE:	<u>CPM 9-30-94</u>	CCN	<u>N-3</u>
		REV.	<u>1</u>
		IRE:	<u>RD 10-5-94</u>

Can 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E      THU, SEP 15 1994 14:47  
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3      MULTI-SECTION  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA      LINE DATA  
X----- MULTI-SECTION LINE GROUPING -----X X----- LINE SECTIONS -----X  
X----- FROM -----X X----- TO -----X ID X----- FROM -----X X----- TO -----X CKT

\* NONE \*

Calc No:	<u>E4C-082</u>	CCN	<u>N-3</u>	Rev.	<u>1</u>	Sheet No.	<u>276</u>
RE:	<u>CPM</u>	<u>9-30-94</u>	IRE:	<u>RL</u>	<u>10-5-94</u>		

CCN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
SAN ONOPRE NUCLEAR GENERATING STATION, UNITS 2 AND 3  
E4C-082, REV 1 - SYSTEM DYNAMIC VOLTAGES DURING A DBA  
X-- ZONE --X BUSES  
1 199

THU, SEP 15 1994 14:47  
ZONE DATA

Calc No: <u>E4C-082</u>	Sheet No. <u>277</u>
RE: <u>LPW 9-30-94</u>	CCN <u>N-3</u>
RE: <u>RL 10-5-94</u>	Rev. <u>1</u>

CCN 9

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./  
 PRELIM. CCN NO. **N-3** PAGE **278** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
 CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURTEL	9-30-94	A. M. PATEL	10-5-99					

**APPENDIX 9.1.2**

Dynamic Simulation Data

ALL BUSES

\*\*\* CALL GENCLS( 1, '1', 1, 1, 1) \*\*\*

BUS	NAME	BASKV	MACH	KOUNT	C	O	N	'	S	STATE'S	SLOT		
1	SYSTEM	230	1	1	1-	2	1-	2	1				
MBASE	Z	S	R	C	E	X	T	R	A	N	GENTAP	H	DAMP
10.0	0.00004+J	0.00108	0.00000+J	0.00000	1.00000	0.00	0.00	0.000					

Calc No:	E4C-082	CCN	N-3	Rev:	1	Sheet No:	279
RE:	LPW 9-30-94	IRE:	RL 10-5-94				

CCN 9



ALL BUSES

\*\* GENSAL \*\* BUS NAME BASKV MACH C O N ' S STATE'S  
 2413 2G002 4.36 1 3- 14 3- 7

MBASE Z S O R C E X T R A N GENTAP  
 5.9 0.00000+J 0.10700 0.00000+J 0.00000 1.00000

T'DO T''DO T''Q0 H P XD XQ X'D X''D XL  
 5.350 0.050 0.050 1.71 0.00 0.9987 0.7261 0.2020 0.1070 0.0740

S(1.0) S(1.2)  
 0.0750 0.2100

\*\*\* CALL IESEVC( 2413,'1', 2, 51) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S S L O T RC XC  
 2413 2G002 4.36 1 2 51- 52 2 -0.00513 -0.00623

\*\*\* CALL IEET2( 2413,'1', 2, 59, 23, 1) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S VAR S L O T  
 2413 2G002 4.36 1 2 59- 72 23- 27 1 2

TR KA TA VRMAX VRMIN KE TE KF TF1 TF2  
 0.000 500.00 0.020 3.600 0.000 0.650 0.130 0.030 0.590 0.140

E1 S(E1) E2 S(E2) KE VAR  
 4.0000 0.0000 5.5000 0.0000 0.0000

\*\*\* CALL DEGOV( 2413,'1', 2, 115, 43, 5) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S V A R ' S S L O T  
 2413 2G002 4.36 1 2 115- 124 43- 47 5- 17 2

T1 T2 T3 K T4 T5 T6 TD TMAX TMIN  
 0.022 0.000 0.060 60.000 0.250 0.039 0.009 0.020 0.850 -0.500

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: RD 10-5-94  
 Sheet No. 280

2809

ALL BUSES

\*\* GENSAL \*\* BUS NAME BASKV MACH C O N ' S STATE'S  
 2613 2G003 4.36 1 15- 26 8- 12

MBASE E S O R C E X T R A N GENTAP  
 5.9 0.00000+J 0.10700 0.90000+J 0.00000 1.00000

T'DO T''DO T''QO H DAMP XD XQ X'D X''D XL  
 5.350 0.050 0.000 1.71 0.00 0.9987 0.7261 0.2020 0.1070 0.0740

S(1.0) S(1.2)  
 0.0750 0.2100

\*\*\* CALL IEEVC( 2613,'1', 3, 53) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S S L O T R C X C  
 2613 2G003 4.36 1 3 53- 54 3 -0.00371 -0.00451

\*\*\* CALL IEEET2( 2613,'1', 3, 73, 28, 2) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S VAR S L O T  
 2613 2G003 4.36 1 3 73- 86 28- 32 2 3

TR KA TA VRMAX VRMIN KE TE KF TP1 TP2  
 0.000 500.00 0.020 3.600 0.000 0.650 0.130 0.030 0.590 0.140

E1 S(E1) E2 S(E2) KE VAR  
 4.0000 0.0000 5.5000 0.0000 0.0000

\*\*\* CALL DEGOV( 2613,'1', 3, 125, 48, 18) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S V A R ' S S L O T  
 2613 2G003 4.36 1 3 125- 134 48- 52 18- 30 3

T1 T2 T3 K T4 T5 T6 TD TMAX TMIN  
 0.022 0.000 0.060 60.000 0.250 0.039 0.009 0.020 0.850 -0.500

Calc No: <u>E4C-082</u>	Sheet No. <u>281</u>
RE: <u>CPM 9-30-94</u>	Rev. <u>1</u>
IRE: <u>RL 10-5-94</u>	

CCN 9

ALL BUSES

\*\* GENSL \*\* BUS NAME BASKV MACH C O N ' S STATE'S  
 3413 3G002 4.36 1 27- 38 13- 17

MBASE E S O R C E X T R A N GENTAP  
 5.9 0.00000+J 0.10700 0.00000+J 0.00000 1.00000

T'D0 T'ID0 T'ID0 H DAMP ND NG E'D K'D XL  
 5.350 0.050 0.050 1.71 0.00 0.9987 0.7261 0.2020 0.1070 0.0740

S(1.0) S(1.2)  
 0.0750 0.2100

\*\*\* CALL IEIEVC( 3413,'1', 4, 55) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S SLOT RC XC  
 3413 3G002 4.36 1 4 55- 56 4 -0.00351 -0.00427

\*\*\* CALL IEIET2( 3413,'1', 4, 87, 33, 3) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S VAR SLOT  
 3413 3G002 4.36 1 4 87- 100 33- 37 3 4

TR KA TA VRMAX VRMIN KE TE KF TP1 TP2  
 0.000 500.00 0.020 3.600 0.000 0.650 0.130 0.030 0.590 0.140

E1 S(E1) E2 S(E2) KE VAR  
 4.0000 0.0000 5.5000 0.0000 0.0000

\*\*\* CALL DEGOV( 3413,'1', 4, 135, 53, 31) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S V A R ' S SLOT  
 3413 3G002 4.36 1 4 135- 144 53- 57 31- 43 4

T1 T2 T3 K T4 T5 T6 TD TMAX TMIN  
 0.022 0.000 0.060 60.000 0.250 0.039 0.009 0.020 0.850 -0.500

Calc No:	E4C-082	CEN	N-3	Rev.	1
RE:	Pen	9-30-94	RE:	PL 10-5-94	
Sheet No.	282				

Pen 9

ALL BUSES

\*\* GENSAL \*\* BUS NAME BASKV MACH C O N ' S STATE'S  
 3613 3G003 4.36 1 39- 50 18- 22

MBASE Z S O R C E X T R A N GENTAP  
 5.9 0.00000+J 0.10700 0.00000+J 0.00000 1.00000

T'DO T''DO T''QO H DAMP XD XQ X'D X''D XL  
 4.350 0.050 0.050 1.71 0.00 0.9987 0.7261 0.2020 0.1070 0.0740

S(1.0) S(1.2)  
 0.0750 0.2100

\*\*\* CALL IEEVC( 3613,'1', 5, 57) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S SLOT RC KC  
 3613 3G003 4.36 1 5 57- 58 5 -0.00371 -0.00451

\*\*\* CALL IEEET2( 3613,'1', 5, 101, 38, 4) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S VAR SLOT  
 3613 3G003 4.36 1 5 101- 114 38- 42 4 5

TR KA TA VRMAX VRMIN KE TE KP TP1 TP2  
 0.000 500.00 0.020 3.600 0.000 0.650 0.130 0.030 0.590 0.140

E1 S(E1) E2 S(E2) KE VAR  
 4.0000 0.0000 5.5000 0.0000 0.0000

\*\*\* CALL DEGOV( 3613,'1', 5, 145, 58, 44) \*\*\*

BUS NAME BSVLT MACH KOUNT C O N ' S STATE'S V A R ' S SLOT  
 3613 3G003 4.36 1 5 145- 154 58- 62 44- 56 5

T1 T2 T3 R T4 T5 T6 TD TMAX TMIN  
 0.022 0.000 0.060 60.000 0.250 0.039 0.009 0.020 0.850 -0.500

Calc No: <u>E4C-082</u>	Sheet No. <u>283</u>
RE: <u>pm 9-30-94</u>	Rev. <u>1</u>
IRE: <u>RU 10-5-94</u>	

2839

CONEC MODELS

\*\*\* CALL CMOTOR( 1, 155, 162, 63, 57, 167) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2403	2P012	4.16	1	155-	161	1J2-	166	63	57- 64		167

RA	LA	LM	R1	L1	R2	L2
0.019	0.077	3.200	0.050	0.077	0.027	0.063

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.45	0.420	2.000	0.01350		0.689	0.7000

\*\*\* CALL CMOTOR( 2, 168, 175, 64, 65, 180) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2404	2P141	4.16	2	168-	174	175-	179	64	65- 72		180

RA	LA	LM	R1	L1	R2	L2
0.004	0.065	3.680	0.029	0.068	0.004	0.050

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.68	1.196	2.000	0.00600		0.983	0.7000

\*\*\* CALL CMOTOR( 3, 181, 188, 65, 73, 193) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2405	2P024	4.16	3	181-	187	188-	192	65	73- 80		193

RA	LA	LM	R1	L1	R2	L2
0.025	0.068	2.500	0.042	0.068	0.017	0.040

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.55	0.304	2.000	0.01160		0.849	0.7000

\*\*\* CALL CMOTOR( 4, 194, 201, 66, 81, 206) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2406	2P025-A	4.16	4	194-	200	201-	205	66	81- 88		206

RA	LA	LM	R1	L1	R2	L2
0.025	0.068	2.500	0.042	0.068	0.017	0.040

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.55	0.304	2.000	0.01160		0.849	0.7000

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: pm 9-30-94 IRE: AD 10-5-94  
 Sheet No. 284

*Ken 9*

\*\*\* CALL CMOTOR( 5, 207, 214, 67, 89, 219) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2407	2P015	4.16	5	207-	213	214-	218	67	89- 96		219

RA	LA	LM	R1	L1	R2	L2
0.019	0.077	3.200	0.050	0.077	0.027	0.063

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.45	0.420	2.000	0.01670		0.850	0.7000

\*\*\* CALL CMOTOR( 6, 220, 227, 68, 97, 232) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2408	2P017	4.16	6	220-	226	227-	231	68	97- 104		232

RA	LA	LM	R1	L1	R2	L2
0.010	0.068	4.100	0.072	0.068	0.031	0.071

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.52	0.870	2.000	0.01820		0.778	0.7000

\*\*\* CALL CMOTOR( 7, 233, 240, 69, 105, 245) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2409	2P018-A	4.16	7	233-	239	240-	244	69	105- 112		245

RA	LA	LM	R1	L1	R2	L2
0.010	0.068	4.100	0.072	0.068	0.031	0.071

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.52	0.870	2.000	0.01820		0.778	0.7000

\*\*\* CALL CMOTOR( 8, 246, 253, 70, 113, 258) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2410	2P112	4.16	8	246-	252	253-	257	70	113- 120		258

RA	LA	LM	R1	L1	R2	L2
0.034	0.095	2.157	0.020	0.070	0.140	0.005

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.38	0.233	2.000	0.01720		0.832	0.7000

\*\*\* CALL CMOTOR( 9, 259, 266, 71, 121, 271) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2411	2P307	4.16	9	259-	265	266-	270	71	121- 128		271

RA	LA	LM	R1	L1	R2	L2
0.034	0.095	2.157	0.020	0.070	0.140	0.005

Calc No: E4C-082 CCN N-3 Rev. 1  
RE: CPM 9-20-94 IRE: AL 10-5-94  
Sheet No. 285

QCN 9

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.38	0.233	2.000	0.01720	0.832	0.7000

\*\*\* CALL CMOTOR( 10, 272, 279, 72, 129, 284) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2412	E336-U2	4.16	10	272-	278	279-	283	72	129- 136		284

RA	LA	LM	R1	L1	R2	L2
0.019	0.080	3.050	0.040	0.095	0.030	0.130

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.53	0.209	2.000	0.01670	0.856	0.7000

\*\*\* CALL CMOTOR( 11, 285, 292, 73, 137, 297) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2603	2P504	4.16	11	285-	291	292-	296	73	137- 144		297

RA	LA	LM	R1	L1	R2	L2
0.004	0.065	3.680	0.029	0.068	0.004	0.050

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.68	1.196	2.000	0.00600	0.983	0.7000

\*\*\* CALL CMOTOR( 12, 298, 305, 74, 145, 310) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2604	2P013	4.16	12	298-	304	305-	309	74	145- 152		310

RA	LA	LM	R1	L1	R2	L2
0.019	0.077	3.200	0.050	0.077	0.027	0.063

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.45	0.420	2.000	0.01350	0.689	0.7000

\*\*\* CALL CMOTOR( 13, 311, 318, 75, 153, 323) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2605	2P026	4.16	13	311-	317	318-	322	75	153- 160		323

RA	LA	LM	R1	L1	R2	L2
0.025	0.068	2.500	0.042	0.068	0.017	0.040

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.55	0.304	2.000	0.01160	0.849	0.7000

\*\*\* CALL CMOTOR( 14, 324, 331, 76, 161, 336) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
-----	------	-------	------	---------	-------	--------	-------	-------	-----------	-----	-----

Calc No:	E4C-082	CCN	N-3	Rev.	1
RE:	Lpm 9-30-94				
IRE:	R1 10-5-94				
Sheet No.	286				

CCN 9

2606 2P025-B 4.16 14 324- 330 331- 335 76 161- 168 336

RA	LA	LM	R1	L1	R2	L2
0.025	0.068	2.500	0.042	0.068	0.017	0.040
MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL	
0.55	0.304	2.006	0.01160	0.849	0.7000	

\*\*\* CALL CMOTOR( 15, 337, 344, 77, 169, 349) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON

2607 2P016 4.16 15 337- 343 344- 348 77 169- 176 349

RA	LA	LM	R1	L1	R2	L2
0.019	0.077	3.200	0.050	0.077	0.027	0.063
MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL	
0.45	0.420	2.000	0.01670	0.850	0.7000	

\*\*\* CALL CMOTOR( 16, 350, 357, 78, 177, 362) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON

2608 2P019 4.16 16 350- 356 357- 361 78 177- 184 362

RA	LA	LM	R1	L1	R2	L2
0.010	0.068	4.100	0.072	0.068	0.031	0.071
MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL	
0.52	0.870	2.000	0.01820	0.778	0.7000	

\*\*\* CALL CMOTOR( 17, 363, 370, 79, 185, 375) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON

2609 2P018-B 4.16 17 363- 369 370- 374 79 185- 192 375

RA	LA	LM	R1	L1	R2	L2
0.010	0.068	4.100	0.072	0.068	0.031	0.071
MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL	
0.52	0.870	2.000	0.01820	0.778	0.7000	

\*\*\* CALL CMOTOR( 18, 376, 383, 80, 193, 388) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON

2610 2P113 4.16 18 376- 382 383- 387 80 193- 200 388

RA	LA	LM	R1	L1	R2	L2
0.034	0.095	2.157	0.020	0.070	0.140	0.005
MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL	
0.38	0.233	2.000	0.01720	0.832	0.7000	

Calc No: EFC-082 CAN N-3 Rev. 1 Sheet No. 287

RE: CPM 9-30-94 IRE: AL 10-5-94

CAN 9



\*\*\* CALL CMOTOR( 19, 389, 396, 81, 201, 401) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2611	2P114	4.16	19	389-	395	396-	400	81	201- 208		401

RA	LA	LM	R1	L1	R2	L2
0.034	0.095	2.157	0.020	0.070	0.140	0.005

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.38	0.233	2.000	0.01720		0.832	0.7000

\*\*\* CALL CMOTOR( 20, 402, 409, 82, 209, 414) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2612	E335-U2	4.16	20	402-	408	409-	413	82	209- 216		414

RA	LA	LM	R1	L1	R2	L2
0.019	0.380	3.050	0.040	0.095	0.030	0.130

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.53	0.209	2.000	0.01670		0.856	0.7000

\*\*\* CALL CMOTOR( 21, 415, 422, 83, 217, 427) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3402	E336-U3	4.16	21	415-	421	422-	426	83	217- 224		427

RA	LA	LM	R1	L1	R2	L2
0.019	0.080	3.050	0.040	0.095	0.030	0.130

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.53	0.209	2.000	0.01670		0.856	0.7000

\*\*\* CALL CMOTOR( 22, 428, 435, 84, 225, 440) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3403	3P012	4.16	22	428-	434	435-	439	84	225- 232		440

RA	LA	LM	R1	L1	R2	L2
0.019	0.077	3.200	0.050	0.077	0.027	0.063

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.45	0.420	2.000	0.01350		0.689	0.7000

\*\*\* CALL CMOTOR( 23, 441, 448, 85, 233, 453) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3404	3P141	4.16	23	441-	447	448-	452	85	233- 240		453

RA	LA	LM	R1	L1	R2	L2
----	----	----	----	----	----	----

RE: CPW 9-30-94 IRE: AL 10-5-94  
Calc No: E4C-082 CCN N-3 Rev: 1  
Sheet No: 288

CCN 9

0.004 0.065 3.680 0.029 0.068 0.004 0.050

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.68 1.196 2.000 0.00600 0.983 0.7000

\*\*\* CALL CMOTOR( 24, 454, 461, 86, 241, 466) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3405 3P024 4.16 24 454- 460 461- 465 86 241- 248 466

RA LA LM R1 L1 R2 L2  
0.025 0.068 2.500 0.042 0.068 0.017 0.040

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.55 0.304 2.000 0.01160 0.849 0.7000

\*\*\* CALL CMOTOR( 25, 467, 474, 87, 249, 479) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3406 3P025-A 4.16 25 467- 473 474- 478 87 249- 256 479

RA LA LM R1 L1 R2 L2  
0.025 0.068 2.500 0.042 0.068 0.017 0.040

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.55 0.304 2.000 0.01160 0.849 0.7000

\*\*\* CALL CMOTOR( 26, 480, 487, 88, 257, 492) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3407 3P015 4.16 26 480- 486 487- 491 88 257- 264 492

RA LA LM R1 L1 R2 L2  
0.019 0.077 3.200 0.050 0.077 0.027 0.063

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.45 0.420 2.000 0.01670 0.850 0.7000

\*\*\* CALL CMOTOR( 27, 493, 500, 89, 265, 505) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3408 3P017 4.16 27 493- 499 500- 504 89 265- 272 505

RA LA LM R1 L1 R2 L2  
0.010 0.068 4.100 0.072 0.068 0.031 0.071

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.52 0.870 2.000 0.01820 0.778 0.7000

\*\*\* CALL CMOTOR( 28, 506, 513, 90, 273, 518) \*\*\*

Call No: Edc-082 CCN N-3 Rev. 1  
RE: Lpm 9-80-94 IRE: R1 10-5-94  
Sheet No. 289

289

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 3409 3P018-A 4.16 28 506- 512 513- 517 90 273- 280 518

RA LA LM R1 L1 R2 L2  
 0.010 0.068 4.100 0.072 0.068 0.031 0.071

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.52 0.870 2.000 0.01820 0.778 0.7000

\*\*\* CALL CMOTOR( 29, 519, 526, 91, 281, 531) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 3410 3P112 4.16 29 519- 525 526- 530 91 281- 288 531

RA LA LM R1 L1 R2 L2  
 0.034 0.095 2.157 0.020 0.070 0.140 0.005

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.38 0.233 2.000 0.01720 0.832 0.7000

\*\*\* CALL CMOTOR( 30, 532, 539, 92, 289, 544) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 3411 3P307 4.16 30 532- 538 539- 543 92 289- 296 544

RA LA LM R1 L1 R2 L2  
 0.034 0.095 2.157 0.020 0.070 0.140 0.005

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.38 0.233 2.000 0.01720 0.832 0.7000

\*\*\* CALL CMOTOR( 31, 545, 552, 93, 297, 557) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 3602 E335-U3 4.16 31 545- 551 552- 556 93 297- 304 557

RA LA LM R1 L1 R2 L2  
 0.019 0.080 3.050 0.040 0.095 0.030 0.130

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.53 0.209 2.000 0.01670 0.856 0.7000

\*\*\* CALL CMOTOR( 32, 558, 565, 94, 305, 570) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 3604 3P013 4.16 32 558- 564 565- 569 94 305- 312 570

RA LA LM R1 L1 R2 L2  
 0.019 0.077 3.200 0.050 0.077 0.027 0.063

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL

Calc No: E4C-082 CCN N-3 Sheet No. 290  
 RE: CPM 9-20-94 IRE: PL 10-5-94 Rev. 1

CAN 9

0.45 0.420 2.000 0.01350 0.689 0.7000

\*\*\* CALL CMOTOR( 33, 571, 578, 95, 313, 583) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3605	3P026	4.16	33	571-	577	578-	582	95	313- 320		583
	RA	LA	LM	R1	L1	R2	L2				
	0.025	0.068	2.500	0.042	0.068	0.017	0.040				
	MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL			
		0.55	0.304	2.000	0.01160		0.849	0.7000			

\*\*\* CALL CMOTOR( 34, 584, 591, 96, 321, 596) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3606	3P025-B	4.16	34	584-	590	591-	595	96	321- 328		596
	RA	LA	LM	R1	L1	R2	L2				
	0.025	0.068	2.500	0.042	0.068	0.017	0.040				
	MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL			
		0.55	0.304	2.000	0.01160		0.849	0.7000			

\*\*\* CALL CMOTOR( 35, 597, 604, 97, 329, 609) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3607	3P016	4.16	35	597-	603	604-	608	97	329- 336		609
	RA	LA	LM	R1	L1	R2	L2				
	0.019	0.077	3.200	0.050	0.077	0.027	0.063				
	MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL			
		0.45	0.420	2.000	0.01670		0.850	0.7000			

\*\*\* CALL CMOTOR( 36, 610, 617, 98, 337, 622) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3608	3P019	4.16	36	610-	616	617-	621	98	337- 344		622
	RA	LA	LM	R1	L1	R2	L2				
	0.010	0.068	4.100	0.072	0.068	0.031	0.071				
	MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL			
		0.52	0.870	2.000	0.01820		0.778	0.7000			

\*\*\* CALL CMOTOR( 37, 623, 630, 99, 345, 635) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3609	3P018-B	4.16	37	623-	629	630-	634	99	345- 352		635

Calc No:	E4C-082	Sheet No:	291
RE:	Open 9-20-94	CCN	N-3
IRE:	RD 10-5-94	Rev:	1

CCN 9

RA	LA	LM	R1	L1	R2	L2
0.010	0.068	4.100	0.072	0.068	0.031	0.071

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.52	0.870	2.000	0.01820	0.778	0.7000

\*\*\* CALL CMOTOR( 38, 636, 643, 100, 353, 648) \*\*\*

BUS NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3610 3P113	4.16	38	636-	642	643-	647	100	353- 360		648

RA	LA	LM	R1	L1	R2	L2
0.034	0.035	2.157	0.020	0.070	0.140	0.005

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.38	0.233	2.000	0.01720	0.832	0.7000

\*\*\* CALL CMOTOR( 39, 649, 656, 101, 361, 661) \*\*\*

BUS NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3611 3P114	4.16	39	649-	655	656-	660	101	361- 368		661

RA	LA	LM	R1	L1	R2	L2
0.034	0.095	2.157	0.020	0.070	0.140	0.005

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.38	0.233	2.000	0.01720	0.832	0.7000

\*\*\* CALL CMOTOR( 40, 662, 669, 102, 369, 674) \*\*\*

BUS NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3612 3P504	4.16	40	662-	668	669-	673	102	369- 376		674

RA	LA	LM	R1	L1	R2	L2
0.004	0.065	3.680	0.029	0.068	0.004	0.050

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.68	1.196	2.000	0.00600	0.983	0.7000

\*\*\* CALL CMOTOR( 41, 675, 682, 103, 377, 687) \*\*\*

BUS NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21405 2P191-A	0.46	41	675-	681	682-	686	103	377- 384		687

RA	LA	LM	R1	L1	R2	L2
0.000	0.065	3.202	0.065	0.085	0.019	0.220

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.10	0.314	2.000	0.00970	0.593	0.7000

Calc No:	E4C-082	CCN	N-3	Rev.	1
RE:	CPM	9-30-94	RE:	AL	10-5-98
Sheet No.	292				

CCN 9

\*\*\* CALL CMOTOR( 42, 688, 695, 104, 385, 700) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21409	2A071	0.46	42	688-	694	695-	699	104	385- 392		700

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.06	2.950	2.000	0.00940		0.962	0.7000

\*\*\* CALL CMOTOR( 43, 701, 708, 105, 393, 713) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21410	2E399	0.46	43	701-	707	708-	712	105	393- 400		713

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	1.771	2.000	0.00810		0.614	0.7000

\*\*\* CALL CMOTOR( 44, 714, 721, 106, 401, 726) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21411	2E401	0.46	44	714-	720	721-	725	106	401- 408		726

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	1.771	2.000	0.00810		0.614	0.7000

\*\*\* CALL CMOTOR( 45, 727, 734, 107, 409, 739) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21413	2P190	0.46	45	727-	733	734-	738	107	409- 416		739

RA	LA	LM	R1	L1	R2	L2
0.000	0.065	3.202	0.065	0.085	0.019	0.220

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	0.314	2.000	0.00970		0.593	0.7000

\*\*\* CALL CMOTOR( 46, 740, 747, 108, 417, 752) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21418	E418-U2	0.46	46	740-	746	747-	751	108	417- 424		752

RA	LA	LM	R1	L1	R2	L2
0.003	0.050	2.190	0.059	0.050	0.009	0.056

Calc No: E4C-082 Sheet No. 293  
RE: LPW 9-30-91 IRE: Bl 10-5-92 Rev. 1

*Can 9*

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.14	1.756	2.000	0.00670	0.839	0.7000

\*\*\* CALL CMOTOR( 47, 753, 760, 109, 425, 765) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21419	2A074	0.46	47	753-	759	760-	764	109	425- 432		765

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.06	2.950	2.000	0.00940	0.962	0.7000

\*\*\* CALL CMOTOR( 48, 766, 773, 110, 433, 778) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21609	2A072	0.46	48	766-	772	773-	777	110	433- 440		778

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.06	2.950	2.000	0.00940	0.962	0.7000

\*\*\* CALL CMOTOR( 49, 779, 786, 111, 441, 791) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21610	2E400	0.46	49	779-	785	786-	790	111	441- 448		791

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.10	1.771	2.000	0.00810	0.614	0.7000

\*\*\* CALL CMOTOR( 50, 792, 799, 112, 449, 804) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
21611	2E402	0.46	50	792-	798	799-	803	112	449- 456		804

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.10	1.771	2.000	0.00810	0.614	0.7000

\*\*\* CALL CMOTOR( 51, 805, 812, 113, 457, 817) \*\*\*

Calc No:	E4C-082	CCN	N-3	Rev.	1
RE:	CPM	9-30-94	IRE:	BJ	10-5-95
			Sheet No.	294	

CCN 9

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 21613 2P192 0.46 51 805- 811 812- 816 113 457- 464 817

RA LA LM R1 L1 R2 L2  
 0.000 0.065 3.202 0.065 0.085 0.019 0.220

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.10 0.314 2.000 0.00970 0.593 0.7000

\*\*\* CALL CMOTOR( 52, 818, 825, 114, 465, 830) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 21615 E419-U2 0.46 52 818- 824 825- 829 114 465- 472 830

RA LA LM R1 L1 R2 L2  
 0.003 0.050 2.190 0.059 0.050 0.009 0.056

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.14 1.756 2.000 0.00670 0.839 0.7000

\*\*\* CALL CMOTOR( 53, 831, 838, 115, 473, 843) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 21617 2P191-B 0.46 53 831- 837 838- 842 115 473- 480 843

RA LA LM R1 L1 R2 L2  
 0.000 0.065 3.202 0.065 0.085 0.019 0.220

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.10 0.314 2.000 0.00970 0.593 0.7000

\*\*\* CALL CMOTOR( 54, 844, 851, 116, 481, 856) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 21619 2A073 0.46 54 844- 850 851- 855 116 481- 488 856

RA LA LM R1 L1 R2 L2  
 0.000 0.060 2.250 0.030 0.062 0.013 0.090

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.06 2.950 2.000 0.00940 0.962 0.7000

\*\*\* CALL CMOTOR( 55, 857, 864, 117, 489, 869) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 31405 3P191-A 0.46 55 857- 863 864- 868 117 489- 496 869

RA LA LM R1 L1 R2 L2  
 0.000 0.065 3.202 0.065 0.085 0.019 0.220

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.10 0.314 2.000 0.00970 0.593 0.7000

Calc No: E4C-082 Sheet No. 295  
 RE: Gen 9-30-91 IRE: Rel 11-5-91  
 Rev. 1

Gen 9



\*\*\* CALL CMOTOR( 56, 870, 877, 118, 497, 882) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31409	3A071	0.46	56	870-	876	877-	881	118	497- 504		882

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.06	2.950	2.000	0.00940		0.962	0.7000

\*\*\* CALL CMOTOR( 57, 883, 890, 119, 505, 895) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31410	3E399	0.46	57	883-	889	890-	894	119	505- 512		895

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	1.771	2.000	0.00810		0.614	0.7000

\*\*\* CALL CMOTOR( 58, 896, 903, 120, 513, 908) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31411	3E401	0.46	58	896-	902	903-	907	120	513- 520		908

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	1.771	2.000	0.00810		0.614	0.7000

\*\*\* CALL CMOTOR( 59, 909, 916, 121, 521, 921) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31413	3P190	0.46	59	909-	915	916-	920	121	521- 528		921

RA	LA	LM	R1	L1	R2	L2
0.000	0.065	3.202	0.065	0.085	0.019	0.220

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	0.314	2.000	0.00970		0.593	0.7000

\*\*\* CALL CMOTOR( 60, 922, 929, 122, 529, 934) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31418	E418-U3	0.46	60	922-	928	929-	933	122	529- 536		934

Call No: E4C-082 CCN N-3 Rev. 1  
Sheet No. 296  
RE: CPM 9-30-94 IRE: RL 10-5-94

QCN 9

RA	LA	LM	R1	L1	R2	L2
0.003	0.050	2.190	0.059	0.050	0.009	0.056

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.14	1.756	2.000	0.00670	0.839	0.7000

\*\*\* CALL CMOTOR( 61, 935, 942, 123, 537, 947) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31419	3A074	0.46	61	935-	941	942-	946	123	537- 544		947

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.06	2.950	2.000	0.00940	0.962	0.7000

\*\*\* CALL CMOTOR( 62, 948, 955, 124, 545, 960) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31609	3A072	0.46	62	948-	954	955-	959	124	545- 552		960

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.06	2.950	2.000	0.00940	0.962	0.7000

\*\*\* CALL CMOTOR( 63, 961, 968, 125, 553, 973) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31610	3E400	0.46	63	961-	967	968-	972	125	553- 560		973

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.10	1.771	2.000	0.00810	0.614	0.7000

\*\*\* CALL CMOTOR( 64, 974, 981, 126, 561, 986) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31611	3E402	0.46	64	974-	980	981-	985	126	561- 568		986

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.720	0.035	0.086	0.018	0.260

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.10	1.771	2.000	0.00810	0.614	0.7000

Calc No: E4C-082 CN N-3 Rev: 1  
 RE: APM 9-20-94 IRE: Ad 10-5-94  
 Sheet No. 297

*CAN 9*

\*\*\* CALL CMOTOR( 65, 987, 994, 127, 569, 999) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31613	3P192	0.46	65	987-	993	994-	998	127	569- 576		999

RA	LA	LM	R1	L1	R2	L2
0.000	0.065	3.202	0.065	0.085	0.019	0.220

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	0.314	2.000	0.00970		0.593	0.7000

\*\*\* CALL CMOTOR( 66, 1000, 1007, 128, 577, 1012) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31615	E419-U3	0.46	66	1000-	1006	1007-	1011	128	577- 584		1012

RA	LA	LM	R1	L1	R2	L2
0.003	0.050	2.190	0.059	0.050	0.009	0.056

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.14	1.756	2.000	0.00670		0.839	0.7000

\*\*\* CALL CMOTOR( 67, 1013, 1020, 129, 585, 1025) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31617	3P192-B	0.46	67	1013-	1019	1020-	1024	129	585- 592		1025

RA	LA	LM	R1	L1	R2	L2
0.000	0.065	3.202	0.065	0.085	0.019	0.220

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	0.314	2.000	0.00970		0.593	0.7000

\*\*\* CALL CMOTOR( 68, 1026, 1033, 130, 593, 1038) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31619	3A073	0.46	68	1026-	1032	1033-	1037	130	593- 600		1038

RA	LA	LM	R1	L1	R2	L2
0.000	0.060	2.250	0.030	0.062	0.013	0.090

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.06	2.950	2.000	0.00940		0.962	0.7000

\*\*\* CALL CMOTOR( 69, 1039, 1046, 131, 601, 1051) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22403	2BRA-M	0.48	69	1039-	1045	1046-	1050	131	601- 608		1051

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

Calc No: E4C-082    CCN N-3    Rev. 1  
 RE: 9-30-94    IRE: 10-5-94  
 Sheet No. 298

QEN 9

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.02 1.467 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 70, 1052, 1059, 132, 609, 1064) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 22407 2BD-M 0.48 70 1052- 1058 1059- 1063 132 609- 616 1064

RA LA LM R1 L1 R2 L2  
 0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.02 1.045 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 71, 1065, 1072, 133, 617, 1077) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 22414 2BE-M 0.48 71 1065- 1071 1072- 1076 133 617- 624 1077

RA LA LM R1 L1 R2 L2  
 0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.07 0.586 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 72, 1078, 1085, 134, 625, 1090) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 22415 2BY-M 0.48 72 1078- 1084 1085- 1089 134 625- 632 1090

RA LA LM R1 L1 R2 L2  
 0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.10 0.595 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 73, 1091, 1098, 135, 633, 1103) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 22417 BQ-U2-M 0.48 73 1091- 1097 1098- 1102 135 633- 640 1103

RA LA LM R1 L1 R2 L2  
 0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.05 1.041 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 74, 1104, 1111, 136, 641, 1116) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON

Calc No: EDC-082 CCN N-3 Rev. 1  
 RE: CPM 9-30-94 IRE: RL 10-5-94  
 Sheet No: 299

CCN 9

22603 2BRB-M 0.48 74 1104- 1110 1111- 1115 136 641- 648 1116

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.02	1.467	2.000	0.04167	0.840	0.5000

\*\*\* CALL CMOTOR( 75, 1117, 1124, 137, 649, 1129) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT CON'S	RATING CON'S	STATE	V A R ' S	ACC CON
22603	2BRB-M	0.48	74	1104- 1110	1111- 1115	136	641- 648	1116

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.02	1.467	2.000	0.04167	0.840	0.5000

\*\*\* CALL CMOTOR( 76, 1130, 1137, 138, 657, 1142) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT CON'S	RATING CON'S	STATE	V A R ' S	ACC CON
22607	2BJ-M	0.48	76	1130- 1136	1137- 1141	138	657- 664	1142

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.07	0.590	2.000	0.04167	0.840	0.5000

\*\*\* CALL CMOTOR( 77, 1143, 1150, 139, 665, 1155) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT CON'S	RATING CON'S	STATE	V A R ' S	ACC CON
22614	2BZ-M	0.48	77	1143- 1149	1150- 1154	139	665- 672	1155

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.06	0.892	2.000	0.04167	0.840	0.5000

\*\*\* CALL CMOTOR( 78, 1156, 1163, 140, 673, 1168) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT CON'S	RATING CON'S	STATE	V A R ' S	ACC CON
22618	BS-U2-M	0.48	78	1156- 1162	1163- 1167	140	673- 680	1168

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.05	1.041	2.000	0.04167	0.840	0.5000

Calc No: E4C-082 CNV N-3 Rev: 1  
 RE: Lpm 9-30-94 IRE: DL 10-5-94  
 Sheet No: 300

22619

\*\*\* CALL CMOTOR( 79, 1169, 1176, 141, 681, 1181) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32403	3BRA-M	0.48	79	1169-	1175	1176-	1180	141	681- 688		1181

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.02	1.467	2.900	0.04167		0.840	0.5000

\*\*\* CALL CMOTOR( 80, 1182, 1189, 142, 689, 1194) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32407	3BD-M	0.48	80	1182-	1188	1189-	1193	142	689- 696		1194

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.02	1.045	2.000	0.04167		0.840	0.5000

\*\*\* CALL CMOTOR( 81, 1195, 1202, 143, 697, 1207) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32414	3BE-M	0.48	81	1195-	1201	1202-	1206	143	697- 704		1207

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.07	0.575	2.000	0.04167		0.840	0.5000

\*\*\* CALL CMOTOR( 82, 1208, 1215, 144, 705, 1220) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32415	3BY-M	0.48	82	1208-	1214	1215-	1219	144	705- 712		1220

RA	LA	LM	R1	L1	R2	L2
0.011	0.092	2.930	0.043	0.160	999.000	999.000

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.10	0.595	2.000	0.04167		0.840	0.5000

\*\*\* CALL CMOTOR( 83, 1221, 1228, 145, 713, 1233) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32417	BQ-U3-M	0.48	83	1221-	1227	1228-	1232	145	713- 720		1233

RA	LA	LM	R1	L1	R2	L2
----	----	----	----	----	----	----

Call No: E4C-082 CCN N-3 Rev. 1  
RE: *CPM 9-30-94* IRE: *Ad 10-5-94*  
Sheet No. 301

*CPM 9*

0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.05 1.041 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 84, 1234, 1241, 146, 721, 1246) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
32603 3BRB-M 0.48 84 1234- 1240 1241- 1245 146 721- 728 1246

RA LA LM R1 L1 R2 L2  
0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.02 1.467 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 85, 1247, 1254, 147, 729, 1259) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
32605 3BR-M 0.48 85 1247- 1253 1254- 1258 147 729- 736 1259

RA LA LM R1 L1 R2 L2  
0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.02 1.045 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 86, 1260, 1267, 148, 737, 1272) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
32607 3BJ-M 0.48 86 1260- 1266 1267- 1271 148 737- 744 1272

RA LA LM R1 L1 R2 L2  
0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.07 0.590 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 87, 1273, 1280, 149, 745, 1285) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
32614 3BE-M 0.48 87 1273- 1279 1280- 1284 149 745- 752 1285

RA LA LM R1 L1 R2 L2  
0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
0.07 0.868 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 88, 1286, 1293, 150, 753, 1298) \*\*\*

Calc No: ETC-082 CCN N-3 Rev. 1  
RE: *CPM 9-30-94* RE: *AE 10-5-94*  
Sheet No. 302

*CCN 9*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 17618 2A-U3-M 0.48 88 1286- 1292 1293- 1297 150 753- 760 1298

RA LA LM R1 L1 R2 L2  
 0.011 0.092 2.930 0.043 0.160 999.000 999.000

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.05 1.041 2.000 0.04167 0.840 0.5000

\*\*\* CALL CMOTOR( 89, 1299, 1306, 151, 761, 1311) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 24412 2A274 0.46 89 1299- 1305 1306- 1310 151 761- 768 1311

RA LA LM R1 L1 R2 L2  
 0.001 0.090 2.400 0.055 0.075 0.027 0.210

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.05 1.607 2.000 0.01830 0.887 0.7000

\*\*\* CALL CMOTOR( 90, 1312, 1319, 152, 769, 1324) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 24413 2A275 0.46 90 1312- 1318 1319- 1323 152 769- 776 1324

RA LA LM R1 L1 R2 L2  
 0.001 0.090 2.400 0.055 0.075 0.027 0.210

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.05 1.607 2.000 0.01830 0.887 0.7000

\*\*\* CALL CMOTOR( 91, 1325, 1332, 153, 777, 1337) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 24421 2E550 0.46 91 1325- 1331 1332- 1336 153 777- 784 1337

RA LA LM R1 L1 R2 L2  
 0.001 0.060 2.813 0.054 0.091 0.027 0.280

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL  
 0.05 0.751 2.000 0.01320 0.658 0.7000

\*\*\* CALL CMOTOR( 92, 1338, 1345, 154, 785, 1350) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
 24422 2E546 0.46 92 1338- 1344 1345- 1349 154 785- 792 1350

RA LA LM R1 L1 R2 L2  
 0.001 0.060 2.813 0.054 0.091 0.027 0.280

MOTOR BASE H DAMP INIT SLIP TORQUE ACCEL

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: R2 10-5-94  
 Sheet No. 303

CCN 9



0.05 0.751 2.000 0.01320 0.658 0.7000

\*\*\* CALL CMOTOR( 93, 1351, 1358, 155, 793, 1363) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
24434	2P009	0.46	93	1351-	1357	1358-	1362	155	793- 800	1363

RA	LA	LM	R1	L1	R2	L2
0.001	0.082	4.000	0.042	0.066	0.028	0.230

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.03	0.361	2.000	0.01500		0.611	0.7000

\*\*\* CALL CMOTOR( 94, 1364, 1371, 156, 801, 1376) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
24606	2E547	0.46	94	1364-	1370	1371-	1375	156	801- 808	1376

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.813	0.054	0.091	0.027	0.280

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	0.751	2.000	0.01320		0.658	0.7000

\*\*\* CALL CMOTOR( 95, 1377, 1384, 157, 809, 1389) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
24607	2E549	0.46	95	1377-	1383	1384-	1388	157	809- 816	1389

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.813	0.054	0.091	0.027	0.280

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	0.751	2.000	0.01320		0.658	0.7000

\*\*\* CALL CMOTOR( 96, 1390, 1397, 158, 817, 1402) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
24611	2A276	0.46	96	1390-	1396	1397-	1401	158	817- 824	1402

RA	LA	LM	R1	L1	R2	L2
0.001	0.090	2.400	0.055	0.075	0.027	0.210

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	1.607	2.000	0.01830		0.887	0.7000

\*\*\* CALL CMOTOR( 97, 1403, 1410, 159, 825, 1415) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
24612	2A277	0.46	97	1403-	1409	1410-	1414	159	825- 832	1415

Calc No: ETC-082  
RE: LPM 9-30-91  
CCN A-3  
REV: 1  
IRE: R 10-5-88  
Sheet No. 304

2019

RA	LA	LM	R1	L1	R2	L2
0.001	0.090	2.400	0.055	0.075	0.027	0.210

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.05	1.607	2.000	0.01830	0.887	0.7000

\*\*\* CALL CMOTOR( 98, 1416, 1423, 160, 833, 1428) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24882	P9810	0.48	98	1416-	1422	1423-	1427	160	833- 840		1428

RA	LA	LM	R1	L1	R2	L2
0.001	0.082	4.000	0.042	0.066	0.028	0.230

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.03	0.301	2.000	0.01500	0.811	0.7000

\*\*\* CALL CMOTOR( 99, 1429, 1436, 161, 841, 1441) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24417	P162-U2	0.46	99	1429-	1435	1436-	1440	161	841- 848		1441

RA	LA	LM	R1	L1	R2	L2
0.001	0.095	2.855	0.073	0.076	0.023	0.152

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.04	0.199	2.000	0.01250	0.631	0.7000

\*\*\* CALL CMOTOR( 100, 1442, 1449, 162, 849, 1454) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24617	P160-U2	0.46	100	1442-	1448	1449-	1453	162	849- 856		1454

RA	LA	LM	R1	L1	R2	L2
0.001	0.095	2.855	0.073	0.070	0.023	0.152

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.04	0.199	2.000	0.01250	0.631	0.7000

\*\*\* CALL CMOTOR( 101, 1455, 1462, 163, 857, 1467) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34417	P162-U3	0.46	101	1455-	1461	1462-	1466	163	857- 864		1467

RA	LA	LM	R1	L1	R2	L2
0.001	0.095	2.855	0.073	0.070	0.023	0.152

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.04	0.199	2.000	0.01250	0.631	0.7000

Calc No:	E4C-082	CCN	N-3	Rev:	1
FE:	CPM-9-30-94	IRE:	AP-10-5-94		
Sheet No.	305				

1 CN 9

\*\*\* CALL CMOTOR( 102, 1468, 1475, 164, 865, 1480) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34618	P160-U3	0.46	102	1468-	1474	1475-	1479	164	865- 872		1480

RA	LA	LM	R1	L1	R2	L2
0.001	0.095	2.655	0.073	0.070	0.023	0.152

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.04	0.199	2.000	0.01250		0.631	0.7000

\*\*\* CALL CMOTOR( 103, 1481, 1488, 165, 873, 1493) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34412	3A274	0.46	103	1481-	1487	1488-	1492	165	873- 880		1493

RA	LA	LM	R1	L1	R2	L2
0.001	0.090	2.400	0.055	0.075	0.027	0.210

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	1.607	2.000	0.01830		0.887	0.7000

\*\*\* CALL CMOTOR( 104, 1494, 1501, 166, 881, 1506) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34413	3A275	0.46	104	1494-	1500	1501-	1505	166	881- 888		1506

RA	LA	LM	R1	L1	R2	L2
0.001	0.090	2.400	0.055	0.075	0.027	0.210

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	1.607	2.000	0.01830		0.887	0.7000

\*\*\* CALL CMOTOR( 105, 1507, 1514, 167, 889, 1519) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34421	3E550	0.46	105	1507-	1513	1514-	1518	167	889- 896		1519

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.813	0.054	0.091	0.027	0.280

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	0.751	2.000	0.01320		0.658	0.7000

\*\*\* CALL CMOTOR( 106, 1520, 1527, 168, 897, 1532) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34422	3E546	0.46	106	1520-	1526	1527-	1531	168	897- 904		1532

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.813	0.054	0.091	0.027	0.280

Calc No:	E4C-082	CCN	N-3	Rev:	1
RE:	CPM 9-30-74	IRE:	AP 10-5-84		
Sheet No.	306				

CCN 9

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.05	0.751	2.000	0.01320	0.658	0.7000

\*\*\* CALL CMOTOR( 107, 1533, 1540, 169, 905, 1545) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
34434	3P009	0.46	107	1533-	1539	1540-	1544	169	905- 912	1545

RA	LA	LM	R1	L1	R2	L2
0.001	0.082	4.000	0.042	0.066	0.028	0.230

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.03	0.301	2.000	0.01500	0.811	0.7000

\*\*\* CALL CMOTOR( 108, 1546, 1553, 170, 913, 1558) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
34606	3E547	0.46	108	1546-	1552	1553-	1557	170	913- 920	1558

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.813	0.054	0.091	0.027	0.280

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.05	0.751	2.000	0.01320	0.658	0.7000

\*\*\* CALL CMOTOR( 109, 1559, 1566, 171, 921, 1571) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
34607	3E549	0.46	109	1559-	1565	1566-	1570	171	921- 928	1571

RA	LA	LM	R1	L1	R2	L2
0.001	0.060	2.813	0.054	0.091	0.027	0.280

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.05	0.751	2.000	0.01320	0.658	0.7000

\*\*\* CALL CMOTOR( 110, 1572, 1579, 172, 929, 1584) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC CON
34611	3A276	0.46	110	1572-	1578	1579-	1583	172	929- 936	1584

RA	LA	LM	R1	L1	R2	L2
0.001	0.090	2.400	0.055	0.075	0.027	0.210

MOTOR BASE	H	DAMP	INIT SLIP	TORQUE	ACCEL
0.05	1.607	2.000	0.01830	0.887	0.7000

\*\*\* CALL CMOTOR( 111, 1585, 1592, 173, 937, 1597) \*\*\*

Calc No:	E4C-082	Sheet No.	307
RE:	4pm 9-30-94	Rev:	1
IRE:	89 10-5-94		

CCN 9

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34612	3A277	0.46	111	1585-	1591	1592-	1596	173	937- 944		1597

RA	LA	LM	R1	L1	R2	L2
0.001	0.090	2.400	0.055	0.075	0.027	0.210

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.05	1.607	2.000	0.01830		0.887	0.7000

\*\*\* CALL CMOTOR( 112, 1598, 1605, 174, 945, 1610) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34622	3P010	0.46	112	1598-	1604	1605-	1609	174	945- 952		1610

RA	LA	LM	R1	L1	R2	L2
0.001	0.082	4.000	0.042	0.066	0.028	0.230

MOTOR	BASE	H	DAMP	INIT	SLIP	TORQUE	ACCEL
	0.03	0.301	2.000	0.01500		0.811	0.7000

Calc No:	E4C-082	CCN	N-3	Rev.	1
RE:	CPM	9-30-94	IRE:	BL	11-5-94
Sheet No.	308				

PCN 9

CONET MODELS

\*\*\* CALL TMOTOR( 1, 155, 162, 63, 57, 167) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2403	2P612	4.16	1	155-	161	162-	166	63	57- 64		167

\*\*\* CALL TMOTOR( 2, 168, 175, 64, 65, 180) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2404	2P141	4.16	2	168-	174	175-	179	64	65- 72		180

\*\*\* CALL TMOTOR( 3, 181, 188, 65, 73, 193) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2405	2P024	4.16	3	181-	187	188-	192	65	73- 80		193

\*\*\* CALL TMOTOR( 4, 194, 201, 66, 81, 206) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2406	2P025-A	4.16	4	194-	200	201-	205	66	81- 88		206

\*\*\* CALL TMOTOR( 5, 207, 214, 67, 89, 219) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2407	2P015	4.16	5	207-	213	214-	218	67	89- 96		219

\*\*\* CALL TMOTOR( 6, 220, 227, 68, 97, 232) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2408	2P017	4.16	6	220-	226	227-	231	68	97- 104		232

\*\*\* CALL TMOTOR( 7, 233, 240, 69, 105, 245) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2409	2P018-A	4.16	7	233-	239	240-	244	69	105- 112		245

\*\*\* CALL TMOTOR( 8, 246, 253, 70, 113, 258) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON

Calc No:	E4C-082	Sheet No:	309
RE:	CPM 9-30-91	Rev:	1
IRE:	AS 10-5-94		

CCN 9

2410 2P112 4.16 8 246- 252 253- 257 70 113- 120 258

\*\*\* CALL TMOTOR( 9, 259, 266, 71, 121, 271) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2411	2P307	4.16	9	259-	265	266-	270	71	121- 128		271

\*\*\* CALL TMOTOR( 10, 272, 279, 72, 129, 284) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2412	E336-U2	4.16	10	272-	278	279-	283	72	129- 136		284

\*\*\* CALL TMOTOR( 11, 285, 292, 73, 137, 297) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2603	2P504	4.16	11	285-	291	292-	296	73	137- 144		297

\*\*\* CALL TMOTOR( 12, 298, 305, 74, 145, 310) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2604	2P013	4.16	12	298-	304	305-	309	74	145- 152		310

\*\*\* CALL TMOTOR( 13, 311, 318, 75, 153, 323) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2605	2P026	4.16	13	311-	317	318-	322	75	153- 160		323

\*\*\* CALL TMOTOR( 14, 324, 331, 76, 161, 336) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2606	2P025-B	4.16	14	324-	330	331-	335	76	161- 168		336

\*\*\* CALL TMOTOR( 15, 337, 344, 77, 169, 349) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2607	2P016	4.16	15	337-	343	344-	348	77	169- 176		349

\*\*\* CALL TMOTOR( 16, 350, 357, 78, 177, 362) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2608	2P019	4.16	16	350-	356	357-	361	78	177- 184		362

Cell No: <u>E4C-082</u>	Sheet No: <u>310</u>
RE: <u>CPW 9-30-94</u>	RE: <u>AP 10-5-94</u>
	RE: <u>N-3</u>
	RE: <u>1</u>

CCN 9

\*\*\* CALL TMOTOR( 17, 363, 370, 79, 185, 375) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2609	2P018-B	4.16	17	363-	369	370-	374	79	185- 192		375

\*\*\* CALL TMOTOR( 18, 376, 383, 80, 193, 388) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2610	2P113	4.16	18	376-	382	383-	387	80	193- 200		388

\*\*\* CALL TMOTOR( 19, 389, 396, 81, 201, 401) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2611	2P114	4.16	19	389-	395	396-	400	81	201- 208		401

\*\*\* CALL TMOTOR( 20, 402, 409, 82, 209, 414) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
2612	E335-U2	4.16	20	402-	408	409-	413	82	209- 216		414

\*\*\* CALL TMOTOR( 21, 415, 422, 83, 217, 427) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3402	E336-U3	4.16	21	415-	421	422-	426	83	217- 224		427

\*\*\* CALL TMOTOR( 22, 428, 435, 84, 225, 440) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3402	3P012	4.16	22	428-	434	435-	439	84	225- 232		440

\*\*\* CALL TMOTOR( 23, 441, 448, 85, 233, 453) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3404	3P141	4.16	23	441-	447	448-	452	85	233- 240		453

\*\*\* CALL TMOTOR( 24, 454, 461, 86, 241, 466) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3405	3P024	4.16	24	454-	460	461-	465	86	241- 248		466

\*\*\* CALL TMOTOR( 25, 467, 474, 87, 249, 479) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3406	3P025-A	4.16	25	467-	473	474-	478	87	249- 256		479

Calc No: E4C-082 Sheet No. 311  
RE: Open 9-30-91 RE: Rel 10-5-94  
Rev: 1

2209



\*\*\* CALL TMOTOR( 26, 480, 487, 88, 257, 492) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3407	3P015	4.16	26	480-	486	487-	491	88	257- 264		492

\*\*\* CALL TMOTOR( 27, 493, 500, 89, 265, 505) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3408	3P017	4.16	27	493-	499	500-	504	89	265- 272		505

\*\*\* CALL TMOTOR( 28, 506, 513, 90, 273, 518) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3409	3P018-A	4.16	28	506-	512	513-	517	90	273- 280		518

\*\*\* CALL TMOTOR( 29, 519, 526, 91, 281, 531) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3410	3P112	4.16	29	519-	525	526-	530	91	281- 288		531

\*\*\* CALL TMOTOR( 30, 532, 539, 92, 289, 544) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3411	3P307	4.16	30	532-	538	539-	543	92	289- 296		544

\*\*\* CALL TMOTOR( 31, 545, 552, 93, 297, 557) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3602	E335-U3	4.16	31	545-	551	552-	556	93	297- 304		557

\*\*\* CALL TMOTOR( 32, 558, 565, 94, 305, 570) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3604	3P013	4.16	32	558-	564	565-	569	94	305- 312		570

\*\*\* CALL TMOTOR( 33, 571, 578, 95, 313, 583) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
3605	3P026	4.16	33	571-	577	578-	582	95	313- 320		583

\*\*\* CALL TMOTOR( 34, 584, 591, 96, 321, 596) \*\*\*

Call No: <u>E4C-082</u>	Sheet No. <u>3/2</u>
RE: <u>CPW 9-30-94</u>	CCN <u>N-3</u>
IRE: <u>Red 10-5-94</u>	Rev. <u>1</u>

CCN 9

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3606 3P025-B 4.16 34 584- 590 591- 595 96 321- 328 596

\*\*\* CALL TMOTOR( 35, 597, 604, 97, 329, 609) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3607 3P016 4.16 35 597- 603 604- 608 97 329- 336 609

\*\*\* CALL TMOTOR( 36, 610, 617, 98, 337, 622) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3608 3P019 4.16 36 610- 616 617- 621 98 337- 344 622

\*\*\* CALL TMOTOR( 37, 623, 630, 99, 345, 635) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3609 3P018-B 4.16 37 623- 629 630- 634 99 345- 352 635

\*\*\* CALL TMOTOR( 38, 636, 643, 100, 353, 648) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3610 3P113 4.16 38 636- 642 643- 647 100 353- 360 648

\*\*\* CALL TMOTOR( 39, 649, 656, 101, 361, 661) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3611 3P114 4.16 39 649- 655 656- 660 101 361- 368 661

\*\*\* CALL TMOTOR( 40, 662, 669, 102, 369, 674) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
3612 3P504 4.16 40 662- 668 669- 673 102 369- 376 674

\*\*\* CALL TMOTOR( 41, 675, 682, 103, 377, 687) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
21405 2P191-A 0.46 41 675- 681 682- 686 103 377- 384 687

\*\*\* CALL TMOTOR( 42, 688, 695, 104, 385, 700) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
21409 2A071 0.46 42 688- 694 695- 699 104 385- 392 700

Call No: <u>E4C-082</u>	Sheet No. <u>313</u>
RE: <u>CPM 9-30-94</u>	Rev: <u>1</u>
RE: <u>BJ 10-5-94</u>	

CCN 9

CCN 9

Sheet No.	314
Calc No:	E4C-082 CCN N-3 Rev. 1
RE:	LRM 9-30-94 IRE: <i>hd</i> 10-5-94

\*\*\* CALL TNOTOR( 43, 701, 708, 105, 393, 713) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21410 2E399 0.46 43 701- 707 708- 712 105 393- 400 713

\*\*\* CALL TNOTOR( 44, 714, 721, 106, 401, 726) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21411 2E401 0.46 44 714- 720 721- 725 106 401- 408 726

\*\*\* CALL TNOTOR( 45, 727, 734, 107, 409, 739) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21413 2P190 0.46 45 727- 733 734- 738 107 409- 416 739

\*\*\* CALL TNOTOR( 46, 740, 747, 108, 417, 752) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21418 E418-U2 0.46 46 740- 746 747- 751 108 417- 424 752

\*\*\* CALL TNOTOR( 47, 753, 760, 109, 425, 765) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21419 2A074 0.46 47 753- 759 760- 764 109 425- 432 765

\*\*\* CALL TNOTOR( 48, 766, 773, 110, 433, 778) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21609 2A072 0.46 48 766- 772 773- 777 110 433- 440 778

\*\*\* CALL TNOTOR( 49, 779, 786, 111, 441, 791) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21610 2E400 0.46 49 779- 785 786- 790 111 441- 448 791

\*\*\* CALL TNOTOR( 50, 792, 799, 112, 449, 804) \*\*\*  
BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC COM  
21611 2E402 0.46 50 792- 798 799- 803 112 449- 456 804

\*\*\* CALL TNOTOR( 51, 805, 812, 113, 457, 817) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
21613 2P192 0.46 51 805- 811 812- 816 113 457- 464 817

\*\*\* CALL TMOTOR( 52, 818, 825, 114, 465, 830) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
21615 E419-U2 0.46 52 818- 824 825- 829 114 465- 472 830

\*\*\* CALL TMOTOR( 53, 831, 838, 115, 473, 843) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
21617 2P191-B 0.46 53 831- 837 838- 842 115 473- 480 843

\*\*\* CALL TMOTOR( 54, 844, 851, 116, 481, 856) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
21619 2A073 0.46 54 844- 850 851- 855 116 481- 488 856

\*\*\* CALL TMOTOR( 55, 857, 864, 117, 489, 869) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
31405 3P191-A 0.46 55 857- 863 864- 868 117 489- 496 869

\*\*\* CALL TMOTOR( 56, 870, 877, 118, 497, 882) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
31409 3A071 0.46 56 870- 876 877- 881 118 497- 504 882

\*\*\* CALL TMOTOR( 57, 883, 890, 119, 505, 895) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
31410 3E399 0.46 57 883- 889 890- 894 119 505- 512 895

\*\*\* CALL TMOTOR( 58, 896, 903, 120, 513, 908) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
31411 3E401 0.46 58 896- 902 903- 907 120 513- 520 908

\*\*\* CALL TMOTOR( 59, 909, 916, 121, 521, 921) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
31413 3P190 0.46 59 909- 915 916- 920 121 521- 528 921

Calc No: E4C-082 CCN N-3  
RE: *LPW 9-30-94* IRE: *Ref 10-5-94*  
Sheet No. 3/5  
Rev. 1

*CCN 9*

\*\*\* CALL TMOTOR( 60, 922, 929, 122, 529, 934) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31418	E418-U3	0.46	60	922-	928	929-	933	122	529- 536		934

\*\*\* CALL TMOTOR( 61, 935, 942, 123, 537, 947) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31419	3A074	0.46	61	935-	941	942-	946	123	537- 544		947

\*\*\* CALL TMOTOR( 62, 948, 955, 124, 545, 960) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31609	3A072	0.46	62	948-	954	955-	959	124	545- 552		960

\*\*\* CALL TMOTOR( 63, 961, 968, 125, 553, 973) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31616	3E400	0.46	63	961-	967	968-	972	125	553- 560		973

\*\*\* CALL TMOTOR( 64, 974, 981, 126, 561, 986) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31611	3E402	0.46	64	974-	980	981-	985	126	561- 568		986

\*\*\* CALL TMOTOR( 65, 987, 994, 127, 569, 999) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31613	3P192	0.46	65	987-	993	994-	998	127	569- 576		999

\*\*\* CALL TMOTOR( 66, 1000, 1007, 128, 577, 1012) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31615	E419-U3	0.46	66	1000-	1006	1007-	1011	128	577- 584		1012

\*\*\* CALL TMOTOR( 67, 1013, 1020, 129, 585, 1025) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
31617	3P191-B	0.46	67	1013-	1019	1020-	1024	129	585- 592		1025

\*\*\* CALL TMOTOR( 68, 1026, 1033, 130, 593, 1038) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
-----	------	-------	------	---------	-------	--------	-------	-------	-----------	-----	-----

Call No: E4C-082 CCV N-3 Res: 1  
RE: CPW 9-30-91 RE: Ad 10-5-91  
Sheet No. 316

Can 9

CCN 9

Sheet No.	317
Calc No:	E4C-082 CCN N-3 Rev. 1
RE:	Lpm 9-30-94 IRE: BJ 10-5-94

31619	3A073	0.46	68	1026-1032	1033-1037	130	593-600	1038			
*** CALL TNOTOR( 69, 1039, 1046, 131, 601, 1051) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22403	ZBRA-M	0.48	69	1039-1045	1046-1050	131	601-608	1051			
*** CALL TNOTOR( 70, 1052, 1059, 132, 609, 1064) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22407	ZBD-M	0.48	70	1052-1058	1059-1063	132	609-616	1064			
*** CALL TNOTOR( 71, 1065, 1072, 133, 617, 1077) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22414	ZBE-M	0.48	71	1065-1071	1072-1076	133	617-624	1077			
*** CALL TNOTOR( 72, 1078, 1085, 134, 625, 1090) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22415	ZBY-M	0.48	72	1078-1084	1085-1089	134	625-632	1090			
*** CALL TNOTOR( 73, 1091, 1098, 135, 633, 1103) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22417	BQ-U2-M	0.48	73	1091-1097	1098-1102	135	633-640	1103			
*** CALL TNOTOR( 74, 1104, 1111, 136, 641, 1116) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22603	ZBRB-M	0.48	74	1104-1110	1111-1115	136	641-648	1116			
*** CALL TNOTOR( 75, 1117, 1124, 137, 649, 1129) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22605	ZBH-M	0.48	75	1117-1123	1124-1128	137	649-656	1129			
*** CALL TNOTOR( 76, 1130, 1137, 138, 657, 1142) ***											
BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22607	ZBJ-M	0.48	76	1130-1136	1137-1141	138	657-664	1142			

\*\*\* CALL TMOTOR( 77, 1143, 1150, 139, 665, 1155) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22614	2BZ-M	0.48	77	1143-	1149	1150-	1154	139	665- 672	1155	

\*\*\* CALL TMOTOR( 78, 1156, 1163, 140, 673, 1168) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
22618	BS-U2-M	0.48	78	1156-	1162	1163-	1167	140	673- 680	1168	

\*\*\* CALL TMOTOR( 79, 1169, 1176, 141, 681, 1181) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32403	3BRA-M	0.48	79	1169-	1175	1176-	1180	141	681- 688	1181	

\*\*\* CALL TMOTOR( 80, 1182, 1189, 142, 689, 1194) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32407	3BD-M	0.48	80	1182-	1188	1189-	1193	142	689- 696	1194	

\*\*\* CALL TMOTOR( 81, 1195, 1202, 143, 697, 1207) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32414	3BE-M	0.48	81	1195-	1201	1202-	1206	143	697- 704	1207	

\*\*\* CALL TMOTOR( 82, 1208, 1215, 144, 705, 1220) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32415	3BY-M	0.48	82	1208-	1214	1215-	1219	144	705- 712	1220	

\*\*\* CALL TMOTOR( 83, 1221, 1228, 145, 713, 1233) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32417	BQ-U3-M	0.48	83	1221-	1227	1228-	1232	145	713- 720	1233	

\*\*\* CALL TMOTOR( 84, 1234, 1241, 146, 721, 1246) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32603	3BRB-M	0.48	84	1234-	1240	1241-	1245	146	721- 728	1246	

\*\*\* CALL TMOTOR( 85, 1247, 1254, 147, 729, 1259) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32605	3BH-M	0.48	85	1247-	1253	1254-	1258	147	729- 736	1259	

Calc No: <u>E4C-082</u>	Sheet No. <u>318</u>
RE: <u>pm 9-30-94</u>	CCN <u>N-3</u>
IRE: <u>AD 10-5-94</u>	Rev: <u>1</u>

LEN9

\*\*\* CALL TMOTOR( 86, 1260, 1267, 148, 737, 1272) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32607	3BJ-M	0.48	86	1260-	1266	1267-	1271	148	737- 744	1272	

\*\*\* CALL TMOTOR( 87, 1273, 1280, 149, 745, 1285) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32614	3BX-M	0.48	87	1273-	1279	1280-	1284	149	745- 752	1285	

\*\*\* CALL TMOTOR( 88, 1286, 1293, 150, 753, 1298) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
32618	BS-U3-M	0.48	88	1286-	1292	1293-	1297	150	753- 760	1298	

\*\*\* CALL TMOTOR( 89, 1299, 1306, 151, 761, 1311) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24412	2A274	0.46	89	1299-	1305	1306-	1310	151	761- 768	1311	

\*\*\* CALL TMOTOR( 90, 1312, 1319, 152, 769, 1324) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24413	2A275	0.46	90	1312-	1318	1319-	1323	152	769- 776	1324	

\*\*\* CALL TMOTOR( 91, 1325, 1332, 153, 777, 1337) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24421	2E550	0.46	91	1325-	1331	1332-	1336	153	777- 784	1337	

\*\*\* CALL TMOTOR( 92, 1338, 1345, 154, 785, 1350) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24422	2E546	0.46	92	1338-	1344	1345-	1349	154	785- 792	1350	

\*\*\* CALL TMOTOR( 93, 1351, 1358, 155, 793, 1363) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
24434	2P009	0.46	93	1351-	1357	1358-	1362	155	793- 800	1363	

\*\*\* CALL TMOTOR( 94, 1364, 1371, 156, 801, 1376) \*\*\*

Calc No: E4C-082 CCN N-3 Rev. 1  
RE: Apr 9-30-94 IRE: Ad 10-5-94  
Sheet No. 319

CCN 9



BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24696 2E547 0.46 94 1364- 1370 1371- 1375 156 801- 808 1376

\*\*\* CALL TMOTOR( 95, 1377, 1384, 157, 809, 1389) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24607 2E549 0.46 95 1377- 1383 1384- 1388 157 809- 816 1389

\*\*\* CALL TMOTOR( 96, 1390, 1397, 158, 817, 1402) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24611 2A276 0.46 96 1390- 1396 1397- 1401 158 817- 824 1402

\*\*\* CALL TMOTOR( 97, 1403, 1410, 159, 825, 1415) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24612 2A277 0.46 97 1403- 1409 1410- 1414 159 825- 832 1415

\*\*\* CALL TMOTOR( 98, 1416, 1423, 160, 833, 1428) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24622 2P010 0.46 98 1416- 1422 1423- 1427 160 833- 840 1428

\*\*\* CALL TMOTOR( 99, 1429, 1436, 161, 841, 1441) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24417 P162-U2 0.46 99 1429- 1435 1436- 1440 161 841- 848 1441

\*\*\* CALL TMOTOR( 100, 1442, 1449, 162, 849, 1454) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
24618 P160-U2 0.46 100 1442- 1448 1449- 1453 162 849- 856 1454

\*\*\* CALL TMOTOR( 101, 1455, 1462, 163, 857, 1467) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
34417 P162-U3 0.46 101 1455- 1461 1462- 1466 163 857- 864 1467

\*\*\* CALL TMOTOR( 102, 1468, 1475, 164, 865, 1480) \*\*\*

BUS NAME BASKV ICON CIRCUIT CON'S RATING CON'S STATE V A R ' S ACC CON  
34618 P160-U3 0.46 102 1468- 1474 1475- 1479 164 865- 872 1480

Call No: E4C-082 CCN N-3 Rev: 1  
RE: Lpm 9-30-91 RE: Rd 10-5-94  
Sheet No. 320

CCN 9

\*\*\* CALL TMOTOR( 103, 1481, 1488, 165, 873, 1493) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34412	3A274	0.46	103	1481-	1487	1488-	1492	165	873- 880		1493

\*\*\* CALL TMOTOR( 104, 1494, 1501, 166, 881, 1506) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34413	3A275	0.46	104	1494-	1500	1501-	1505	166	881- 888		1506

\*\*\* CALL TMOTOR( 105, 1507, 1514, 167, 889, 1519) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34421	3E550	0.46	105	1507-	1513	1514-	1518	167	889- 896		1519

\*\*\* CALL TMOTOR( 106, 1520, 1527, 168, 897, 1532) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34422	3E546	0.46	106	1520-	1526	1527-	1531	168	897- 904		1532

\*\*\* CALL TMOTOR( 107, 1533, 1540, 169, 905, 1545) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34434	3P009	0.46	107	1533-	1539	1540-	1544	169	905- 912		1545

\*\*\* CALL TMOTOR( 108, 1546, 1553, 170, 913, 1558) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34606	3E547	0.46	108	1546-	1552	1553-	1557	170	913- 920		1558

\*\*\* CALL TMOTOR( 109, 1559, 1566, 171, 921, 1571) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34607	3E549	0.46	109	1559-	1565	1566-	1570	171	921- 928		1571

\*\*\* CALL TMOTOR( 110, 1572, 1579, 172, 929, 1584) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34611	3A276	0.46	110	1572-	1578	1579-	1583	172	929- 936		1584

\*\*\* CALL TMOTOR( 111, 1585, 1592, 173, 937, 1597) \*\*\*

Calc No: <u>E4C-082</u>	Sheet No: <u>321</u>
RE: <u>Apr 9-30-94</u>	Rev: <u>1</u>
IRE: <u>AL 10-5-94</u>	

2019

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34612	3A277	0.46	111	1585-	1591	1592-	1596	173	937- 944		1597

\*\*\* CALL TROTOR( 111, 1598, 1605, 174, 945, 1610) \*\*\*

BUS	NAME	BASKV	ICON	CIRCUIT	CON'S	RATING	CON'S	STATE	V A R ' S	ACC	CON
34622	3P010	0.46	112	1598-	1604	1605-	1609	174	945- 952		1610

\*\*\* CALL NETFRQ \*\*\*

Calc No:	<u>EDC-082</u>	Sheet No:	<u>322</u>
RE:	<u>CPM 9-30-99</u>	Rev:	<u>1</u>
IRE:	<u>AD 10-5-98</u>		

CCN 9

CHAN MODELS

\*\*\* CALL VOLMAG( 113, 953, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
113 953 0 24 2A04 4.16

\*\*\* CALL VOLMAG( 114, 954, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
114 954 0 26 2A06 4.16

\*\*\* CALL VOLMAG( 115, 955, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
115 955 0 34 3A04 4.16

\*\*\* CALL VOLMAG( 116, 956, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
116 956 0 36 3A06 4.16

\*\*\* CALL VOLMAG( 117, 957, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
117 957 0 214 2B04 0.48

\*\*\* CALL VOLMAG( 118, 958, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
118 958 0 216 2B06 0.48

\*\*\* CALL VOLMAG( 119, 959, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
119 959 0 314 3B04 0.48

\*\*\* CALL VOLMAG( 120, 960, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV

Calc No: E4C-082 CCN N-3 Rev. 1  
RE: CPN 9-30-94 IRE: Ref 10-5-94  
Sheet No. 323

CPN 9

120 960 0 316 3B06 0.48

\*\*\* CALL VOLMAG( 121, 961, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
121	961		0		2403	2P012	4.16

\*\*\* CALL VOLMAG( 122, 962, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
122	962		0		2404	2P141	4.16

\*\*\* CALL VOLMAG( 123, 963, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
123	963		0		2405	2P024	4.16

\*\*\* CALL VOLMAG( 124, 964, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
124	964		0		2406	2P025-A	4.16

\*\*\* CALL VOLMAG( 125, 965, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
125	965		0		2407	2P015	4.16

\*\*\* CALL VOLMAG( 126, 966, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
126	966		0		2408	2P017	4.16

\*\*\* CALL VOLMAG( 127, 967, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
127	967		0		2409	2P018-A	4.16

\*\*\* CALL VOLMAG( 128, 968, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
128	968		0		2410	2P112	4.16

Calc No:	E4C-082
CCN	N-3
Rev:	1
Sheet No.	324
RE: <i>pm 9-30-94</i>	IRE: <i>BJ 10-5-94</i>

*2219*

\*\*\* CALL VOLMAG( 129, 969, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
129		969		0	2411	2P307	4.16

\*\*\* CALL VOLMAG( 130, 970, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
130		970		0	2412	E336-U2	4.16

\*\*\* CALL VOLMAG( 131, 971, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
131		971		0	2413	2G002	4.36

\*\*\* CALL VOLMAG( 132, 972, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
132		972		0	2603	2P504	4.16

\*\*\* CALL VOLMAG( 133, 973, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
133		973		0	2604	2P013	4.16

\*\*\* CALL VOLMAG( 134, 974, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
134		974		0	2605	2P026	4.16

\*\*\* CALL VOLMAG( 135, 975, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
135		975		0	2606	2P025-B	4.16

\*\*\* CALL VOLMAG( 136, 976, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
136		976		0	2607	2P016	4.16

\*\*\* CALL VOLMAG( 137, 977, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
137		977		0	2608	2P019	4.16

Calo No: <u>E4C-082</u>	Sheet No: <u>325</u>
RE: <u>CPM 9-30-94</u>	CCN <u>N-3</u>
IRE: <u>RD 10-5-94</u>	Rev: <u>1</u>

Pen 9

CCN 9

Sheet No. 326  
Calc No: EAC-082 CCN N-3 Rev. 1  
RE: Lpm 9-30-94 IRE: Dr 10-5-94

\*\*\* CALL VOLMAG( 138, 978, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
138 978 0 2609 2P018-B 4.16

\*\*\* CALL VOLMAG( 139, 979, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
139 979 0 2610 2P113 4.16

\*\*\* CALL VOLMAG( 140, 980, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
140 980 0 2611 2P114 4.16

\*\*\* CALL VOLMAG( 141, 981, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
141 981 0 2612 E335-U2 4.16

\*\*\* CALL VOLMAG( 142, 982, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
142 982 0 2613 2G003 4.36

\*\*\* CALL VOLMAG( 143, 983, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
143 983 0 3402 E336-U3 4.16

\*\*\* CALL VOLMAG( 144, 984, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
144 984 0 3403 3P012 4.16

\*\*\* CALL VOLMAG( 145, 985, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
145 985 0 3404 3P141 4.16

\*\*\* CALL VOLMAG( 146, 986, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
146		986		0	3405	3P024	4.16

\*\*\* CALL VOLMAG( 147, 987, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
147		987		0	3406	3P025-A	4.16

\*\*\* CALL VOLMAG( 148, 988, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
148		988		0	3407	3P015	4.16

\*\*\* CALL VOLMAG( 149, 989, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
149		989		0	3408	3P017	4.16

\*\*\* CALL VOLMAG( 150, 990, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
150		990		0	3409	3P018-A	4.16

\*\*\* CALL VOLMAG( 151, 991, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
151		991		0	3410	3P112	4.16

\*\*\* CALL VOLMAG( 152, 992, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
152		992		0	3411	3P307	4.16

\*\*\* CALL VOLMAG( 153, 993, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
153		993		0	3413	3G002	4.36

\*\*\* CALL VOLMAG( 154, 994, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
154		994		0	3602	E335-U3	4.16

Calc No: <u>EDC-082</u>	Sheet No. <u>327</u>
RE: <u>Cam 9-30-94</u>	Rev. <u>1</u>
IRE: <u>Ed 10-5-94</u>	

Cam 9



\*\*\* CALL VOLMAG( 155, 995, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 155 995 0 3604 3P013 4.16

\*\*\* CALL VOLMAG( 156, 996, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 156 996 0 3605 3P026 4.16

\*\*\* CALL VOLMAG( 157, 997, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 157 997 0 3606 3P025-B 4.16

\*\*\* CALL VOLMAG( 158, 998, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 158 998 0 3607 3P016 4.16

\*\*\* CALL VOLMAG( 159, 999, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 159 999 0 3608 3P019 4.16

\*\*\* CALL VOLMAG( 160, 1000, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 160 1000 0 3609 3P018-B 4.16

\*\*\* CALL VOLMAG( 161, 1001, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 161 1001 0 3610 3P113 4.16

\*\*\* CALL VOLMAG( 162, 1002, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 162 1002 0 3611 3P114 4.16

\*\*\* CALL VOLMAG( 163, 1003, 0) \*\*\*

Calc No: E4C-082 CCN N-3 Sheet No. 328  
 RE: Apr 9-30-94 RE: AD 10-5-94 Rev. 1

CCN 9

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
163	1003	0	3612	3P504	4.16

\*\*\* CALL VOLMAG( 164, 1004, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
164	1004	0	3613	3G003	4.36

\*\*\* CALL VOLMAG( 165, 1005, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
165	1005	0	21403	2BRA	0.48

\*\*\* CALL VOLMAG( 166, 1006, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
166	1006	0	21405	2P191-A	0.46

\*\*\* CALL VOLMAG( 167, 1007, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
167	1007	0	21407	2BD	0.48

\*\*\* CALL VOLMAG( 168, 1008, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
168	1008	0	21409	2A071	0.46

\*\*\* CALL VOLMAG( 169, 1009, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
169	1009	0	21410	2E399	0.46

\*\*\* CALL VOLMAG( 170, 1010, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
170	1010	0	21411	2E401	0.46

\*\*\* CALL VOLMAG( 171, 1011, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
171	1011	0	21413	2P190	0.46

Calc No: <u>ETC-082</u>	Sheet No: <u>329</u>
RE: <u>CPM 9-30-94</u>	Rev: <u>1</u>
IRE: <u>AL 10-5-94</u>	

2209

\*\*\* CALL VOLMAG( 172, 1012, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 172 1012 0 21414 2BE 0.48

\*\*\* CALL VOLMAG( 173, 1013, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 173 1013 0 21415 2BY 0.48

\*\*\* CALL VOLMAG( 174, 1014, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 174 1014 0 21417 BQ-U2 0.48

\*\*\* CALL VOLMAG( 175, 1015, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 175 1015 0 21418 E418-U2 0.46

\*\*\* CALL VOLMAG( 176, 1016, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 176 1016 0 21419 2A074 0.46

\*\*\* CALL VOLMAG( 177, 1017, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 177 1017 0 21603 2BRB 0.48

\*\*\* CALL VOLMAG( 178, 1018, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 178 1018 0 21605 2BH 0.48

\*\*\* CALL VOLMAG( 179, 1019, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
 179 1019 0 21607 2BJ 0.48

\*\*\* CALL VOLMAG( 180, 1020, 0) \*\*\*  
 ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV

Calc No:	E4C-082	CCN	N-3	Rev:	1
RE:	Open 9-30-94	IRE:	AP	10-5-98	
Sheet No.	330				

CC19

180 1020 0 21609 2A072 0.46

\*\*\* CALL VOLMAG( 181, 1021, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
181	1021	0	21610	2E400	0.46

\*\*\* CALL VOLMAG( 182, 1022, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
182	1022	0	21611	2E402	0.46

\*\*\* CALL VOLMAG( 183, 1023, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
183	1023	0	21613	2P192	0.46

\*\*\* CALL VOLMAG( 184, 1024, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
184	1024	0	21614	2E2	0.48

\*\*\* CALL VOLMAG( 185, 1025, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
185	1025	0	21615	E419-U2	0.46

\*\*\* CALL VOLMAG( 186, 1026, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
186	1026	0	21617	2P191-B	0.46

\*\*\* CALL VOLMAG( 187, 1027, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
187	1027	0	21618	BS-U2	0.48

\*\*\* CALL VOLMAG( 188, 1028, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
188	1028	0	21619	2A073	0.46

Calc No: <u>EFC-082</u>	CCN <u>N-3</u>	Sheet No. <u>331</u>
RE: <u>CPM 9-30-94</u>	IRE: <u>AD 10-5-94</u>	Rev. <u>1</u>

CPN 9

\*\*\* CALL VOLMAG( 189, 1029, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
189	1029		0		31403	3BRA	0.48

\*\*\* CALL VOLMAG( 190, 1030, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
190	1030		0		31405	3P191-A	0.46

\*\*\* CALL VOLMAG( 191, 1031, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
191	1031		0		31407	3BD	0.48

\*\*\* CALL VOLMAG( 192, 1032, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
192	1032		0		31409	3A071	0.46

\*\*\* CALL VOLMAG( 193, 1033, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
193	1033		0		31410	3E399	0.46

\*\*\* CALL VOLMAG( 194, 1034, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
194	1034		0		31411	3E401	0.46

\*\*\* CALL VOLMAG( 195, 1035, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
195	1035		0		31413	3P190	0.46

\*\*\* CALL VOLMAG( 196, 1036, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
196	1036		0		31414	3BE	0.48

\*\*\* CALL VOLMAG( 197, 1037, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
197	1037		0		31415	3BY	0.48

Calc No: <u>E4C-082</u>	Sheet No. <u>332</u>
CCN <u>N-3</u>	Rev. <u>1</u>
RE: <u>Open 9-30-94</u>	IRE: <u>AL 10-5-94</u>

2019

\*\*\* CALL VOLMAG( 198, 1038, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
198	1038	0	31417	BQ-U3	0.48

\*\*\* CALL VOLMAG( 199, 1039, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
199	1039	0	31418	E418-U3	0.46

\*\*\* CALL VOLMAG( 200, 1040, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
200	1040	0	31419	3A074	0.46

\*\*\* CALL VOLMAG( 201, 1041, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
201	1041	0	31603	3BRB	0.48

\*\*\* CALL VOLMAG( 202, 1042, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
202	1042	0	31605	3BH	0.48

\*\*\* CALL VOLMAG( 203, 1043, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
203	1043	0	31607	3BJ	0.48

\*\*\* CALL VOLMAG( 204, 1044, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
204	1044	0	31609	3A072	0.46

\*\*\* CALL VOLMAG( 205, 1045, 0) \*\*\*

ICON	VOLTAGE VAR	ANGLE VAR	BUS	NAME	BSKV
205	1045	0	31610	3E400	0.46

\*\*\* CALL VOLMAG( 206, 1046, 0) \*\*\*

Calc No: <u>E4C-082</u>	Sheet No: <u>333</u>
RE: <u>Gen 9-30-94</u>	CCN <u>N-3</u>
IRE: <u>Bl 10-5-94</u>	Rev: <u>1</u>

CCN 9

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
206	1046		0		31611	3E402	0.46

\*\*\* CALL VOLMAG( 207, 1047, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
207	1047		0		31613	3P192	0.46

\*\*\* CALL VOLMAG( 208, 1048, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
208	1048		0		31614	3BZ	0.48

\*\*\* CALL VOLMAG( 209, 1049, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
209	1049		0		31615	E419-U3	0.46

\*\*\* CALL VOLMAG( 210, 1050, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
210	1050		0		31617	3P191-B	0.46

\*\*\* CALL VOLMAG( 211, 1051, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
211	1051		0		31618	BS-U3	0.48

\*\*\* CALL VOLMAG( 212, 1052, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
212	1052		0		31619	3A073	0.46

\*\*\* CALL VOLMAG( 213, 1053, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
213	1053		0		24412	2A274	0.46

\*\*\* CALL VOLMAG( 214, 1054, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
214	1054		0		24413	2A275	0.46

Calc No: <u>E4C-082</u>	Sheet No: <u>334</u>
RE: <u>CPM 9-20-94</u>	CCN <u>N-3</u>
IRE: <u>AD 11-5-94</u>	Rev: <u>1</u>

CEM9

CCN 9

Sheet No.	935
Case No:	E4C-082 CCN N-3 Rev. 1
RE:	Lpm 9-30-94 IRE: <u>Feb 10-5-94</u>

\*\*\* CALL VOLMAG( 215, 1055, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
215 1055 0 24417 P162-U2 0.46

\*\*\* CALL VOLMAG( 216, 1056, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
216 1056 0 24421 2E550 0.46

\*\*\* CALL VOLMAG( 217, 1057, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
217 1057 0 24422 2E546 0.46

\*\*\* CALL VOLMAG( 218, 1058, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
218 1058 0 24434 2P009 0.46

\*\*\* CALL VOLMAG( 219, 1059, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
219 1059 0 24606 2E547 0.46

\*\*\* CALL VOLMAG( 220, 1060, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
220 1060 0 24607 2E549 0.46

\*\*\* CALL VOLMAG( 221, 1061, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
221 1061 0 24611 2A276 0.46

\*\*\* CALL VOLMAG( 222, 1062, 0) \*\*\*  
ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
222 1062 0 24612 2A277 0.46

\*\*\* CALL VOLMAG( 223, 1063, 0) \*\*\*



ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
223 1063 0 24618 P160-U2 0.46

\*\*\* CALL VOLMAG( 224, 1064, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
224 1064 0 24622 2P010 0.46

\*\*\* CALL VOLMAG( 225, 1065, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
225 1065 0 34412 3A274 0.46

\*\*\* CALL VOLMAG( 226, 1066, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
226 1066 0 34413 3A275 0.46

\*\*\* CALL VOLMAG( 227, 1067, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
227 1067 0 34417 P162-U3 0.46

\*\*\* CALL VOLMAG( 228, 1068, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
228 1068 0 34421 3E550 0.46

\*\*\* CALL VOLMAG( 229, 1069, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
229 1069 0 34422 3E546 0.46

\*\*\* CALL VOLMAG( 230, 1070, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
230 1070 0 34434 3P009 0.46

\*\*\* CALL VOLMAG( 231, 1071, 0) \*\*\*

ICON VOLTAGE VAR ANGLE VAR BUS NAME BSKV  
231 1071 0 34606 3E547 0.46

Calc No:	E4C-082	CCN	N-3	Rev.	1
RE:	Lpm 9-30-94 IRE: RD 10-5-94				
Sheet No.	336				

ACN9

\*\*\* CALL VOLMAG( 232, 1072, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
232	1072		0		34607	3E549	0.46

\*\*\* CALL VOLMAG( 233, 1073, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
233	1073		0		34611	3A276	0.46

\*\*\* CALL VOLMAG( 234, 1074, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
234	1074		0		34612	3A277	0.46

\*\*\* CALL VOLMAG( 235, 1075, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
235	1075		0		34618	P160-U3	0.46

\*\*\* CALL VOLMAG( 236, 1076, 0) \*\*\*

ICON	VOLTAGE	VAR	ANGLE	VAR	BUS	NAME	BSKV
236	1076		0		34622	3P010	0.46

Calc No:	E4C-082
Sheet No.	337
RE:	CPM-9-30-94
IRE:	RD 11-5-94
CCN	N-3 Rev: 1

CCN 9

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. **N-3** PAGE **338** OF **453**

CCN CONVERSION CCN NO. CCN - **9**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1


Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					


**APPENDIX 9.1.3**

**CASE IIIAX**

Initial Condition Power Flow (Steady State) Report  
Post Accident Condition Power Flow (Steady State) Report



Sheet No. 239  
 Case No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: RL 10-5-94



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AX - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX];LP-1\_IIIAX.SAV

WED, SEP 14 1994 15:01

BUS DATA								LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
24	2A04	4.16	1	1.048	0.0	0.0	0.0	0.0	2403	2P012	4.16	1	1	0.0	0.0			
			1	4.36		0.0	0.0	0.0	2404	2P141	4.16	1	1	0.0	0.0			
									2406	2P025-A	4.16	1	1	0.0	0.0			
									2407	2P015	4.16	1	1	0.0	0.0			
									2408	2P017	4.16	1	1	0.0	0.0			
									2409	2P018-A	4.16	1	1	0.0	0.0			
									2411	2P307	4.16	1	1	0.1	0.1			
									2412	E336-U2	4.16	1	1	0.0	0.1			
									2413	2G002	4.36	1	1	0.6	-0.1	0.954UN		
									2416	2T014	4.16	1	1	0.0	0.0			
									2420	2B04X	4.16	1	1	-0.1	0.1			
									M I S M A T C H				-0.6	-0.1				
26	2A06	4.16	1	1.048	0.0	0.0	0.0	0.0	2603	2P504	4.16	1	1	-0.1	0.0			
			1	4.36		0.0	0.0	0.0	2604	2P013	4.16	1	1	0.0	0.0			
									2606	2P025-B	4.16	1	1	0.0	0.0			
									2607	2P016	4.16	1	1	0.0	0.0			
									2608	2P019	4.16	1	1	0.0	0.0			
									2609	2P018-B	4.16	1	1	0.0	0.0			
									2611	2P114	4.16	1	1	-0.1	0.0			
									2612	E335-U2	4.16	1	1	0.0	0.0			
									2613	2G003	4.36	1	1	0.5	0.6	0.954UN		
									2620	2B06X	4.16	1	1	-0.1	0.2			
									M I S M A T C H				-0.3	-0.6				
214	2B04	0.48	1	1.049	0.0	0.0	0.0	0.0	2420	2B04X	4.16	1	1	0.0	0.0	0.999UN		
			1	0.50		0.0	0.0	0.0	21402	2E61N	0.48	1	1	0.0	0.0			
									21403	2BRA	0.48	1	1	0.0	0.0			
									21405	2P191-A	0.46	1	1	0.0	0.0	1.043UN		
									21407	2BD	0.48	1	1	0.0	0.0			
									21409	2A071	0.46	1	1	0.0	0.0	1.043UN		
									21410	2E399	0.46	1	1	0.0	0.0	1.043UN		
									21411	2E401	0.46	1	1	0.0	0.0	1.043UN		
									21413	2P190	0.46	1	1	0.0	0.0	1.043UN		
									21414	2BE	0.48	1	1	0.0	0.0			
									21415	2BY	0.48	1	1	0.0	0.0			
									21417	BQ-U2	0.48	1	1	0.0	0.0			
									21418	E418-U2	0.46	1	1	0.0	0.0	1.043UN		
									21419	2A074	0.46	1	1	0.0	0.0	1.043UN		

Calc No: E4C-082 CCN N-3 Rev. 1  
RE: LPW 9-30-94 RE: BL 10-5-94  
Sheet No. 340

2299

CCN9

Sheet No. 341

Calc No: E4C-082 CCN N-3 Rev. 1

RE: Lpm 9-30-94 IRE: Bl 11-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, SEP 14 1994 15:01  
CASE III.AX - INITIAL STEADY STATE CONDITION  
DBS200:[MURIEL.E4C-082-AGA.CASE.III.AX|LP-1.III.AX.SAV

BUS DATA				LINE DATA											
FROM BUS	AREA	VOLT	ANGLE	GER	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	RATIO	ANGLE	RATING
		PU/KV		KW/KVAR	KW/KVAR	KW/KVAR									MI KVA
216 2B06	1	1.049	0.0	0.0	0.0	0.0	2620 2B06X	4.16	1	1	0.0	0.0	0.0	0.0	0.999UN
	1	0.50		0.0	0.0	0.0	21602 2E62H	0.48	1	1	0.0	0.0	0.0	0.0	
							21603 2BRB	0.48	1	1	0.0	0.0	0.0	0.0	
							21605 2BH	0.48	1	1	0.0	0.0	0.0	0.0	
							21607 2BJ	0.48	1	1	0.0	0.0	0.0	0.0	
							21609 2A072	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
							21610 2E400	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
							21611 2E402	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
							21613 2P192	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
							21614 2BZ	0.48	1	1	0.0	0.0	0.0	0.0	
							21615 E419-U2	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
							21617 2P191-B	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
							21618 BS-U2	0.48	1	1	0.0	0.0	0.0	0.0	
							21619 2A073	0.46	1	1	0.0	0.0	0.0	0.0	1.043UN
2403 2P012	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2404 2P141	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2406 2P025-A	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2407 2P015	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2408 2P017	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2409 2P018-A	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2411 2P307	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2412 E336-U2	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	-0.1	-0.1	-0.1	-0.1	
	1	4.36		0.0	0.0	0.0									
2413 2G002	1	1.000	0.0	-0.6	0.0	0.0	24 2A04	4.16	1	1	0.0	-0.1	-0.1	-0.1	
	1	4.36		0.1R	0.0	0.0									
2416 2T014	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	-0.6	0.1	0.954LK	0.954LK	
	1	4.36		0.0	0.0	0.0									
2420 2B04X	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0	0.0	
	1	4.36		0.0	0.0	0.0									
2603 2P504	1	1.048	0.0	0.0	0.0	0.0	24 2A04	4.16	1	1	0.1	-0.1	-0.1	-0.1	
	1	4.36		0.0	0.0	0.0	214 2B04	0.48	1	1	0.0	0.0	0.0	0.999LK	0.999LK
							26 2A06	4.16	1	1	0.1	0.1	0.0	0.0	



BUS DATA					LINE DATA											
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A
		ZONE	PU/KV		KW/KVAR	KW/KVAR	KW/KVAR									%I KVA
21411	2E401	0.46	1	1.095	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0	1.043LK	
21413	2P190	0.46	1	1.095	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0	1.043LK	
21414	2BE	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0		
									22414	2BE-M	0.48	1	1	0.0	0.0	
									23414	2BE-S	0.48	1	1	0.0	0.0	
21415	2BY	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0		
									22415	2BY-M	0.48	1	1	0.0	0.0	
									23415	2BY-S	0.48	1	1	0.0	0.0	
									24434	2P009	0.46	1	1	0.0	0.0	1.043UN
21417	BQ-U2	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0		
									22417	BQ-U2-M	0.48	1	1	0.0	0.0	
									23417	BQ-U2-S	0.48	1	1	0.0	0.0	
									24417	P162-U2	0.46	1	1	0.0	0.0	1.043UN
21418	E418-U2	0.46	1	1.095	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0	1.043LK	
21419	2A074	0.46	1	1.095	0.0	0.0	0.0									
			1	0.50		0.0	0.0	214	2B04	0.48	1	1	0.0	0.0	1.043LK	
21602	2E62N	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	216	2B06	0.48	1	1	0.0	0.0		
21603	2BRB	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	216	2B06	0.48	1	1	0.0	0.0		
									22603	2BRB-M	0.48	1	1	0.0	0.0	
									23603	2BRB-S	0.48	1	1	0.0	0.0	
21605	2BH	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	216	2B06	0.48	1	1	0.0	0.0		
									22605	2BH-M	0.48	1	1	0.0	0.0	
									23605	2BH-S	0.48	1	1	0.0	0.0	
									24606	2E547	0.46	1	1	0.0	0.0	1.043UN
									24607	2E549	0.46	1	1	0.0	0.0	1.043UN
									24611	2A276	0.46	1	1	0.0	0.0	1.043UN
									24612	2A277	0.46	1	1	0.0	0.0	1.043UN
21607	2BJ	0.48	1	1.049	0.0	0.0	0.0									
			1	0.50		0.0	0.0	216	2B06	0.48	1	1	0.0	0.0		
									22607	2BJ-M	0.48	1	1	0.0	0.0	
									23607	2BJ-S	0.48	1	1	0.0	0.0	
21609	2A072	0.46	1	1.095	0.0	0.0	0.0									
			1	0.50		0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK	
21610	2E400	0.46	1	1.095	0.0	0.0	0.0									
			1	0.50		0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK	

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: Lpm 9-30-94 IRE: RL 10-5-94  
Sheet No. 343

LEN 9



FTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, SEP 14 1994 15:01  
CASE III.AX - INITIAL STEADY STATE CONDITION  
DRB200:[MURIEL.E4C-082-AGA.CASE III.AX]LF-1\_III.AX.SAV

BUS DATA				LINE DATA										
FROM BUS	AREA	VOLT	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	RATIO	ANGLE	RATING
		PU	KW	KW	KW/KVAR									KA
21511	2E402	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
21613	2P192	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
21614	2B2	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
21615	E419-U2	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
21617	2P191-B	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
21618	BS-U2	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
21619	2A073	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	216 2B06	0.48	1	1	0.0	0.0	0.0	1.043LK
22403	2BRA-N	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21403 2BRA	0.48	1	1	0.0	0.0	0.0	1.043LK
22407	2BD-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21407 2BD	0.48	1	1	0.0	0.0	0.0	1.043LK
22414	2BE-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21414 2BE	0.48	1	1	0.0	0.0	0.0	1.043LK
22415	2BY-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21415 2BY	0.48	1	1	0.0	0.0	0.0	1.043LK
22417	BQ-U2-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21417 BQ-U2	0.48	1	1	0.0	0.0	0.0	1.043LK
22603	2BRB-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21603 2BRB	0.48	1	1	0.0	0.0	0.0	1.043LK
22605	2RR-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21605 2RR	0.48	1	1	0.0	0.0	0.0	1.043LK
22607	2BJ-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21607 2BJ	0.48	1	1	0.0	0.0	0.0	1.043LK
22614	2B5-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK
			1	0.50	0.0	0.0	21614 2B5	0.48	1	1	0.0	0.0	0.0	1.043LK

Sheet No. 344  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: LPW 9-30-94 IRE: DL 10-5-94

CCN 9



CCN 9



Sheet No. 346

Calc No: E4C-082 CCN N-3 Rev. 1



RE: Lpm 9-30-94 IRE: Pul 10-5-94

FTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AX - INITIAL STEADY STATE CONDITION  
NR200:[MURIEL.E4C-082-AGA.CASE III.AX]LP-1\_III.AX.SAV  
WED, SEP 14 1994 15:01

BUS DATA				LINE DATA													
FROM BUS	AREA	VOLT	ZONE	PU/KV	ANGLE	GEN	KW/KVAR	LOAD	SHUNT	TO BUS	NAME	CKT AREA	KW	KVAR	RATIO	ANGLE	RATING
24606	2E547	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	0.0	0.0	1.043LK	
24607	2E549	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	0.0	0.0	1.043LK	
24611	2A276	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	0.0	0.0	1.043LK	
24612	2A277	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	0.0	0.0	1.043LK	
24618	P160-U2	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	21618	BS-U2	0.48	1	0.0	0.0	1.043LK	
24622	2F010	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	21614	2B2	0.48	1	0.0	0.0	1.043LK	



Sheet No. 347  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 RE: Del 10-5-94



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX]LP-2\_IIIAX.SAV

WED, SEP 14 1994 17:18

BUS DATA								LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA	
24	2A04	4.16	1	1.048	171.2	0.0	0.0	0.0	2403	2P012	4.16	1	1	306.0	183.7			
			1	4.36		0.0	0.0	0.0	2404	2P141	4.16	1	1	668.0	307.8			
									2406	2P025-A	4.16	1	1	468.4	287.4			
									2407	2P015	4.16	1	1	376.2	201.7			
									2408	2P017	4.16	1	1	395.6	185.0			
									2409	2P018-A	4.16	1	1	395.7	185.0			
									2411	2P307	4.16	1	1	317.7	219.4			
									2412	E336-U2	4.16	1	1	445.6	260.5			
									2413	2G002	4.36	1	1	-4897.5	-2880.7	0.954UN		
									2416	2T014	4.16	1	1	127.8	78.1			
									2420	2B04X	4.16	1	1	1399.0	972.5			
									M I S M A T C H									
26	2A06	4.16	1	1.048	-111.5	0.0	0.0	0.0	2603	2P504	4.16	1	1	670.9	307.5			
			1	4.36		0.0	0.0	0.0	2604	2P013	4.16	1	1	308.4	183.6			
									2606	2P025-B	4.16	1	1	472.8	287.4			
									2607	2P016	4.16	1	1	379.4	201.9			
									2608	2P019	4.16	1	1	397.6	184.7			
									2609	2P018-B	4.16	1	1	397.6	184.7			
									2611	2P114	4.16	1	1	320.8	219.4			
									2612	E335-U2	4.16	1	1	449.7	261.1			
									2613	2G003	4.36	1	1	-4733.5	-2744.0	0.954UN		
									2620	2B06X	4.16	1	1	1335.3	913.7			
									M I S M A T C H									
214	2B04	0.48	1	0.977	166.5	0.0	0.0	0.0	2420	2B04X	4.16	1	1	-1372.3	-792.4	0.999UN		
			1	0.47		0.0	0.0	0.0	21402	2E61N	0.48	1	1	201.8	2.5			
									21403	2BRA	0.48	1	1	22.2	13.9			
									21405	2P191-A	0.46	1	1	55.7	39.6	1.043UN		
									21407	2BD	0.48	1	1	184.2	130.8			
									21409	2A071	0.46	1	1	56.9	35.3	1.043UN		
									21410	2E399	0.46	1	1	60.9	46.6	1.043UN		
									21411	2E401	0.46	1	1	61.0	46.6	1.043UN		
									21413	2P190	0.46	1	1	55.7	39.6	1.043UN		
									21414	2BE	0.48	1	1	142.3	97.5			
									21415	2BY	0.48	1	1	215.0	140.1			
									21417	BQ-U2	0.48	1	1	140.7	88.9			
									21418	E418-U2	0.46	1	1	120.1	78.1	1.043UN		
									21419	2A074	0.46	1	1	57.2	35.3	1.043UN		
									M I S M A T C H									

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: Lpm 9-30-94 IRE: 08-10-5-94  
Sheet No. 348  
CCN 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS/E  
 CASE III.AX - POST ACCIDENT (STEADY STATE) CONDITION  
 DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX]LF-2 IIIAX.SAV

WED, SEP 14 1994 17:18

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A KI KVA
216	2B06	0.48	1	0.981	-116.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	2620	2B06X	4.16	1	1	-1312.5	-753.5	0.9999UN
									21602	2E62N	0.48	1	1	202.5	2.6	
									21603	2BRB	0.48	1	1	22.3	13.9	
									21605	2BH	0.48	1	1	182.9	129.7	
									21607	2BJ	0.48	1	1	132.6	91.2	
									21609	2A072	0.46	1	1	56.7	35.2	1.043UN
									21610	2E400	0.46	1	1	60.9	46.5	1.043UN
									21611	2E402	0.46	1	1	61.4	46.5	1.043UN
									21613	2P192	0.46	1	1	56.4	39.8	1.043UN
									21614	2BZ	0.48	1	1	198.3	127.5	
									21615	E419-U2	0.46	1	1	117.2	78.9	1.043UN
									21617	2P191-P	0.46	1	1	56.4	39.8	1.043UN
									21618	BS-U2	0.48	1	1	107.9	66.8	
									21619	2A073	0.46	1	1	57.1	35.2	1.043UN
2403	2P012	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-305.8	-183.6	
			1	4.36		0.0	0.0	0.0	M I S M A T C H				305.8	183.6		
2404	2P141	4.16	1	1.046	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-667.1	-307.2	
			1	4.35		0.0	0.0	0.0	M I S M A T C H				667.1	307.2		
2406	2P025-A	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-468.1	-287.2	
			1	4.36		0.0	0.0	0.0	M I S M A T C H				468.1	287.2		
2407	2P015	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-376.1	-201.6	
			1	4.36		0.0	0.0	0.0	M I S M A T C H				376.1	201.6		
2408	2P017	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-395.4	-184.9	
			1	4.36		0.0	0.0	0.0	M I S M A T C H				395.4	184.9		
2409	2P018-A	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-395.5	-184.9	
			1	4.36		0.0	0.0	0.0	M I S M A T C H				395.5	184.9		
2411	2P307	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-317.6	-219.2	
			1	4.36		0.0	0.0	0.0	M I S M A T C H				317.6	219.2		
2412	E336-U2	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-445.2	-260.3	
			1	4.35		0.0	0.0	0.0	M I S M A T C H				445.2	260.3		
2413	2G002	4.36	1	1.006	171.3	4936.1	0.0	0.0	24	2A04	4.16	1	1	4923.1	2911.8	0.954LK
			1	4.39		2909.8R	0.0	0.0	M I S M A T C H				13.0	-2.1		
2416	2T014	4.16	1	1.047	171.2	0.0	128.0	0.0	24	2A04	4.16	1	1	-127.8	-78.1	
			1	4.36		0.0	78.0	0.0	M I S M A T C H							
2420	2B04X	4.16	1	1.047	171.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-1398.6	-972.2	
			1	4.36		0.0	0.0	0.0	214	2B04	0.48	1	1	1397.6	969.2	0.999LK
									M I S M A T C H				1.0	3.0		
2603	2P504	4.16	1	1.046	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	1	-670.1	-307.0	
			1	4.35		0.0	0.0	0.0								

Calc No: E4C-082 CN N-3 Rev: 1  
 RE: Lpm 9-30-94 IRE: PJ 10-5-94  
 Sheet No. 349

CAN 9

CCN 9

Sheet No. <u>350</u>	
Case No: <u>E4C-082 CCN N-3</u>	Rev. <u>1</u>
RE: <u>Lpm 9-30-94</u>	IRE: <u>Bl 10-5-94</u>

670.1 307.0

M I S M A T C H

BUS DATA										LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
2604	2P013	4.16	1	1.047	-111.5	0.0	0.0	0.0										
			1	4.36		0.0	0.0	0.0	26	2A06	4.16	1	-308.2	-183.5				
										M I S M A T C H			308.2	183.5				
2606	2P025-E	4.16	1	1.047	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	-472.6	-287.2				
			1	4.36		0.0	0.0	0.0		M I S M A T C H			472.6	287.2				
2607	2P016	4.16	1	1.047	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	-379.2	-201.7				
			1	4.36		0.0	0.0	0.0		M I S M A T C H			379.2	201.7				
2608	2P019	4.16	1	1.047	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	-397.4	-184.6				
			1	4.36		0.0	0.0	0.0		M I S M A T C H			397.4	184.6				
2609	2P018-B	4.16	1	1.047	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	-397.5	-184.6				
			1	4.36		0.0	0.0	0.0		M I S M A T C H			397.5	184.6				
2611	2P114	4.16	1	1.047	-111.5	6.0	0.0	0.0	26	2A06	4.16	1	-320.6	-219.2				
			1	4.36		0.0	0.0	0.0		M I S M A T C H			320.6	219.2				
2612	E335-U2	4.16	1	1.047	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	-449.4	-260.8				
			1	4.35		0.0	0.0	0.0		M I S M A T C H			449.4	260.8				
2613	2G003	4.36	1	1.004	-111.4	4750.7	0.0	0.0	26	2A06	4.16	1	4750.8	2764.9	0.954LK			
			1	4.38		2764.9R	0.0	0.0										
2620	2B06X	4.16	1	1.047	-111.5	0.0	0.0	0.0	26	2A06	4.16	1	-1335.0	-913.4				
			1	4.36		0.0	0.0	0.0	216	2B06	0.48	1	1335.4	913.6	0.999LK			
21402	2E61N	0.48	1	0.967	165.8	0.0	200.0	0.0	214	2B04	0.48	1	-199.7	-0.3				
			1	0.46		0.0	0.0	0.0										
21403	2BPA	0.48	1	0.977	166.5	0.0	0.0	0.0	214	2B04	0.48	1	-22.2	-13.9				
			1	0.47		0.0	0.0	0.0	22403	2BRA-M	0.48	1	13.8	8.6				
									23403	2BRA-S	0.48	1	8.5	5.3				
21405	2P191-A	0.46	1	1.010	166.5	0.0	0.0	0.0	214	2B04	0.48	1	-55.2	-39.3	1.043LK			
			1	0.46		0.0	0.0	0.0		M I S M A T C H			55.2	39.3				
21407	2BD	0.48	1	0.919	165.8	0.0	0.0	0.0	214	2B04	0.48	1	-174.9	-120.9				
			1	0.44		0.0	0.0	0.0	22407	2BD-M	0.48	1	17.6	10.8				
									23407	2BD-S	0.48	1	8.5	5.3				
									24412	2A274	0.46	1	42.3	29.9	1.043UN			
									24413	2A275	0.46	1	42.5	29.9	1.043UN			
									24421	2E550	0.46	1	32.1	22.6	1.043UN			
									24422	2E546	0.46	1	32.1	22.6	1.043UN			
21409	2A071	0.46	1	1.000	166.7	0.0	0.0	0.0	214	2B04	0.48	1	-55.7	-34.9	1.043LK			
			1	0.46		0.0	0.0	0.0		M I S M A T C H			55.7	34.9				
21410	2E399	0.46	1	1.008	166.6	0.0	0.0	0.0	214	2B04	0.48	1	-60.1	-46.2	1.043LK			
			1	0.46		0.0	0.0	0.0		M I S M A T C H			60.1	46.2				

Calc No: EEC-082 CAN N-3 Rev: 1  
RE: EEC 9-30-94 IRE: AL 10-5-94  
Sheet No: 351

CAN 9



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AX - POST ACCIDENT (STEADY STATE) CONDITION  
DRB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX]LP-2\_IIIAX.SAV

WED, SEP 14 1994 17:18

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I	KVA
21411	2E401	0.46	1 1.006	166.6	0.0	0.0	0.0										
			1 0.46		0.0	0.0	0.0	214	2B04	0.48	1 1	-60.1	-46.1	1.043LK			
									M I S M A T C H			60.1	46.1				
21413	2P190	0.46	1 1.011	166.5	0.0	0.0	0.0										
			1 0.46		0.0	0.0	0.0	214	2B04	0.48	1 1	-55.2	-39.4	1.043LK			
									M I S M A T C H			55.2	39.4				
21414	2BE	0.48	1 0.974	166.4	0.0	0.0	0.0										
			1 0.47		0.0	0.0	0.0	214	2B04	0.48	1 1	-142.0	-97.1				
								22414	2BE-M	0.48	1 1	52.9	33.0				
								23414	2BE-S	0.48	1 1	89.4	64.1				
21415	2BY	0.48	1 0.974	166.4	0.0	0.0	0.0										
			1 0.47		0.0	0.0	0.0	214	2B04	0.48	1 1	-214.6	-139.3				
								22415	2BY-M	0.48	1 1	79.8	69.8				
								23415	2BY-S	0.48	1 1	112.5	78.1				
								24434	2P009	0.46	1 1	22.9	11.5	1.043UM			
									M I S M A T C H			-0.7	-0.1				
21417	BQ-U2	0.48	1 0.975	166.4	0.0	0.0	0.0										
			1 0.47		0.0	0.0	0.0	214	2B04	0.48	1 1	-140.4	-88.6				
								22417	BQ-U2-M	0.48	1 1	40.2	25.1				
								23417	BQ-U2-S	0.48	1 1	75.9	45.8				
								24417	P162-U2	0.46	1 1	24.6	17.6	1.043UM			
21418	E418-U2	0.46	1 0.990	166.6	0.0	0.0	0.0										
			1 0.46		0.0	0.0	0.0	214	2B04	0.48	1 1	-116.4	-76.0	1.043LK			
									M I S M A T C H			116.4	76.0				
21419	2A074	0.46	1 0.995	166.7	0.0	0.0	0.0										
			1 0.46		0.0	0.0	0.0	214	2B04	0.48	1 1	-55.7	-34.7	1.043LK			
									M I S M A T C H			55.7	34.7				
21602	2E62W	0.48	1 0.969	-116.7	0.0	200.0	0.0										
			1 0.47		0.0	0.0	0.0	216	2B06	0.48	1 1	-200.0	0.0				
21603	2BRB	0.48	1 0.981	-116.0	0.0	0.0	0.0										
			1 0.47		0.0	0.0	0.0	216	2B06	0.48	1 1	-22.3	-13.9				
								22603	2BRB-M	0.48	1 1	13.8	8.6				
								23603	2BRB-S	0.48	1 1	8.5	5.3				
21605	2BH	0.48	1 0.936	-116.5	0.0	0.0	0.0										
			1 0.45		0.0	0.0	0.0	216	2B06	0.48	1 1	-175.6	-122.0				
								22605	2BH-M	0.48	1 1	17.7	10.9				
								23605	2BH-S	0.48	1 1	8.5	5.3				
								24608	2E547	0.46	1 1	32.2	22.9	1.043UM			
								24607	2E549	0.46	1 1	32.3	22.9	1.043UM			
								24611	2A276	0.46	1 1	42.4	30.0	1.043UM			
								24612	2A277	0.46	1 1	42.5	30.0	1.043UM			
21607	2BJ	0.48	1 0.978	-116.0	0.0	0.0	0.0										
			1 0.47		0.0	0.0	0.0	216	2B06	0.48	1 1	-132.4	-90.9				
								22607	2BJ-M	0.48	1 1	53.1	33.1				
								23607	2BJ-S	0.48	1 1	79.2	57.8				
21609	2A072	0.46	1 1.002	-115.7	0.0	0.0	0.0										
			1 0.46		0.0	0.0	0.0	216	2B06	0.48	1 1	-55.3	-34.7	1.043LK			
									M I S M A T C H			55.3	34.7				
21610	2E400	0.46	1 1.007	-115.9	0.0	0.0	0.0										
			1 0.46		0.0	0.0	0.0	216	2B06	0.48	1 1	-59.9	-46.0	1.043LK			

Case No: E4C-082 CCN N-3 Rev. 1  
RE: Lpm 9-30-94 RE: PL 10-5-94  
Sheet No 352

CCN 9

CCN 9

Sheet No. <u>353</u>	
Calc No: <u>E4C-082 CCN N-3</u>	Rev: <u>1</u>
RE: <u>LPM 9-30-94</u>	IRE: <u>Ad 10-5-94</u>

59.9 46.0

R I S M A T C H

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX]LF-2\_IIIAX.SAV

WED, SEP 14 1994 17:18

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI KVA
21611	2E402	0.46	1	1.001	-115.8	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-59.9	-45.6	1.043LK	
									M I S M A T C H				59.9	45.6		
21613	2P192	0.46	1	1.010	-115.9	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-55.6	-39.4	1.043LK	
									M I S M A T C H				55.6	39.4		
21614	2BZ	0.48	1	0.979	-116.1	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	216 2B06	0.48	1	1	-198.0	-127.0		
									22614 2BZ-M	0.48	1	1	50.5	31.5		
									23614 2BZ-S	0.48	1	1	124.4	83.9		
									24622 2P010	0.46	1	1	23.1	11.6	1.043UN	
21615	E419-U2	0.46	1	1.017	-116.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	216 2B06	0.48	1	1	-116.5	-78.4	1.043LK	
									M I S M A T C H				116.5	78.4		
21617	2P191-B	0.46	1	1.010	-115.9	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-55.6	-39.3	1.043LK	
									M I S M A T C H				55.6	39.3		
21618	BS-U2	0.48	1	0.977	-116.1	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	216 2B06	0.48	1	1	-107.6	-66.4		
									22618 BS-U2-M	0.48	1	1	40.4	25.2		
									23618 BS-U2-S	0.48	1	1	42.6	23.4		
									24618 P160-U2	0.46	1	1	24.6	17.8	1.043UN	
21619	2A073	0.46	1	0.995	-115.7	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-55.3	-34.5	1.043LK	
									M I S M A T C H				55.3	34.5		
22403	2BRA-M	0.48	1	0.977	166.5	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21403 2BRA	0.48	1	1	-13.8	-8.6		
									M I S M A T C H				13.8	8.6		
22407	2BD-M	0.48	1	0.919	165.8	0.0	0.0	0.0								
			1	0.44		0.0	0.0	0.0	21407 2BD	0.48	1	1	-17.6	-10.8		
									M I S M A T C H				17.6	10.8		
22414	2BE-M	0.48	1	0.974	166.4	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21414 2BE	0.48	1	1	-52.9	-33.0		
									M I S M A T C H				52.9	33.0		
22415	2BY-M	0.48	1	0.974	166.4	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21415 2BY	0.48	1	1	-79.8	-49.8		
									M I S M A T C H				79.8	49.8		
22417	BQ-U2-M	0.48	1	0.975	166.4	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21417 BQ-U2	0.48	1	1	-40.2	-25.1		
									M I S M A T C H				40.2	25.1		
22603	2BRB-M	0.48	1	0.981	-116.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21603 2BRB	0.48	1	1	-13.2	-8.6		
									M I S M A T C H				13.2	8.6		
22605	2BH-M	0.48	1	0.936	-116.5	0.0	0.0	0.0								
			1	0.45		0.0	0.0	0.0	21605 2BH	0.48	1	1	-17.7	-10.9		
									M I S M A T C H				17.7	10.9		
22607	2BJ-M	0.48	1	0.978	-116.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21607 2BJ	0.48	1	1	-53.1	-33.1		
									M I S M A T C H				53.1	33.1		
22614	2BZ-M	0.48	1	0.979	-116.1	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21614 2BZ	0.48	1	1	-50.5	-31.5		

Calc No: E4C-082 CCA N-3 Rev: 1  
 RE: Lpm 9-30-94 IRE: BR 10-5-94  
 Sheet No: 354

ANN 9

CCN9

Sheet No. <u>355</u>
Calc No: <u>E4C-082 CCN N-3</u> Rev. <u>1</u>
RE: <u>Upm 9-30-94</u> IRE: <u>Ad 10-5-99</u>

50.5 31.5

MISMATCH

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAX]LF-2\_IIIAX.SAV

WED, SEP 14 1994 17:18

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
22618	BS-U2-M	0.48	1	0.977	-116.1	0.0	0.0	0.0									
			1	0.47		0.0	0.0	0.0	21618	BS-U2	0.48	1	1	-40.4	-25.2		
										M I S M A T C H				40.4	25.2		
23403	2BRA-S	0.48	1	0.977	166.5	0.0	8.5	0.0									
			1	0.47		0.0	5.3	0.0	21403	2BRA	0.48	1	1	-8.5	-5.3		
23407	2BD-S	0.48	1	0.919	165.8	0.0	8.5	0.0									
			1	0.44		0.0	5.3	0.0	21407	2BD	0.48	1	1	-8.5	-5.3		
23414	2BE-S	0.48	1	0.974	166.4	0.0	89.4	0.0									
			1	0.47		0.0	64.1	0.0	21414	2BE	0.48	1	1	-89.4	-64.1		
23415	2BY-S	0.48	1	0.974	166.4	0.0	112.5	0.0									
			1	0.47		0.0	78.1	0.0	21415	2BY	0.48	1	1	-112.5	-78.1		
23417	BQ-U2-S	0.48	1	0.975	166.4	0.0	75.9	0.0									
			1	0.47		0.0	45.8	0.0	21417	BQ-U2	0.48	1	1	-75.9	-45.8		
23603	2BRB-S	0.48	1	0.941	-116.0	0.0	8.5	0.0									
			1	0.47		0.0	5.3	0.0	21600	2BRB	0.48	1	1	-8.5	-5.3		
23605	2BH-S	0.48	1	0.936	-116.5	0.0	8.5	0.0									
			1	0.45		0.0	5.3	0.0	21605	2BH	0.48	1	1	-8.5	-5.3		
23607	2BJ-S	0.48	1	0.978	-116.0	0.0	79.2	0.0									
			1	0.47		0.0	57.8	0.0	21607	2BJ	0.48	1	1	-79.2	-57.8		
23614	2BZ-S	0.48	1	0.979	-116.1	0.0	124.4	0.0									
			1	0.47		0.0	83.9	0.0	21614	2BZ	0.48	1	1	-124.4	-83.9		
23618	BS-U2-S	0.48	1	0.977	-116.1	0.0	42.6	0.0									
			1	0.47		0.0	23.4	0.0	21618	BS-U2	0.48	1	1	-42.6	-23.4		
24412	2A274	0.46	1	0.957	165.8	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-42.2	-29.8	1.043LK	
										M I S M A T C H				42.2	29.8		
24413	2A275	0.46	1	0.954	165.9	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-42.2	-29.8	1.043LK	
										M I S M A T C H				42.2	29.8		
24417	P162-U2	0.46	1	1.005	166.7	0.0	0.0	0.0									
			1	0.46		0.0	0.0	0.0	21417	BQ-U2	0.48	1	1	-24.2	-17.6	1.043LK	
										M I S M A T C H				24.2	17.6		
24421	2E550	0.46	1	0.954	165.9	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-31.9	-22.5	1.043LK	
										M I S M A T C H				31.9	22.5		
24422	2E546	0.46	1	0.954	165.9	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-31.9	-22.5	1.043LK	
										M I S M A T C H				31.9	22.5		
24434	2P009	0.46	1	1.004	166.6	0.0	0.0	0.0									
			1	0.46		0.0	0.0	0.0	21415	2BY	0.48	1	1	-22.6	-11.5	1.043LK	
										M I S M A T C H				22.6	11.5		

Case No: E4C-082 CCN N-3 Rev: 1  
RE: *CPM 9-30-94* IRE: *Ad 10-5-94*  
Sheet No. 356

*CCN 9*

BUS DATA					LINE DATA											
FROM BUS	NAME	AREA	VOLT SONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A 9I KVA
24606	2E547	0.46	1 0.971	-116.4	0.0	0.0	0.0	21605	2BH	0.48	1	1	-32.0	-22.9	1.043LK	
			1 0.45		0.0	0.0	0.0		M I S M A T C H				32.0	22.9		
24607	2E549	0.46	1 0.971	-116.4	0.0	0.0	0.0	21605	2BH	0.48	1	1	-32.0	-22.9	1.043LK	
			1 0.45		0.0	0.0	0.0		M I S M A T C H				32.0	22.9		
24611	2A276	0.46	1 0.974	-116.5	0.0	0.0	0.0	21605	2BH	0.48	1	1	-42.2	-30.0	1.043LK	
			1 0.45		0.0	0.0	0.0		M I S M A T C H				42.2	30.0		
24612	2A277	0.46	1 0.971	-116.4	0.0	0.0	0.0	21605	2BH	0.48	1	1	-42.2	-30.0	1.043LK	
			1 0.45		0.0	0.0	0.0		M I S M A T C H				42.2	30.0		
24618	P160-U2	0.46	1 1.013	-115.9	0.0	0.0	0.0	21618	BS-U2	0.48	1	1	-24.4	-17.7	1.043LK	
			1 0.47		0.0	0.0	0.0		M I S M A T C H				24.4	17.7		
24622	2P010	0.46	1 1.009	-115.9	0.0	0.0	0.0	21614	2BZ	0.48	1	1	-22.8	-11.6	1.043LK	
			1 0.46		0.0	0.0	0.0		M I S M A T C H				22.8	11.6		

RE: *Lpm* 9-30-94 IRE: *DL 10-1-94*

Calc No: *E4C-082* CCN *N-3* Rev: *1*

Sheet No. *357*

*CCN 9*

**NES&L DEPARTMENT  
CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>358</b> OF <b>453</b>
CCN CONVERSION CCN NO. CCN - <b>9</b>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_




REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**APPENDIX 9.1.4**




**CASE IIIAY**

Initial Condition Power Flow (Steady State) Report  
Post Accident Condition Power Flow (Steady State) Report

CCN 9



Sheet No. 359  
 Case No: EAC-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-91 IRE: Ad 10-5-99



PSS/E RELEASE 19.0





BUS DATA								LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	KVA
24	2A04	4.16	1	1.048	0.0	0.0	0.0	0.0	2403	2P012	4.16	1	1	0.0	0.0			
			1	4.36		0.0	0.0	0.0	2404	2P141	4.16	1	1	0.0	0.0			
									2406	2P025-A	4.16	1	1	0.0	0.0			
									2407	2P015	4.16	1	1	0.0	0.0			
									2408	2P017	4.16	1	1	0.0	0.0			
									2409	2P018-A	4.16	1	1	0.0	0.0			
									2411	2P307	4.16	1	1	0.1	0.1			
									2412	E336-U2	4.16	1	1	0.0	0.1			
									2413	2G002	4.36	1	1	0.6	-0.1	0.954UN		
									2416	2T014	4.16	1	1	0.0	0.0			
									2420	2B04X	4.16	1	1	-0.1	0.1			
									M I S M A T C H									
26	2A06	4.16	1	1.048	0.0	0.0	0.0	0.0	2603	2P504	4.16	1	1	-0.1	0.0			
			1	4.36		0.0	0.0	0.0	2604	2P013	4.16	1	1	0.0	0.0			
									2606	2P025-B	4.16	1	1	0.0	0.0			
									2607	2P016	4.16	1	1	0.0	0.0			
									2608	2P019	4.16	1	1	0.0	0.0			
									2609	2P018-B	4.16	1	1	0.0	0.0			
									2611	2P114	4.16	1	1	-0.1	0.0			
									2612	E335-U2	4.16	1	1	0.0	0.0			
									2613	2G003	4.36	1	1	0.5	0.6	0.954UN		
									2620	2B06X	4.16	1	1	-0.1	0.2			
									M I S M A T C H									
214	2B04	0.48	1	1.049	0.0	0.0	0.0	0.0	2420	2B04X	4.16	1	1	0.0	0.0	0.999UN		
			1	0.50		0.0	0.0	0.0	21402	2E61N	0.48	1	1	0.0	0.0			
									21403	2BRA	0.48	1	1	0.0	0.0			
									21405	2P191-A	0.46	1	1	0.0	0.0	1.043UN		
									21407	2BD	0.48	1	1	0.0	0.0			
									21409	2A071	0.46	1	1	0.0	0.0	1.043UN		
									21410	2E399	0.46	1	1	0.0	0.0	1.043UN		
									21411	2E401	0.46	1	1	0.0	0.0	1.043UN		
									21413	2P190	0.46	1	1	0.0	0.0	1.043UN		
									21414	2BE	0.48	1	1	0.0	0.0			
									21415	2BY	0.48	1	1	0.0	0.0			
									21417	E-U2	0.48	1	1	0.0	0.0			
									21418	E418-U2	0.46	1	1	0.0	0.0	1.043UN		
									21419	2A074	0.46	1	1	0.0	0.0	1.043UN		

Case No: E4C-082 CCN N-3 Rev. 1  
 RE: LPW 9-30-94 IRE: RR 10-5-94  
 Sheet No. 360  
 2219

CCN 9

Sheet No. 361  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: Lpm 9-30-94 IRE: RL 10-5-94

BUS DATA				LINE DATA				TRANSFORMER DATA						
FROM BUS	AREA	VOLT	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	RATIO	ANGLE	RATING
	ZONE	PU/KV	ANGLE	KW/KVAR	KW/KVAR									% KVA
216 2B06	1	1.049	0.0	0.0	0.0	2620 2B06X	4.16	1	1	0.0	0.0	0.0	0.9999UN	
	1	0.50	0.0	0.0	0.0	21602 2E62N	0.48	1	1	0.0	0.0	0.0		
						21603 2BRB	0.48	1	1	0.0	0.0	0.0		
						21605 2BRH	0.48	1	1	0.0	0.0	0.0		
						21607 2BJ	0.48	1	1	0.0	0.0	0.0		
						21609 2A072	0.46	1	1	0.0	0.0	0.0	1.043UN	
						21610 2E400	0.46	1	1	0.0	0.0	0.0	1.043UN	
						21611 2E402	0.46	1	1	0.0	0.0	0.0	1.043UN	
						21613 2P192	0.46	1	1	0.0	0.0	0.0	1.043UN	
						21614 2B2	0.48	1	1	0.0	0.0	0.0		
						21615 E419-U2	0.46	1	1	0.0	0.0	0.0	1.043UN	
						21617 2P191-B	0.46	1	1	0.0	0.0	0.0	1.043UN	
						21618 BS-U2	0.48	1	1	0.0	0.0	0.0		
						21619 2A073	0.46	1	1	0.0	0.0	0.0	1.043UN	
2403 2P012	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2404 2P141	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2406 2P025-A	1	1.048	0.0	0.0	0.0	24 2A04	4.15	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2407 2P015	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2408 2P017	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2409 2P018-A	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2411 2P307	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	-0.1	-0.1	0.0		
	1	4.36	0.0	0.0	0.0									
2412 E336-U2	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	-0.1	0.0		
	1	4.36	0.0	0.0	0.0									
2413 2G002	1	1.000	0.0	-0.6	0.0	24 2A04	4.16	1	1	0.0	-0.1	0.0		
	1	4.36	0.0	0.1K	0.0									
2416 2T014	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	-0.6	0.1	0.954LK		
	1	4.36	0.0	0.0	0.0									
2420 2B04X	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.0	0.0	0.0		
	1	4.36	0.0	0.0	0.0									
2603 2P504	1	1.048	0.0	0.0	0.0	24 2A04	4.16	1	1	0.1	-0.1	0.0		
	1	4.36	0.0	0.0	0.0	26 2A06	4.16	1	1	0.1	0.1	0.999LK		



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, SEP 14 1994 15:06  
CASE III.AY - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAY]LP-1\_IIIAY.SAV

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA
21411	2E401	0.46	1 1.095	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0	1.043LK			
21413	2P190	0.46	1 1.095	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0	1.043LK			
21414	2BE	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0				
								22414	2BE-M	0.48	1 1	0.0	0.0				
								23414	2BE-S	0.48	1 1	0.0	0.0				
21415	2BY	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0				
								22415	2BY-M	0.48	1 1	0.0	0.0				
								23415	2BY-S	0.48	1 1	0.0	0.0				
								24434	2P009	0.46	1 1	0.0	0.0	1.043UN			
21417	BQ-U2	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0				
								22417	BQ-U2-M	0.48	1 1	0.0	0.0				
								23417	BQ-U2-S	0.48	1 1	0.0	0.0				
								24417	P162-U2	0.46	1 1	0.0	0.0	1.043UN			
21418	E418-U2	0.46	1 1.095	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0	1.043LK			
21419	2A074	0.46	1 1.095	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	214	2B04	0.48	1 1	0.0	0.0	1.043LK			
21602	2E62N	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	216	2B06	0.48	1 1	0.0	0.0				
21603	2BRB	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	216	2B06	0.48	1 1	0.0	0.0				
								22603	2BRB-M	0.48	1 1	0.0	0.0				
								23603	2BRB-S	0.48	1 1	0.0	0.0				
21605	2BH	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	216	2B06	0.48	1 1	0.0	0.0				
								22605	2BH-M	0.48	1 1	0.0	0.0				
								23605	2BH-S	0.48	1 1	0.0	0.0				
								24606	2E547	0.46	1 1	0.0	0.0	1.043UN			
								24607	2E549	0.46	1 1	0.0	0.0	1.043UN			
								24611	2A276	0.46	1 1	0.0	0.0	1.043UN			
								24612	2A277	0.46	1 1	0.0	0.0	1.043UN			
21607	2BJ	0.48	1 1.049	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	216	2B06	0.48	1 1	0.0	0.0				
								22607	2BJ-M	0.48	1 1	0.0	0.0				
								23607	2BJ-S	0.48	1 1	0.0	0.0				
21609	2A072	0.46	1 1.095	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	216	2B06	0.48	1 1	0.0	0.0	1.043LK			
21610	2E400	0.46	1 1.095	0.0	0.0	0.0	0.0										
			1 0.50		0.0	0.0	0.0	216	2B06	0.48	1 1	0.0	0.0	1.043LK			

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: *lpw* 9-30-94 IRE: *Bl* 10-5-94  
Sheet No: 363

*CCN 9*

CCN 9

Sheet No. 364  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: UPM 9-30-94 IRE: PL 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AY - INITIAL STEADY STAT. CONDITION  
DRB200: {MURIEL.E4C-082-AGP.-----} IIIAY\LF-1\_IIIAY.SAV

WED, SEP 14 1994 15:06

BUS DATA				LINE DATA												
FROM BUS	AREA	VOLT	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	RATIO	ANGLE	RATING		
	ZONE	PU/KV	FW/EVAR	KW/KVAR	FW/KVAR									SI KVA		
21611	2E402	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK		
			1	0.50	0.0	0.0	0.0	0.0	216	2B05	0.48	1	1	0.0	0.0	1.043LK
21613	2P192	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043LK		
			1	0.50	0.0	0.0	0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK
21614	2BZ	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK
21615	E419-U2	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043UN		
			1	0.50	0.0	0.0	0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK
21617	2P191-B	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK
21618	BS-U2	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK
21619	2A073	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.043UN		
			1	0.50	0.0	0.0	0.0	0.0	216	2B06	0.48	1	1	0.0	0.0	1.043LK
22403	2BRA-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21403	2BRA	0.48	1	1	0.0	0.0
22407	2BD-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21407	2BD	0.48	1	1	0.0	0.0
22414	2BE-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21414	2BE	0.48	1	1	0.0	0.0
22415	2BY-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21415	2BY	0.48	1	1	0.0	0.0
22417	BQ-U2-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21417	BQ-U2	0.46	1	1	0.0	0.0
22603	2BRB-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21603	2BRB	0.48	1	1	0.0	0.0
22605	2BR-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21605	2BR	0.48	1	1	0.0	0.0
22607	2BJ-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21607	2BJ	0.48	1	1	0.0	0.0
22614	2BE-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
			1	0.50	0.0	0.0	0.0	0.0	0.0	21614	2BE	0.46	1	1	0.0	0.0

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, SEP 14 1994 15:06  
CASE III.AY - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE.III.AY|LF-I.III.AY.SAV

BUS DATA				SHUNT				LINE DATA							
FROM BUS	AREA	NAME	ANGLE	GER	LOAD	TO BUS	NAME	CXT AREA	RW	KVAR	TRANSFORMER RATIO	RATING A			
	ZONE		PJ/KV	KW/KVAR	KW/KVAR						ANGLE	% KVA			
22618	BS-U2-M	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	21618	BS-U2	0.48	1	1	0.0	0.0	
23403	2BRA-S	0.46	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21403	2BRA	0.48	1	1	0.0	0.0
23407	2BD-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21407	2BD	0.48	1	1	0.0	0.0
23414	2BE-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21414	2BE	0.48	1	1	0.0	0.0
23415	2BY-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21415	2BY	0.48	1	1	0.0	0.0
23417	BQ-U2-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21417	BQ-U2	0.48	1	1	0.0	0.0
23603	2BRB-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21603	2BRB	0.48	1	1	0.0	0.0
23605	2BH-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	1	0.0	0.0
23607	2BJ-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21607	2BJ	0.48	1	1	0.0	0.0
23614	2BZ-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21614	2BZ	0.48	1	1	0.0	0.0
23618	BS-U2-S	0.48	1	1.049	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21618	BS-U2	0.48	1	1	0.0	0.0
24412	2A274	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21407	2BD	0.48	1	1	0.0	0.0
24413	2A275	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21407	2BD	0.48	1	1	0.0	0.0
24417	P162-U2	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21417	BQ-U2	0.48	1	1	0.0	0.0
24421	2E550	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21407	2BD	0.48	1	1	0.0	0.0
24422	2E546	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21407	2BD	0.48	1	1	0.0	0.0
24434	2P009	0.46	1	1.095	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
1				0.50	0.0	0.0	0.0	0.0	21415	2BY	0.48	1	1	0.0	0.0

Sheet No. 365  
Calc No: E4C-082 CCN N-3 Rev. 1  
RE: Lpm 9-30-94 IRE: pl 10-5-94

CCN 9


CCN 9

Sheet No. 366

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: Lpm 9-30-94 IRE: PL 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR---PSS/E WED, SEP 14 1994 15:06  
CASE III.AY - INITIAL STEADY STATE CONDITION  
DIR200:[MURIEL.E4C-082-AGA.CASE III.AY|LF-1 III.AY.SAV

BUS DATA										LINE DATA									
FROM BUS	NAME	AREA	VOLT	ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT TO BUS	NAME	CKT AREA	KW	KVAR	RATIO	ANGLE	TRANSFORMER RATING A			
24606	2E547	1	1.095	1	0.50	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	1	0.0	0.0	1.043LK	
24607	2E549	1	1.095	1	0.50	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	1	0.0	0.0	1.043LK	
24611	2A276	1	1.095	1	0.50	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	1	0.0	0.0	1.043LK	
24612	2A277	1	1.095	1	0.50	0.0	0.0	0.0	0.0	0.0	21605	2BH	0.48	1	1	0.0	0.0	1.043LK	
24618	F160-U2	1	1.095	1	0.50	0.0	0.0	0.0	0.0	0.0	21618	BS-U2	0.48	1	1	0.0	0.0	1.043LK	
24622	2P010	1	1.095	1	0.50	0.0	0.0	0.0	0.0	0.0	21614	2BZ	0.48	1	1	0.0	0.0	1.043LK	



Sheet No. 367  
 Cabin No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-20-94 WRE: Bld 10-5-94





PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAY]LF-2\_IIIAY.SAV

WED, SEP 14 1994 17:20

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER	RATING A	
			PU/KV		KW/KVAR	KW/KVAR	KW/KVAR							RATIO	ANGLE	
24	2A04	4.16	1	1.048	-173.2	0.0	0.0	0.0	2403	2P012	4.16	1	1	306.0	183.7	
			1	4.36		0.0	0.0	0.0	2404	2P141	4.16	1	1	668.0	307.8	
									2406	2P025-A	4.16	1	1	468.4	287.4	
									2407	2P015	4.16	1	1	376.3	201.8	
									2408	2P017	4.16	1	1	395.5	185.0	
									2409	2P018-A	4.16	1	1	395.6	185.1	
									2411	2P307	4.16	1	1	317.8	219.4	
									2412	E336-U2	4.16	1	1	445.5	260.5	
									2413	2G002	4.36	1	1	-4897.4	-2880.6	0.954UN
									2416	2T014	4.16	1	1	127.8	78.1	
									2420	2B04X	4.16	1	1	1399.1	972.4	
									M I S M A T C H			-2.7	-0.6			
26	2A06	4.16	1	1.048	-106.4	0.0	0.0	0.0	2603	2P504	4.16	1	1	670.9	307.5	
			1	4.36		0.0	0.0	0.0	2604	2P013	4.16	1	1	308.3	183.6	
									2606	2P025-B	4.16	1	1	472.9	287.4	
									2607	2P016	4.16	1	1	379.4	201.9	
									2608	2P019	4.16	1	1	397.5	184.7	
									2609	2P018-B	4.16	1	1	397.6	184.7	
									2511	2P114	4.16	1	1	320.8	219.4	
									2612	E335-U2	4.16	1	1	449.7	261.0	
									2613	2G003	4.36	1	1	-4733.5	-2744.0	0.954UN
									2620	2B06X	4.16	1	1	1335.4	913.7	
									M I S M A T C H			1.0	0.2			
214	2B04	0.48	1	0.977	-177.9	0.0	0.0	0.0	2420	2B04X	4.16	1	1	-1372.3	-792.4	0.999UN
			1	0.47		0.0	0.0	0.0	21402	2E61N	0.48	1	1	201.8	2.5	
									21403	2BRA	0.48	1	1	22.2	13.9	
									21405	2P191-A	0.46	1	1	55.7	39.6	1.043UN
									21407	2BD	0.48	1	1	184.2	130.8	
									21409	2A071	0.46	1	1	56.9	35.3	1.043UN
									21410	2E399	0.46	1	1	60.9	46.6	1.043UN
									21411	2E401	0.46	1	1	61.0	46.6	1.043UN
									21413	2P190	0.46	1	1	55.7	39.6	1.043UN
									21414	2BE	0.48	1	1	142.3	97.5	
									21415	2BY	0.48	1	1	215.0	140.1	
									21417	BQ-U2	0.48	1	1	140.7	88.9	
									21418	E418-U2	0.46	1	1	120.1	78.1	1.043UN
									21419	2A074	0.46	1	1	57.2	35.3	1.043UN
									M I S M A T C H			-1.4	-2.5			

Case No: E4C-082 CCN N-3 Rev: 1  
Date: 9-30-94  
Sheet No: 368  
Date: 10-5-94

can 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
 CASE III.AY - POST ACCIDENT (STEADY STATE) CONDITION  
 DKB200:[NURIEL.E4C-082-AGA.CASE\_IIIAY]LP-2\_IIIAY.SAV

WED, SEP 14 1994 17:20

BUS DATA									LINE DATA													
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA				
216	2B06	0.48	1	0.981	-110.9	0.0	0.0	0.0	2620	2B06X	4.16	1	1	-1312.5	-753.5	0.999UN						
			1	0.47		0.0	0.0	0.0	21602	2E62N	0.48	1	1	202.5	2.6							
									21603	2BRB	0.48	1	1	22.3	13.9							
									21605	2BH	0.48	1	1	182.9	129.7							
									21607	2BJ	0.48	1	1	132.6	91.2							
									21609	2A072	0.46	1	1	56.7	35.2	1.043UN						
									21610	2E400	0.46	1	1	60.9	46.5	1.043UN						
									21611	2E402	0.46	1	1	61.4	46.5	1.043UN						
									21613	2P192	0.46	1	1	56.4	39.8	1.043UN						
									21614	2BZ	0.48	1	1	198.3	127.5							
									21615	E419-U2	0.46	1	1	117.2	78.9	1.043UN						
									21617	2P191-B	0.46	1	1	56.4	39.8	1.043UN						
									21618	BS-U2	0.48	1	1	107.9	66.8							
									21619	2A073	0.46	1	1	57.1	35.2	1.043UN						
2403	2P012	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-305.9	-183.7							
			1	4.36		0.0	0.0	0.0	M I S M A T C H										305.9	183.7		
2404	2P141	4.16	1	1.046	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-667.2	-307.2							
			1	4.35		0.0	0.0	0.0	M I S M A T C H										667.2	307.2		
2406	2P025-A	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-468.2	-287.2							
			1	4.36		0.0	0.0	0.0	M I S M A T C H										468.2	287.2		
2407	2P015	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-376.1	-231.6							
			1	4.36		0.0	0.0	0.0	M I S M A T C H										376.1	231.6		
2408	2P017	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-395.4	-184.8							
			1	4.36		0.0	0.0	0.0	M I S M A T C H										395.4	184.8		
2409	2P018-A	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-395.5	-184.9							
			1	4.36		0.0	0.0	0.0	M I S M A T C H										395.5	184.9		
2411	2P307	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-317.6	-219.2							
			1	4.36		0.0	0.0	0.0	M I S M A T C H										317.6	219.2		
2412	E336-U2	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-445.2	-260.2							
			1	4.35		0.0	0.0	0.0	M I S M A T C H										445.2	260.2		
2413	2G002	4.36	1	1.006	-173.1	4936.1	0.0	0.0	24	2A04	4.16	1	1	4923.0	2911.7	0.954LK						
			1	4.39		2909.8R	0.0	0.0	M I S M A T C H										13.0	-2.0		
2416	2T014	4.16	1	1.047	-173.2	0.0	128.0	0.0	24	2A04	4.16	1	1	-127.7	-78.1							
			1	4.36		0.0	78.0	0.0	M I S M A T C H													
2420	2B04X	4.16	1	1.047	-173.2	0.0	0.0	0.0	24	2A04	4.16	1	1	-1398.7	-972.1							
			1	4.36		0.0	0.0	0.0	214	2B04	0.48	1	1	1397.6	969.2	0.999LK						
									M I S M A T C H										1.1	2.9		
2603	2P504	4.16	1	1.046	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-670.1	-307.0							
			1	4.35		0.0	0.0	0.0														

Case No: E4C-082 CCN N-3 Rev. 1  
 Date: 9-30-94  
 Sheet No: 369  
 RE: [Signature] IRE: [Signature]

ANN 9

CCN 9

Sheet No.	370
Calc No:	E4C-082 CCN N-3 Rev. 1
RE:	Lpm 9-30-94 RE: <i>bl</i> 10-5-94

670.1 307.0

M I S M A T C H

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAY]LF-2\_IIIAY.SAV

WED, SEP 14 1994 17:20

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CRT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI KVA
2604	2P013	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-308.2	-183.5	
			1	4.36		0.0	0.0	0.0		M I S M A T C H				308.2	183.5	
2606	2P025-B	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-472.6	-287.2	
			1	4.36		0.0	0.0	0.0		M I S M A T C H				472.6	287.2	
2607	2P016	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-379.3	-201.7	
			1	4.36		0.0	0.0	0.0		M I S M A T C H				379.3	201.7	
2608	2P019	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-397.4	-184.6	
			1	4.36		0.0	0.0	0.0		M I S M A T C H				397.4	184.6	
2609	2P018-B	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-397.5	-184.6	
			1	4.36		0.0	0.0	0.0		M I S M A T C H				397.5	184.6	
2611	2P114	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-320.7	-219.2	
			1	4.36		0.0	0.0	0.0		M I S M A T C H				320.7	219.2	
2612	E335-U2	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-449.4	-260.8	
			1	4.35		0.0	0.0	0.0		M I S M A T C H				449.4	260.8	
2613	2G003	4.36	1	1.004	-106.3	4750.7	0.0	0.0	26	2A06	4.16	1	1	4750.8	2764.9	0.954LK
			1	4.38		2764.9R	0.0	0.0								
2620	2B06X	4.16	1	1.047	-106.4	0.0	0.0	0.0	26	2A06	4.16	1	1	-1335.0	-913.4	
			1	4.36		0.0	0.0	0.0	216	2B06	0.48	1	1	1335.4	913.6	0.999LK
21402	2E61N	0.48	1	0.967	-178.6	0.0	200.0	0.0	214	2B04	0.48	1	1	-199.7	-0.3	
			1	0.46		0.0	0.0	0.0								
21403	2BRA	0.48	1	0.977	-177.9	0.0	0.0	0.0	214	2B04	0.48	1	1	-22.2	-13.9	
			1	0.47		0.0	0.0	0.0	22403	2BRA-M	0.48	1	1	13.8	8.6	
									23403	2BRA-S	0.48	1	1	8.5	5.3	
21405	2P191-A	0.46	1	1.010	-177.9	0.0	0.0	0.0	214	2B04	0.48	1	1	-55.2	-39.3	1.043LK
			1	0.46		0.0	0.0	0.0		M I S M A T C H				55.2	39.3	
21407	2BD	0.48	1	0.919	-178.6	0.0	0.0	0.0	214	2B04	0.48	1	1	-174.9	-120.9	
			1	0.44		0.0	0.0	0.0	22407	2BD-M	0.48	1	1	17.5	10.8	
									23407	2BD-S	0.48	1	1	8.5	5.3	
									24412	2A274	0.46	1	1	42.3	29.9	1.043UN
									24413	2A275	0.46	1	1	42.5	29.9	1.043UN
									24421	2E550	0.46	1	1	32.1	22.6	1.043UN
									24422	2E546	0.46	1	1	32.1	22.6	1.043UN
21409	2A071	0.46	1	1.000	-177.7	0.0	0.0	0.0	214	2B04	0.48	1	1	-55.7	-34.9	1.043LK
			1	0.46		0.0	0.0	0.0		M I S M A T C H				55.7	34.9	
21410	2E399	0.46	1	1.008	-177.8	0.0	0.0	0.0	214	2B04	0.48	1	1	-60.1	-46.2	1.043LK
			1	0.46		0.0	0.0	0.0		M I S M A T C H				60.1	46.2	

Calc No: E4C-082 CCN N-3 Rev: 1  
 RE: Lpm 9-20-94 IRE: Dd 10-5-94  
 Sheet No. 371

CCN 9

BUS DATA					LINE DATA											
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI KVA
21411	ZE401	0.46	1	1.006	-177.8	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	214	2B04	0.48	1	1	-60.1	-46.1	1.043LK
														60.1	46.1	
21413	2P190	0.46	1	1.011	-177.9	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	214	2B04	0.48	1	1	-55.2	-39.4	1.043LK
														55.2	39.4	
21414	2BE	0.48	1	0.974	-178.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	214	2B04	0.48	1	1	-142.0	-97.1	
									22414	2BE-M	0.48	1	1	52.9	33.0	
									23414	2BE-S	0.48	1	1	89.4	64.1	
21415	2BY	0.48	1	0.974	-178.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	214	2B04	0.48	1	1	-214.6	-139.3	
									22415	2BY-M	0.48	1	1	79.8	49.8	
									23415	2BY-S	0.48	1	1	112.5	78.1	
									24434	2P009	0.46	1	1	22.9	11.5	1.043UN
														-0.7	-0.1	
21417	BQ-U2	0.48	1	0.975	-178.0	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	214	2B04	0.48	1	1	-140.4	-88.6	
									22417	BQ-U2-M	0.48	1	1	40.2	25.1	
									23417	BQ-U2-S	0.48	1	1	75.9	45.8	
									24417	P162-U2	0.46	1	1	24.6	17.6	1.043UN
21418	E418-U2	0.46	1	0.990	-177.8	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	214	2B04	0.48	1	1	-116.4	-76.0	1.043LK
														116.4	76.0	
21419	2A074	0.46	1	0.995	-177.7	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	214	2B04	0.48	1	1	-55.7	-34.7	1.043LK
														55.7	34.7	
21602	2E62N	0.48	1	0.969	-111.6	0.0	200.0	0.0								
			1	0.47		0.0	0.0	0.0	216	2B06	0.48	1	1	-200.0	0.0	
21603	2BRB	0.48	1	0.981	-110.9	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	216	2B06	0.48	1	1	-22.3	-13.9	
									22603	2BRB-M	0.48	1	1	13.8	8.6	
									23603	2BRB-S	0.48	1	1	8.5	5.3	
21605	2BH	0.48	1	0.936	-111.5	0.0	0.0	0.0								
			1	0.45		0.0	0.0	0.0	216	2B06	0.48	1	1	-175.6	-122.0	
									22605	2BH-M	0.48	1	1	17.7	10.9	
									23605	2BH-S	0.48	1	1	8.5	5.3	
									24606	2E547	0.46	1	1	32.2	22.9	1.043UN
									24607	2E549	0.46	1	1	32.3	22.9	1.043UN
									24611	2A276	0.46	1	1	42.4	30.0	1.043UN
									24612	2A277	0.46	1	1	42.5	30.0	1.043UN
21607	2BJ	0.48	1	0.978	-110.9	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	216	2B06	0.48	1	1	-132.4	-90.9	
									22607	2BJ-M	0.48	1	1	53.1	33.1	
									23607	2BJ-S	0.48	1	1	79.2	57.8	
21609	2A072	0.46	1	1.002	-110.7	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	216	2B06	0.48	1	1	-55.3	-34.7	1.043LK
														55.3	34.7	
21610	2E400	0.46	1	1.007	-110.8	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	216	2B06	0.48	1	1	-59.9	-46.0	1.043LK

Calc No: E4C-082 CCN N-3 Rev: 1  
 RE: LPM 9-30-94 IRE: AL 10-5-94  
 Sheet No: 372  
 CCN 9

CCN 9

Case No:	E4C-082	CCN N-3	Rev:	1
RE:	Uru 9-30-94	IRE:	BJ 12-5-94	

59.9 46.0

N I S M A T C H

BUS DATA							LINE DATA														
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	RATING KVA				
21611	2E402	0.46	1	1.061	-110.7	0.0	0.0	0.0													
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-59.9	-45.6	1.043LK						
									M I S M A T C H									59.9	45.6		
21613	2P192	0.46	1	1.010	-110.8	0.0	0.0	0.0													
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-55.6	-39.4	1.043LK						
									M I S M A T C H									55.6	39.4		
21614	2BZ	0.48	1	0.979	-111.0	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	216 2B06	0.48	1	1	-198.0	-127.0							
									22614 2BZ-M	0.48	1	1	50.5	31.5							
									23614 2BZ-S	0.48	1	1	124.4	83.9							
									24622 2P010	0.46	1	1	23.1	11.6	1.043UN						
21615	E419-U2	0.46	1	1.017	-110.9	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	216 2B06	0.48	1	1	-116.5	-78.4	1.043LK						
									M I S M A T C H									116.5	78.4		
21617	2P191-B	0.46	1	1.010	-110.8	0.0	0.0	0.0													
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-55.6	-39.3	1.043LK						
									M I S M A T C H									55.6	39.3		
21618	BS-U2	0.48	1	0.977	-111.0	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	216 2B06	0.48	1	1	-107.6	-66.4							
									22618 BS-U2-M	0.48	1	1	40.4	25.2							
									23618 BS-U2-S	0.48	1	1	42.6	23.4							
									24618 P160-U2	0.46	1	1	24.6	17.8	1.043UN						
21619	2A073	0.46	1	0.995	-110.6	0.0	0.0	0.0													
			1	0.46		0.0	0.0	0.0	216 2B06	0.48	1	1	-55.3	-34.5	1.043LK						
									M I S M A T C H									55.3	34.5		
22403	2BRA-M	0.48	1	0.977	-177.9	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21493 2BRA	0.48	1	1	-13.8	-8.6							
									M I S M A T C H									13.8	8.6		
22407	2BD-M	0.48	1	0.919	-178.6	0.0	0.0	0.0													
			1	0.44		0.0	0.0	0.0	21407 2BD	0.48	1	1	-17.6	-10.8							
									M I S M A T C H									17.6	10.8		
22414	2BE-M	0.48	1	0.974	-178.0	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21414 2BE	0.48	1	1	-52.9	-33.0							
									M I S M A T C H									52.9	33.0		
22415	2BY-M	0.48	1	0.974	-178.0	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21415 2BY	0.48	1	1	-79.8	-49.8							
									M I S M A T C H									79.8	49.8		
22417	BQ-U2-M	0.48	1	0.975	-178.0	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21417 BQ-U2	0.48	1	1	-40.2	-25.1							
									M I S M A T C H									40.2	25.1		
22603	2BRB-M	0.48	1	0.981	-110.9	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21603 2BRB	0.48	1	1	-13.8	-8.6							
									M I S M A T C H									13.8	8.6		
22605	2BH-M	0.48	1	0.936	-111.5	0.0	0.0	0.0													
			1	0.45		0.0	0.0	0.0	21605 2BH	0.48	1	1	-17.7	-10.9							
									M I S M A T C H									17.7	10.9		
22607	2BJ-M	0.48	1	0.978	-110.9	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21607 2BJ	0.48	1	1	-53.1	-33.1							
									M I S M A T C H									53.1	33.1		
22614	2BZ-M	0.48	1	0.979	-111.0	0.0	0.0	0.0													
			1	0.47		0.0	0.0	0.0	21614 2BZ	0.48	1	1	-50.5	-31.5							

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: Pm 9-30-94 IRE: PL 10-5-94  
Sheet No: 374  
CCN 9

CCN 9

Sheet No. <u>375</u>	
Calc No: <u>E4C-082 CCN N-3</u>	Rev: <u>1</u>
RE: <u>Lpm 9-30-94</u>	IRE: <u>RJ 10-5-99</u>

50.5 31.5

M I S M A T C H



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAY]LF-2\_IIIAY.SAV

WED, SEP 14 1994 17:20

BUS DATA					LINE DATA												
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
22618	BS-U2-M	0.48	1	0.977	-111.0	0.0	0.0	0.0									
			1	0.47		0.0	0.0	0.0	21618	BS-U2	0.48	1	1	-40.4	-25.2		
										M I S M A T C H				40.4	25.2		
23403	2BRA-S	0.48	1	0.977	-177.9	0.0	8.5	0.0									
			1	0.47		0.0	5.3	0.0	21403	2BRA	0.48	1	1	-8.5	-5.3		
23407	2BD-S	0.48	1	0.919	-178.6	0.0	8.5	0.0									
			1	0.44		0.0	5.3	0.0	21407	2BD	0.48	1	1	-8.5	-5.3		
23414	2BE-S	0.48	1	0.974	-178.0	0.0	89.4	0.0									
			1	0.47		0.0	64.1	0.0	21414	2BE	0.48	1	1	-89.4	-64.1		
23415	2BY-S	0.48	1	0.974	-178.0	0.0	112.5	0.0									
			1	0.47		0.0	78.1	0.0	21415	2BY	0.48	1	1	-112.5	-78.1		
23417	BQ-U2-S	0.48	1	0.975	-178.0	0.0	75.9	0.0									
			1	0.47		0.0	45.8	0.0	21417	BQ-U2	0.48	1	1	-75.9	-45.8		
23603	2BRB-S	0.48	1	0.981	-110.9	0.0	8.5	0.0									
			1	0.47		0.0	5.3	0.0	21603	2BRB	0.48	1	1	-8.5	-5.3		
23605	2BH-S	0.48	1	0.936	-111.5	0.0	8.5	0.0									
			1	0.45		0.0	5.3	0.0	21605	2BH	0.48	1	1	-8.5	-5.3		
23607	2BJ-S	0.48	1	0.978	-110.9	0.0	79.2	0.0									
			1	0.47		0.0	57.8	0.0	21607	2BJ	0.48	1	1	-79.2	-57.8		
23614	2BZ-S	0.48	1	0.979	-111.0	0.0	124.4	0.0									
			1	0.47		0.0	83.9	0.0	21614	2BZ	0.48	1	1	-124.4	-83.9		
23618	BS-U2-S	0.48	1	0.977	-111.0	0.0	42.6	0.0									
			1	0.47		0.0	23.4	0.0	21618	BS-U2	0.48	1	1	-42.6	-23.4		
24412	2A274	0.46	1	0.957	-178.6	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-42.2	-29.8	1.043LK	
										M I S M A T C H				42.2	29.8		
24413	2A275	0.46	1	0.954	-178.5	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-42.2	-29.8	1.043LK	
										M I S M A T C H				42.2	29.8		
24417	P162-U2	0.46	1	1.005	-177.7	0.0	0.0	0.0									
			1	0.46		0.0	0.0	0.0	21417	BQ-U2	0.48	1	1	-24.2	-17.6	1.043LK	
										M I S M A T C H				24.2	17.6		
24421	2E550	0.46	1	0.954	-178.5	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-31.9	-22.5	1.043LK	
										M I S M A T C H				31.9	22.5		
24422	2E546	0.46	1	0.954	-178.5	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	21407	2BD	0.48	1	1	-31.9	-22.5	1.043LK	
										M I S M A T C H				31.9	22.5		
24434	2P009	0.46	1	1.004	-177.8	0.0	0.0	0.0									
			1	0.46		0.0	0.0	0.0	21415	2BY	0.48	1	1	-22.6	-11.5	1.043LK	
										M I S M A T C H				22.6	11.5		

Call No: E4C-082  
CN N-3 Rev: 1  
RE: LPM 9-30-94  
IRE: A.P. 10-5-94  
Sheet No: 376

2449

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE III.AY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IIIAY]LP-2\_IIIAY.SAV

WED, SEP 14 1994 17:20

BUS DATA										LINE DATA						
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I KVA	
24606	2E547	0.46	1	0.971	-111.3	0.0	0.0	0.0								
			1	0.45		0.0	0.0	0.0	21605	2BH	0.48	1	1	-32.0	-22.9	1.043LK
														32.0	22.9	
24607	2E549	0.46	1	0.971	-111.3	0.0	0.0	0.0								
			1	0.45		0.0	0.0	0.0	21605	2BH	0.48	1	1	-32.0	-22.9	1.043LK
														32.0	22.9	
24611	2A276	0.46	1	0.974	-111.4	0.0	0.0	0.0								
			1	0.45		0.0	0.0	0.0	21605	2BH	0.48	1	1	-42.2	-30.0	1.043LK
														42.2	30.0	
24612	2A277	0.46	1	0.971	-111.3	0.0	0.0	0.0								
			1	0.45		0.0	0.0	0.0	21605	2BH	0.48	1	1	-42.2	-30.0	1.043LK
														42.2	30.0	
24618	P160-U2	0.46	1	1.013	-110.8	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	21618	BS-U2	0.48	1	1	-24.4	-17.7	1.043LK
														24.4	17.7	
24622	2P010	0.46	1	1.009	-110.8	0.0	0.0	0.0								
			1	0.46		0.0	0.0	0.0	21614	2BZ	0.48	1	1	-22.8	-11.6	1.043LK
														22.8	11.6	

Calc No: E4C-082 CCN N-2 Rev: 1  
RE: Lpin 9-30-94 IRE: RL 10-5-94  
Sheet No. 377

CCN9

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>378</b> OF <b>453</b>
CCN CONVERSION CCN NO. CCN - <b>9</b>	

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1


Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**APPENDIX 9.1.5**

**CASE IVBX**

Initial Condition Power Flow (Steady State) Report  
Post Accident Condition Power Flow (Steady State) Report



Sheet No. 379


Calc No: E4C-082 CCN N-3 Rev. 1

RE: Lpm 7-30-94 [RT: DL 10-5-79]




PSS/E RELEASE 19.0






CASE IV.BX - INITIAL STEADY STATE CONDITION  
 OKB200:CMURIEL.E4C-082-AGA.CASE\_IVBX]LF-1\_IVBX.SAV  
 THU, SEP 15 1994 11:11






Sheet No. 380  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Cpm 9-30-94 IRE: Bdl 10-5-94





Sheet No. 381  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Upm C-30-94 IRE: Al 10-5-94



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BX - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]LF-1\_IVBX.SAV

THU, SEP 15 1994 11:12

BUS DATA								LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA
1	SYSTEM	230	1	0.948	0.0	22693.3	0.0	0.0										
			1	218.0		13410.3R	0.0	0.0	41	2XMS	22.0	1	1	22693.313410.3	0.973UN			
24	2A04	4.16	1	0.981	-3.2	0.0	0.0	0.0										
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	2.1	-0.5			
									44	2XU1Y	4.16	1	1	-3576.1	-2086.7			
									2403	2P012	4.16	1	1	353.0	180.1			
									2404	2P141	4.16	1	1	675.5	308.1			
									2406	2P025-A	4.16	1	1	477.3	270.2			
									2407	2P015	4.16	1	1	389.2	199.1			
									2408	2P017	4.16	1	1	405.2	173.1			
									2411	2P017	4.16	1	1	331.2	214.1			
									2420	2B04X	4.16	1	1	942.7	742.6			
26	2A06	4.16	1	0.984	-2.9	0.0	0.0	0.0										
			1	4.09		0.0	0.0	0.0	36	3A06	4.16	1	1	-1.0	-0.5			
									46	2XU1X	4.16	1	1	-3537.2	-2061.6			
									2603	2P504	4.16	1	1	675.4	308.0			
									2604	2P013	4.16	1	1	353.0	180.1			
									2606	2P025-B	4.16	1	1	477.3	270.2			
									2607	2P016	4.16	1	1	389.2	199.1			
									2608	2P019	4.16	1	1	405.1	173.2			
									2611	2P114	4.16	1	1	331.3	214.2			
									2620	2B06X	4.16	1	1	905.8	717.1			
									M I S M A T C H					1.2	0.2			
34	3A04	4.16	1	0.981	-3.2	0.0	0.0	0.0										
			1	4.08		0.0	0.0	0.0	24	2P04	4.16	1	1	-2.1	0.5			
									3402	3P36-U3	4.16	1	1	-0.1	0.0			
									3403	3P012	4.16	1	1	0.1	0.0			
									3404	3P141	4.16	1	1	0.0	0.0			
									3405	3P024	4.16	1	1	0.0	0.0			
									3407	3P015	4.16	1	1	0.0	0.0			
									3408	3P017	4.16	1	1	0.0	0.0			
									3409	3P018-A	4.16	1	1	0.1	0.0			
									3411	3P307	4.16	1	1	0.1	0.0			
									3412	3T014	4.16	1	1	0.0	0.0			
									3417	3B04X	4.16	1	1	0.6	-0.1			
									M I S M A T C H					1.3	-0.5			
36	3A06	4.16	1	0.984	-2.9	0.0	0.0	0.0										
			1	4.09		0.0	0.0	0.0	26	2A06	4.16	1	1	1.0	0.5			
									3602	3P35-U3	4.16	1	1	0.0	0.0			
									3604	3P013	4.16	1	1	0.0	0.0			
									3606	3P025-B	4.16	1	1	0.0	-0.1			
									3607	3P016	4.16	1	1	0.0	0.0			
									3608	3P019	4.16	1	1	0.0	0.0			
									3609	3P018-B	4.16	1	1	-0.1	0.0			
									3611	3P114	4.16	1	1	0.0	0.0			
									3612	3P504	4.16	1	1	0.0	0.0			
									3619	3B06X	4.16	1	1	0.4	0.0			
									M I S M A T C H					-1.2	-0.2			

Case No: E4C-082 CCN N-3 Rev. 1  
RE: [Signature] 9-30-94  
RE: [Signature] 10-5-94  
Sheet No. 382  
CAN 9

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING	A KVA
41	2XMS	22.0	1	0.921	-0.1	0.0	0.0	0.0									
			1	20.25		0.0	0.0	0.0	1	SYSTEM	230	1	1	*****		0.973LK	
			1			0.0	0.0	0.0	45	2XUL*	4.36	1	1	22692.413333.4	0.950LK		
			1			0.0	8384.0	0.0	M I S M A T C H								
			1	0.983	-3.2	0.0	4067.0	0.0	24	2A04	4.16	1	1	3581.6	2095.1		
			1	4.09		0.0	0.0	0.0	45	2XUL*	4.36	1	1	*****	-6161.8	1.048LK	
45	2XUL*	4.36	1	0.968	-0.2	0.0	0.0	0.0	41	2XMS	22.0	1	1	*****		0.950UN	
			1	4.22		0.0	0.0	0.0	44	2XULY	4.16	1	1	12007.9	6984.4	1.048UN	
			1			0.0	7106.0	0.0	46	2XULX	4.16	1	1	10682.5	6297.5	1.048UN	
			1	0.986	-2.8	0.0	3572.0	0.0	M I S M A T C H								
			1	4.10		0.0	0.0	0.0	26	2A06	4.16	1	1	3542.7	2070.1		
			1			0.0	0.0	0.0	45	2XUL*	4.36	1	1	*****	-5642.0	1.048LK	
214	2B04	0.48	1	0.924	-6.8	0.0	0.0	0.0	2420	2J04X	4.16	1	1	-928.3	-641.9	0.999UN	
			1	0.44		0.0	0.0	0.0	21403	2BFA	0.48	1	1	23.0	15.2		
			1			0.0	0.0	0.0	21405	2P191-A	0.46	1	1	57.6	35.3	1.043UN	
			1			0.0	0.0	0.0	21407	2ED	0.48	1	1	195.6	136.2		
			1			0.0	0.0	0.0	21409	2A071	0.46	1	1	56.4	37.5	1.043UN	
			1			0.0	0.0	0.0	21410	2E399	0.46	1	1	61.8	41.4	1.043UN	
			1			0.0	0.0	0.0	21411	2E401	0.46	1	1	62.0	41.5	1.043UN	
			1			0.0	0.0	0.0	21413	2P190	0.46	1	1	57.6	35.3	1.043UN	
			1			0.0	0.0	0.0	21414	2EE	0.48	1	1	134.8	115.2		
			1			0.0	0.0	0.0	21415	2BY	0.48	1	1	222.7	146.4		
			1			0.0	0.0	0.0	21419	2A074	0.46	1	1	56.8	37.7	1.043UN	
216	2B06	0.48	1	0.929	-6.3	0.0	0.0	0.0	2620	2A06X	4.16	1	1	-892.4	-624.2	0.999UN	
			1	0.45		0.0	0.0	0.0	2160	2L1B	0.48	1	1	23.0	15.2		
			1			0.0	0.0	0.0	21605	2BH	0.48	1	1	192.7	133.2		
			1			0.0	0.0	0.0	21607	23J	0.48	1	1	124.6	108.8		
			1			0.0	0.0	0.0	21609	2A072	0.46	1	1	56.6	37.6	1.043UN	
			1			0.0	0.0	0.0	21610	2E400	0.46	1	1	62.1	41.6	1.043UN	
			1			0.0	0.0	0.0	21611	2E402	0.46	1	1	62.6	41.9	1.043UN	
			1			0.0	0.0	0.0	21613	2P192	0.46	1	1	57.8	35.5	1.043UN	
			1			0.0	0.0	0.0	21614	2BZ	0.48	1	1	198.2	137.2		
			1			0.0	0.0	0.0	21617	2P191-B	0.46	1	1	57.9	35.5	1.043UN	
			1			0.0	0.0	0.0	21619	2A073	0.46	1	1	57.0	37.8	1.043UN	

Calc No: E4C-082  
 Case No: CCN N-3  
 Rev: 1  
 RE: *Lpm 9-31-94*  
 IRE: *RD 10-5-94*  
 Sheet No: 383  
 CCN 9



BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CRT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KVA
314	3B04	0.48	1	0.982	-3.2	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	3417	3B04X	4.16	1	1	0.0	0.1	0.9999UN
									31402	3E61N	0.48	1	1	0.0	0.0	
									31403	3BRA	0.48	1	1	0.0	0.0	
									31405	3P191-A	0.46	1	1	0.0	0.0	1.043UN
									31407	39D	0.48	1	1	0.0	0.0	
									31409	3A071	0.46	1	1	0.0	0.0	1.043UN
									31410	3E399	0.46	1	1	0.0	0.0	1.043UN
									31411	3E401	0.46	1	1	0.0	0.0	1.043UN
									31413	3P190	0.46	1	1	0.0	0.0	1.043UN
									31414	3BE	0.48	1	1	0.0	0.0	
									31415	3BY	0.48	1	1	0.0	0.0	
									31417	BQ-U3	0.48	1	1	0.0	0.0	
									31418	E418-U3	0.46	1	1	0.0	0.0	1.043UN
									31419	2A074	0.46	1	1	0.0	0.0	1.043UN
316	3B06	0.48	1	0.985	-2.9	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	3619	3B06X	4.16	1	1	0.0	0.0	0.9999UN
									31602	3E62N	0.48	1	1	0.0	0.0	
									31603	3BRB	0.48	1	1	0.0	0.0	
									31605	3BH	0.48	1	1	0.0	0.0	
									31607	3BJ	0.48	1	1	0.0	0.0	
									31609	3A072	0.46	1	1	0.0	0.0	1.043UN
									31610	3E400	0.46	1	1	0.0	0.0	1.043UN
									31611	3E402	0.46	1	1	0.0	0.0	1.043UN
									31613	3P192	0.46	1	1	0.0	0.0	1.043UN
									31614	3BZ	0.48	1	1	0.0	0.0	
									31615	E419-U3	0.46	1	1	0.0	0.0	1.043UN
									31617	3P191-B	0.46	1	1	0.0	0.0	1.043UN
									31618	BZ-U3	0.48	1	1	0.0	0.0	
									31619	3A073	0.46	1	1	0.0	0.0	1.043UN
2403	2P012	4.16	1	0.980	-3.2	0.0	352.9	0.0								
			1	4.08		0.0	180.0	0.0	24	2A04	4.16	1	1	-352.8	-180.0	
2404	2P141	4.16	1	0.979	-3.3	0.0	674.5	0.0								
			1	4.07		0.0	307.3	0.0	24	2A04	4.16	1	1	-674.5	-307.3	
2406	2P025-A	4.16	1	0.980	-3.2	0.0	477.0	0.0								
			1	4.08		0.0	270.0	0.0	24	2A04	4.16	1	1	-477.0	-270.0	
2407	2P015	4.16	1	0.980	-3.2	0.0	389.0	0.0								
			1	4.08		0.0	199.0	0.0	24	2A04	4.16	1	1	-389.0	-199.0	
2408	2P017	4.16	1	0.980	-3.2	0.0	405.0	0.0								
			1	4.08		0.0	173.0	0.0	24	2A04	4.16	1	1	-405.0	-173.0	
2411	2P307	4.16	1	0.980	-3.2	0.0	331.0	0.0								
			1	4.08		0.0	214.0	0.0	24	2A04	4.16	1	1	-331.0	-214.0	
2420	2B04X	4.16	1	0.981	-3.2	0.0	0.0	0.0								
			1	4.08		0.0	0.0	0.0	24	2A04	4.16	1	1	-942.5	-742.4	
									214	2B04	0.48	1	1	942.6	742.2	0.9999LK

Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 RE: RR 10-5-94  
 SINGAR No. 384  
 2CN19

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	A KVA
2603	2P504	4.16	1	0.982	-2.9	0.0	674.5	0.0	26	2A06	4.16	1	1	-674.5	-307.3			
			1	4.09		0.0	307.3	0.0										
2604	2P013	4.16	1	0.983	-2.9	0.0	352.9	0.0	26	2A06	4.16	1	1	-352.9	-180.0			
			1	4.09		0.0	180.0	0.0										
2606	2P025-B	4.16	1	0.983	-2.9	0.0	477.0	0.0	26	2A06	4.16	1	1	-477.0	-270.0			
			1	4.09		0.0	270.0	0.0										
2607	2P016	4.16	1	0.983	-2.9	0.0	389.0	0.0	26	2A06	4.16	1	1	-389.0	-199.0			
			1	4.09		0.0	199.0	0.0										
2608	2P019	4.16	1	0.983	-2.9	0.0	405.0	0.0	26	2A06	4.16	1	1	-404.9	-173.1			
			1	4.09		0.0	173.0	0.0										
2611	2P114	4.16	1	0.983	-2.9	0.0	331.0	0.0	26	2A06	4.16	1	1	-331.1	-214.0			
			1	4.09		0.0	214.0	0.0										
2620	2B06X	4.16	1	0.984	-2.9	0.0	0.0	0.0	26	2A06	4.16	1	1	-905.6	-717.0			
			1	4.09		0.0	0.0	0.0	216	2B06	0.48	1	1	905.6	716.6	0.999LK		
3402	E336-U3	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	0.1	0.0			
			1	4.08		0.0	0.0	0.0										
3403	3P012	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	-0.1	0.0			
			1	4.08		0.0	0.0	0.0										
3404	3P141	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0			
			1	4.08		0.0	0.0	0.0										
3405	3P024	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0			
			1	4.08		0.0	0.0	0.0										
3407	3P015	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0			
			1	4.08		0.0	0.0	0.0										
3408	3P017	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0			
			1	4.08		0.0	0.0	0.0										
3409	3P018-A	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	-0.1	0.0			
			1	4.08		0.0	0.0	0.0										
3411	3P307	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	-0.1	0.0			
			1	4.08		0.0	0.0	0.0										
3412	3T014	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0			
			1	4.08		0.0	0.0	0.0										
3417	3B04X	4.16	1	0.981	-3.2	0.0	0.0	0.0	34	3A04	4.16	1	1	-0.6	0.1			
			1	4.08		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	-0.1	0.999LK		

Case No: E4C-082 CCN N-3 Rev. 1  
RE: Lpm 9-14-94 Y.IRE: RD 10-5-94  
Sheet No. 385

LN 9

CCN 9

Sheet No. <u>386</u>	
Case No: <u>E4C-082 CCN N-3</u>	Rev: <u>1</u>
RE: <u>Lpm 9-30-94</u>	IRE: <u>AL 10-5-94</u>

H I S M A T C H      0.6      0.0

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I KVA
3602	E335-U3	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.0	
			1	4.09		0.0	0.0	0.0								
3604	3P013	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.0	
			1	4.09		0.0	0.0	0.0								
3606	3P025-B	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.1	
			1	4.09		0.0	0.0	0.0								
3607	3P016	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.0	
			1	4.09		0.0	0.0	0.0								
3608	3P019	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.0	
			1	4.09		0.0	0.0	0.0								
3609	3P018-B	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.1	0.0	
			1	4.09		0.0	0.0	0.0								
3611	3P114	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.0	
			1	4.09		0.0	0.0	0.0								
3612	3P504	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	0.0	0.0	
			1	4.09		0.0	0.0	0.0								
3619	3B06X	4.16	1	0.984	-2.9	0.0	0.0	0.0	36	3A06	4.16	1	1	-0.4	0.0	
			1	4.09		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	0.999LK
21403	2BRA	0.48	1	0.923	-6.8	0.0	0.0	0.0	214	2B04	0.48	1	1	-23.0	-15.2	
			1	0.44		0.0	0.0	0.0	22403	2BRA-M	0.48	1	1	14.5	10.0	
									23403	2BRA-S	0.48	1	1	8.5	5.3	
21405	2P191-A	0.46	1	0.954	-6.8	0.0	57.0	0.0	214	2B04	0.48	1	1	-57.0	-35.0	1.043LK
			1	0.44		0.0	35.0	0.0								
21407	2BD	0.48	1	0.860	-7.7	0.0	0.0	0.0	214	2B04	0.48	1	1	-184.0	-123.9	
			1	0.41		0.0	0.0	0.0	22407	2BD-M	0.48	1	1	18.3	13.6	
									23407	2BD-S	0.48	1	1	8.5	5.3	
									24412	2A274	0.46	1	1	45.3	30.3	1.043UN
									24413	2A275	0.46	1	1	45.5	30.4	1.043UN
									24421	2E550	0.46	1	1	33.2	22.2	1.043UN
									24422	2E546	0.46	1	1	33.2	22.2	1.043UN
21409	2A071	0.46	1	0.943	-6.5	0.0	55.0	0.0	214	2B04	0.48	1	1	-55.0	-37.0	1.043LK
			1	0.43		0.0	37.0	0.0								
21410	2E399	0.46	1	0.952	-6.7	0.0	61.0	0.0	214	2B04	0.48	1	1	-61.0	-41.0	1.043LK
			1	0.44		0.0	41.0	0.0								
21411	2E401	0.46	1	0.949	-6.7	0.0	61.0	0.0	214	2B04	0.48	1	1	-61.0	-41.0	1.043LK
			1	0.44		0.0	41.0	0.0								

Case No: E4C-082 CCN N-3 Rev: 1  
RE: Cpm 9-30-94 IRE: PL 10-5-94  
Sheet No: 387

Pen 9

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BX - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]LF-1\_IVBX.SAV

THU, SEP 15 1994 11:12

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CST	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA
21413	2P190	0.46	1	0.955	-6.8	0.0	57.0	0.0	214	2B04	0.48	1	1	-57.0	-35.0	1.043LK		
			1	0.44		0.0	35.0	0.0										
21414	2BE	0.48	1	0.921	-6.8	0.0	0.0	0.0	214	2B04	0.48	1	1	-134.5	-114.9			
			1	0.44		0.0	0.0	0.0		22414	2BE-M	0.48	1	1	45.0	50.8		
										23414	2BE-S	0.48	1	1	89.4	64.1		
21415	2BY	0.48	1	0.920	-5.9	0.0	0.0	0.0	214	2B01	0.48	1	1	-222.2	-145.5			
			1	0.44		0.0	0.0	0.0		22415	2BY-M	0.48	1	1	86.2	55.4		
										23415	2BY-S	0.48	1	1	112.5	78.1		
										24434	2P009	0.46	1	1	23.6	12.0	1.043UN	
21419	2A074	0.46	1	0.938	-6.4	0.0	55.0	0.0	214	2B04	0.48	1	1	-55.0	-37.0	1.043LK		
			1	0.43		0.0	37.0	0.0										
21603	2BRB	0.48	1	0.928	-6.3	0.0	0.0	0.0	216	2B06	0.48	1	1	-23.0	-15.2			
			1	0.45		0.0	0.0	0.0		22603	2BRB-M	0.48	1	1	14.5	10.0		
										23603	2BRB-S	0.48	1	1	8.5	5.3		
21605	2BH	0.48	1	0.879	-7.0	0.0	0.0	0.0	216	2B06	0.48	1	1	-183.9	-123.9			
			1	0.42		0.0	0.0	0.0		22605	2BH-M	0.48	1	1	18.3	13.6		
										23605	2BH-S	0.48	1	1	8.5	5.3		
										24606	2E547	0.46	1	1	33.1	22.1	1.043UN	
										24607	2E519	0.46	1	1	33.2	22.2	1.043UN	
										24611	2A276	0.46	1	1	45.3	30.3	1.043UN	
										24612	2A277	0.46	1	1	45.5	30.4	1.043UN	
21607	2BJ	0.48	1	0.926	-6.3	0.0	0.0	0.0	216	2B06	0.48	1	1	-124.2	-108.5			
			1	0.44		0.0	0.0	0.0		22607	2BJ-M	0.48	1	1	45.0	50.7		
										23607	2BJ-S	0.48	1	1	79.2	57.8		
21609	2A072	0.46	1	0.946	-6.0	0.0	55.0	0.0	216	2B06	0.48	1	1	-55.0	-37.0	1.043LK		
			1	0.44		0.0	37.0	0.0										
21610	2E400	0.46	1	0.952	-6.2	0.0	61.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK		
			1	0.44		0.0	41.0	0.0										
21611	2E402	0.46	1	0.946	-6.2	0.0	61.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK		
			1	0.44		0.0	41.0	0.0										
21613	2P192	0.46	1	0.956	-6.3	0.0	57.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK		
			1	0.44		0.0	35.0	0.0										
21614	2BZ	0.48	1	0.926	-6.4	0.0	0.0	0.0	216	2B06	0.48	1	1	-197.9	-136.6			
			1	0.44		0.0	0.0	0.0		22614	2BZ-M	0.48	1	1	50.0	40.7		
										23614	2BZ-S	0.48	1	1	124.4	83.9		
										24622	2P010	0.46	1	1	23.6	12.0	1.043UN	
21617	2P191-B	0.46	1	0.955	-6.3	0.0	57.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK		
			1	0.44		0.0	35.0	0.0										

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: Lpm 9-30-94 IRE: PL 10-5-94  
Sheet No. 388  
CCN 9

BUS DATA									LINE DATA							
FROM BUS	NAME	AREA	VOLT	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I	KVA
		ZONE	PU/KV	ANGLE	KW/KVAR	KW/KVAR										
21619	2A073	0.46	1	0.939	-5.9	0.0	55.0	0.0								
			1	0.43		0.0	37.0	0.0	216	2B06	0.48	1	1	-55.0	-37.0	1.043LK
22403	2BRA-M	0.48	1	0.923	-6.8	0.0	14.4	0.0								
			1	0.44		0.0	10.0	0.0	21403	2BRA	0.48	1	1	-14.5	-10.0	
22407	2BD-M	0.48	1	0.860	-7.7	0.0	18.3	0.0								
			1	0.41		0.0	13.6	0.0	21407	2BD	0.48	1	1	-18.3	-13.6	
22414	2BE-M	0.48	1	0.921	-6.8	0.0	45.0	0.0								
			1	0.44		0.0	50.8	0.0	21414	2BE	0.48	1	1	-45.0	-50.8	
22415	2BY-M	0.48	1	0.920	-6.9	0.0	86.2	0.0								
			1	0.44		0.0	55.4	0.0	21415	2BY	0.48	1	1	-86.2	-55.4	
22603	2BRB-M	0.48	1	0.928	-6.3	0.0	14.4	0.0								
			1	0.45		0.0	10.0	0.0	21603	2BRB	0.48	1	1	-14.5	-10.0	
22605	2BH-M	0.48	1	0.879	-7.0	0.0	18.3	0.0								
			1	0.42		0.0	13.6	0.0	21605	2BH	0.48	1	1	-18.3	-13.6	
22607	2BJ-M	0.48	1	0.926	-6.3	0.0	45.0	0.0								
			1	0.44		0.0	50.7	0.0	21607	2BJ	0.48	1	1	-45.0	-50.7	
22614	2BZ-M	0.48	1	0.926	-6.4	0.0	50.0	0.0								
			1	0.44		0.0	40.7	0.0	21614	2BZ	0.48	1	1	-50.0	-40.7	
23403	2BRA-S	0.48	1	0.923	-6.8	0.0	8.5	0.0								
			1	0.44		0.0	5.3	0.0	21403	2BRA	0.48	1	1	-8.5	-5.3	
23407	2BD-S	0.48	1	0.860	-7.7	0.0	8.5	0.0								
			1	0.41		0.0	5.3	0.0	21407	2BD	0.48	1	1	-8.5	-5.3	
23414	2BE-S	0.48	1	0.921	-6.8	0.0	89.4	0.0								
			1	0.44		0.0	64.1	0.0	21414	2BE	0.48	1	1	-89.4	-64.1	
23415	2BY-S	0.48	1	0.920	-6.9	0.0	112.5	0.0								
			1	0.44		0.0	78.1	0.0	21415	2BY	0.48	1	1	-112.5	-78.1	
23603	2BRB-S	0.48	1	0.928	-6.3	0.0	8.5	0.0								
			1	0.45		0.0	5.3	0.0	21603	2BRB	0.48	1	1	-8.5	-5.3	
23605	2BH-S	0.48	1	0.879	-7.0	0.0	8.5	0.0								
			1	0.42		0.0	5.3	0.0	21605	2BH	0.48	1	1	-8.5	-5.3	
23607	2BJ-S	0.48	1	0.926	-6.3	0.0	79.2	0.0								
			1	0.44		0.0	57.8	0.0	21607	2BJ	0.48	1	1	-79.2	-57.8	
23614	2BZ-S	0.48	1	0.926	-6.4	0.0	124.4	0.0								
			1	0.44		0.0	83.9	0.0	21614	2BZ	0.48	1	1	-124.4	-83.9	

Cell No: E4C-082 CCN N-3 Rev: 1  
RE: *Lpm 9-30-94* RE: *DL 10-5-94*  
Sheet No. 389

*CCN 9*

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA
24412	2A274	0.46	1	0.894	-7.6	0.0	45.1	0.0										
			1	0.41		0.0	30.3	0.0	21407	2BD	0.48	1	1	-45.1	-30.3	1.043LK		
24413	2A275	0.46	1	0.891	-7.5	0.0	45.1	0.0										
			1	0.41		0.0	30.3	0.0	21407	2BD	0.48	1	1	-45.1	-30.3	1.043LK		
24421	2E550	0.46	1	0.890	-7.5	0.0	32.9	0.0										
			1	0.41		0.0	22.1	0.0	21407	2BD	0.48	1	1	-32.9	-22.1	1.043LK		
24422	2E546	0.46	1	0.891	-7.5	0.0	32.9	0.0										
			1	0.41		0.0	22.1	0.0	21407	2BD	0.48	1	1	-32.9	-22.1	1.043LK		
24434	2P009	0.46	1	0.947	-6.7	0.0	23.2	0.0										
			1	0.44		0.0	11.9	0.0	21415	2BY	0.48	1	1	-23.2	-11.9	1.043LK		
24606	2E547	0.46	1	0.912	-6.8	0.0	32.9	0.0										
			1	0.42		0.0	22.1	0.0	21605	2BH	0.48	1	1	-32.9	-22.1	1.043LK		
24607	2E549	0.46	1	0.911	-6.8	0.0	32.9	0.0										
			1	0.42		0.0	22.1	0.0	21605	2BH	0.48	1	1	-32.9	-22.1	1.043LK		
24611	2A276	0.46	1	0.914	-6.9	0.0	45.1	0.0										
			1	0.42		0.0	30.3	0.0	21605	2BH	0.48	1	1	-45.1	-30.3	1.043LK		
24612	2A277	0.46	1	0.912	-6.8	0.0	45.1	0.0										
			1	0.42		0.0	30.3	0.0	21605	2BH	0.48	1	1	-45.1	-30.3	1.043LK		
24622	2P010	0.46	1	0.953	-6.1	0.0	23.2	0.0										
			1	0.44		0.0	11.9	0.0	21614	2BZ	0.48	1	1	-23.2	-11.9	1.043LK		
31402	3E61N	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	314	3D04	0.48	1	1	0.0	0.0			
31403	3BRA	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0			
									32403	3BRA-M	0.48	1	1	0.0	0.0			
									33403	3BRA-S	0.48	1	1	0.0	0.0			
31405	3P191-A	0.46	1	1.025	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	314	3E04	0.48	1	1	0.0	0.0	1.043LK		
31407	3BD	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	314	3E04	0.48	1	1	0.0	0.0			
									32407	3BD-M	0.48	1	1	0.0	0.0			
									33407	3BD-S	0.48	1	1	0.0	0.0			
									34412	3A274	0.46	1	1	0.0	0.0	1.043UN		
									34413	3A275	0.46	1	1	0.0	0.0	1.043UN		
									34421	3E550	0.46	1	1	0.0	0.0	1.043UN		
									34422	3E546	0.46	1	1	0.0	0.0	1.043UN		
31409	3A071	0.46	1	1.025	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK		

Calc No: E4C-082 CCN N-3 Rev: 1  
RE: LPW 9-30-94 IRE: AD 10-5-94  
9  
Sheet No: 390

BUS DATA									LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I	KVA	
31410	3E399	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK			
31411	3E401	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK			
31413	3P190	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK			
31414	3BE	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0				
									32414	3BE-M	0.48	1	1	0.0	0.0				
									33414	3BE-S	0.48	1	1	0.0	0.0				
31415	3BT	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0				
									32415	3BT-M	0.48	1	1	0.0	0.0				
									33415	3BT-S	0.48	1	1	0.0	0.0				
									34434	3B09	0.46	1	1	0.0	0.0	1.043UN			
31417	BQ-U3	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0				
									32417	BQ-U3-M	0.48	1	1	0.0	0.0				
									33417	BQ-U3-S	0.48	1	1	0.0	0.0				
									34417	P162-U3	0.46	1	1	0.0	0.0	1.043UN			
31418	E418-U3	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3L04	0.48	1	1	0.0	0.0	1.043LK			
31419	3A074	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK			
31602	3E62N	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0				
31603	3BRB	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0				
									32603	3BRB-M	0.48	1	1	0.0	0.0				
									33603	3BRB-S	0.48	1	1	0.0	0.0				
31605	3BH	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0				
									32605	3BH-M	0.48	1	1	0.0	0.0				
									33605	3BH-S	0.48	1	1	0.0	0.0				
									34606	3E547	0.46	1	1	0.0	0.0	1.043UN			
									34607	3E549	0.46	1	1	0.0	0.0	1.043UN			
									34611	3A276	0.46	1	1	0.0	0.0	1.043UN			
									34612	3A277	0.46	1	1	0.0	0.0	1.043UN			
31607	3BJ	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0				
									32607	3BJ-M	0.48	1	1	0.0	0.0				
									33607	3BJ-S	0.48	1	1	0.0	0.0				
31609	3A072	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK			

Calc No: E4C-082 CCN N-3 Rev: 1  
 RE: *CPW 9-30-94* IRE: *AS 10-5-94*  
 9 Sheet No. 391



BUS DATA									LINE DATA										
FROM BUS	NAME	AREA	ZONE	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA	
31610	3E400	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3306	0.48	1	1	0.0	0.0	1.043LK			
31611	3E402	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3806	0.48	1	1	0.0	0.0	1.043LK			
31613	3P192	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3806	0.48	1	1	0.0	0.0	1.043LK			
31614	3BZ	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3806	0.48	1	1	0.0	0.0				
									32614	3BZ-M	0.48	1	1	0.0	0.0				
									33614	3BZ-S	0.48	1	1	0.0	0.0				
									34622	3P010	0.46	1	1	0.0	0.0	1.043UN			
31615	E419-U3	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3306	0.48	1	1	0.0	0.0	1.043LK			
31617	3P191-B	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3806	0.48	1	1	0.0	0.0	1.043LK			
31618	BS-U3	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3806	0.48	1	1	0.0	0.0				
									32618	BS-U3-M	0.48	1	1	0.0	0.0				
									33618	BS-U3-S	0.48	1	1	0.0	0.0				
									34618	P160-U3	0.46	1	1	0.0	0.0	1.043UN			
31619	3A073	0.46	1	1.028	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	316	3806	0.48	1	1	0.0	0.0	1.043LK			
32403	3BRA-M	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31403	3BRA	0.48	1	1	0.0	0.0				
32407	3BD-M	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0				
32414	3BE-M	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31414	3BE	0.48	1	1	0.0	0.0				
32415	3BY-M	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31415	3BY	0.48	1	1	0.0	0.0				
32417	BQ-U3-M	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	0.0	0.0				
32603	3BRB-M	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31603	3BRB	0.48	1	1	0.0	0.0				
32605	3BH-M	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31605	3BH	0.48	1	1	0.0	0.0				
32607	3BJ-M	0.48	1	0.985	-2.9	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	31607	3BJ	0.48	1	1	0.0	0.0				

Calc No: E4C-082  
 Rev: 1  
 Date: 9-30-94  
 IRE: RL 10-5-94  
 Sheet No. 392


BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CRT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
32614	3BZ-M	0.48	1	0.985	-2.9	0.0	0.0	0.0	31614	3BZ	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
32618	BS-U3-M	0.48	1	0.985	-2.9	0.0	0.0	0.0	31618	BS-U3	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33403	3BRA-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31403	3BRA	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33407	3BD-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33414	3BE-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31414	3BE	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33415	3BY-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31415	3BY	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33417	BQ-U3-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33603	3BRB-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31603	3BRB	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33605	3BH-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31605	3BH	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33607	3BJ-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31607	3BJ	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33614	3BE-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31614	3BE	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
33618	BS-U3-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31618	BS-U3	0.48	1	1	0.0	0.0		
			1	0.47		0.0	0.0	0.0									
34412	3A274	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK	
			1	0.47		0.0	0.0	0.0									
34413	3A275	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK	
			1	0.47		0.0	0.0	0.0									
34417	P162-U3	0.46	1	1.025	-3.2	0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	0.0	0.0	1.043LK	
			1	0.47		0.0	0.0	0.0									
34421	3E550	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK	
			1	0.47		0.0	0.0	0.0									
34422	3E546	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK	
			1	0.47		0.0	0.0	0.0									

Calc No: E4C-082  
CN 9-N-3  
Rev. 1  
Sheet No. 393  
RE: Lpm 9-30-94  
RE: RL 10-5-94

FTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E THU, SEP 15 1994 11:12  
CASE IV.BX - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]L-1\_IVBX.SAV

Sheet No. 394  
Case No: E4C-082 CCAN-3 Rev. 1  
RE: Lpm 9-30-94 IRE: PL 10-5-99

BUS DATA										LINE DATA									
FROM BUS	AREA	VOLT	ZONE	FU/KV	ANGLE	GER	KW/KVAR	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	RATIO	TRANSFORMER	ANGLE	RATING
34434	3P009	0.46	1	1.025	-3.2	0.0	0.0	0.0	0.0	0.0	31415	3BY	1	0.0	0.0	1.043LK			
34606	3E547	0.46	1	1.028	-2.9	0.0	0.0	0.0	0.0	0.0	31605	211	1	0.0	0.0	1.043LK			
34607	3E549	0.46	1	1.028	-2.9	0.0	0.0	0.0	0.0	0.0	31605	32H	1	0.0	0.0	1.043LK			
34611	3A276	0.46	1	1.028	-2.9	0.0	0.0	0.0	0.0	0.0	31605	3DH	1	0.0	0.0	1.043LK			
34612	3A277	0.46	1	1.028	-2.9	0.0	0.0	0.0	0.0	0.0	31605	3BH	1	0.0	0.0	1.043LK			
34618	P160-U3	0.46	1	1.028	-2.9	0.0	0.0	0.0	0.0	0.0	31615	D5-U3	1	0.0	0.0	1.043LK			
34622	3P010	0.46	1	1.028	-2.9	0.0	0.0	0.0	0.0	0.0	31614	3Z2	1	0.0	0.0	1.043LK			




Sheet No. 395




Calc No: E4C-082 CCN 9 N-3 Rev. 1



RE: Lpin 9-30-94 IRE: DL 10-5-94









Sheet No. 396  
 Calc No: E4C-082 CCNDN-3 Rev. 1  
 RE: Apr 9-30-94 IRE: Rel. 10-5-94





Sheet No. 397  
 Calc No: E4C-082 CCN-N-3 Rev. 1  
 RE: Upm 9-30-94 IRE: Ad 10-5-94



BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I KVA
1	SYSTEM	230	1 0.947	-0.1	32504.4	0.0	0.0	41	230S	22.0	1	32504.4	20709.7	0.973UN		
			1 217.8		20709.0R	0.0	0.0		M I S M A T C H			0.0	-0.7			
24	2A04	4.16	1 0.960	-4.8	0.0	0.0	0.0	34	3A04	4.16	1	4930.5	2758.7			
			1 3.99		0.0	0.0	0.0	44	2XU1Y	4.16	1	-8507.7	-4853.5			
								2403	2P012	4.16	1	353.1	180.2			
								2404	2P141	4.16	1	675.6	308.1			
								2406	2P025-A	4.16	1	477.3	270.3			
								2407	2P015	4.16	1	389.2	199.2			
								2408	2P017	4.16	1	405.2	173.2			
								2411	2P307	4.16	1	331.2	214.2			
								2420	2E04X	4.16	1	944.6	748.9			
									M I S M A T C H			0.9	0.8			
26	2A06	4.16	1 0.964	-4.4	0.0	0.0	0.0	36	3A06	4.16	1	4735.0	2621.1			
			1 4.01		0.0	0.0	0.0	46	2XU1X	4.16	1	-8274.3	-4688.8			
								2603	2P504	4.16	1	675.4	308.0			
								2604	2P013	4.16	1	353.1	180.1			
								2606	2P025-B	4.16	1	477.4	270.3			
								2607	2P016	4.16	1	389.2	199.2			
								2608	2P019	4.16	1	405.2	173.1			
								2611	2P114	4.16	1	331.2	214.2			
								2620	2E06X	4.16	1	907.5	722.5			
									M I S M A T C H			0.4	0.4			
34	3A04	4.16	1 0.958	-4.8	0.0	0.0	0.0	24	2A04	4.16	1	-4925.7	-2752.8			
			1 3.99		0.0	0.0	0.0	3402	E2P6-U3	4.16	1	448.3	247.3			
								3403	3P012	4.16	1	307.6	166.1			
								3404	3P141	4.16	1	670.6	297.6			
								3405	3P024	4.16	1	472.6	261.2			
								3407	3P015	4.16	1	378.2	188.3			
								3408	3P017	4.16	1	395.5	171.6			
								3409	3P018-A	4.16	1	395.5	171.6			
								3411	3P007	4.16	1	320.4	197.7			
								3412	3P014	4.16	1	128.0	78.0			
								3417	3E04X	4.16	1	1407.5	973.7			
									M I S M A T C H			1.5	-0.2			
36	3A06	4.16	1 0.963	-4.4	0.0	0.0	0.0	26	2A06	4.16	1	-4731.6	-2616.9			
			1 4.01		0.0	0.0	0.0	3602	E2P5-U3	4.16	1	448.3	247.8			
								3604	3P013	4.16	1	307.6	166.9			
								3606	3P025-B	4.16	1	472.5	262.3			
								3607	3P016	4.16	1	378.3	188.8			
								3608	3P019	4.16	1	395.5	172.0			
								3609	3P018-B	4.16	1	395.7	172.1			
								3611	3P114	4.16	1	320.3	198.7			
								3612	3P504	4.16	1	670.7	297.9			
								3619	3E06X	4.16	1	1340.6	909.5			
									M I S M A T C H			1.9	1.0			

Case No: E4C-082  
 Rev: 1  
 Date: 9-30-94  
 RE: 10-5-94  
 Sheet No. 398

BUS DATA									LINE DATA							
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CRT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KVA
41	2XMS	22.0	1	0.919	-0.3	0.0	0.0	0.0	1	SYSTEM	230	1	1	*****	0.973LK	
			1	20.22		0.0	0.0	0.0	45	2XU1*	4.36	1	1	32502.620547.0	0.950LK	
44	2XU1Y	4.16	1	0.965	-4.6	0.0	8384.0	0.0	24	2A04	4.16	1	1	8539.6 4902.3		
			1	4.01		0.0	4067.0	0.0	45	2XU1*	4.36	1	1	*****-8969.2	1.048LK	
45	2XU1*	4.36	1	0.966	-0.4	0.0	0.0	0.0	41	2XMS	22.0	1	1	*****	0.950UN	
			1	4.21		0.0	0.0	0.0	44	2XU1Y	4.16	1	1	17012.810698.9	1.048UN	
									46	2XU1X	4.16	1	1	15485.1 9741.4	1.048UN	
									M I S M A T C H			0.0	0.9			
46	2XU1X	4.16	1	0.969	-4.2	0.0	7106.0	0.0	26	2A06	4.16	1	1	8305.3 4736.3		
			1	4.03		0.0	3572.0	0.0	45	2XU1*	4.36	1	1	*****-8308.1	1.048LK	
214	2B04	0.48	1	0.901	-8.5	0.0	0.0	0.0	2420	2B04X	4.16	1	1	-929.5 -642.9	0.999UN	
			1	0.43		0.0	0.0	0.0	21403	2BRA	0.48	1	1	23.0 15.2		
									21405	2P191-A	0.46	1	1	57.6 35.4	1.043UN	
									21407	2ED	0.48	1	1	196.4 136.9		
									21409	2A071	0.46	1	1	56.5 37.6	1.043UN	
									21410	2E399	0.46	1	1	61.8 41.5	1.043UN	
									21411	2E401	0.46	1	1	62.0 41.6	1.043UN	
									21413	2P190	0.46	1	1	57.6 35.3	1.043UN	
									21414	2BE	0.48	1	1	134.9 115.3		
									21415	2BY	0.48	1	1	222.7 146.4		
									21419	2A074	0.46	1	1	56.9 37.7	1.043UN	
216	2B06	0.48	1	0.907	-7.9	0.0	0.0	0.0	2620	2B06X	4.16	1	1	-893.4 -625.0	0.999UN	
			1	0.44		0.0	0.0	0.0	21603	2BRB	0.48	1	1	23.0 15.2		
									21605	2BH	0.48	1	1	193.2 133.7		
									21607	2BJ	0.48	1	1	124.6 108.8		
									21609	2A072	0.46	1	1	56.6 37.6	1.043UN	
									21610	2E400	0.46	1	1	62.2 41.7	1.043UN	
									21611	2E402	0.46	1	1	62.7 41.9	1.043UN	
									21613	2P192	0.46	1	1	57.9 35.5	1.043UN	
									21614	2EZ	0.48	1	1	198.3 137.2		
									21617	2P191-B	0.46	1	1	57.9 35.5	1.043UN	
									21619	2A073	0.46	1	1	57.1 37.8	1.043UN	

Calc No: E4C-082 CCN 9N-3 Rev. 1  
Sheet No. 399  
RE: Apr 9-30-94 IRE: 10-5-94



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]LF-2\_IVBX.SAV

THU, SEP 15 1994 13:24

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	A KVA
314	3B04	0.48	1	0.881	-10.6	0.0	0.0	0.0	31417	3B34X	4.16	1	1	-1376.4	-759.3	0.999UN		
			1	0.42		0.0	0.0	0.0	31402	3E51N	0.48	1	1	202.6	2.8			
									31403	3B0A	0.48	1	1	22.0	13.5			
									31401	3E191-A	0.46	1	1	56.1	36.4	1.043UN		
									31407	3ED	0.48	1	1	185.1	129.3			
									31409	3A071	0.46	1	1	56.6	32.6	1.043UN		
									31410	3E599	0.46	1	1	60.5	42.0	1.043UN		
									31411	3E401	0.46	1	1	60.6	42.0	1.043UN		
									31413	3P190	0.46	1	1	55.9	36.4	1.043UN		
									31414	3BE	0.48	1	1	143.1	96.8			
									31415	3EY	0.48	1	1	214.6	138.0			
									31417	BQ-J3	0.48	1	1	141.3	87.1			
									31418	E119-U3	0.46	1	1	121.0	69.8	1.043UN		
									31419	3A074	0.46	1	1	56.9	32.6	1.043UN		
316	3B06	0.48	1	0.891	-9.9	0.0	0.0	6.0	3619	3E06X	4.16	1	1	-1313.1	-719.3	0.999UN		
			1	0.43		0.0	0.0	0.0	31602	3E62N	0.48	1	1	202.9	3.1			
									31603	3BRB	0.48	1	1	22.0	13.5			
									31605	3BH	0.48	1	1	182.6	126.4			
									31607	3BJ	0.48	1	1	131.8	89.9			
									31609	3A072	0.46	1	1	56.8	32.8	1.043UN		
									31610	3E400	0.46	1	1	60.9	42.4	1.043UN		
									31611	3E402	0.46	1	1	61.4	42.4	1.043UN		
									31613	3P192	0.46	1	1	56.2	36.7	1.043UN		
									31614	3E2	0.48	1	1	199.8	127.5			
									31615	E419-U3	0.46	1	1	117.6	70.5	1.043UN		
									31617	3E191-B	0.46	1	1	56.2	36.7	1.043UN		
									31618	BS-U3	0.48	1	1	107.6	64.6			
									31619	3A073	0.46	1	1	57.2	32.8	1.043UN		
2403	2P012	4.16	1	0.959	-4.8	0.0	352.9	0.0	24	2A34	4.16	1	1	-352.9	-180.0			
			1	3.99		0.0	180.0	0.0										
2404	2P141	4.16	1	0.958	-4.8	0.0	674.5	0.0	24	2A04	4.16	1	1	-674.5	-307.3			
			1	3.99		0.0	307.3	0.0										
2406	2P025-A	4.16	1	0.959	-4.8	0.0	477.0	0.0	24	2A04	4.16	1	1	-477.0	-270.0			
			1	3.99		0.0	270.0	0.0										
2407	2P015	4.16	1	0.959	-4.8	0.0	389.0	0.0	24	2A04	4.16	1	1	-389.0	-199.0			
			1	3.99		0.0	199.0	0.0										
2408	2P017	4.16	1	0.959	-4.8	0.0	405.0	0.0	24	2A04	4.16	1	1	-405.0	-173.0			
			1	3.99		0.0	173.0	0.0										
2411	2P307	4.16	1	0.959	-4.8	0.0	331.0	0.0	24	2A04	4.16	1	1	-331.0	-214.0			
			1	3.99		0.0	214.0	0.0										
2420	2B04X	4.16	1	0.959	-4.8	0.0	0.0	0.0	24	2A04	4.16	1	1	-944.4	-748.7			
			1	3.99		0.0	0.0	0.0	211	2B04	0.48	1	1	944.6	748.7	0.999LK		

Calc No: E4C-082 CCA9V-3 Rev. 1  
 RE: Cpm 9-30-94  
 RE: AD 10-5-94  
 Sheet No. 400

THU, SEP 15 1994 13:24

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BX - POST ACCIDENT (STEADY STATE) CONDITION  
DEB200:[MURIEL.E4C-082-AGA.CASE\_IVBX|LF-2\_IVBX.SAV

Sheet No. 401  
Calc No: E4C-082 CCN 9-3 Rev. 1  
RE: Lpm 9-30-94 IRE: RL 10-5-94

BUS DATA				LINE DATA				TRANSFORMER RATING A						
FROM BUS	AREA	VOLT	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT TO BUS	NAME	CKT AREA	KW	KVAR	RATIO	ANGLE	NI	KVA
2603 2P504	4.16	1	0.962	-4.4	0.0	674.5	0.0	26 2A06	4.16	1	1	-674.5	-307.3	
2604 2P013	4.16	1	0.963	-4.4	0.0	307.3	0.0	26 2A06	4.16	1	1	-352.9	-180.0	
2606 2P025-B	4.16	1	0.963	-4.4	0.0	477.0	0.0	26 2A06	4.16	1	1	-477.1	-270.0	
2607 2P016	4.16	1	0.963	-4.4	0.0	369.0	0.0	26 2A06	4.16	1	1	-389.0	-199.0	
2608 2P019	4.16	1	0.963	-4.4	0.0	405.0	0.0	25 2A66	4.16	1	1	-405.0	-173.0	
2611 2P114	4.16	1	0.963	-4.4	0.0	331.0	0.0	26 2A06	4.16	1	1	-331.0	-214.0	
2620 2B06X	4.16	1	0.963	-4.4	0.0	0.0	0.0	26 2A06	4.16	1	1	-907.3	-722.3	
3402 E336-U3	4.16	1	0.958	-4.8	0.0	0.0	0.0	216 2B06	0.48	1	1	907.3	722.1	0.999LK
3403 3P012	4.16	1	0.958	-4.8	0.0	0.0	0.0	34 3A04	4.16	1	1	-448.0	-247.1	
3404 3P141	4.16	1	0.957	-4.8	0.0	0.0	0.0	M I S M A T C H				448.0	247.1	
3405 3P024	4.16	1	0.958	-4.8	0.0	0.0	0.0	34 3A04	4.16	1	1	-307.5	-166.0	
3407 3P015	4.16	1	0.958	-4.8	0.0	0.0	0.0	M I S M A T C H				307.5	166.0	
3408 3P017	4.16	1	0.958	-4.8	0.0	0.0	0.0	34 3A04	4.16	1	1	-669.6	-296.9	
3409 3P018-A	4.16	1	0.958	-4.8	0.0	0.0	0.0	M I S M A T C H				669.6	296.9	
3411 3P307	4.16	1	0.958	-4.8	0.0	0.0	0.0	34 3A04	4.16	1	1	-472.3	-260.9	
3412 3T014	4.16	1	0.958	-4.8	0.0	0.0	0.0	M I S M A T C H				472.3	260.9	
3417 3B04X	4.16	1	0.958	-4.8	0.0	0.0	0.0	34 3A04	4.16	1	1	-378.0	-188.1	
								M I S M A T C H				378.0	188.1	
								34 3A04	4.16	1	1	-395.3	-171.4	
								M I S M A T C H				395.3	171.4	
								34 3A04	4.16	1	1	-395.3	-171.4	
								M I S M A T C H				395.3	171.4	
								34 3A04	4.16	1	1	-320.2	-197.5	
								M I S M A T C H				320.2	197.5	
								34 3A04	4.16	1	1	-128.0	-78.0	
								M I S M A T C H				128.0	78.0	
								34 3A04	4.16	1	1	-1406.8	-973.1	
								M I S M A T C H				1406.8	973.1	0.999LK

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]LF-2\_IVBX.SAV

THU, SEP 15 1994 13:24

BUS DATA								LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE	FU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
3602	E335-U3	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-448.1	-247.6				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			448.1	247.6				
3604	3P013	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-307.5	-166.8				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			307.5	166.8				
3606	3P025-B	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-472.3	-262.1				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			472.3	262.1				
3607	3P016	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-378.1	-188.7				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			378.1	188.7				
3608	3P019	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-395.4	-171.9				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			395.4	171.9				
3609	3P018-B	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-395.5	-172.0				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			395.5	172.0				
3611	3P114	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-320.2	-198.5				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			320.2	198.5				
3612	3P504	4.16	1	0.961	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-669.6	-297.1				
			1	4.00		0.0	0.0	0.0		M I S M A T C H			669.6	297.1				
3619	3B06X	4.16	1	0.962	-4.4	0.0	0.0	0.0										
			1	4.00		0.0	0.0	0.0	36	3A06	4.16	1	-1340.2	-909.2				
			1	4.00		0.0	0.0	0.0	316	3A06	0.48	1	1340.2	909.1	0.999LK			
21403	2BRA	0.48	1	0.900	-8.5	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	214	2B04	0.48	1	-22.9	-15.2				
			1	0.43		0.0	0.0	0.0	2240	2A-M	0.48	1	14.4	10.0				
			1	0.43		0.0	0.0	0.0	2340	2BRA-S	0.48	1	8.5	5.3				
21405	2P191-A	0.46	1	0.930	-8.5	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	214	2B04	0.48	1	-57.0	-35.0	1.043LK			
21407	2BD	0.48	1	0.835	-9.5	0.0	0.0	0.0										
			1	0.40		0.0	0.0	0.0	214	2E04	0.48	1	-184.1	-123.9				
			1	0.40		0.0	0.0	0.0	22407	2BD-M	0.48	1	18.3	13.6				
			1	0.40		0.0	0.0	0.0	23407	2BD-S	0.48	1	8.5	5.3				
			1	0.40		0.0	0.0	0.0	24412	2A274	0.46	1	45.3	30.3	1.043UN			
			1	0.40		0.0	0.0	0.0	24413	2A275	0.46	1	45.5	30.4	1.043UN			
			1	0.40		0.0	0.0	0.0	24421	2E550	0.46	1	33.2	22.2	1.043UN			
			1	0.40		0.0	0.0	0.0	24422	2E546	0.46	1	33.2	22.2	1.043UN			
21409	2A071	0.46	1	0.918	-8.2	0.0	55.0	0.0										
			1	0.42		0.0	37.0	0.0	214	2B04	0.48	1	-55.0	-37.0	1.043LK			
21410	2E399	0.46	1	0.928	-8.5	0.0	61.0	0.0										
			1	0.43		0.0	41.0	0.0	214	2B04	0.48	1	-61.0	-41.0	1.043LK			
21411	2E401	0.46	1	0.925	-8.5	0.0	61.0	0.0										
			1	0.43		0.0	41.0	0.0	214	2B04	0.48	1	-61.0	-41.0	1.043LK			

Case No: E4C-082 CCN9N-3 Rev: 1  
 RE: Lpm 9-30-94 RE: AD 10-5-94  
 Sheet No: 402

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]LF-2\_IVBX.SAV

THU, SEP 15 1994 13:24

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	RATING A KVA
21413	2P190	0.46	1	0.930	-8.5	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	214	2B04	0.48	1	1	-57.0	-35.0	1.043LK		
21414	2BE	0.48	1	0.898	-8.5	0.0	9.0	0.0										
			1	0.43		0.0	0.0	0.0	214	2E04	0.48	1	1	-134.5	-114.8			
									22414	2BE-M	0.48	1	1	45.0	50.8			
									23414	2BE-S	0.48	1	1	89.4	64.1			
21415	2BY	0.48	1	0.897	-8.6	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	214	2B04	0.48	1	1	-222.2	-145.5			
									22415	2BY-M	0.48	1	1	86.2	55.4			
									23415	2BY-S	0.48	1	1	112.5	78.1			
									24434	2F009	0.46	1	1	23.6	12.0	1.043UN		
21419	2A074	0.46	1	0.913	-8.1	0.0	55.0	0.0										
			1	0.42		0.0	37.0	0.0	214	2E04	0.48	1	1	-55.0	-37.0	1.043LK		
21603	2BRB	0.48	1	0.907	-7.9	0.0	0.0	0.0										
			1	0.44		0.0	0.0	0.0	216	2B06	0.48	1	1	-22.9	-15.2			
									22603	2BRB-M	0.48	1	1	14.4	10.0			
									23603	2BRB-S	0.48	1	1	8.5	5.3			
21605	2BH	0.48	1	0.856	-8.7	0.0	0.0	0.0										
			1	0.41		0.0	0.0	0.0	216	2B06	0.48	1	1	-183.9	-123.9			
									22605	2BH-M	0.48	1	1	18.3	13.6			
									23605	2BH-S	0.48	1	1	8.5	5.3			
									24606	2A547	0.46	1	1	33.2	22.1	1.043UN		
									24607	2A549	0.46	1	1	33.2	22.2	1.043UN		
									24611	2A276	0.46	1	1	45.3	30.3	1.043UN		
									24612	2A277	0.46	1	1	45.5	30.4	1.043UN		
21607	2BJ	0.48	1	0.904	-8.0	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	216	2B06	0.48	1	1	-124.2	-108.4			
									22607	2BJ-M	0.48	1	1	45.0	50.7			
									23607	2BJ-S	0.48	1	1	79.2	57.8			
21609	2A072	0.46	1	0.923	-7.6	0.0	55.0	0.0										
			1	0.42		0.0	37.0	0.0	216	2B06	0.48	1	1	-55.0	-37.0	1.043LK		
21610	2E400	0.46	1	0.929	-7.9	0.0	61.0	0.0										
			1	0.43		0.0	41.0	0.0	216	2E06	0.48	1	1	-61.0	-41.0	1.043LK		
21611	2E402	0.46	1	0.923	-7.8	0.0	61.0	0.0										
			1	0.42		0.0	41.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK		
21613	2P192	0.46	1	0.933	-7.9	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK		
21614	2BZ	0.48	1	0.905	-8.0	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	216	2B06	0.48	1	1	-197.9	-136.6			
									22614	2BZ-M	0.48	1	1	50.0	40.7			
									23614	2BZ-S	0.48	1	1	124.4	83.9			
									24622	2P010	0.46	1	1	23.6	12.0	1.043UN		
21617	2P191-B	0.46	1	0.932	-7.9	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK		

Case No: E4C-082 CCNQM-3 Rev 1  
Sheet No. 403  
RE: Lpm 9-30-94 IRE: AJ 10-5-94

BUS DATA									LINE DATA							
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	PY	KVAR	TRANSFORMER RATIO	ANGLE	RATING KVA
21619	2A073	0.46	1 0.916	-7.5	0.0	55.0	0.0									
			1 0.42		0.0	37.0	0.0	21619	2A06	0.48	1	1	-55.0	-37.0	1.043LK	
22403	2BRA-M	0.48	1 0.900	-8.5	0.0	14.4	0.0									
			1 0.43		0.0	10.0	0.0	21403	2BRA	0.48	1	1	-14.4	-10.0		
22407	2BD-M	0.48	1 0.835	-9.5	0.0	18.3	0.0									
			1 0.40		0.0	13.6	0.0	21407	2BD	0.48	1	1	-18.3	-13.6		
22414	2BE-M	0.48	1 0.898	-8.5	0.0	45.0	0.0									
			1 0.43		0.0	50.8	0.0	21414	2BE	0.48	1	1	-45.0	-50.8		
22415	2BY-M	0.48	1 0.897	-8.6	0.0	86.2	0.0									
			1 0.43		0.0	55.4	0.0	21415	2BY	0.48	1	1	-86.2	-55.4		
22603	2BRB-M	0.48	1 0.907	-7.9	0.0	14.4	0.0									
			1 0.44		0.0	10.0	0.0	21603	2BRB	0.48	1	1	-14.4	-10.0		
22605	2BH-M	0.48	1 0.856	-8.7	0.0	18.3	0.0									
			1 0.41		0.0	13.6	0.0	21605	2BH	0.48	1	1	-18.3	-13.6		
22607	2BJ-M	0.48	1 0.904	-8.0	0.0	45.0	0.0									
			1 0.43		0.0	50.7	0.0	21607	2BJ	0.48	1	1	-45.0	-50.7		
22614	2BZ-M	0.48	1 0.905	-8.0	0.0	50.9	0.0									
			1 0.43		0.0	40.7	0.0	21614	2BZ	0.48	1	1	-50.0	-40.7		
23403	2BRA-S	0.48	1 0.900	-8.5	0.0	8.5	0.0									
			1 0.43		0.0	5.3	0.0	21403	2BRA	0.48	1	1	-8.5	-5.3		
23407	2BD-S	0.48	1 0.835	-9.5	0.0	8.5	0.0									
			1 0.40		0.0	5.3	0.0	21407	2BD	0.48	1	1	-8.5	-5.3		
23414	2BE-S	0.48	1 0.898	-8.5	0.0	89.4	0.0									
			1 0.43		0.0	64.1	0.0	21414	2BE	0.48	1	1	-89.4	-64.1		
23415	2BY-S	0.48	1 0.897	-8.6	0.0	112.5	0.0									
			1 0.43		0.0	78.1	0.0	21415	2BY	0.48	1	1	-112.5	-78.1		
23603	2BRB-S	0.48	1 0.907	-7.9	0.0	8.5	0.0									
			1 0.44		0.0	5.3	0.0	21603	2BRB	0.48	1	1	-8.5	-5.3		
23605	2BH-S	0.48	1 0.856	-8.7	0.0	8.5	0.0									
			1 0.41		0.0	5.3	0.0	21605	2BH	0.48	1	1	-8.5	-5.3		
23607	2BJ-S	0.48	1 0.904	-8.0	0.0	79.2	0.0									
			1 0.43		0.0	57.8	0.0	21607	2BJ	0.48	1	1	-79.2	-57.8		
23614	2BZ-S	0.48	1 0.905	-8.0	0.0	124.4	0.0									
			1 0.43		0.0	83.9	0.0	21614	2BZ	0.48	1	1	-124.4	-83.9		

Case No: E4C-082 CCN/QW-3 Rev: 1  
 RE: Lpm 9-30-94 RE: RD 10-5-94  
 Sheet No. 2104

BUS DATA									LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I	KVA
24412	2A274	0.46	1 0.868 1 0.40	-9.4	0.0 0.0	45.1 30.3	0.0	21407	2LD	0.48	1 1	-45.1	-30.3	1.043LK			
24413	2A275	0.46	1 0.865 1 0.40	-9.3	0.0 0.0	45.1 30.3	0.0	21407	2BD	0.48	1 1	-45.1	-30.3	1.043LK			
24421	2E550	0.46	1 0.864 1 0.40	-9.3	0.0 0.0	32.9 22.1	0.0	21407	2ED	0.48	1 1	-32.9	-22.1	1.043LK			
24422	2E546	0.46	1 0.865 1 0.40	-9.3	0.0 0.0	32.9 22.1	0.0	21407	2ED	0.48	1 1	-32.9	-22.1	1.043LK			
24434	2P0C9	0.46	1 0.923 1 0.42	-8.4	0.0 0.0	23.2 11.9	0.0	21415	2BY	0.48	1 1	-23.2	-11.9	1.043LK			
24606	2E547	0.46	1 0.888 1 0.41	-8.5	0.0 0.0	32.9 22.1	0.0	21605	2BH	0.48	1 1	-32.9	-22.1	1.043LK			
24607	2E549	0.46	1 0.887 1 0.41	-8.5	0.0 0.0	32.9 22.1	0.0	21605	2BH	0.48	1 1	-32.9	-22.1	1.043LK			
24611	2A276	0.46	1 0.890 1 0.41	-8.6	0.0 0.0	45.1 30.3	0.0	21605	2BH	0.48	1 1	-45.1	-30.3	1.043LK			
24612	2A277	0.46	1 0.887 1 0.41	-8.5	0.0 0.0	45.1 30.3	0.0	21605	2EH	0.48	1 1	-45.1	-30.3	1.043LK			
24622	2P010	0.46	1 0.930 1 0.43	-7.8	0.0 0.0	23.2 11.9	0.0	21614	2BE	0.48	1 1	-23.2	-11.9	1.043LK			
31402	3E61N	0.48	1 0.870 1 0.42	-11.4	0.0 0.0	200.0 0.0	0.0	314	3B04	0.48	1 1	-200.0	0.0				
31403	3BRA	0.48	1 0.881 1 0.42	-10.6	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	-22.0	-13.5				
								32403	3BRA-M	0.48	1 1	13.5	8.2				
								33403	3BTA-S	0.48	1 1	8.5	5.3				
31405	3P191-A	0.46	1 0.908 1 0.42	-10.6	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	-55.3	-36.0	1.043LK			
								M I S M A T C H				55.3	36.0				
31407	3BD	0.48	1 0.818 1 0.39	-11.5	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	-173.7	-117.2				
								32403	3B04-M	0.48	1 1	17.3	10.6				
								33407	3BD-S	0.48	1 1	8.5	5.3				
								34411	2A274	0.46	1 1	41.8	29.5	1.043UN			
								34412	2A275	0.46	1 1	42.0	29.5	1.043UN			
								34421	3E550	0.46	1 1	32.1	21.2	1.043UN			
								34422	3E546	0.46	1 1	32.0	21.1	1.043UN			
31409	3A071	0.46	1 0.897 1 0.41	-10.4	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	-55.0	-32.0	1.043LK			
								M I S M A T C H				55.0	32.0				

Case No: E4C-082 CCN 9N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: PJ 10-5-94  
 Sheet No. 405

BUS DATA								LINE DATA											
FROM BUS	NAME	AREA	VOLT ZONE	PU/FV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	KVA	
31410	3E399	0.46	1	0.908	-10.5	0.0	0.0	0.0											
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	-59.6	-41.5	1.043LK				
										M I S M A T C H			59.6	41.5					
31411	3E401	0.46	1	0.906	-10.5	0.0	0.0	0.0	314	3B04	0.48	1	-59.6	-41.5	1.043LK				
			1	0.42		0.0	0.0	0.0		M I S M A T C H			59.6	41.5					
31413	3P190	0.46	1	0.910	-10.6	0.0	0.0	0.0	314	3B04	0.48	1	-55.3	-36.0	1.043LK				
			1	0.42		0.0	0.0	0.0		M I S M A T C H			55.3	36.0					
31414	3BE	0.48	1	0.879	-10.6	0.0	0.0	0.0	314	3B04	0.48	1	-142.8	-96.5					
			1	0.42		0.0	0.0	0.0	32414	3BE-M	0.48	1	53.3	32.5					
									33414	3BE-S	0.48	1	69.4	64.1					
31415	3BY	0.48	1	0.879	-10.7	0.0	0.0	0.0	314	3B04	0.48	1	-214.3	-137.3					
			1	0.42		0.0	0.0	0.0	32415	3BY-M	0.48	1	78.8	48.0					
									33415	3BY-S	0.48	1	112.5	78.1					
									34434	3I009	0.46	1	23.0	11.3	1.043UN				
31417	BQ-U3	0.48	1	0.873	-10.8	0.0	0.0	0.0	314	3B04	0.48	1	-140.1	-85.9					
			1	0.42		0.0	0.0	0.0	32417	BQ-U3-M	0.48	1	39.6	24.1					
									33417	BQ-U3-S	0.48	1	75.9	45.8					
									34417	21G2-U3	0.46	1	24.7	16.0	1.043UN				
31418	E418-U3	0.46	1	0.882	-10.6	0.0	0.0	0.0	314	3B04	0.48	1	-116.0	-67.0	1.043LK				
			1	0.41		0.0	0.0	0.0		M I S M A T C H			116.0	67.0					
31419	3A074	0.46	1	0.892	-10.3	0.0	0.0	0.0	314	3B04	0.48	1	-55.0	-31.9	1.043LK				
			1	0.41		0.0	0.0	0.0		M I S M A T C H			55.0	31.9					
31602	3E62N	0.48	1	0.878	-10.7	0.0	200.0	0.0	316	3B06	0.48	1	-200.0	0.0					
			1	0.42		0.0	0.0	0.0		M I S M A T C H									
31603	3BRB	0.48	1	0.891	-9.9	0.0	0.0	0.0	316	3B06	0.48	1	-22.0	-13.5					
			1	0.43		0.0	0.0	0.0	32600	3BRB-M	0.48	1	13.5	8.2					
									33600	3BRB-S	0.48	1	8.5	5.3					
31605	3BH	0.48	1	0.842	-10.6	0.0	0.0	0.0	316	3B06	0.48	1	-174.1	-117.4					
			1	0.40		0.0	0.0	0.0	32600	3BH-M	0.48	1	17.4	10.6					
									33605	3BH-S	0.48	1	8.5	5.3					
									34600	3E547	0.46	1	32.1	21.4	1.043UN				
									34600	3E549	0.46	1	32.1	21.4	1.043UN				
									34610	3A276	0.46	1	41.9	29.3	1.043UN				
									34610	3A277	0.46	1	42.1	29.4	1.043UN				
31607	3BJ	0.48	1	0.888	-9.9	0.0	0.0	0.0	316	3B06	0.48	1	-131.5	-89.6					
			1	0.43		0.0	0.0	0.0	32607	3BJ-M	0.48	1	52.2	31.8					
									33607	3BJ-S	0.48	1	79.2	57.8					
31609	3A072	0.46	1	0.904	-9.6	0.0	0.0	0.0	316	3B06	0.48	1	-55.1	-32.2	1.043LK				
			1	0.42		0.0	0.0	0.0		M I S M A T C H			55.1	32.2					

Case No: E4C-082  
 Date: Sep 9-30-94  
 Rev: 1  
 Sheet No: 406  
 IRE: AD 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS/E  
CASE IV.BX - POST ACCIDENT {STEADY STATE} CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX]LG-2\_IVBX.SAV

THU, SEP 15 1994 13:24

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI KVA
31610	3E400	0.46	1	0.912	-9.8	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3B06	0.48	1	-59.7	-41.7	1.043LK		
										M I S M A T C H			59.7	41.7			
31611	3E402	0.46	1	0.905	-9.7	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3E06	0.48	1	-59.6	-41.4	1.043LK		
										M I S M A T C H			59.6	41.4			
31613	3P192	0.46	1	0.916	-9.8	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3E06	0.48	1	-55.3	-36.2	1.043LK		
										M I S M A T C H			55.3	36.2			
31614	3BZ	0.48	1	0.889	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	316	3B06	0.48	1	-199.5	-126.9			
									32614	3EZ-M	0.48	1	52.0	31.7			
									33614	3BZ-S	0.48	1	124.4	83.9			
									34622	3P010	0.46	1	23.1	11.3	1.043UN		
31615	E419-U3	0.46	1	0.918	-9.9	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3F06	0.48	1	-116.2	-69.6	1.043LK		
										M I S M A T C H			116.2	69.6			
31617	3P191-B	0.46	1	0.916	-9.8	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3B06	0.48	1	-55.3	-36.2	1.043LK		
										M I S M A T C H			55.3	36.2			
31618	BS-U3	0.48	1	0.883	-10.0	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3B06	0.48	1	-106.7	-63.7			
									32618	BC-U3-M	0.48	1	39.6	24.1			
									33618	BS-U3-S	0.48	1	42.6	23.4			
									34618	P160-U3	0.46	1	24.5	16.2	1.043UN		
31619	3A073	0.46	1	0.898	-9.5	0.0	0.0	0.0									
			1	0.41		0.0	0.0	0.0	316	3B06	0.48	1	-55.0	-32.1	1.043LK		
										M I S M A T C H			55.0	32.1			
32403	3BRA-M	0.48	1	0.881	-10.6	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31403	3BRA	0.48	1	-13.5	-8.2			
										M I S M A T C H			13.5	8.2			
32407	3BD-M	0.48	1	0.818	-11.5	0.0	0.0	0.0									
			1	0.39		0.0	0.0	0.0	31407	3BD	0.48	1	-17.3	-10.6			
										M I S M A T C H			17.3	10.6			
32414	3BE-M	0.48	1	0.879	-10.6	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31414	3BE	0.48	1	-53.3	-32.5			
										M I S M A T C H			53.3	32.5			
32415	3BY-M	0.48	1	0.879	-10.7	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31415	3BY	0.48	1	-78.8	-48.0			
										M I S M A T C H			78.8	48.0			
32417	BQ-U3-M	0.48	1	0.873	-10.8	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31417	BQ-U3	0.48	1	-39.6	-24.1			
										M I S M A T C H			39.6	24.1			
32603	3BRB-M	0.48	1	0.891	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	31603	3BRB	0.48	1	-13.5	-8.2			
										M I S M A T C H			13.5	8.2			
32605	3BH-M	0.48	1	0.842	-10.6	0.0	0.0	0.0									
			1	0.40		0.0	0.0	0.0	31605	3BH	0.48	1	-17.4	-10.6			
										M I S M A T C H			17.4	10.6			
32607	3BJ-M	0.48	1	0.888	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	31607	3BJ	0.48	1	-52.2	-31.8			

Case No: E4C-082 CCN9W-3 Rev. 1  
RE: LPM 9-30-94 IRE: PL 10-5-94  
Sheet No. 707



Sheet No.	<u>408</u>
Case No:	<u>E4C-082 CCN: N-3</u>
Rev.	<u>1</u>
RE:	<u>Lpm 9-30-94</u>
IRE:	<u>Ad 10-5-94</u>

52.2 31.8

M I S M A T C H

PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS/E  
CASE IV.BX - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBX|LF-2\_IVBX.SAV

THU, SEP 15 1994 13:24

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A I KVA
32614	3BZ-M	0.48	1	0.889	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	31614	3BZ	0.48	1	1	-52.0	-31.7		
										M I S M A T C H				52.0	31.7		
32618	BS-U3-M	0.48	1	0.883	-10.0	0.0	0.0	0.0	31618	PS-U3	0.48	1	1	-39.6	-24.1		
			1	0.42		0.0	0.0	0.0		M I S M A T C H				39.6	24.1		
33403	3BRA-S	0.48	1	0.881	-10.6	0.0	8.5	0.0	31403	3BRA	0.48	1	1	-8.5	-5.3		
			1	0.42		0.0	5.3	0.0									
33407	3BD-S	0.48	1	0.818	-11.5	0.0	8.5	0.0	31407	3BD	0.48	1	1	-8.5	-5.3		
			1	0.39		0.0	5.3	0.0									
33414	3BE-S	0.48	1	0.879	-10.6	0.0	89.4	0.0	31414	3BE	0.48	1	1	-89.4	-64.1		
			1	0.42		0.0	64.1	0.0									
33415	3BY-S	0.48	1	0.879	-10.7	0.0	112.5	0.0	31415	3BY	0.48	1	1	-112.5	-78.1		
			1	0.42		0.0	78.1	0.0									
33417	BQ-U3-S	0.48	1	0.873	-10.8	0.0	75.9	0.0	31417	BQ-U3	0.48	1	1	-75.9	-45.8		
			1	0.42		0.0	45.8	0.0									
33603	3BRB-S	0.48	1	0.891	-9.9	0.0	8.5	0.0	31603	3BRB	0.48	1	1	-8.5	-5.3		
			1	0.43		0.0	5.3	0.0									
33605	3BH-S	0.48	1	0.842	-10.6	0.0	8.5	0.0	31605	3BH	0.48	1	1	-8.5	-5.3		
			1	0.40		0.0	5.3	0.0									
33607	3BJ-S	0.48	1	0.888	-9.9	0.0	79.2	0.0	31607	3BJ	0.48	1	1	-79.2	-57.8		
			1	0.43		0.0	57.8	0.0									
33614	3BZ-S	0.48	1	0.889	-9.9	0.0	124.4	0.0	31614	3BZ	0.48	1	1	-124.4	-83.9		
			1	0.43		0.0	83.9	0.0									
33618	BS-U3-S	0.48	1	0.883	-10.0	0.0	42.6	0.0	31618	BS-U3	0.48	1	1	-42.6	-23.4		
			1	0.42		0.0	23.4	0.0									
34412	3A274	0.46	1	0.850	-11.4	0.0	0.0	0.0	31407	3BD	0.48	1	1	-41.6	-29.4	1.043LK	
			1	0.39		0.0	0.0	0.0		M I S M A T C H				41.6	29.4		
34413	3A275	0.46	1	0.847	-11.3	0.0	0.0	0.0	31407	3BD	0.48	1	1	-41.6	-29.4	1.043LK	
			1	0.39		0.0	0.0	0.0		M I S M A T C H				41.6	29.4		
34417	P162-U3	0.46	1	0.897	-10.4	0.0	0.0	0.0	31417	D2-U3	0.48	1	1	-24.2	-15.9	1.043LK	
			1	0.41		0.0	0.0	0.0		M I S M A T C H				24.2	15.9		
34421	3E550	0.46	1	0.846	-11.3	0.0	0.0	0.0	31407	3BD	0.48	1	1	-31.7	-21.1	1.043LK	
			1	0.39		0.0	0.0	0.0		M I S M A T C H				31.7	21.1		
34422	3E546	0.46	1	0.848	-11.4	0.0	0.0	0.0	31407	3BD	0.48	1	1	-31.7	-21.1	1.043LK	
			1	0.39		0.0	0.0	0.0		M I S M A T C H				31.7	21.1		

Case No: E4C-082 CCN9N-3 Rev. 1  
RE: Lpm 9-30-94 IRE: RL 10-5-94  
Sheet No. 409

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI KVA
34434	3P009	0.46	1 0.905	-10.5	0.0	0.0	0.0	31415	3BY	0.48	1	-22.6	-11.2	1.043LK		
			1 0.42		0.0	0.0	0.0		M I S M A T C H			22.6	11.2			
34606	3E547	0.46	1 0.873	-10.4	0.0	0.0	0.0	31005	3BH	0.48	1	-31.8	-21.3	1.043LK		
			1 0.40		0.0	0.0	0.0		M I S M A T C H			31.8	21.3			
34607	3E549	0.46	1 0.873	-10.4	0.0	0.0	0.0	31605	3BH	0.48	1	-31.8	-21.3	1.043LK		
			1 0.40		0.0	0.0	0.0		M I S M A T C H			31.8	21.3			
34611	3A276	0.46	1 0.876	-10.5	0.0	0.0	0.0	31605	3BH	0.48	1	-41.8	-29.3	1.043LK		
			1 0.40		0.0	0.0	0.0		M I S M A T C H			41.8	29.3			
34612	3A277	0.46	1 0.873	-10.4	0.0	0.0	0.0	31605	3BH	0.48	1	-41.8	-29.3	1.043LK		
			1 0.40		0.0	0.0	0.0		M I S M A T C H			41.8	29.3			
34618	P160-U3	0.46	1 0.915	-9.8	0.0	0.0	0.0	31618	BS-U3	0.48	1	-24.3	-16.1	1.043LK		
			1 0.42		0.0	0.0	0.0		M I S M A T C H			24.3	16.1			
34622	3P010	0.46	1 0.913	-9.7	0.0	0.0	0.0	31614	3BZ	0.48	1	-22.6	-11.2	1.043LK		
			1 0.42		0.0	0.0	0.0		M I S M A T C H			22.6	11.2			

Case No: E4C-082 CCN/9V-3 Rev. 1  
Sheet No. 710  
RE: Lpwr 9-30-94  
IRE: Bp 10-5-94

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./ PRELIM. CCN NO. N-3 PAGE 411 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9


Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**APPENDIX 9.1.6**

CASE IVBY




Initial Condition Power Flow (Steady State) Report  
Post Accident Condition Power Flow (Steady State) Report




PSS/E RELEASE 19.0





CASE IV.BY - INITIAL STEADY STATE CONDITION  
 OKB200:CMURIEL.E4C-082-AGA.CASE\_IVBYJLF-1\_IVBY.SAV  
 THU, SEP 15 1994 11:17





Sheet No. 4/3  
 Calc No: E4C-082 CCN9N-3 Rev. 1  
 RE: 4m 9-30-94 IRE: Rd 10-5-99





Sheet No. 414  
Calc No: E4C-082 CCN-3 Rev. 1  
RE: Lpm 9-30-94 IRE: dl 12-5-99



BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I KVA
1	SYSTEM	230	1 0.948	0.0	22693.3	0.0	0.0									
			1 218.0		13410.3R	0.0	0.0	41	2XMS	22.0	1	1	22693.313410.3	0.973UN		
24	2A04	4.16	1 0.981	-3.2	0.0	0.0	0.0									
			1 4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	2.1	-0.5		
								44	2XU1Y	4.16	1	1	-3576.1	-2086.7		
								2403	2P012	4.16	1	1	353.0	180.1		
								2404	2P141	4.16	1	1	675.5	308.1		
								2406	2P025-A	4.16	1	1	477.3	270.2		
								2407	2P015	4.16	1	1	389.2	199.1		
								2408	2P017	4.16	1	1	405.2	173.1		
								2411	2P307	4.16	1	1	331.2	214.1		
								2420	2B04X	4.16	1	1	942.7	742.6		
26	2A06	4.16	1 0.984	-2.9	0.0	0.0	0.0									
			1 4.09		0.0	0.0	0.0	34	2A06	4.16	1	1	-1.0	-0.5		
								46	2XU1X	4.16	1	1	-3537.2	-2061.6		
								2603	2P504	4.16	1	1	675.4	308.0		
								2604	2P013	4.16	1	1	353.0	180.1		
								2606	2P025-B	4.16	1	1	477.3	270.2		
								2607	2P016	4.16	1	1	389.2	199.1		
								2608	2P019	4.16	1	1	405.1	173.2		
								2611	2P114	4.16	1	1	331.3	214.2		
								2620	2B06X	4.16	1	1	905.8	717.1		
									M I S M A T C H			1.2	0.2			
34	3A04	4.16	1 0.981	-3.2	0.0	0.0	0.0									
			1 4.08		0.0	0.0	0.0	24	2A04	4.16	1	1	-2.1	0.5		
								3402	E336-U3	4.16	1	1	-0.1	0.0		
								3403	3P012	4.16	1	1	0.1	0.0		
								3404	3P141	4.16	1	1	0.0	0.0		
								3405	3P024	4.16	1	1	0.0	0.0		
								3407	3P015	4.16	1	1	0.0	0.0		
								3408	3P017	4.16	1	1	0.0	0.0		
								3409	3P018-A	4.16	1	1	0.1	0.0		
								3411	3P307	4.16	1	1	0.1	0.0		
								3412	3P014	4.16	1	1	0.0	0.0		
								3417	3B04X	4.16	1	1	0.6	-0.1		
									M I S M A T C H			1.3	-0.5			
36	3A06	4.16	1 0.984	-2.9	0.0	0.0	0.0									
			1 4.09		0.0	0.0	0.0	26	2A06	4.16	1	1	1.0	0.5		
								3602	E335-U3	4.16	1	1	0.0	0.0		
								3604	3P013	4.16	1	1	0.0	0.0		
								3606	3P025-B	4.16	1	1	0.0	-0.1		
								3607	3P016	4.16	1	1	0.0	0.0		
								3608	3P019	4.16	1	1	0.0	0.0		
								3609	3P018-B	4.16	1	1	-0.1	0.0		
								3611	3P114	4.16	1	1	0.0	0.0		
								3612	3P504	4.16	1	1	0.0	0.0		
								3619	3B06X	4.16	1	1	0.4	0.0		
									M I S M A T C H			-1.2	-0.2			

Case No: E4C-082 CCN SW-3 Rev. 1  
 RE: Lpm 9-30-94 RE: DL 10-5-94  
 Sheet No. 2/15



BUS DATA									LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
41	2XMS	22.0	1	0.921	-0.1	0.0	0.0	0.0	1	SYSTEM	230	1	1	*****			0.973LK
			1	20.25		0.0	0.0	0.0	45	2XU1*	4.36	1	1	22692.413333.4			0.950LK
									M I S M A T C H				0.1	1.1			
44	2XU1Y	4.16	1	0.983	-3.2	0.0	8384.0	0.0	24	2A04	4.16	1	1	3581.6	2095.1		
			1	4.09		0.0	4067.0	0.0	45	2XU1*	4.36	1	1	*****	-6161.8		1.048LK
45	2XU1*	4.36	1	0.968	-0.2	0.0	0.0	0.0	41	2XMS	22.0	1	1	*****			0.950UN
			1	4.22		0.0	0.0	0.0	44	2XU1Y	4.16	1	1	12007.9	6984.4		1.048UN
									40	2XU1X	4.16	1	1	10682.5	6297.5		1.048UN
									M I S M A T C H				-0.1	2.0			
46	2XU1X	4.16	1	0.986	-2.8	0.0	7106.0	0.0	26	2A06	4.16	1	1	3542.7	2070.1		
			1	4.10		0.0	3572.0	0.0	45	2XU1*	4.36	1	1	*****	-5642.0		1.048LK
214	2B04	0.48	1	0.924	-6.8	0.0	0.0	0.0	2420	2B04X	4.16	1	1	-928.3	-641.9		0.999UN
			1	0.44		0.0	0.0	0.0	21403	2BRA	0.48	1	1	23.0	15.2		
									21405	2P191-A	0.46	1	1	57.6	35.3		1.043UN
									21407	2BD	0.48	1	1	195.6	136.2		
									21409	2A071	0.46	1	1	56.4	37.5		1.043UN
									21110	2E399	0.46	1	1	61.8	41.4		1.043UN
									21411	2E401	0.46	1	1	62.0	41.5		1.043UN
									21413	2P190	0.46	1	1	57.6	35.3		1.043UN
									21414	2BE	0.48	1	1	134.8	115.2		
									21415	2BY	0.48	1	1	222.7	146.4		
									21419	2A074	0.46	1	1	56.8	37.7		1.043UN
216	2B06	0.48	1	0.929	-6.3	0.0	0.0	0.0	2620	2B06X	4.16	1	1	-892.4	-624.2		0.999UN
			1	0.45		0.0	0.0	0.0	21003	2BRB	0.48	1	1	23.0	15.2		
									21605	2DH	0.48	1	1	192.7	133.2		
									21607	2BJ	0.48	1	1	124.6	108.8		
									21609	2A072	0.46	1	1	56.6	37.6		1.043UN
									21519	2E400	0.46	1	1	62.1	41.6		1.043UN
									21611	2E402	0.46	1	1	62.6	41.9		1.043UN
									21613	2P192	0.46	1	1	57.8	35.5		1.043UN
									21011	2BZ	0.48	1	1	198.2	137.2		
									21617	2P191-B	0.46	1	1	57.9	35.5		1.043UN
									21010	2L073	0.46	1	1	57.0	37.8		1.043UN

Cell No: E4C-082 CCN 9 Sheet No: 416  
 RE: Open 9-30-94 IRE: RD 10-5-94 Rev: 1

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KVA
314	3B04	0.48	1	0.982	-3.2	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	3117	3B04X	4.16	1	1	0.0	0.1	0.999UN
									31402	3E61N	0.48	1	1	0.0	0.0	
									31403	3BRA	0.48	1	1	0.0	0.0	
									31405	3P191-A	0.46	1	1	0.0	0.0	1.043UN
									31407	3DD	0.48	1	1	0.0	0.0	
									31409	3A071	0.46	1	1	0.0	0.0	1.043UN
									31410	3E399	0.46	1	1	0.0	0.0	1.043UN
									31411	3E401	0.46	1	1	0.0	0.0	1.043UN
									31413	3P190	0.46	1	1	0.0	0.0	1.043UN
									31414	3BE	0.48	1	1	0.0	0.0	
									31415	3BY	0.48	1	1	0.0	0.0	
									31417	BQ-U3	0.48	1	1	0.0	0.0	
									31418	E418-U3	0.46	1	1	0.0	0.0	1.043UN
									31419	3A074	0.46	1	1	0.0	0.0	1.043UN
316	3B06	0.48	1	0.985	-2.9	0.0	0.0	0.0								
			1	0.47		0.0	0.0	0.0	31613	3D06X	4.16	1	1	0.0	0.0	0.999UN
									31602	3E62N	0.48	1	1	0.0	0.0	
									31603	3DRB	0.48	1	1	0.0	0.0	
									31605	3DH	0.48	1	1	0.0	0.0	
									31607	3DJ	0.48	1	1	0.0	0.0	
									31609	3A072	0.46	1	1	0.0	0.0	1.043UN
									31610	3E400	0.46	1	1	0.0	0.0	1.043UN
									31611	3E402	0.46	1	1	0.0	0.0	1.043UN
									31613	3P192	0.46	1	1	0.0	0.0	1.043UN
									31614	3DZ	0.48	1	1	0.0	0.0	
									31615	E419-U3	0.46	1	1	0.0	0.0	1.043UN
									31617	3P191-B	0.46	1	1	0.0	0.0	1.043UN
									31618	BS-U3	0.48	1	1	0.0	0.0	
									31619	3A073	0.46	1	1	0.0	0.0	1.043UN
2403	2P012	4.16	1	0.980	-3.2	0.0	352.9	0.0								
			1	4.08		0.0	180.0	0.0	24	2A04	4.16	1	1	-352.8	-180.0	
2404	2P141	4.16	1	0.979	-3.3	0.0	674.5	0.0								
			1	4.07		0.0	307.3	0.0	24	2A04	4.16	1	1	-674.5	-307.3	
2406	2P025-A	4.16	1	0.980	-3.2	0.0	477.0	0.0								
			1	4.08		0.0	270.0	0.0	24	2A04	4.16	1	1	-477.0	-270.0	
2407	2P015	4.16	1	0.980	-3.2	0.0	389.0	0.0								
			1	4.08		0.0	199.0	0.0	24	2A04	4.16	1	1	-389.0	-199.0	
2408	2P017	4.16	1	0.980	-3.2	0.0	405.0	0.0								
			1	4.08		0.0	173.0	0.0	24	2A04	4.16	1	1	-405.0	-173.0	
2411	2P307	4.16	1	0.980	-3.2	0.0	331.0	0.0								
			1	4.08		0.0	214.0	0.0	24	2A04	4.16	1	1	-331.0	-214.0	
2420	2B04X	4.16	1	0.981	-3.2	0.0	0.0	0.0								
			1	4.08		0.0	0.0	0.0	24	2A04	4.16	1	1	-942.5	-742.4	
									214	2B04	0.48	1	1	942.6	742.2	0.999LK

Case No: E4C-082 CCN 9M-3  
Rev: 1  
Stress No: 417  
RE: Lpm 9-30-94  
IRE: RL 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-1\_IVBY.SAV

THU, SEP 15 1994 11:18

BUS DATA									LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA
2603	2P504	4.16	1	0.982	-2.9	0.0	674.5	0.0									
			1	4.09		0.0	307.3	0.0	26	2A06	4.16	1	1	-674.5	-307.3		
2604	2P013	4.16	1	0.983	-2.9	0.0	352.9	0.0									
			1	4.09		0.0	180.0	0.0	26	2A06	4.16	1	1	-352.9	-180.0		
2606	2P025-B	4.16	1	0.983	-2.9	0.0	477.0	0.0									
			1	4.09		0.0	270.0	0.0	26	2A06	4.16	1	1	-477.0	-270.0		
2607	2P016	4.16	1	0.983	-2.9	0.0	389.0	0.0									
			1	4.09		0.0	199.0	0.0	26	2A06	4.16	1	1	-389.0	-199.0		
2608	2P019	4.16	1	0.983	-2.9	0.0	405.0	0.0									
			1	4.09		0.0	173.0	0.0	26	2A06	4.16	1	1	-404.9	-173.1		
2611	2P114	4.16	1	0.983	-2.9	0.0	331.0	0.0									
			1	4.09		0.0	214.0	0.0	26	2A06	4.16	1	1	-331.1	-214.0		
2620	2B06X	4.16	1	0.984	-2.9	0.0	0.0	0.0									
			1	4.09		0.0	0.0	0.0	26	2A06	4.16	1	1	-905.6	-717.0		
									216	2B06	0.48	1	1	905.6	716.6	0.999LK	
3402	E336-U3	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	0.1	0.0		
3403	3P012	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	-0.1	0.0		
3404	3P141	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0		
3405	3P024	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0		
3407	3P015	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0		
3408	3P017	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0		
3409	3P018-A	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	-0.1	0.0		
3411	3P307	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	-0.1	0.0		
3412	3T014	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	0.0	0.0		
3417	3B04X	4.16	1	0.981	-3.2	0.0	0.0	0.0									
			1	4.08		0.0	0.0	0.0	34	3A04	4.16	1	1	-0.6	0.1		
									314	3B04	0.48	1	1	0.0	-0.1	0.999LK	

CASE NO: E4C-082 CCN 9N-3  
 RE: Lpm 9-30-94 IRE: BL 10-5-94  
 SHEET NO. 418  
 REV. 1

Sheet No. 419  
Calc No: EAC-082 CCN 9N-3 Rev. 1  
RE: Lpm 9-30-94 IRE: Bl 10-5-94

M I S M A T C H 0.6 0.0

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]L-1\_IVBY.SAV

THU, SEP 15 1994 11:18

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I KVA
3602	E335-U3	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.0		
3604	3P013	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.0		
3606	3P025-B	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.1		
3607	3P016	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.0		
3608	3P019	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.0		
3609	3P018-B	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.1	0.0		
3611	3P114	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.0		
3612	3P504	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	0.0	0.0		
3619	3B06X	4.16	1	0.984	-2.9	0.0	0.0	0.0								
			1	4.09		0.0	0.0	0.0	36 3A06	4.16	1	1	-0.4	0.0		
									316 2D06	0.48	1	1	0.0	0.0	0.999LK	
21403	2BRA	0.48	1	0.923	-6.8	0.0	0.0	0.0								
			1	0.44		0.0	0.0	0.0	214 2B04	0.48	1	1	-23.0	-15.2		
									22403 2BRA-M	0.48	1	1	14.5	10.0		
									23403 2BRA-S	0.48	1	1	8.5	5.3		
21405	2F191-A	0.46	1	0.954	-6.8	0.0	57.0	0.0								
			1	0.44		0.0	35.0	0.0	214 2B04	0.48	1	1	-57.0	-35.0	1.043LK	
21407	2BD	0.48	1	0.860	-7.7	0.0	0.0	0.0								
			1	0.41		0.0	0.0	0.0	214 2B04	0.48	1	1	-184.0	-123.9		
									22407 2BD-M	0.48	1	1	18.3	13.6		
									23407 2BD-S	0.48	1	1	8.5	5.3		
									24412 2A274	0.46	1	1	45.3	30.3	1.043UN	
									24413 2A275	0.46	1	1	45.5	30.4	1.043UN	
									24421 2E550	0.46	1	1	33.2	22.2	1.043UN	
									24422 2E546	0.46	1	1	33.2	22.2	1.043UN	
21409	2A071	0.46	1	0.943	-6.5	0.0	55.0	0.0								
			1	0.43		0.0	37.0	0.0	214 2B04	0.48	1	1	-55.0	-37.0	1.043LK	
21410	2E399	0.46	1	0.952	-6.7	0.0	61.0	0.0								
			1	0.44		0.0	41.0	0.0	211 2B04	0.48	1	1	-61.0	-41.0	1.043LK	
21411	2E401	0.46	1	0.949	-6.7	0.0	61.0	0.0								
			1	0.44		0.0	41.0	0.0	214 2B04	0.48	1	1	-61.0	-41.0	1.043LK	

Case No: E4C-082 CAN N-3  
 RE: LPM 9-30-94  
 RE: RL 10-5-94  
 Sheet No. 420  
 Rev. 1

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]L7-1\_IVBY.SAV

THU, SEP 15 1994 11:18

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
21413	2P190	0.46	1	0.955	-6.8	0.0	57.0	0.0									
			1	0.44		0.0	35.0	0.0	214	2B04	0.48	1	1	-57.0	-35.0	1.043LK	
21414	2BE	0.48	1	0.921	-6.8	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	214	2B04	0.48	1	1	-134.5	-114.9		
									22414	2BE-M	0.48	1	1	45.0	50.8		
									23414	2BE-S	0.48	1	1	89.4	64.1		
21415	2BY	0.48	1	0.920	-6.9	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	214	2B04	0.48	1	1	-222.2	-145.5		
									22415	2BY-M	0.48	1	1	86.2	55.4		
									23415	2BY-S	0.48	1	1	112.5	78.1		
									24434	2P009	0.46	1	1	23.6	12.0	1.043UN	
21419	2A074	0.46	1	0.938	-6.4	0.0	55.0	0.0									
			1	0.43		0.0	37.0	0.0	214	2B04	0.48	1	1	-55.0	-37.0	1.043LK	
21603	2BRB	0.48	1	0.928	-6.3	0.0	0.0	0.0									
			1	0.45		0.0	0.0	0.0	216	2B06	0.48	1	1	-23.0	-15.2		
									22603	2BRB-M	0.48	1	1	14.5	10.0		
									23603	2BRB-S	0.48	1	1	8.5	5.3		
21605	2BH	0.48	1	0.879	-7.0	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	216	2B06	0.48	1	1	-183.9	-123.9		
									22605	2BH-M	0.48	1	1	18.3	13.6		
									23605	2BH-S	0.48	1	1	8.5	5.3		
									24600	2E547	0.46	1	1	33.1	22.1	1.043UN	
									24607	2E549	0.46	1	1	33.2	22.2	1.043UN	
									24611	2A276	0.46	1	1	45.3	30.3	1.043UN	
									24612	2A277	0.46	1	1	45.5	30.4	1.043UN	
21607	2BJ	0.48	1	0.926	-6.3	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	216	2B06	0.48	1	1	-124.2	-108.5		
									22607	2BJ-M	0.48	1	1	45.0	50.7		
									23607	2BJ-S	0.48	1	1	79.2	57.8		
21609	2A072	0.46	1	0.946	-6.0	0.0	55.0	0.0									
			1	0.44		0.0	37.0	0.0	216	2B06	0.48	1	1	-55.0	-37.0	1.043LK	
21610	2E400	0.46	1	0.952	-6.2	0.0	61.0	0.0									
			1	0.44		0.0	41.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK	
21611	2E402	0.46	1	0.946	-6.2	0.0	61.0	0.0									
			1	0.44		0.0	41.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK	
21613	2P192	0.46	1	0.956	-6.3	0.0	57.0	0.0									
			1	0.44		0.0	35.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK	
21614	2BZ	0.48	1	0.926	-6.4	0.0	0.0	0.0									
			1	0.44		0.0	0.0	0.0	216	2B06	0.48	1	1	-197.9	-136.6		
									22614	2BZ-M	0.48	1	1	50.0	40.7		
									23614	2BZ-S	0.48	1	1	124.4	83.9		
									24622	2P010	0.46	1	1	23.6	12.0	1.043UN	
21617	2P191-B	0.46	1	0.955	-6.3	0.0	57.0	0.0									
			1	0.44		0.0	35.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK	

Case No: E4C-082 CCN 9N-3  
Rev: 1  
Sheet No: 421  
RE: Lpm 9-30-94 IRE: BJ 10-5-94

BUS DATA									LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I	KVA
21619	2A073	0.46	1 0.939	-5.9	0.0	55.0	0.0										
			1 0.43		0.0	37.0	0.0	216	2B06	0.48	1	1	-55.0	-37.0	1.043LK		
22403	2BRA-M	0.48	1 0.923	-6.8	0.0	14.4	0.0										
			1 0.44		0.0	10.0	0.0	21403	2BRA	0.48	1	1	-14.5	-10.0			
22407	2BD-M	0.48	1 0.860	-7.7	0.0	18.3	0.0										
			1 0.41		0.0	13.6	0.0	21407	2BD	0.48	1	1	-18.3	-13.6			
22414	2BE-M	0.48	1 0.921	-6.8	0.0	45.0	0.0										
			1 0.44		0.0	50.8	0.0	21414	2BE	0.48	1	1	-45.0	-50.8			
22415	2BY-M	0.48	1 0.920	-6.9	0.0	86.2	0.0										
			1 0.44		0.0	55.4	0.0	21415	2BY	0.48	1	1	-86.2	-55.4			
22603	2BRB-M	0.48	1 0.928	-6.3	0.0	14.4	0.0										
			1 0.45		0.0	10.0	0.0	21603	2BRB	0.48	1	1	-14.5	-10.0			
22605	2BH-M	0.48	1 0.879	-7.0	0.0	18.3	0.0										
			1 0.42		0.0	13.6	0.0	21605	2BH	0.48	1	1	-18.3	-13.6			
22607	2BJ-M	0.48	1 0.926	-6.3	0.0	45.0	0.0										
			1 0.44		0.0	50.7	0.0	21607	2BJ	0.48	1	1	-45.0	-50.7			
22614	2BZ-M	0.48	1 0.926	-6.4	0.0	50.0	0.0										
			1 0.44		0.0	40.7	0.0	21614	2BZ	0.48	1	1	-50.0	-40.7			
23403	2BRA-S	0.48	1 0.923	-6.8	0.0	8.5	0.0										
			1 0.44		0.0	5.3	0.0	21103	2BRA	0.48	1	1	-8.5	-5.3			
23407	2BD-S	0.48	1 0.860	-7.7	0.0	8.5	0.0										
			1 0.41		0.0	5.3	0.0	21407	2BD	0.48	1	1	-8.5	-5.3			
23414	2BE-S	0.48	1 0.921	-6.8	0.0	89.4	0.0										
			1 0.44		0.0	64.1	0.0	21414	2BE	0.48	1	1	-89.4	-64.1			
23415	2BY-S	0.48	1 0.920	-6.9	0.0	112.5	0.0										
			1 0.44		0.0	78.1	0.0	21415	2BY	0.48	1	1	-112.5	-78.1			
23603	2BRB-S	0.48	1 0.928	-6.3	0.0	8.5	0.0										
			1 0.45		0.0	5.3	0.0	21603	2BRB	0.48	1	1	-8.5	-5.3			
23605	2BH-S	0.48	1 0.879	-7.0	0.0	8.5	0.0										
			1 0.42		0.0	5.3	0.0	21605	2BH	0.48	1	1	-8.5	-5.3			
23607	2BJ-S	0.48	1 0.926	-6.3	0.0	79.2	0.0										
			1 0.44		0.0	57.8	0.0	21607	2BJ	0.48	1	1	-79.2	-57.8			
23614	2BZ-S	0.48	1 0.926	-6.4	0.0	124.4	0.0										
			1 0.44		0.0	83.9	0.0	21614	2BZ	0.48	1	1	-124.4	-83.9			

Case No: E4C-082 CCN9N-3 Rev: 1  
 Date: Sep 9-30-94  
 RE: PL 10-5-94  
 Sheet No: 422

BUS DATA								LINE DATA											
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA	
24412	2A274	0.46	1	0.894	-7.6	0.0	45.1	0.0											
			1	0.41		0.0	30.3	0.0	21407	2BD	0.48	1	1	-45.1	-30.3	1.043LK			
24413	2A275	0.46	1	0.891	-7.5	0.0	45.1	0.0											
			1	0.41		0.0	30.3	0.0	21407	2BD	0.48	1	1	-45.1	-30.3	1.043LK			
24421	2E550	0.46	1	0.890	-7.5	0.0	32.9	0.0											
			1	0.41		0.0	22.1	0.0	21407	2BD	0.48	1	1	-32.9	-22.1	1.043LK			
24422	2E546	0.46	1	0.891	-7.5	0.0	32.9	0.0											
			1	0.41		0.0	22.1	0.0	21407	2BD	0.48	1	1	-32.9	-22.1	1.043LK			
24434	2P009	0.46	1	0.947	-6.7	0.0	23.2	0.0											
			1	0.44		0.0	11.9	0.0	21415	2BY	0.48	1	1	-23.2	-11.9	1.043LK			
24606	2E547	0.46	1	0.912	-6.8	0.0	32.9	0.0											
			1	0.42		0.0	22.1	0.0	21605	2BH	0.48	1	1	-32.9	-22.1	1.043LK			
24607	2E549	0.46	1	0.911	-6.8	0.0	32.9	0.0											
			1	0.42		0.0	22.1	0.0	21605	2BH	0.48	1	1	-32.9	-22.1	1.043LK			
24611	2A276	0.46	1	0.914	-6.9	0.0	45.1	0.0											
			1	0.42		0.0	30.3	0.0	21605	2DH	0.48	1	1	-45.1	-30.3	1.043LK			
24612	2A277	0.46	1	0.912	-6.8	0.0	45.1	0.0											
			1	0.42		0.0	30.3	0.0	21605	2CH	0.48	1	1	-45.1	-30.3	1.043LK			
24622	2P010	0.46	1	0.953	-6.1	0.0	23.2	0.0											
			1	0.44		0.0	11.9	0.0	21607	2BZ	0.48	1	1	-23.2	-11.9	1.043LK			
31402	3E61N	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0				
31403	3BRA	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0				
									32103	3BRA-M	0.48	1	1	0.0	0.0				
									33403	3BRA-S	0.48	1	1	0.0	0.0				
31405	3P191-A	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK			
31407	3BD	0.48	1	0.982	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0				
									32407	3BD-M	0.48	1	1	0.0	0.0				
									33407	3BD-S	0.48	1	1	0.0	0.0				
									34412	3A274	0.46	1	1	0.0	0.0	1.043UN			
									34413	3A275	0.46	1	1	0.0	0.0	1.043UN			
									34421	3E550	0.46	1	1	0.0	0.0	1.043UN			
									34422	3E546	0.46	1	1	0.0	0.0	1.043UN			
31409	3A071	0.46	1	1.025	-3.2	0.0	0.0	0.0											
			1	0.47		0.0	0.0	0.0	314	3B04	0.48	1	1	0.0	0.0	1.043LK			

Case No: E4C-082  
 Case No: CCN-3  
 Rev: 1  
 Date: 10-5-94  
 Sheet No: 423



BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
31410	3E399	0.46	1 1.025 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0	1.043LK			
31411	3E401	0.46	1 1.025 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0	1.043LK			
31413	3P190	0.46	1 1.025 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0	1.043LK			
31414	3BE	0.48	1 0.982 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0				
								32414	3BE-M	0.48	1 1	0.0	0.0				
								33414	3BE-S	0.48	1 1	0.0	0.0				
31415	3BY	0.48	1 0.982 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0				
								32415	3BY-M	0.48	1 1	0.0	0.0				
								33415	3BY-S	0.48	1 1	0.0	0.0				
								34434	3P009	0.46	1 1	0.0	0.0	1.043UN			
31417	BQ-U3	0.48	1 0.982 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0				
								32417	BQ-U3-M	0.48	1 1	0.0	0.0				
								33417	BQ-U3-S	0.48	1 1	0.0	0.0				
								34417	P162-U3	0.46	1 1	0.0	0.0	1.043UN			
31418	E418-U3	0.46	1 1.025 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0	1.043LK			
31419	3A074	0.46	1 1.025 1 0.47	-3.2	0.0 0.0	0.0 0.0	0.0	314	3B04	0.48	1 1	0.0	0.0	1.043LK			
31602	3E62N	0.48	1 0.985 1 0.47	-2.9	0.0 0.0	0.0 0.0	0.0	316	3B06	0.48	1 1	0.0	0.0				
31603	3BRE	0.48	1 0.985 1 0.47	-2.9	0.0 0.0	0.0 0.0	0.0	316	3B06	0.48	1 1	0.0	0.0				
								32603	3DRB-M	0.48	1 1	0.0	0.0				
								33603	3DRB-S	0.48	1 1	0.0	0.0				
31605	3BH	0.48	1 0.985 1 0.47	-2.9	0.0 0.0	0.0 0.0	0.0	316	3B06	0.48	1 1	0.0	0.0				
								32605	3BH-M	0.48	1 1	0.0	0.0				
								33605	3BH-S	0.48	1 1	0.0	0.0				
								34606	3E547	0.46	1 1	0.0	0.0	1.043UN			
								34607	3E549	0.46	1 1	0.0	0.0	1.043UN			
								34611	3A276	0.46	1 1	0.0	0.0	1.043UN			
								34612	3A277	0.46	1 1	0.0	0.0	1.043UN			
31607	3BJ	0.48	1 0.985 1 0.47	-2.9	0.0 0.0	0.0 0.0	0.0	316	3B06	0.48	1 1	0.0	0.0				
								32607	3BJ-M	0.48	1 1	0.0	0.0				
								33607	3BJ-S	0.48	1 1	0.0	0.0				
31609	3A072	0.46	1 1.028 1 0.47	-2.9	0.0 0.0	0.0 0.0	0.0	316	3B06	0.48	1 1	0.0	0.0	1.043LK			

Case No: E4C-082 CCN 9N-3  
Date: Sep 9-30-94  
Page: 1  
Sheet No: 424  
Date: 8/10-5-94

BUS DATA								LINE DATA										
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	KT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
31610	3E400	0.46	1	1.028	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK		
31611	3E402	0.46	1	1.028	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK		
31613	3P192	0.46	1	1.028	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK		
31614	3BZ	0.48	1	0.985	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0			
									32624	3BZ-M	0.48	1	1	0.0	0.0			
									33624	3BZ-S	0.48	1	1	0.0	0.0			
									34622	3P010	0.46	1	1	0.0	0.0	1.043UN		
31615	E419-U3	0.46	1	1.028	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK		
31617	3P191-B	0.46	1	1.028	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK		
31618	BS-U3	0.48	1	0.985	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0			
									32618	BS-U3-M	0.48	1	1	0.0	0.0			
									33618	BS-U3-S	0.48	1	1	0.0	0.0			
									34613	P150-U3	0.46	1	1	0.0	0.0	1.043UN		
31619	3A073	0.46	1	1.028	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	316	3B06	0.48	1	1	0.0	0.0	1.043LK		
32403	3BRA-M	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31403	3BRA	0.48	1	1	0.0	0.0			
32407	3BD-M	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0			
32414	3BE-M	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31414	3BE	0.48	1	1	0.0	0.0			
32415	3BY-M	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31415	3BY	0.48	1	1	0.0	0.0			
32417	BQ-U3-M	0.48	1	0.982	-3.2	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	0.0	0.0			
32603	3BRB-M	0.48	1	0.985	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31603	3BRB	0.48	1	1	0.0	0.0			
32605	3BH-M	0.48	1	0.985	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31605	3BH	0.48	1	1	0.0	0.0			
32607	3BJ-M	0.48	1	0.985	-2.9	0.0	0.0	0.0										
			1	0.47		0.0	0.0	0.0	31607	3BJ	0.48	1	1	0.0	0.0			

RE: *Per 9-30-94*  
 RE: *10-5-94*  
 Case No: E4C-082  
 CCNDN-3 Rev. 1  
 Sheet No. 425

PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS/E  
CASE IV.BY - INITIAL STEADY STATE CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LP-1\_IVBY.SAV


THU, SEP 15 1994 11:18

BUS DATA								LINE DATA											
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	A KVA	
32614	3BZ-M	0.48	1	0.985	-2.9	0.0	0.0	0.0	31614	3BZ	0.48	1	1	0.0	0.0				
32618	BS-U3-M	0.48	1	0.985	-2.9	0.0	0.0	0.0	31618	BS-U3	0.48	1	1	0.0	0.0				
33403	3BRA-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31403	3BRA	0.48	1	1	0.0	0.0				
33407	3BD-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0				
33414	3BE-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31414	3BE	0.48	1	1	0.0	0.0				
33415	3BY-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31415	3BY	0.48	1	1	0.0	0.0				
33417	BQ-U3-S	0.48	1	0.982	-3.2	0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	0.0	0.0				
33603	3BRB-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31603	3BRB	0.48	1	1	0.0	0.0				
33605	3BH-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31605	3BH	0.48	1	1	0.0	0.0				
33607	3BJ-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31607	3BJ	0.48	1	1	0.0	0.0				
33614	3BZ-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31614	3BZ	0.48	1	1	0.0	0.0				
33618	BS-U3-S	0.48	1	0.985	-2.9	0.0	0.0	0.0	31618	BS-U3	0.48	1	1	0.0	0.0				
34412	3A274	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK			
34413	3A275	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK			
34417	P162-U3	0.46	1	1.025	-3.2	0.0	0.0	0.0	31417	P2-U3	0.48	1	1	0.0	0.0	1.043LK			
34421	3E550	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK			
34422	3E546	0.46	1	1.025	-3.2	0.0	0.0	0.0	31407	3BD	0.48	1	1	0.0	0.0	1.043LK			

Case No: E4C-082 CCN 9N-3 Rev. 1  
Sheet No. 426  
RE: Lpm 9-30-94  
IRE: AL 10-5-89



BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	KVA
34434	3P009	0.46	1	1.025	-3.2	0.0	0.0	0.0	31415	3BY	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
34606	3E547	0.46	1	1.028	-2.9	0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
34607	3E549	0.46	1	1.028	-2.9	0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
34611	3A276	0.46	1	1.028	-2.9	0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
34612	3A277	0.46	1	1.028	-2.9	0.0	0.0	0.0	31605	3BH	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0	31618	S-U3	0.48	1	0.0	0.0	1.043LK			
34618	P160-U3	0.46	1	1.028	-2.9	0.0	0.0	0.0	31618	S-U3	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0	31614	3BZ	0.48	1	0.0	0.0	1.043LK			
34622	3P010	0.46	1	1.028	-2.9	0.0	0.0	0.0	31614	3BZ	0.48	1	0.0	0.0	1.043LK			
			1	0.47		0.0	0.0	0.0										

RE: *Lpm 9-30-94*  
 Case No: *E4C-082 CNDN-3*  
 Sheet No: *427*  
 Rev: *1*  
 RE: *10-5-94*







Calc No: E4C-082 CCN<sup>9</sup>N-3 Rev. 1 Sheet No. 428  
 RE: Lim 9-30-94 IRE: Rd 10-5-99

PSS/E RELEASE 19.0



Sheet No. 429  
 Calc No: E4C-082 CCN N-3 Rev. 1  
 RE: Lpm 9-30-94 IRE: Bf 10-5-94



PSS/E RELEASE 19.0



CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
 OKB200:CMURIEL.E4C-082-AGA.CASE\_IVBYJLF-2\_IVBY.SAV  
 THU, SEP 15 1994 13:25



BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KVA
1	SYSTEM	230	1	0.947	-0.1	32504.4	0.0	0.0								
			1	217.8		20709.0R	0.0	0.0	41	2XMS	22.0	1	1	32504.4	20709.7	0.973UM
														0.0	-0.7	
24	2A04	4.16	1	0.960	-4.8	0.0	0.0	0.0								
			1	3.99		0.0	0.0	0.0	34	3A04	4.16	1	1	4930.5	2758.7	
									44	2XU1Y	4.16	1	1	-8507.7	-4853.5	
									2403	2P012	4.16	1	1	353.1	180.2	
									2404	2P141	4.16	1	1	675.6	308.1	
									2406	2P025-A	4.16	1	1	477.3	270.3	
									2407	2P015	4.16	1	1	389.2	199.2	
									2408	2P017	4.16	1	1	405.2	173.2	
									2411	2P307	4.16	1	1	331.2	214.2	
									2420	2B04X	4.16	1	1	944.6	748.9	
														0.9	0.8	
26	2A06	4.16	1	0.964	-4.4	0.0	0.0	0.0								
			1	4.01		0.0	0.0	0.0	36	3A06	4.16	1	1	4735.0	2621.1	
									46	2XU1X	4.16	1	1	-8274.3	-4688.8	
									2603	2P504	4.16	1	1	675.4	308.0	
									2604	2P013	4.16	1	1	353.1	180.1	
									2606	2P025-B	4.16	1	1	477.4	270.3	
									2607	2P016	4.16	1	1	389.2	199.2	
									2608	2P019	4.16	1	1	405.2	173.1	
									2611	2P114	4.16	1	1	331.2	214.2	
									2620	2B06X	4.16	1	1	907.5	722.5	
														0.4	0.4	
34	3A04	4.16	1	0.958	-4.8	0.0	0.0	0.0								
			1	3.99		0.0	0.0	0.0	24	2A04	4.16	1	1	-4925.7	-2752.8	
									3402	2B36-U3	4.16	1	1	448.3	247.3	
									3403	2P012	4.16	1	1	307.6	166.1	
									3404	2P141	4.16	1	1	670.6	297.6	
									3405	2P024	4.16	1	1	472.6	261.2	
									3407	2P015	4.16	1	1	378.2	188.3	
									3408	2P017	4.16	1	1	395.5	171.6	
									3409	2P018-A	4.16	1	1	395.5	171.6	
									3411	2P307	4.16	1	1	320.4	197.7	
									3412	2P014	4.16	1	1	128.0	78.0	
									3417	2B04X	4.16	1	1	1407.5	973.7	
														1.5	-0.2	
36	3A06	4.16	1	0.963	-4.4	0.0	0.0	0.0								
			1	4.01		0.0	0.0	0.0	26	2A06	4.16	1	1	-4731.6	-2616.9	
									3602	2B35-U3	4.16	1	1	448.3	247.8	
									3604	2P013	4.16	1	1	307.6	166.9	
									3606	2P025-B	4.16	1	1	472.5	262.3	
									3607	2P016	4.16	1	1	378.3	188.8	
									3608	2P019	4.16	1	1	395.5	172.0	
									3609	2P018-B	4.16	1	1	395.7	172.1	
									3611	2P114	4.16	1	1	320.3	198.7	
									3612	2P504	4.16	1	1	670.7	297.9	
									3619	2B06X	4.16	1	1	1340.6	909.5	
														1.9	1.0	

Calc No: E4C-082 CCNBN-3 Rev: 1  
 RE: *Per 9-30-94* IRE: *PL 10-5-94*  
 Sheet No. 431



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CRT	AREJ	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI KVA
41	2XMS	22.0	1	0.919	-0.3	0.0	0.0	0.0								
			1	20.22		0.0	0.0	0.0	1	SYSTEM	230	1	1	*****	0.973LK	
			1			0.0	0.0	0.0	45	2XU1*	4.36	1	1	32502.620547.0	0.950LK	
44	2XU1Y	4.16	1	0.965	-4.6	0.0	8384.0	0.0								
			1	4.01		0.0	4067.0	0.0	24	2A04	4.16	1	1	8539.6 4902.3		
			1			0.0		0.0	45	2XU1*	4.36	1	1	*****-8969.2	1.048LK	
45	2XU1*	4.36	1	0.966	-0.4	0.0	0.0	0.0								
			1	4.21		0.0	0.0	0.0	41	2XMS	22.0	1	1	*****	0.950UN	
									44	2XU1Y	4.16	1	1	17012.810698.9	1.048UN	
									46	2XU1X	4.16	1	1	15485.1 9741.4	1.048UN	
									M I S M A T C H			0.0	0.9			
46	2XU1X	4.16	1	0.969	-4.2	0.0	7106.0	0.0								
			1	4.03		0.0	3572.0	0.0	26	2A06	4.16	1	1	8305.3 4736.3		
									45	2XU1*	4.36	1	1	*****-8308.1	1.048LK	
214	2B04	0.48	1	0.901	-8.5	0.0	0.0	0.0								
			1	0.43		0.0	0.0	0.0	2420	2B04X	4.16	1	1	-929.5 -642.9	0.999UN	
									21403	2B04	0.48	1	1	23.0 15.2		
									21405	2P191-A	0.46	1	1	57.6 35.4	1.043UN	
									21407	2BD	0.48	1	1	196.4 136.9		
									21409	2A071	0.46	1	1	56.5 37.6	1.043UN	
									21410	2E399	0.46	1	1	61.8 41.5	1.043UN	
									21411	2E401	0.46	1	1	62.0 41.6	1.043UN	
									21413	2P190	0.46	1	1	57.8 35.3	1.043UN	
									21414	2BZ	0.48	1	1	134.9 115.3		
									21415	2BY	0.48	1	1	222.7 146.4		
									21419	2A074	0.46	1	1	56.9 37.7	1.043UN	
216	2B06	0.48	1	0.907	-7.9	0.0	0.0	0.0								
			1	0.44		0.0	0.0	0.0	2620	2B06X	4.16	1	1	-893.4 -625.0	0.999UN	
									21603	2B06	0.48	1	1	23.0 15.2		
									21605	2BH	0.48	1	1	193.2 133.7		
									21607	2BJ	0.48	1	1	124.6 108.8		
									21609	2A072	0.46	1	1	56.6 37.6	1.043UN	
									21610	2E400	0.46	1	1	62.2 41.7	1.043UN	
									21611	2E402	0.46	1	1	62.7 41.9	1.043UN	
									21612	2P192	0.46	1	1	57.9 35.5	1.043UN	
									21614	2BZ	0.48	1	1	198.3 137.2		
									21617	2P191-B	0.46	1	1	57.9 35.5	1.043UN	
									21619	2A073	0.46	1	1	57.1 37.8	1.043UN	

Calc No: E4C-082 CCN 9N-3 Rev. 1  
Sheet No. 432  
RE: *lpw* 9-30-94 IRE: *AD* 10-5-94

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER	RATING A		
			PU/KV		KW/KVAR	KW/KVAR	KW/KVAR							RATIO	ANGLE	%	KVA
314	3B04	0.48	1	0.881	-10.6	0.0	0.0	0.0	3417	3E04X	4.16	1	1	-1376.4	-759.3	0.999UN	
			1	0.42		0.0	0.0	0.0	31402	3E61N	0.48	1	1	202.6	2.8		
									31403	3BRA	0.48	1	1	22.0	13.5		
									31405	3P191-A	0.46	1	1	56.1	36.4	1.043UN	
									31407	3BD	0.48	1	1	185.1	129.3		
									31409	3A071	0.46	1	1	56.6	32.6	1.043UN	
									31410	3E399	0.46	1	1	60.5	42.0	1.043UN	
									31411	3E401	0.46	1	1	60.6	42.0	1.043UN	
									31413	3P190	0.46	1	1	55.9	36.4	1.043UN	
									31414	3BE	0.48	1	1	143.1	96.8		
									31415	3BY	0.48	1	1	214.6	138.0		
									31417	BQ-U3	0.48	1	1	141.3	87.1		
									31418	L418-U3	0.46	1	1	121.0	69.8	1.043UN	
									31419	3A074	0.46	1	1	56.9	32.6	1.043UN	
316	3B06	0.48	1	0.891	-9.9	0.0	0.0	0.0	3619	3B06X	4.16	1	1	-1313.1	-719.3	0.999UN	
			1	0.43		0.0	0.0	0.0	31602	3E62N	0.48	1	1	202.9	3.1		
									31603	3BRB	0.48	1	1	22.0	13.5		
									31605	3BH	0.48	1	1	182.6	126.4		
									31607	3BJ	0.48	1	1	131.8	89.9		
									31609	3A072	0.46	1	1	56.8	32.8	1.043UN	
									31610	3E400	0.46	1	1	60.9	42.4	1.043UN	
									31611	3E402	0.46	1	1	61.4	42.4	1.043UN	
									31613	3P192	0.46	1	1	56.2	36.7	1.043UN	
									31614	3BZ	0.48	1	1	199.8	127.5		
									31615	E419-U3	0.46	1	1	117.6	70.5	1.043UN	
									31617	3P191-B	0.46	1	1	56.2	36.7	1.043UN	
									31618	ES-U3	0.48	1	1	107.6	64.6		
									31619	3A073	0.46	1	1	57.2	32.8	1.043UN	
2403	2P012	4.16	1	0.959	-4.8	0.0	352.9	0.0	21	2A04	4.16	1	1	-352.9	-180.0		
			1	3.99		0.0	180.0	0.0									
2404	2P141	4.16	1	0.958	-4.8	0.0	674.5	0.0	24	2A04	4.16	1	1	-674.5	-307.3		
			1	3.99		0.0	307.3	0.0									
2406	2P025-A	4.16	1	0.959	-4.8	0.0	477.0	0.0	24	2A04	4.16	1	1	-477.0	-270.0		
			1	3.99		0.0	270.0	0.0									
2407	2P015	4.16	1	0.959	-4.8	0.0	389.0	0.0	21	2A04	4.16	1	1	-389.0	-199.0		
			1	3.99		0.0	199.0	0.0									
2408	2P017	4.16	1	0.959	-4.8	0.0	405.0	0.0	24	2A04	4.16	1	1	-405.0	-173.0		
			1	3.99		0.0	173.0	0.0									
2411	2P307	4.16	1	0.959	-4.8	0.0	331.0	0.0	24	2A04	4.16	1	1	-331.0	-214.0		
			1	3.99		0.0	214.0	0.0									
2420	2B04X	4.16	1	0.959	-4.8	0.0	0.0	0.0	24	2A04	4.16	1	1	-944.4	-748.7		
			1	3.99		0.0	0.0	0.0	214	2B04	0.48	1	1	944.6	748.7	0.999LK	

Case No: E4C-082 CUNM-3 Rev. 1  
 SHEET NO. - 433  
 RE: LPM 9-30-94  
 RE: AL 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA								LINE DATA									
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER	RATING A		
		ZONE	PU/KV		KW/KVAR	KW/KVAR	KW/KVAR							RATIO	ANGLE	%I	KVA
2603	2P504	4.16	1	0.962	-4.4	0.0	674.5	0.0									
			1	4.00		0.0	307.3	0.0	26	2A06	4.16	1	1	-674.5	-307.3		
2604	2P013	4.16	1	0.963	-4.4	0.0	352.9	0.0									
			1	4.01		0.0	180.0	0.0	26	2A06	4.16	1	1	-352.9	-180.0		
2606	2P025-B	4.16	1	0.963	-4.4	0.0	477.0	0.0									
			1	4.61		0.0	270.0	0.0	26	2A06	4.16	1	1	-477.1	-270.0		
2607	2P016	4.16	1	0.963	-4.4	0.0	389.0	0.0									
			1	4.01		0.0	199.0	0.0	26	2A06	4.16	1	1	-389.0	-199.0		
2608	2P019	4.16	1	0.963	-4.4	0.0	405.0	0.0									
			1	4.01		0.0	173.0	0.0	26	2A06	4.16	1	1	-405.0	-173.0		
2611	2P114	4.16	1	0.963	-4.4	0.0	331.0	0.0									
			1	4.01		0.0	214.0	0.0	26	2A06	4.16	1	1	-331.0	-214.0		
2620	2B06X	4.16	1	0.963	-4.4	0.0	0.0	0.0									
			1	4.01		0.0	0.0	0.0	26	2A06	4.16	1	1	-907.3	-722.3		
									216	2B06	0.48	1	1	907.3	722.1	0.999LK	
3402	E336-U3	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.98		0.0	0.0	0.0	34	3A04	4.16	1	1	-448.0	-247.1		
										M I S M A T C H				448.0	247.1		
3403	3P012	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.99		0.0	0.0	0.0	34	3A04	4.16	1	1	-307.5	-166.0		
										M I S M A T C H				307.5	166.0		
3404	3P141	4.16	1	0.957	-4.8	0.0	0.0	0.0									
			1	3.98		0.0	0.0	0.0	34	3A04	4.16	1	1	-669.6	-296.9		
										M I S M A T C H				669.6	296.9		
3405	3P024	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.98		0.0	0.0	0.0	31	3A04	4.16	1	1	-472.3	-260.9		
										M I S M A T C H				472.3	260.9		
3407	3P015	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.98		0.0	0.0	0.0	34	3A04	4.16	1	1	-378.0	-188.1		
										M I S M A T C H				378.0	188.1		
3408	3P017	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.98		0.0	0.0	0.0	34	3A04	4.16	1	1	-395.3	-171.4		
										M I S M A T C H				395.3	171.4		
3409	3P018-A	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.99		0.0	0.0	0.0	34	3A04	4.16	1	1	-395.3	-171.4		
										M I S M A T C H				395.3	171.4		
3411	3P307	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.98		0.0	0.0	0.0	34	3A04	4.16	1	1	-320.2	-197.5		
										M I S M A T C H				320.2	197.5		
3412	3T014	4.16	1	0.958	-4.8	0.0	128.0	0.0									
			1	3.99		0.0	78.0	0.0	34	2A04	4.16	1	1	-128.0	-78.0		
3417	3B04X	4.16	1	0.958	-4.8	0.0	0.0	0.0									
			1	3.99		0.0	0.0	0.0	34	3A04	4.16	1	1	-1406.8	-973.1		
									314	3B04	0.48	1	1	1406.9	973.1	0.999LK	

Case No: E4C-082 CCN9N-3 Rev: 1  
Date: Sep 9-30-94  
Time: 10-5-94  
Sheet No. 434

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LP-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA								LINE DATA								
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A
3602	E335-U3	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-448.1	-247.6		
									M I S M A T C H				448.1	247.6		
3604	3P013	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-307.5	-166.8		
									M I S M A T C H				307.5	166.8		
3606	3P025-B	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-472.3	-262.1		
									M I S M A T C H				472.3	262.1		
3607	3P016	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-378.1	-188.7		
									M I S M A T C H				378.1	188.7		
3608	3P019	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-395.4	-171.9		
									M I S M A T C H				395.4	171.9		
3609	3P018-B	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-395.5	-172.0		
									M I S M A T C H				395.5	172.0		
3611	3P114	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-320.2	-198.5		
									M I S M A T C H				320.2	198.5		
3612	3P504	4.16	1 0.961	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-669.6	-297.1		
									M I S M A T C H				669.6	297.1		
3619	3B06X	4.16	1 0.962	-4.4	0.0	0.0	0.0									
			1 4.00		0.0	0.0	0.0	36	3A06	4.16	1	1	-1340.2	-909.2		
									M I S M A T C H				1340.2	909.1	0.999LK	
21403	2BRA	0.48	1 0.900	-8.5	0.0	0.0	0.0									
			1 0.43		0.0	0.0	0.0	214	2B04	0.48	1	1	-22.9	-15.2		
								22403	2BRA-M	0.48	1	1	14.4	10.0		
								23403	2BRA-S	0.48	1	1	8.5	5.3		
21405	2P191-A	0.46	1 0.930	-8.5	0.0	57.0	0.0									
			1 0.43		0.0	35.0	0.0	214	2B04	0.48	1	1	-57.0	-35.0	1.043LK	
21407	2BD	0.48	1 0.835	-9.5	0.0	0.0	0.0									
			1 0.40		0.0	0.0	0.0	214	2B04	0.48	1	1	-184.1	-123.9		
								22107	2BD-M	0.48	1	1	18.3	13.6		
								23407	2BD-S	0.48	1	1	8.5	5.3		
								24412	2A274	0.46	1	1	45.3	30.3	1.043UN	
								24111	2A275	0.46	1	1	45.5	30.4	1.043UN	
								24421	2E550	0.46	1	1	33.2	22.2	1.043UN	
								24122	2E546	0.46	1	1	33.2	22.2	1.043UN	
21409	2A071	0.46	1 0.918	-8.2	0.0	55.0	0.0									
			1 0.42		0.0	37.0	0.0	214	2B04	0.48	1	1	-55.0	-37.0	1.043LK	
21410	2E399	0.46	1 0.928	-8.5	0.0	61.0	0.0									
			1 0.43		0.0	41.0	0.0	214	2B04	0.48	1	1	-61.0	-41.0	1.043LK	
21411	2E401	0.46	1 0.925	-8.5	0.0	61.0	0.0									
			1 0.43		0.0	41.0	0.0	214	2B04	0.48	1	1	-61.0	-41.0	1.043LK	

Case No: E4C-082  
 Date: 9-30-94  
 Sheet No: 435  
 RE: LPM 9-30-94  
 PRE: RL 10-5-94  
 Case No: CN 9N-3  
 Rev: 1

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LP-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	A KVA
21413	2P190	0.46	1	0.930	-8.5	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	214	2B04	0.48	1	1	-57.0	-35.0	1.043LK		
21414	2BE	0.48	1	0.898	-8.5	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	214	2B04	0.48	1	1	-134.5	-114.8			
									22414	2BE-M	0.48	1	1	45.0	50.8			
									23414	2BE-S	0.48	1	1	89.4	64.1			
21415	2BY	0.48	1	0.897	-8.6	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	214	2B04	0.48	1	1	-222.2	-145.5			
									22415	2BY-M	0.48	1	1	86.2	55.4			
									23415	2BY-S	0.48	1	1	112.5	78.1			
									24434	2P009	0.46	1	1	23.6	12.0	1.043UN		
21419	2A074	0.46	1	0.913	-8.1	0.0	55.0	0.0										
			1	0.42		0.0	37.0	0.0	214	2B04	0.48	1	1	-55.0	-37.0	1.043LK		
21603	2BRB	0.48	1	0.907	-7.9	0.0	0.0	0.0										
			1	0.44		0.0	0.0	0.0	216	2B06	0.48	1	1	-22.9	-15.2			
									22603	2BRB-M	0.48	1	1	14.4	10.0			
									23603	2BRB-S	0.48	1	1	8.5	5.3			
21605	2BH	0.48	1	0.856	-8.7	0.0	0.0	0.0										
			1	0.41		0.0	0.0	0.0	216	2B06	0.48	1	1	-183.9	-123.9			
									22605	2BH-M	0.48	1	1	18.3	13.6			
									23605	2BH-S	0.48	1	1	8.5	5.3			
									24606	2E547	0.46	1	1	33.2	22.1	1.043UN		
									24607	2E549	0.46	1	1	33.2	22.2	1.043UN		
									24611	2A276	0.46	1	1	45.3	30.3	1.043UN		
									24612	2A277	0.46	1	1	45.5	30.4	1.043UN		
21607	2BJ	0.48	1	0.904	-8.0	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	216	2B06	0.48	1	1	-124.2	-108.4			
									22607	2BJ-M	0.48	1	1	45.0	50.7			
									23607	2BJ-S	0.48	1	1	79.2	57.8			
21609	2A072	0.46	1	0.923	-7.6	0.0	55.0	0.0										
			1	0.42		0.0	37.0	0.0	216	2B06	0.48	1	1	-55.0	-37.0	1.043LK		
21610	2E400	0.46	1	0.929	-7.9	0.0	61.0	0.0										
			1	0.43		0.0	41.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK		
21611	2E402	0.46	1	0.923	-7.8	0.0	61.0	0.0										
			1	0.42		0.0	41.0	0.0	216	2B06	0.48	1	1	-61.0	-41.0	1.043LK		
21613	2P102	0.46	1	0.933	-7.9	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK		
21614	2BZ	0.48	1	0.905	-8.0	0.0	0.0	0.0										
			1	0.43		0.0	0.0	0.0	216	2B06	0.48	1	1	-197.9	-136.6			
									22614	2BZ-M	0.48	1	1	50.0	40.7			
									23614	2BZ-S	0.48	1	1	124.4	83.9			
									24622	2P010	0.46	1	1	23.6	12.0	1.043UN		
21617	2P191-B	0.46	1	0.932	-7.9	0.0	57.0	0.0										
			1	0.43		0.0	35.0	0.0	216	2B06	0.48	1	1	-57.0	-35.0	1.043LK		

Case No: E4C-082  
Date: 9-30-94  
Rev: 1  
Sheet No: 436  
RE: [Signature] 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA									LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	KVA
21619	2A073	0.46	1 0.916	-7.5	0.0	55.0	0.0										
			1 0.42		0.0	37.0	0.0	216	2J06	0.48	1	1	-55.0	-37.0	1.043LK		
22403	2BRA-M	0.48	1 0.900	-8.5	0.0	14.4	0.0										
			1 0.43		0.0	10.0	0.0	21403	2BRA	0.48	1	1	-14.4	-10.0			
22407	2BD-M	0.48	1 0.835	-9.5	0.0	18.3	0.0										
			1 0.40		0.0	13.6	0.0	21407	2BD	0.48	1	1	-18.3	-13.6			
22414	2BE-M	0.48	1 0.898	-8.5	0.0	45.0	0.0										
			1 0.43		0.0	50.8	0.0	21414	2BE	0.48	1	1	-45.0	-50.8			
22415	2BY-M	0.48	1 0.897	-8.6	0.0	86.2	0.0										
			1 0.43		0.0	55.4	0.0	21415	2BY	0.48	1	1	-86.2	-55.4			
22603	2BRB-M	0.48	1 0.907	-7.9	0.0	14.4	0.0										
			1 0.44		0.0	10.0	0.0	21603	2BRB	0.48	1	1	-14.4	-10.0			
22605	2BH-M	0.48	1 0.856	-8.7	0.0	18.3	0.0										
			1 0.41		0.0	13.6	0.0	21605	2BH	0.48	1	1	-18.3	-13.6			
22607	2BJ-M	0.48	1 0.904	-8.0	0.0	45.0	0.0										
			1 0.43		0.0	50.7	0.0	21607	2BJ	0.48	1	1	-45.0	-50.7			
22614	2BZ-M	0.48	1 0.905	-8.0	0.0	50.0	0.0										
			1 0.43		0.0	40.7	0.0	21614	2BZ	0.48	1	1	-50.0	-40.7			
23403	2BRA-S	0.48	1 0.900	-8.5	0.0	8.5	0.0										
			1 0.43		0.0	5.3	0.0	21403	2BRA	0.48	1	1	-8.5	-5.3			
23407	2BD-S	0.48	1 0.835	-9.5	0.0	8.5	0.0										
			1 0.40		0.0	5.3	0.0	21407	2BD	0.48	1	1	-8.5	-5.3			
23414	2BE-S	0.48	1 0.898	-8.5	0.0	89.4	0.0										
			1 0.43		0.0	64.1	0.0	21414	2BE	0.48	1	1	-89.4	-64.1			
23415	2BY-S	0.48	1 0.897	-8.6	0.0	112.5	0.0										
			1 0.43		0.0	78.1	0.0	21415	2BY	0.48	1	1	-112.5	-78.1			
23603	2BRB-S	0.48	1 0.907	-7.9	0.0	8.5	0.0										
			1 0.44		0.0	5.3	0.0	21603	2BRB	0.48	1	1	-8.5	-5.3			
23605	2BH-S	0.48	1 0.856	-8.7	0.0	8.5	0.0										
			1 0.41		0.0	5.3	0.0	21605	2BH	0.48	1	1	-8.5	-5.3			
23607	2BJ-S	0.48	1 0.904	-8.0	0.0	79.2	0.0										
			1 0.43		0.0	57.8	0.0	21607	2BJ	0.48	1	1	-79.2	-57.8			
23614	2BZ-S	0.48	1 0.905	-8.0	0.0	124.4	0.0										
			1 0.43		0.0	83.9	0.0	21614	2BZ	0.48	1	1	-124.4	-83.9			

Calc No: E4C-082 CCN 9/1-3 Rev: 1  
RE: *Cpm 9-30-94* RE: *Ad 10-5-94*  
Sheet No: 437

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT TO	BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING KI	KVA
24412	2A274	0.46	1	0.868	-9.4	0.0	45.1	0.0										
			1	0.40		0.0	30.3	0.0	21407	2BD	0.48	1	1	-45.1	-30.3	1.043LK		
24413	2A275	0.46	1	0.865	-9.3	0.0	45.1	0.0										
			1	0.40		0.0	30.3	0.0	21407	2BD	0.48	1	1	-45.1	-30.3	1.043LK		
24421	2E550	0.46	1	0.864	-9.3	0.0	32.9	0.0										
			1	0.40		0.0	22.1	0.0	21407	2BD	0.48	1	1	-32.9	-22.1	1.043LK		
24422	2E546	0.46	1	0.865	-9.3	0.0	32.9	0.0										
			1	0.40		0.0	22.1	0.0	21407	2BD	0.48	1	1	-32.9	-22.1	1.043LK		
24434	2P009	0.46	1	0.923	-8.4	0.0	23.2	0.0										
			1	0.42		0.0	11.9	0.0	21415	2DY	0.48	1	1	-23.2	-11.9	1.043LK		
24606	2E547	0.46	1	0.888	-8.5	0.0	32.9	0.0										
			1	0.41		0.0	22.1	0.0	21605	2BH	0.48	1	1	-32.9	-22.1	1.043LK		
24607	2E549	0.46	1	0.887	-8.5	0.0	31.9	0.0										
			1	0.41		0.0	22.1	0.0	21605	2BH	0.48	1	1	-32.9	-22.1	1.043LK		
24611	2A276	0.46	1	0.890	-8.6	0.0	45.1	0.0										
			1	0.41		0.0	30.3	0.0	21605	2BH	0.48	1	1	-45.1	-30.3	1.043LK		
24612	2A277	0.46	1	0.887	-8.5	0.0	45.1	0.0										
			1	0.41		0.0	30.3	0.0	21535	2BH	0.48	1	1	-45.1	-30.3	1.043LK		
24622	2P010	0.46	1	0.930	-7.8	0.0	23.2	0.0										
			1	0.43		0.0	11.9	0.0	21414	2BE	0.48	1	1	-23.2	-11.9	1.043LK		
31402	3E61N	0.48	1	0.870	-11.4	0.0	200.0	0.0										
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-200.0	0.0			
31403	3BRA	0.48	1	0.881	-10.6	0.0	0.0	0.0										
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-22.0	-13.5			
									32403	3ERA-M	0.48	1	1	13.5	8.2			
									33423	3ERA-S	0.48	1	1	8.5	5.3			
31405	3P191-A	0.46	1	0.908	-10.6	0.0	0.0	0.0										
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-55.3	-36.0	1.043LK		
31407	3BD	0.48	1	0.818	-11.5	0.0	0.0	0.0	M I S M A T C H									
			1	0.39		0.0	0.0	0.0	314	3B04	0.48	1	1	-173.7	-117.2			
									32407	3BD-M	0.48	1	1	17.3	10.6			
									33407	3BD-S	0.48	1	1	8.5	5.3			
									34412	3A274	0.46	1	1	41.8	29.5	1.043UN		
									34413	3A275	0.46	1	1	42.0	29.5	1.043UN		
									34421	3E550	0.46	1	1	32.1	21.2	1.043UN		
									34422	3E546	0.46	1	1	32.0	21.1	1.043UN		
31409	3A071	0.46	1	0.897	-10.4	0.0	0.0	0.0										
			1	0.41		0.0	0.0	0.0	314	3B04	0.48	1	1	-55.0	-32.0	1.043LK		
									M I S M A T C H									

Calc No: E4C-082  
Case No: CANYW-3  
Rev: 1  
Sheet No. 438  
RE: Lpm 9-30-94  
IRE: RL 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY|LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA							LINE DATA										
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %	A KVA
31410	3E399	0.46	1	0.908	-10.5	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-59.6	-41.5	1.043LK	
														59.6	41.5		
31411	3E401	0.46	1	0.906	-10.5	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-59.6	-41.5	1.043LK	
														59.6	41.5		
31413	3P190	0.46	1	0.910	-10.6	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-55.3	-36.0	1.043LK	
														55.3	36.0		
31414	3BE	0.48	1	0.879	-10.6	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-142.8	-96.5		
									32414	3BE-M	0.48	1	1	53.3	32.5		
									33414	3BE-S	0.48	1	1	89.4	64.1		
31415	3BY	0.48	1	0.879	-10.7	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-214.3	-137.3		
									32415	3BY-M	0.48	1	1	78.8	48.0		
									33415	3BY-S	0.48	1	1	112.5	78.1		
									34414	3P009	0.46	1	1	23.0	11.3	1.043UN	
31417	BQ-U3	0.48	1	0.873	-10.8	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	314	3B04	0.48	1	1	-140.1	-85.9		
									32417	BQ-U3-M	0.48	1	1	39.6	24.1		
									33417	BQ-U3-S	0.48	1	1	75.9	45.8		
									34417	B162-U3	0.46	1	1	24.7	16.0	1.043UN	
31418	E418-U3	0.46	1	0.882	-10.6	0.0	0.0	0.0									
			1	0.41		0.0	0.0	0.0	314	3B04	0.48	1	1	-116.0	-67.0	1.043LK	
														116.0	67.0		
31419	3A074	0.46	1	0.892	-10.3	0.0	0.0	0.0									
			1	0.41		0.0	0.0	0.0	314	3B04	0.48	1	1	-55.0	-31.9	1.043LK	
														55.0	31.9		
31602	3E62N	0.48	1	0.878	-10.7	0.0	200.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3B06	0.48	1	1	-200.0	0.0		
31603	3BRB	0.48	1	0.891	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	316	3B06	0.48	1	1	-22.0	-13.5		
									32603	3BRB-M	0.48	1	1	13.5	8.2		
									33603	3BRB-S	0.48	1	1	8.5	5.3		
31605	3BH	0.48	1	0.842	-10.6	0.0	0.0	0.0									
			1	0.40		0.0	0.0	0.0	316	3B06	0.48	1	1	-174.1	-117.4		
									32605	3BH-M	0.48	1	1	17.4	10.6		
									33605	3BH-S	0.48	1	1	8.5	5.3		
									34606	3E547	0.46	1	1	32.1	21.4	1.043UN	
									34607	3E549	0.46	1	1	32.1	21.4	1.043UN	
									34611	3A276	0.46	1	1	41.9	29.3	1.043UN	
									34622	3A277	0.46	1	1	42.1	29.4	1.043UN	
31607	3BJ	0.48	1	0.888	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	316	3B06	0.48	1	1	-131.5	-89.6		
									32607	3BJ-M	0.48	1	1	52.2	31.8		
									33607	3BJ-S	0.48	1	1	79.2	57.8		
31609	3A072	0.46	1	0.904	-9.6	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	316	3B06	0.48	1	1	-55.1	-32.2	1.043LK	
														55.1	32.2		

Case No: E4C-082 CCN 9N-3 Rev. 1  
Sheet No. 439  
RE: Lpm 9-30-94 IRE: R8 10-5-94



PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA									LINE DATA									
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I	KVA
31610	3E400	0.46	1	0.912	-9.8	0.0	0.0	0.0	316	3B06	0.48	1	1	-59.7	-41.7	1.043LK		
			1	0.42		0.0	0.0	0.0		M I S M A T C H				59.7	41.7			
31611	3E402	0.46	1	0.905	-9.7	0.0	0.0	0.0	316	3B06	0.48	1	1	-59.6	-41.4	1.043LK		
			1	0.42		0.0	0.0	0.0		M I S M A T C H				59.6	41.4			
31613	3P192	0.46	1	0.916	-9.8	0.0	0.0	0.0	316	3B06	0.48	1	1	-55.3	-36.2	1.043LK		
			1	0.42		0.0	0.0	0.0		M I S M A T C H				55.3	36.2			
31614	3BZ	0.48	1	0.889	-9.9	0.0	0.0	0.0	316	3B06	0.48	1	1	-199.5	-126.9			
			1	0.43		0.0	0.0	0.0		32614 3BZ-M	0.48	1	1	52.0	31.7			
										33614 3BZ-S	0.48	1	1	124.4	83.9			
										34623 3P010	0.46	1	1	23.1	11.3	1.043UN		
31615	E419-U3	0.46	1	0.918	-9.9	0.0	0.0	0.0	316	3B06	0.48	1	1	-116.2	-69.6	1.043LK		
			1	0.42		0.0	0.0	0.0		M I S M A T C H				116.2	69.6			
31617	3P191-B	0.46	1	0.916	-9.8	0.0	0.0	0.0	316	3B06	0.48	1	1	-55.3	-36.2	1.043LK		
			1	0.42		0.0	0.0	0.0		M I S M A T C H				55.3	36.2			
31618	BS-U3	0.48	1	0.883	-10.0	0.0	0.0	0.0	316	3B06	0.48	1	1	-106.7	-53.7			
			1	0.42		0.0	0.0	0.0		32618 BS-U3-M	0.48	1	1	39.6	24.1			
										33618 BS-U3-S	0.48	1	1	42.6	23.4			
										34618 1160-U3	0.46	1	1	24.5	16.2	1.043UN		
31619	3A073	0.46	1	0.898	-9.5	0.0	0.0	0.0	316	3B06	0.48	1	1	-55.0	-32.1	1.043LK		
			1	0.41		0.0	0.0	0.0		M I S M A T C H				55.0	32.1			
32403	3BRA-M	0.48	1	0.881	-10.6	0.0	0.0	0.0	31403	3BRA	0.48	1	1	-13.5	-8.2			
			1	0.42		0.0	0.0	0.0		M I S M A T C H				13.5	8.2			
32407	3BD-M	0.48	1	0.818	-11.5	0.0	0.0	0.0	31407	3BD	0.48	1	1	-17.3	-10.6			
			1	0.39		0.0	0.0	0.0		M I S M A T C H				17.3	10.6			
32414	3BE-M	0.48	1	0.879	-10.6	0.0	0.0	0.0	31414	3BE	0.48	1	1	-53.3	-32.5			
			1	0.42		0.0	0.0	0.0		M I S M A T C H				53.3	32.5			
32415	3BY-M	0.48	1	0.879	-10.7	0.0	0.0	0.0	31415	3BY	0.48	1	1	-78.8	-48.0			
			1	0.42		0.0	0.0	0.0		M I S M A T C H				78.8	48.0			
32417	BQ-U3-M	0.48	1	0.873	-10.8	0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	-39.6	-24.1			
			1	0.42		0.0	0.0	0.0		M I S M A T C H				39.6	24.1			
32603	3BRB-M	0.48	1	0.891	-9.9	0.0	0.0	0.0	31603	3BRB	0.48	1	1	-13.5	-8.2			
			1	0.43		0.0	0.0	0.0		M I S M A T C H				13.5	8.2			
32605	3BH-M	0.48	1	0.842	-10.6	0.0	0.0	0.0	31605	3BH	0.48	1	1	-17.4	-10.6			
			1	0.40		0.0	0.0	0.0		M I S M A T C H				17.4	10.6			
32607	3BJ-M	0.48	1	0.888	-9.9	0.0	0.0	0.0	31607	3BJ	0.48	1	1	-52.2	-31.8			
			1	0.43		0.0	0.0	0.0										

Calc No: E4C-082 CCN 9N-3  
Rev: 1  
Sheets No. 440  
RE: Pwr 9-30-94  
RE: R. P. 10-5-94

Sheet No. 441  
Calc No: EAC-082 CCN<sup>9</sup>N-3 Rev. 1  
RE: Lpm 9-30-94 IRE: Pl 10-5-94

M I S M A T C H      52.2    31.8

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA										LINE DATA							
FROM BUS	NAME	AREA	VOLT PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING %I	A KVA
32614	3BZ-M	0.48	1	0.889	-9.9	0.0	0.0	0.0									
			1	0.43		0.0	0.0	0.0	31611	DDZ	0.48	1	1	-52.0	-31.7		
										M I S M A T C H				52.0	31.7		
32618	BS-U3-M	0.48	1	0.883	-10.0	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31618	BS-U3	0.48	1	1	-39.6	-24.1		
										M I S M A T C H				39.6	24.1		
33403	3BRA-S	0.48	1	0.881	-10.6	0.0	8.5	0.0									
			1	0.42		0.0	5.3	0.0	31403	BRA	0.48	1	1	-8.5	-5.3		
33407	3BD-S	0.48	1	0.818	-11.5	0.0	8.5	0.0									
			1	0.39		0.0	5.3	0.0	31407	3BD	0.48	1	1	-8.5	-5.3		
33414	3BE-S	0.48	1	0.879	-10.6	0.0	89.4	0.0									
			1	0.42		0.0	64.1	0.0	31414	3BE	0.48	1	1	-89.4	-64.1		
33415	3BY-S	0.48	1	0.879	-10.7	0.0	112.5	0.0									
			1	0.42		0.0	78.1	0.0	31415	3BY	0.48	1	1	-112.5	-78.1		
33417	BQ-U3-S	0.48	1	0.873	-10.8	0.0	75.9	0.0									
			1	0.42		0.0	45.8	0.0	31417	BQ-U3	0.48	1	1	-75.9	-45.8		
33603	3BRB-S	0.48	1	0.891	-9.9	0.0	8.5	0.0									
			1	0.43		0.0	5.3	0.0	31603	3BRB	0.48	1	1	-8.5	-5.3		
33605	3BH-S	0.48	1	0.842	-10.6	0.0	8.5	0.0									
			1	0.40		0.0	5.3	0.0	31605	3BH	0.48	1	1	-8.5	-5.3		
33607	3BJ-S	0.48	1	0.888	-9.9	0.0	79.2	0.0									
			1	0.43		0.0	57.8	0.0	31607	3BJ	0.48	1	1	-79.2	-57.8		
33614	3BZ-S	0.48	1	0.889	-9.9	0.0	124.4	0.0									
			1	0.43		0.0	83.9	0.0	31614	3BZ	0.48	1	1	-124.4	-83.9		
33618	BS-U3-S	0.48	1	0.883	-10.0	0.0	42.6	0.0									
			1	0.42		0.0	23.4	0.0	31618	BS-U3	0.48	1	1	-42.6	-23.4		
34412	3A274	0.46	1	0.850	-11.4	0.0	0.0	0.0									
			1	0.39		0.0	0.0	0.0	31117	3BD	0.48	1	1	-41.6	-29.4	1.043LK	
										M I S M A T C H				41.6	29.4		
34413	3A275	0.46	1	0.847	-11.3	0.0	0.0	0.0									
			1	0.39		0.0	0.0	0.0	31117	3BD	0.48	1	1	-41.6	-29.4	1.043LK	
										M I S M A T C H				41.6	29.4		
34417	P162-U3	0.46	1	0.897	-10.4	0.0	0.0	0.0									
			1	0.41		0.0	0.0	0.0	31417	BQ-U3	0.48	1	1	-24.2	-15.9	1.043LK	
										M I S M A T C H				24.2	15.9		
34421	3E550	0.46	1	0.846	-11.3	0.0	0.0	0.0									
			1	0.39		0.0	0.0	0.0	31117	3BD	0.48	1	1	-31.7	-21.1	1.043LK	
										M I S M A T C H				31.7	21.1		
34422	3E546	0.46	1	0.848	-11.4	0.0	0.0	0.0									
			1	0.39		0.0	0.0	0.0	31407	3BD	0.48	1	1	-31.7	-21.1	1.043LK	
										M I S M A T C H				31.7	21.1		

Case No: E4C-082 CEN-3 Rev. 1  
Sheet No. 442  
RE: Cpu 9-30-94  
IRE: RJ 10-5-94

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E  
CASE IV.BY - POST ACCIDENT (STEADY STATE) CONDITION  
DKB200:[MURIEL.E4C-082-AGA.CASE\_IVBY]LF-2\_IVBY.SAV

THU, SEP 15 1994 13:26

BUS DATA									LINE DATA								
FROM BUS	NAME	AREA	VOLT ZONE	PU/KV	ANGLE	GEN KW/KVAR	LOAD KW/KVAR	SHUNT KW/KVAR	TO BUS	NAME	CKT	AREA	KW	KVAR	TRANSFORMER RATIO	ANGLE	RATING A %I KVA
34434	3P009	0.46	1	0.905	-10.5	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31415	3BY	0.48	1	-22.6	-11.2	1.043LK		
										M I S M A T C H			22.6	11.2			
34606	3E547	0.46	1	0.873	-10.4	0.0	0.0	0.0									
			1	0.40		0.0	0.0	0.0	31605	3DH	0.48	1	-31.8	-21.3	1.043LK		
										M I S M A T C H			31.8	21.3			
34607	3E549	0.46	1	0.873	-10.4	0.0	0.0	0.0									
			1	0.40		0.0	0.0	0.0	31605	3DH	0.48	1	-31.8	-21.3	1.043LK		
										M I S M A T C H			31.8	21.3			
34611	3A276	0.46	1	0.876	-10.5	0.0	0.0	0.0									
			1	0.40		0.0	0.0	0.0	31605	3BH	0.48	1	-41.8	-29.3	1.043LK		
										M I S M A T C H			41.8	29.3			
34612	3A277	0.46	1	0.873	-10.4	0.0	0.0	0.0									
			1	0.40		0.0	0.0	0.0	31605	3DH	0.48	1	-41.8	-29.3	1.043LK		
										M I S M A T C H			41.8	29.3			
34618	P160-U3	0.46	1	0.915	-9.8	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31618	BS-U3	0.48	1	-24.3	-16.1	1.043LK		
										M I S M A T C H			24.3	16.1			
34622	3P010	0.46	1	0.913	-9.7	0.0	0.0	0.0									
			1	0.42		0.0	0.0	0.0	31611	3BZ	0.48	1	-22.6	-11.2	1.043LK		
										M I S M A T C H			22.6	11.2			

RE: *Low* 9-30-94  
 Case No: E4C-082 CCN 9N-3 Rev. 1  
 Stress No. 443  
 RE: *AL* 10-5-94

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./  
PRELIM. CCN NO. **N-3**

PAGE **444** OF **453**

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - **9**

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

## APPENDIX 9.1.7

### PSS/E VALIDATION




VERIFICATION, SAV PSS/E VERIFICATION BASE CASE: START OF  
FEEDRATER PUMP (BUS 404) FOR COMPARISON WITH HAND CALC.

FILE: VERIFICATION.OUT

1

Calc No: E4C-082 CCN 9-N-3 Rev. 1 Sheet No. 445  
 RE: From 9-30-94 IRE: 02 10-5-94




THU, SEP 15 1994 15:08  
MOTOR SPEED



VERIFICATION, SAV PSS/E VERIFICATION BASE CASE: START OF  
FEEDRATER PUMP (BUS 404) FOR COMPARISON WITH HAND CALC.

FILE: VERIFICATION.OUT



THU, SEP 15 1994 15:08  
VOLTAGES (PU)

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO. /  
PRELIM. CCN NO. N-3      PAGE 446 OF 453

Project or DCP/MMP SONGS 2 & 3      Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT      Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
1	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

## ENGINEERING DEPARTMENT CALCULATION SHEET

SHEET OF SHEETS

SUBJECT: PTI Program Verification Start of FDW Pump G3A      DESIGN CALCULATION NO. DC-3128      REVISION 0


J.O. NO. \_\_\_\_\_ MADE BY P. Smae      DATE 2-14-89      CHK. BY VMA      DATE 2/14/89

A-3  
OF 3

ALL LOADS OFF - FEEDWATER PUMP TO BE STARTED  
FEEDWATER PUMP STARTING AT T=0.1SEC

FILE: FMSTART.OUT

DEC 29 1988 16:58



# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./  
PRELIM. CCN NO. N-3      PAGE 447 OF 453

Project or DCP/MMP SONGS 2 & 3      Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT      Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
1	L. R. MURIEL	<i>pm</i> 9-30-91	A. M. PATEL	10-5-91					

## ENGINEERING DEPARTMENT CALCULATION SHEET

SHEET OF SHEETS

SUBJECT: PTI Program Verification Start of FDW Pump G3A      DESIGN CALCULATION NO. DC-3128      REVISION 0

I.O. NO. \_\_\_\_\_ MADE BY PS      DATE 2-14-89      CHK. BY W      DATE 2/11/89


A-2  
OF 3



SAN ONOFRE MOTOR STARTING STUDY  
ALL LOADS OFF - FEEDWATER PUMP TO BE STARTED  
FEEDWATER PUMP STARTING AT T=0.1SEC

FILE: FWSTART.OUT

THU, DEC 29 1988 16:52  
VOLTAGES



FROM POWER TECH SCHDY      12/29/88 17:18      P. 3



# CALCULATION SHEET

ICCN NO./

PRELIM. CCN NO. N-3

PAGE 448 OF 453

CCN CONVERSION -

CCN NO. CCN - 9

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	<u>9-30-94</u>	A. M. PATEL	<u>10-5-94</u>					

**9.2 ATTACHMENTS:**

9.2.1 FAX Transmittal From D. Otto To B. Lennartz.....SHEET 449

9.2.2 TYPICAL MOV DATA.....SHEET 451

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO. / PRELIM. CCN NO. N-3 PAGE 449 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN-9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

**ATTACHMENT 9.2.1**

FAX Transmittal From D. Otto of Joy Technologies, Inc. To B. Lennartz of SCE  
SUBJECT: Inertia For E-418/E-419

# CALCULATION SHEET

ICCN NO./

PRELIM. CCN NO. *N-3*

PAGE

*450* OF *453*

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION

CCN NO. CCN - *9*

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
1	L. R. MURIEL	<i>9-30-94</i>	A. M. PATEL	<i>10-5-94</i>					

MAY 11 '93 09:07

FROM JOYTECH NEWPHILA OH .

PAGE.001

## FAX TRANSMITTAL

TO: Mr. Bill Lennarts

DATE: May 17, 1993

COMPANY: Southern California Edison

FROM: Dan Otto  
Joy Technologies, Inc.  
New Philadelphia, Ohio

FAX NO: 714-458-4876

NUMBER OF PAGES SENT INCLUDING THIS COVER SHEET: 1

CALL 216-339-1111 IF THERE ARE ANY PROBLEMS WITH THIS TRANSMITTAL.

SUBJECT: Rotor inertia for your Joy vaneaxial fan

Per our phone conversation, you have two Joy fans, model 38-26-1770 two stage, serial numbers GP-20776 & 777, with full bladed aluminum rotors. You requested the rotational inertia for this fan so that you could perform some starting time calculations. The number you need is 136 lb.-ft.<sup>2</sup> per rotor, 272 lb.-ft.<sup>2</sup> total.

Please let us know if we can be of further assistance.

Best regards,

*Dan Otto*

Daniel R. Otto, P.E.  
Project engineer for nuclear fans

# CALCULATION SHEET

NES&L DEPARTMENT

ICCN NO./ PRELIM. CCN NO. <b>N-3</b>	PAGE <b>451</b> OF <b>453</b>
---	-------------------------------

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION CCN NO. CCN - <b>9</b>
--

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

ATTACHMENT 9.2.2

Typical MOV Data  
Limiterque Publication SEL-17

# NES&L DEPARTMENT CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO. N-3      PAGE 452 OF 453

Project or DCP/MMP SONGS 2 & 3      Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT      Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
1	L. R. MURIEL	9-30-99	A. M. PATEL	10-5-99					

APPROXIMATE MOTOR DATA  
3/60/460° or 3/50/380°  
15 Min. Duty, 20% Run

Certified Values Can Be Supplied On Receipt Of A Purchase Order

UNIT TYPE	SIZE FT/LB	SPEED RPM	FRAME	N.P.	FULL LOAD	LOCKED ROTOR
SMB	2	1800	48	.13	.45	3.2
		3600	48	.25	.55	5.0
SMC	2	1800	42	.13	.4	2
SNC	3	1200	42	.13	.7	2.2
		1800	42	.2	.6	2.8
SMB	5	1800	48/56	.33	.83	5.0
SNC	5	1800	42	.33	1.0	4.6
SNC	7 1/2	1800	42	.48	2.25	7.5
SMB	10	1800	56	.66	2.5	12.0
		3600	56	1.33	2.5	16.0
SMB	15	1800	56	1.0	3.0	16.0
		3600	56	2.0	3.5	26.0
SMB	25	1800	56	1.6	5.0	26.0
		3600	56	3.3	6.0	50.0
SMB	40	1800	56	2.6	6.0	37.0
		3600	184	5.3	8.5	73.3
SMB	60	1800	184	3.9	9.0	60.0
		3600	184	7.9	12.0	95.0
SMB	80	1800	184	5.2	11.0	60.0
		3600	215	10.5	16.0	124.0
SMB	100	1800	215	6.4	10.0	85.0
		3600	215	13.0	18.3	154.0
SMB	150	1800	215	9.5	20.0	130.0
		3600	256	20.0	26.0	217.0
SMB	200	1800	256	13.0	23.0	164.0
		3600	256	26.0	38.0	332.0
SMB	250	1800	256	16.0	26.0	211.0
		3600	256	32.0	43.0	400.0
SMB	300	1800	256	19.0	30.0	215.0
		3600	326	38.0	50.0	444.0
SMB	350	1800	256	22.0	36.0	280.0
		3600	326	44.0	64.0	510.0

\*For voltages other than those shown - the amps will vary as follows:

    @ 60 Hz     $\frac{460 \text{ volts}}{\text{Required volts}} = \text{Revised Amps}$

    @ 50 Hz     $\frac{380 \text{ volts}}{\text{Required volts}} = \text{Revised Amps}$

COMMON TO ALL MOTORS

- Manufacturer      - Limitorque
- Type                - Induction
- Enclosure         - TENV (for W.P.) or TEXP (for X.P.)
- Service Factor    - 1.3
- Rotation           - Reversible
- Horiz. or Vert.    - Universal
- Bearings          - Permanently Lubricated Ball
- Wk<sup>2</sup>                 - N.A.
- Weight             - N.A. (Motor is an integral part of actuator)

	Power Factor	Efficiency
100% Load	60	70
75% Load	50	60
50% Load	40	50

SEL-17  
3/1/78

# CALCULATION SHEET

CCN NO. / PRELIM. CCN NO. N-3 PAGE 453 OF 453

Project or DCP/MMP SONGS 2 & 3 Calc No. E4C-082 Rev.1

CCN CONVERSION  
CCN NO. CCN - 9

Subject SYSTEM DYNAMIC VOLTAGES DURING DESIGN BASIS ACCIDENT Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	L. R. MURIEL	9-30-94	A. M. PATEL	10-5-94					

LAST PAGE