NRC Form (9-83)	366		٠	LICENSEE EVENT REPORT (LER)									U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/85											
FACILITY NAME (1)										DOC	KET N	UMI	BER ((2)			PAGE (3)							
JAMES A. FITZPATRICK NUCLEAR POWER PLANT										0 1	510	0 1	0 1	0 1	31	3 3	1	OF	0 1					
TITLE (4)								-									_			-1	-1-		_	
LOS	S OF	SE	CON	DARS	, 00	TMC	ATNME	TM	TM	TEGR	TTV													
LOSS OF SECONDARY CONTAINMENT															R FACILITIES INVOLVED (8)									
MONTH DAY YE		YEAR	YE	AR	R SEQUENTIAL REVISION			HONTH DAY VEAR			FACILITY NAMES						T	DOCKET NUMBER(S)						
	-		+		70	MBER	NUM	BER											0 1	51	0 1 0	101	- 1	-
ol a	d c	8 5	8	5 -	1	d	1-10		nla	110	8 5										0 10			
V1 4	ULO	-	-		/3 SU	BMITTI	ED PURSUA	NT T	O THE R	EQUIREN		O CFR 8: /6	Check on	or mor	e of th	e follow	wing		_			1-1	_	
POWER LEVEL (10) 11 () ()			20.402(b) 20.408(a)(1)(i) 20.408(a)(1)(ii) 20.408(a)(1)(iv) 20.408(a)(1)(iv)				20.406(c) 50.36(c)(1) 50.36(c)(2) 50.73(c)(2)(i) 50.73(a)(2)(ii) 50.73(a)(2)(iii)			50.73(a)(2)(iv) \$0.73(a)(2)(v) 50.73(a)(2)(vii) 50.73(a)(2)(viii)(A) 50.73(a)(2)(viii)(B) 50.73(a)(2)(x)									TI(a)					
NAME								LI	CENSEE	CONTAC	T FOR THIS	LER (12)					-	7	FLE	PHON	E NUM	RER		
	illi	am	Fer	nanc	lez	, 0	perat	io	ns S	Supe	rinte	nden	t			3 1			3	4	2 -	3	8 1	4 10
					CON	PLETE	ONE LINE	FOR	EACH CO	OMPONEN	T FAILURE	DESCRIBE	D IN TH	IS REP	ORT (1	3)								
CAUSE	SYSTEM	сом	PONEN	MANUFAC- TURER		REPORTABLE TO NPROS				CAUSE	SYSTEM	COMPONENT			MANUFAC TURER			REPORTAB TO NPRO		ABLE				
Х	N _I G	DI	R	1 3	9	9	9 N										L	L						
	1	1	1		1 1	1						1	1	1 1		1	1	1						•
					SU	PPLEM	ENTAL REP	PORT	EXPECT	ED (14)							v 0 1	ECTE	,		MONTH	DA	Y	YEAR
YES III yes, complete EXPECTED SUBMISSION DATE								7	X NO					SUBMISSION DATE (15)						1				

Secondary containment integrity was apparently breached during full power operation for approximately 30 seconds. The cause was the opening of the reactor building inner track bay personnel door which created a pressure differential and caused the outer track bay door to move due to a faulty latch mechanism.

The personnel door was shut and secondary containment restored.

Long term corrective action includes:

- a) Posting of an operator aid to provide guidance on proper door operation and
- b) Investigation into an improved latching mechanism.

8503220405 850310 PDR ADOCK 05000333 S PDR

(9-83)

IE27

NRC Form 366A

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OM8 NO. 3150-0104 EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)			L	ER NUMBER (6)	PAGE (3)		
JAMES A. FITZPATRICK			YEAR		SEQUENTIAL NUMBER	REVISION NUMBER		
NUCLEAR POWER PLANT	0 5 0 0 0 3 3	3	815	_	0 0 5	01.0	012 OF	0 1

TEXT (If more space is required, use additional NRC Form 366A's) (17)

During full power operation the reactor building inner track bay personnel door was opened which, due to a differential pressure, caused the outer track bay door to move, break its seal, and cause a loss of reactor building differential pressure. This is indicative of an apparent loss of secondary containment integrity. The personnel door was closed and differential pressure restored within 30 seconds.

The cause of the containment integrity loss was a faulty latch mechanism on the outer door which, during a prior operation, had indicated fully shut. This indication allowed the outer door seal to be inflated and the track bay door interlock to be met.

Repair of the outer door mechanism was performed. Long term corrective action includes the posting of operator aid to provide guidance on proper door operation and investigation into an improved latching mechanism.

Harold A. Glovier Resident Manager



March 11, 1985 JAFP 85-0236

United States Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

REFERENCE: DOCKET NO. 50-333 Licensee Event Report: 85-005-00

Dear Sir:

We have enclosed the referenced Licensee Event Report in accordance with 10CFR50.73.

If there are any questions concerning this report, please contact Mr. William Fernandez at (315) 342-3840, Extension 300.

H. A. GLOVIER

HAG: WF: dmh

Enclsure

CC: USNRC, Region I (1)
INPO Records Center, Altanta, Georgia (1)
Internal Power Authority Distribution
American Nuclear Insurers (1)
NRC Resident Inspector
Document Control Center
LER/OR File

1E22