OPERATING DATA REPORT

DOCKET NO. 050-0261 COMPLETED BY A. E. SCOTT TELEPHONE (803)383-4524

There are presently 222 Fuel

Assemblies in the Spent Fuel

Pool.

. UNIT NAME: ROBINSON UNIT 2

2. REPORTING PERIOD: FEBRUARY 85

3. LICENSED THERMAL POWER (MWT): 2300

4. NAMEPLATE RATING (GROSS MWE): 739.0

5. DESIGN ELECTRICAL RATING (NET MWE): 700.0

6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0

7. MAX DEPENDABLE CAPACITY (NET MWE): 665.0

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS:

9. FOWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): None

10. REASONS FOR RESTRICTION IF ANY: None

	2IHT HTMOM	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD 12. NUMBER OF HOURS REACTOR CRITICAL 13. REACTOR RESERVE SHUTDOWN HRS 14. HOURS GENERATOR ON LINE 15. UNIT RESERVE SHUTDOWN HOURS 16. GROSS THERMAL ENERGY GEN. (MWH) 17. GROSS ELEC. ENERGY GEN. (MWH) 18. NET ELEC. ENERGY GENERATED (MWH) 19. UNIT SERVICE FACTOR 20. UNIT AVAILABILITY FACTOR 21. UNIT CAP. FACTOR (USING MDC NET) 22. UNIT CAP. FACTOR (USING DER NET) 23. UNIT FORCED OUTAGE RATE 24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS	672.00 421.65 250.35 413.37 .00 797932.56 261158.00 245904.00 61.51 61.51 55.03 52.28 38.49 (TYPE, DATE,	54.32	122646.00 84851.15 2672.54 82617.92 23.20 163812767.52 52649282.00 49687648.00 67.36 67.38 60.92 57.88 15.65 0F EACH):

None

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP: 03/01/85 26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORCAST

INITIAL ELECTRICITY

8503220470 850228

APPENDIX B AVERAGE DAILY POWER LEVEL

DOCKET NO. 050-0261 UNIT ROBINSON UNIT 2 DATE 03/01/85 COMPLETED BY A. E. SCOTT TELEPHONE (803)383-4524

FEBRI	JARY 1985		
DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-4	17	648
2	-4	18	692
3	-4	19	650
4	-4	20	631
5	-4	21	709
6	-4	22	728
7	-4	23	721
8	-11	24	603
9	-21	25	739
10	82	26	738
11	357	27	539
12	362	28	-25
13	-508		
14	529		
15	531		
16	564		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. UNIT NAME DATE

050-0261 H. B. Robinson 850301

COMPLETED BY A. E. Scott 803-383-4524 TELEPHONE

REPORT MONTH February

No.	Date	Type1	Duration (Hours)	Reason -	Method of Shutting Down Reactor3	Licensee Event Report #	System Code4	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0201	850116	F	228.53	Н	1	85-06	SH	SUPORT	Unit removed from line due to seismic restraint repairs. Reanalysis of restraint performed to ensure that appropriate safety factors are maintained. Unit returned on line 02-10-85.
0202	850219	F		Н	4		СН	PUMPXX	Unit was at 100% power when heater drain pumps tripped due to low heater drain tank level while removing level control valve at discharge of heater drain pump from service. Low level was due to drain tank level control valve to the condenser being stuck shut, thereby permitting drain tank level to rise. The valve was freed causing a rapid drop in level, thus causing the pumps

F: Forced

S. Scheduled

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scrain.

3-Automatic Scram.

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

Exhibit 1 - Same Source

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

UNIT NAME DATE

DOCKET NO.

050-0261 H. B. Robinson 850301

REPORT MONTH February

A. E. Scott COMPLETED BY 803-383-4524 **TELEPHONE**

No.	Date	Type1	Duration (Hours)	Reason-	Method of Shutting Down Reactor-3	Licensee Event Report #	System Code4	Component Code5	Cause & Corrective Action to Prevent Recurrence
0202	850219	F		Н	4		СН	PUMPXX	to trip. Unit load was decreased to 85% power to compensate. Level control valves were subsequently returned to normal problem free operation. Return to full load was delayed due to the transient causing secondary chemistry problems. Condensate polisher demineralizers were regenerated allowing cleanup of the secondary water. Unit returned to full load.
0203	850227	F	30.10	A	3	85-09	EA	TRANSF	"C" main transformer lightning arrestor failure resulted in a loss of a phase/generator lockout, which caused a reactor trip. "C" main transformer lightning arrestor was repaired.

F: Forced S: Scheduled

Reason:

A-Equipment Failure (Explain) B-Maintenance of Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

Exhibit 1 - Same Source

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. UNIT NAME H. B. Robinson 850301

COMPLETED BY A. E. Scott 803-383-4524

REPORT MONTH February

No.	Date	Type1	Duration (Hours)	Reason-	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code4	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0204	850223	S		В	4		ZZ	TURBIN	Unit load reduced to 65% reactor power to perform bi-weekly turbine valve test. Upon completion of test the unit returned to full load.

F: Forced S: Scheduled

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit I - Same Source

(9/77)

Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

MAR 8 1985

Robinson File: 15505 Serial: RSEP/85-525

Mr. James M. Taylor, Director Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

ROBINSON NUCLEAR PROJECT DEPARTMENT UNIT NO. 2

DOCKET NO. 50-261

LICENSE NO. DPR-23

MONTHLY OPERATIONS REPORT

Dear Mr. Taylor:

In accordance with Technical Specifications 6.9.1.c for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power & Light Company herewith submits the report of operation statistics and shutdown experience for the month of February 1985.

Very truly yours,

General Manager
H. B. Robinson SEG Plant

AES:sr/C-240

Enclosure

cc: R. A. Hartfield (2)

J. N. Grace (1)

IE24