




KANSAS GAS AND ELECTRIC COMPANY

GLENN L. KOESTER
VICE PRESIDENT - NUCLEAR

January 3, 1985

Mr. R.P. Denise, Director
Wolf Creek Task Force
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 85-002
Re: Docket No. STN 50-482
Ref: Interim Report KMLNRC 83-161 dated
12/07/83 from GLKoester, KG&E, to
JEGagliardo, NRC
Subj: Interim Status Report for Wolf Creek
Generating Station 10CFR50.55(e) Items

Dear Mr. Denise:

Attached is a copy of Kansas Gas and Electric Company's Status Report for December, 1984, on 10CFR50.55(e) items. The format and purpose of this report were described in the Reference.

If you have any questions concerning this subject, please contact me or Mr. Otto Maynard of my staff.

Yours very truly,

Glenn L. Koester

GLK:bb
Attach
xc:RCDeYoung, w/a
PO'Connor (2), w/a
HBundy, w/a

8501150401 850103
PDR ADOCK 05000482
S PDR

IE-27

Status Report

On

10CFR50.55(e)/Part 21 Open Items

December 27, 1984

- I. Legend
- II. Status of KG&E Reported Items
- III. Status of SNUPPS Reported Items

I. LEGEND

File: QA Record File Number

Title: Title or Subject Matter

Reported: When Deficiency Was Initially Reported to NRC

Status: Status

RPT: NRC Inspection Report Reference

OPEN - Concern has not been resolved

FINAL - Final report has been submitted but corrective action has not been completed or closure documentation has not been through final review.

REVIEW - Ready for NRC review. All corrective actions completed or evaluation has determined that this item is not reportable pursuant to 50.55(e)/ Part 21.

*CLOSE - Has been reviewed and recommended for closure by the NRC. No inspection report has been received.

CLOSED - The NRC has reviewed and closed this item.

II. Status of Significant Deficiencies Report by KG&E

10CFR50.55(a) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
53564-K005	ESWS DAMAGED VALVE OPERATOR	79/02/15	*CLOSE 84-44	KMLNRC XX-XXX,79/03/14	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K026	MASONRY WALLS - MISALIGNED REBAR	79/12/19	*CLOSE 84-44	KMLNRC XX-XXX,80/01/24 KMLNRC XX-XXX,80/04/30 KMLNRC 80-009,80/06/27 KMLNRC 80-030,80/09/30 KMLNRC 80-042,80/11/28 KMLNRC 81-072,81/06/29 KMLNRC 81-139,81/11/24 KMLNRC 82-180,82/03/25	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K052	GENERAL ELECTRIC AKR 30 AND 50 BREAKERS	81/04/02	REVIEW	KMLNRC 81-074,81/04/30	THIS ITEM IS PRESENTLY READY FOR REVIEW BY THE NRC.
53564-K065	WESTINGHOUSE POST ACCIDENT INSTRUMENTATION ERRORS	82/04/08	*CLOSE 84-44	KMLNRC 82-196,82/05/04 KMLNRC 82-211,82/06/09 KMLNRC 82-250,82/11/03 KMLNRC 83-018,83/03/01 KMLNRC 83-084,83/07/01	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K068	DANIELS TEST FOR WELDING INSPECTORS	82/07/12	*CLOSE 84-49	KMLNRC 82-234,82/08/11 KMLNRC 82-247,82/10/20 KMLNRC 83-013,83/01/31 KMLNRC 83-049,83/03/25 KMLNRC 83-114,83/08/26 KMLNRC 83-157,83/11/28 KMLNRC 84-134,84/08/06	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K101	VULKENE SUPREME CABLE	83/06/20	*CLOSE 84-44	KMLNRC 83-093,83/07/20 KMLNRC 83-125,83/09/28 KMLNRC 83-151,83/11/23 KMLNRC 84-185,84/10/17	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K103	SWAY STRUT WASHERS	83/07/15	*CLOSE 84-49	KMLNRC 83-104,83/08/12 KMLNRC 83-143,83/11/03 KMLNRC 84-165,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K106	GOULD - RUNDELL HANDSWITCHES	83/08/24	*CLOSE 84-49	SLNRC 84-028,84/02/09 SLNRC 84-067,84/04/13 SLNRC 84-103,84/07/20	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K112	POLAR CRANE TESTING	83/11/18	REVIEW	KMLNRC 83-165,83/12/16 KMLNRC 84-164,84/09/21	AWAITING COMPLETION OF NRC REVIEW.
53564-K113	CABLE TERMINATION LUGS	83/11/18	*CLOSE 84-44	KMLNRC 83-164,83/12/16 KMLNRC 84-090,84/06/15	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K114	I - BEAMS	83/12/01	*CLOSE 84-49	KMLNRC 83-170,83/12/30 KMLNRC 84-184,84/10/17	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K116	PIPE SCHEDULE	83/12/13	*CLOSE 84-55	KMLNRC 84-005,84/01/12	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.

10CFR50.55(a) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
53564-K118	FIELD PROCUREMENT	84/01/03	REVIEW	KMLNRC 84-011,84/02/02	AWAITING COMPLETION OF NRC REVIEW.
53564-K120	FUSION WELDED PIPE	84/01/20	*CLOSE 84-49	KMLNRC 84-018,84/02/17 KMLNRC 84-163,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K121	LIMITORQUE OPERATORS	84/02/03	REVIEW	KMLNRC 84-024,84/03/01	FINAL REPORT IN JANUARY.
53564-K122	CHECK VALVES	84/02/06	*CLOSE 84-49	KMLNRC 84-027,84/03/07 KMLNRC 84-166,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K126	DIESEL GENERATOR LUBE OIL KEEP WARM PUMP	84/03/09	*CLOSE 84-55	KMLNRC 84-056,84/04/05	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K127	VALCOR WIRING	84/03/15	*CLOSE 84-49	SLNRC 84-065,84/04/13 SLNRC 84-079,84/05/10	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K128	FAN MECHANICAL INTERLOCKS	84/03/16	REVIEW	KMLNRC 84-061,84/04/11	THIS ITEM IS READY FOR NRC REVIEW.
53564-K132	SEISMIC POSITIONER PLATES ON DS-416 REACTOR TRIP BREAKERS	84/03/27	*CLOSE 84-44	KMLNRC 84-071,84/04/26 KMLNRC 84-160,84/09/21	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K133	CONTAINMENT SPRAY PUMP ROOM FLOODING	84/03/27	*CLOSE 84-44	KMLNRC 84-072,84/04/26 KMLNRC 84-178,84/10/08	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K135	BARTON 752 TRANSMITTERS	84/04/24	FINAL	KMLNRC 84-078,84/05/23 KMLNRC 84-177,84/10/08	AWAITING NRC REVIEW.
53564-K138	DIESEL GENERATOR TURBOCHARGER	84/05/04	OPEN	KMLNRC 84-083,84/06/01	FINAL REPORT IN JANUARY.
53564-K139	TMI LEAD AUDITOR	84/05/24	*CLOSE 84-55	KMLNRC 84-098,84/06/21	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K140	THREE HOUR FIRE DOORS	84/05/24	REVIEW	KMLNRC 84-097,84/06/21	THIS ITEM IS READY FOR NRC REVIEW.
53564-K141	MICROBIOLOGICALLY INDUCED CORROSION	84/06/01	OPEN	KMLNRC 84-106,84/06/29	FINAL REPORT IN JANUARY.
53564-K143	ASME COMPONENT REMOVAL	84/06/13	OPEN	KMLNRC 84-115,84/07/11	FINAL REPORT IN JANUARY.
53564-K146	LIMITORQUE SB-2-80 ACTUATOR GEAR DAMAGE	84/04/19	*CLOSE 84-55	SLNRC 84-090,84/06/01 SLNRC 84-106,84/07/20 SLNRC 84-126,84/11/15	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K147	LUBE OIL PIPING SYSTEM	84/07/17	*CLOSE 84-55	KMLNRC 84-147,84/08/17	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K148	RCS RTD CALIBRATION DATA	84/08/01	*CLOSE 84-55	KMLNRC 84-158,84/08/31	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K149	INCORE THERMOCOUPLE ADAPTOR CABLES	84/08/06	*CLOSE 84-55	KMLNRC 84-159,84/09/05	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K150	TC/CCM ALARM AND CAUTION RELAYS	84/08/21	OPEN	KMLNRC 84-162,84/09/20	FINAL REPORT IN JANUARY.

10CFR50.55(e) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
53564-K151	MECHANICAL SHOCK ARRESTORS	84/08/23	REVIEW	KMLNRC 84-168,84/09/21	THIS ITEM IS READY FOR REVIEW BY THE NRC.
53564-K152	INSPECTION OF WELDS	84/09/18	OPEN	KMLNRC 84-187,84/10/17 KMLNRC 84-191,84/10/29	COMPLETION OF WORK AND FINAL REPORT ON THIS ITEM IN JANUARY.
53564-K153	TURBINE DRIVEN AUXILIARY FEEDWATER PUMP TERMINAL STRIP	84/07/17	*CLOSE	84-44 KMLNRC 84-188,84/10/22	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
53564-K154	EXCORE NEUTRON DETECTORS	84/10/09	*CLOSE	84-55 KMLNRC 84-195,84/11/09	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K155	PRESSURIZER POWER OPERATED RELIEF VALVES	84/10/11	*CLOSE	84-55 KMLNRC 84-196,84/11/13	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
53564-K156	TURBINE DRIVEN AUXILIARY FEEDWATER PUMP GUIDE STEM BUSHING	84/10/17	*CLOSE	84-49 KMLNRC 84-192,84/11/16	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
53564-K157	MAIN STEAM ISOLATION VALVE LOCKWASHERS	84/12/07	OPEN		30 DAY REPORT TO BE SUBMITTED ON OR BEFORE 85/01/04.
53564-K158	ASME HANGERS AND COMPONENT SUPPORTS	84/12/12	OPEN		30 DAY REPORT TO BE SUBMITTED BY 85/01/...
53564-K159	CONTAINMENT FLOOR COATING	84/12/13	OPEN		30 DAY REPORT TO BE SUBMITTED BY 85/01/11.

III. Status of SNUPPS Reported Items

10CFR 2.55(e) / PART 21 ITEMS

FILE	TITLE	REPORTED STATUS	RPT.	REFERENCES	REMARKS
55780-K007	RUSKIN FIRE DAMPERS	80/01/18 *CLOSE	84-49	SLNRC 80-008,80/02/15 SLNRC 80-016,80/04/03 SLNRC 80-024,80/05/16	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
55780-K024	WESTINGHOUSE EMD GATE VALVES	80/10/30 *CLOSE	84-44	SLNRC 80-054,80/11/26 SLNRC 81-022,81/04/01 SLNRC 82-038,82/09/03	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
55780-K026	PIPE WHIP RESTRAINTS (FOUR INCHES AND UNDER)	80/12/24 *CLOSE	84-55	SLNRC 81-043,81/06/05	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
55780-K033	REACTOR TRIP SWITCHGEAR	83/04/21 *CLOSE	84-44	SLNRC 83-028,83/05/23	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.
55780-K034	WESTINGHOUSE 7300 PROCESS SYSTEM	83/06/02 *CLOSE	84-55	SLNRC 83-039,83/07/21 SLNRC 84-007,84/01/24	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-55.
55780-K035	YARWAY VALVES	83/06/17 *CLOSE	84-49	SLNRC 83-037,83/07/18 SLNRC 83-043,83/07/29	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
55780-K036	EXCESSIVE VOLTAGE DROP IN CONTROL CABLES	83/06/23 *CLOSE	84-49	SLNRC 83-040,83/07/22	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-49.
55780-K037	HANGER CLASSIFICATION	83/10/23 *CLOSE	84-44	SLNRC 83-060,83/11/22 SLNRC 84-006,84/01/20	REVIEWED AND RECOMMENDED FOR CLOSURE. PENDING RECEIPT OF INSPECTION REPORT 84-44.