

114

KIRKPATRICK & LOCKHART

RELATED CORRESPONDENCE

1900 M STREET, N.W.
WASHINGTON, D.C. 20036
TELEPHONE (202) 452-7000
TELEX 440209 HPH UI
TELECOPIER (202) 452-7052

SEARCHED
SERIALIZED

ONE BOSTON PLACE
BOSTON, MA 02108
(617) 973-5400

'85 JAN 15 A10:27

BRICKELL AVENUE
MIAMI, FL 33131
(305) 374-8112

OFFICE
DOCKET & SERVICE
BRANCH

1500 OLIVER BUILDING
PITTSBURGH, PA 15222
(412) 355-6500

WRITER'S DIRECT DIAL NUMBER

(202) 452-7060

January 14, 1985

BY HAND

Lawrence J. Brenner, Esquire
Dr. Peter A. Morris
Administrative Judges
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. George A. Ferguson
School of Engineering
Howard University
2300 Sixth Street, N.W.
Washington, D.C. 20059

Re: Long Island Lighting Company;
Shoreham Nuclear Power Station,
Unit 1; Docket No. 50-322-OL

Gentlemen:

Suffolk County hereby informs the Board and parties that it withdraws the crankshaft contention insofar as it challenges the adequacy of the replacement crankshafts at 3300 KW. This action is based on calculations which indicate that the crankshafts comply with the standards of Lloyd's Register, the American Bureau of Shipping and the Diesel Engine Manufacturer's Association at 3300 KW.

We are authorized to state that the State of New York has no objection to the withdrawal of the crankshaft issue to the limited extent described above.

Sincerely,


Joseph J. Brigati

8501170135 850114
PDR ADOCK 05000322
G PDR

JJB:so
cc: Service List

DS03