

MAR 27 1985

Docket No. 50-219/DPR-16

GPU Nuclear Corporation
ATTN: Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
P. O. Box 388
Forked River, NJ 08731

Gentlemen:

Subject: Inspection 50-219/85-03

This letter refers to the special safety inspection by Mr. E. Kelly on January 8, 1985, at the United Engineers and Constructors, Inc. Philadelphia, Pennsylvania office. The inspection consisted of a review of calculations and the results of your shielding study in response to NUREG-0737, Item II.B.2 for Oyster Creek. The findings were discussed with Mr. M. Laggart of your staff at the conclusion of the inspection.

With the exception of one item, your shielding study was found to meet the requirements of TMI Item II.B.2. Therefore, all open items associated with your study, previously documented in Inspection Report 83-13, have been closed. However, the results of your study predict a whole body dose of 62 Rem inside of the main security building. This will be carried as an open item until you propose an acceptable resolution.

No reply is required, and your cooperation with us in this matter is appreciated.

Sincerely,

8504020274 850327
PDR ADOCK 05000219
G PDR

Original signed by:
Harry B. Kister, Chief
Projects Branch No. 1
Division of Reactor Projects

Enclosure:
NRC Region I Report 50-219/85-03

cc w/encl:
M. Laggart, BWR Licensing Manager
Licensing Manager, Oyster Creek
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New Jersey

1E01 1/1

bcc w/encl:
Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encl)
E. Tourigny, NRR
J. Donahew, NRR
Director, DRS
Director, DRSS
DRP Section Chief

Am Kelly
RI:DRP
Kelly/dmg
3/25/85
3/25

[Signature]
RI:DRP
Strosnider
3/25

WB
RI:DRP
Baunack
3/24

[Signature]
RI:DRP
Kister
3/26