

APPENDIX A

NOTICE OF VIOLATION

Gulf States Utilities  
River Bend Station

Docket: 50-458/85-07  
Permit: CPPR-145

Based on the results of an NRC inspection conducted during the period of January 1 through February 28, 1985, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8587, dated March 8, 1984, the following violation was identified:

Failure to Implement Procedures

10 CFR Part 50, Appendix B, Criterion V, and the licensee's approved quality assurance program require that activities affecting the quality of safety-related systems and components be conducted in accordance with approved instructions, procedures, and drawings.

The spent fuel storage area is classified as a Class B cleanliness system in accordance with Regulatory Guide 1.37, which requires the surface to be free of particulate contaminates such as sand, metal chips, weld slag, etc.

Contrary to the above, procedures were not implemented to maintain Class B cleanliness requirements in the spent fuel storage area where the new fuel was to be stored in accordance with the Special Nuclear Material License issued on January 15, 1985. The spent fuel pool floor surface beneath the spent fuel racks contained scattered dirt and debris such as concrete chips, nails, wire, etc.

This is a Severity Level IV Violation. (Supplement II D) (458-8507-01)

Pursuant to the provisions of 10 CFR 2.201, Gulf States Utilities is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: MAR 22 1985

8504050095 B50322  
PDR ADDCK 0500045B  
Q PDR