

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company
Limerick Generating Station, Unit 1

Docket Nos. 50-352
License No. NFP-27

As a result of the inspection conducted on November 13 - December 4, 1984, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), the following violation was identified:

Technical Specification 6.8 requires that written procedures be established, implemented, and maintained covering, among other activities, surveillance and test activities of safety-related equipment. Surveillance Test Procedure ST-2-078-402-0, provides requirements for calibrating safety-related chlorine detectors located in the air intake of the Control Enclosure. Section 6 of this procedure requires that "As Found" chlorine detector readout data be compared with the acceptance limits found in Tables 1 through 4 of the procedure. If "As Found" data is found not to be within the specified limits, the detector is to be recalibrated, or if recalibration cannot be performed satisfactorily, shift supervision is to be notified and the detector is to be repaired and/or replaced.

Contrary to the above, during performance of ST-2-078-402-0, on November 1, 1984 "C" chlorine detector "As Found" trip set point exceeded the acceptance limit specified in Table 2 of the procedure, and the detector was not recalibrated; shift supervision was not notified and the detector was not repaired or replaced.

This is a Severity Level IV violation. (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8501210162 850114
PDR ADDCK 05000352
Q PDR

Limerick Hearing Service List

Judge Helen F. Hoyt
Atomic Safety and Licensing
Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Judge Richard F. Cole
Atomic Safety and Licensing
Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Judge Jerry Harbour
Atomic Safety and Licensing
Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Atomic Safety and Licensing
Appeal Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Mr. Frank R. Romano
61 Forest Avenue
Ambler, Pennsylvania 19002

Mr. Robert L. Anthony
Friends of the Earth of
the Delaware Valley
P.O. Box 186
103 Vernon Lane
Moylan, PA 19065

Mr. Marvin I. Lewis
6504 Bradford Terrace
Philadelphia, PA 19149

Phyllis Zitner
LER
P.O. Box 761
Pottstown, PA 19464

Docketing and Service Station
Office of the Secretary
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Ann P. Hodgdon, Esq.
Benjamin H. Vogler, Esq.
Counsel for NRC Staff
Office of the Executive
Legal Director
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Philadelphia Electric Company
ATTN: Edward G. Bauer, Jr.
Vice President &
General Counsel
2301 Market Street
Philadelphia, PA 19101

David Wersan, Esq. Consumer
Assistant Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Steven P. Hershey, Esq.
Community Legal Services,
Inc.
Law Center
North Central Beury Bldg.
3701 North Broad Street
Philadelphia, PA 19140

Angus Love, Esq.
101 East Main Street
Norristown, PA 19401

Mr. Joseph H. White, III
15 Ardmore Avenue
Ardmore, PA 19003

Charles W. Elliott, Esq.
Brose and Postwistilo
1101 Building
11th & Northampton Street
Easton, PA 18042

Robert J. Sugarman, Esq.
Sugarman & Denworth Suite
101 North Broad Street
Center Plaza - 16th Floor
Philadelphia, PA 19107

Director, Pennsylvania
Emergency Management Agency
Basement, Transportation
and Safety Building
Harrisburg, PA 17120

Thomas Y. Au, Esq.
Assistant Counsel
Commonwealth of Pennsylvania
DER
505 Executive House
P.O. Box 2357
Harrisburg, PA 17120

Martha W. Bush, Esq.
Kathryn S. Lewis, Esq.
City of Philadelphia
Municipal Services Bldg.
15th and JFK Blvd.
Philadelphia, PA 19107

Thomas Gerusky, Director
Bureau of Radiation
Protection
Department of Environmental
Resources
5th Floor, Fulton Bank Bldg.
Third and Locust Streets
Harrisburg, PA 17120

Spence W. Perry, Esq.
Associate General Counsel
Federal Emergency
Management Agency
500 C Street, S.W., Rm. 840
Washington, D.C. 20472

Jay M. Gutierrez, Esq.
U.S. Nuclear Regulatory
Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Troy B. Conner, Jr., Esquire
Mark J. Wetterhahn, Esquire
Conner & Wetterhahn
1747 Pennsylvania Ave
Washington, D.C. 20006

U.S. Nuclear Regulatory Commission
ATTN: Mr. J. T. Wiggins
Senior Resident Inspector
P.O. Box 47
Sanatoga, PA 19464