



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 24, 1996

Carl D. Terry, Vice-President  
Nuclear Engineering  
Niagara Mohawk Power Company  
Post Office Box 63  
Lycoming, NY 13093

Dear Mr. Terry:

On Tuesday, April 30, 1996, you and I spoke via conference call on several subjects, including issues related to full implementation of actions required to address the suction strainer bulletin by the end of the first refueling outage after January 1, 1997, the Boiling Water Reactors Vessel & Internals Project (BWRVIP) proposal to reduce requirements for beltline inspections of the reactor vessel, and a Nine Mile Point Unit 1 plant-specific Technical Specification (TS) change request. I would like to take this opportunity to clarify my remarks.

Regarding the suction strainer issue, on May 6, 1996, the staff issued NRC Bulletin 96-03, "Potential Plugging of Emergency Core Cooling Suction Strainers by Debris in Boiling-Water Reactors." The bulletin requests holders of operating licenses or construction permits for boiling-water reactors (BWR), except Big Rock Point and holders of possession-only licenses, to implement appropriate procedural measures and plant modifications to minimize the potential for clogging of emergency core cooling system (ECCS) suppression pool suction strainers by debris generated during a loss-of-coolant accident (LOCA). The bulletin also requires two responses from addressees. The first response is to notify the NRC whether and to what extent the requested actions will be taken. This response is due 180 days from the date of the bulletin. The second required response is to notify the NRC when any actions associated with this bulletin are complete.

All licensees are requested to implement the actions associated with the bulletin by the end of the first refueling outage commencing after January 1, 1997. Recently, you and other members of the BWROG have raised concerns regarding whether or not utilities having refueling outages during the spring of 1997 will be able to meet the requested implementation deadline. Your concerns have been based primarily on two main points. The first is whether or not a licensee proposing a modification has an unreviewed safety question which must be first reviewed and approved by the NRC before the licensee can implement the modification. The second is whether or not licensees have sufficient lead time to accomplish the design and procurement to support their modifications. The staff will work with the BWROG to resolve these questions, and will review extension requests on a plant specific basis. The staff notes that the bulletin's implementation date was selected because it was believed that licensees (particularly those with primarily reflective metallic insulation) could bound the problem and implement appropriate action. In

9606280167 960624  
PDR ADOCK 05000220  
P PDR

96-46 ID#A5 Facility  
Licenses  
RETURN TO REGULATORY CENTRAL FILES

DF03  
10

fact, at least one licensee appears to be doing just that. Lead time for strainer procurement appears to be that utility's main problem.

In regard to extension requests, licensees are cautioned that the staff will expect licensees to demonstrate that they have attempted to take expeditious action in response to the bulletin, and are unable to meet the implementation date for reasons beyond their control. Licensee requests for extensions in implementation should include a discussion on any compensatory measures taken by the licensee, and licensees should implement any portions of their resolution plan that they can (e.g., suppression pool cleaning, installation of components that they are able to procure in time for their refueling outage, etc.).

Regarding the BWRVIP proposal to reduce requirements for beltline inspections of the reactor vessel, the NRC staff is presently reviewing the EPRI Topical Report TR-105697, "BWR Vessel and Internals Project, BWR Reactor Pressure Vessel Shell Weld Inspection Recommendations (BWRVIP-05)," dated September 28, 1995. To aid in this review, the NRC staff has sent two requests for additional information (RAIs), dated April 2, and May 20, 1996. As stated in the second RAI, the staff's position is that the augmented inspection requirements of 10 CFR 50.55a(g)(6)(ii)(A)(3) are still appropriate and that all BWR licensees should perform inspections per this regulation.

This position is based on the fact that most earlier BWR vessels did not receive baseline inspections, few BWR vessels have received beltline inservice weld examinations, and previous reliefs granted because of inaccessibility are no longer warranted based on improved inspection technology. Nonetheless, the staff is continuing review of this report in that it may provide additional technical support for granting limited relief under 10 CFR 50.55a when the coverage requirement of "more than 90% of the examination volume of each weld" cannot be fully met due to physical interferences.

Further, the staff, including myself and William Russell, has agreed to a meeting on July 11, 1996, with you and other members of the BWRVIP, to discuss the technical merits of the BWRVIP-05 proposal.

Regarding the Nine Mile Point Unit 1 plant-specific TS change request on scram solenoid pilot valve (SSPV) testing, several BWR plants have noted the trend toward slower scram insertion times to notch 46 (5-percent insertion) after about 6 months in service. It is believed that the slow scram times resulted from adherence of the exhaust Viton diaphragm to the brass valve seat in the Dual-type SSPVs. The BWR Owners Group RRG issued interim recommendations to address the Viton SSPV response time delay issue on February 16, 1996, which supplement the requirements in each utility's current TSs. General Electric and ASCO are currently pursuing three potential hardware alternatives to the Viton diaphragm. In addition, we understand that the industry has not ruled out the option of an analytical solution to allow an increase in the 5-percent scram insertion time.

In this regard, several licensees have recently made inquiries to the NRC staff about amendments to the TSs which would increase the 5-percent scram

C. Terry

-3-

time while maintaining the other scram insertion times (e.g., 20-, 50-, and 90-percent scram insertion times). Although the NRC staff recognizes that the 5-percent insertion time does not affect a safety limit, the NRC staff believes that it is important for indication of SSPV degradation. Therefore, the NRC staff will not entertain changes to the 5-percent scram insertion time technical specification at this time.

I trust that the above more fully clarifies the NRC staff's position on the three topics we discussed. However, if further technical information is required, please feel free to contact Mr. Robert Elliott at (301) 415-1397 regarding suction strainer issues, Mr. C. E. (Gene) Carpenter, Jr. at (301) 415-2169 regarding BWRVIP issues, or Ms. Kerri Kavanagh at (301) 415-3743 regarding SSPV testing.

Sincerely,

151

Ashok C. Thadani, Associate Director  
for Technical Review  
Office of Nuclear Reactor Regulation

Central File  
PUBLIC  
NRR/EMCB Reading  
ADT RF

W. Russell/F. Miraglia  
M. E. Mayfield (RES)  
ACRS (4)  
D. S. Hood

R. P. Zimmerman  
E. L. Jordan (AEOD)  
OPA

B. K. Grimes  
R. B. Elliott  
K. A. Kavanagh

DOCUMENT NAME: G:\BWRVIP\CTERRY.LTR

\*SEE PREVIOUS CONCURRENCE

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

EMCB:LPM	E	EMCB:BC	E	SRXB:BC		SCSB:BC	
CECarpenter*		JRStrosnider*		RCJones*		CHBerlinger*	
06/18/96		06/18/96		06/20/96		06/19/96	
DSSA:D		DEAD	E	DEG		ADT:AD	B 2 E
GMHolahan*		BSNeron				ACThadani	B for
06/21/96		6/24/96		/96		6/24/96	

RECORD COPY

C. Terry

time while maintaining the other scram insertion times (e.g., 20-, 50-, and 90-percent scram insertion times). Although the NRC staff recognizes that the 5-percent insertion time does not affect a safety limit, the NRC staff believes that it is important for indication of SSPV degradation. Therefore, the NRC staff will not entertain changes to the 5-percent scram insertion time technical specification at this time.

I trust that the above more fully clarifies the NRC staff's position on the three topics we discussed. However, if further technical information is required, please feel free to contact Mr. Robert Elliott at (301) 415-1397 regarding suction strainer issues, Mr. C. E. (Gene) Carpenter, Jr. at (301) 415-2169 regarding BWRVIP issues, or Ms. Kerri Kavanagh at (301) 415-3743 regarding SSPV testing.

Sincerely,

151

Ashok C. Thadani, Associate Director  
for Technical Review  
Office of Nuclear Reactor Regulation

Central File  
PUBLIC  
NRR/EMCB Reading  
ADT RF

W. Russell/F. Miraglia  
M. E. Mayfield (RES)  
ACRS (4)  
D. S. Hood

R. P. Zimmerman  
E. L. Jordan (AEOD)  
OPA

B. K. Grimes  
R. B. Elliott  
K. A. Kavanagh

DOCUMENT NAME: G:\BWRVIP\CTERRY.LTR

\*SEE PREVIOUS CONCURRENCE

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

EMCB:LPM	E	EMCB:BC	E	SRXB:BC		SCSB:BC	
CECarpenter*		JRStrosnider*		RCJones*		CHBerlinger*	
06/18/96		06/18/96		06/20/96		06/19/96	
DSSA:D		DE: D	E	DGS		ADT:AD	B 24 E
GMHolahan*		BWSheron				ACThadani	B for
06/21/96		6/24/96		1/96		6/24/96	

RECORD COPY

Recently, several licensees have made inquiries to the NRC staff about amendments to the TSs which would increase the five percent scram time while maintaining the other scram insertion times (e.g. twenty, fifty, and ninety percent scram insertion times). Although the NRC staff recognizes that the five percent insertion time does not affect a safety limit, the NRC staff believes that it is important for indication of SSPV degradation. Therefore, the NRC staff will not entertain changes to the five percent scram insertion time technical specification at this time.

I trust that the above more fully clarifies the NRC staff's position on the three topics we discussed. However, if further technical information is required, please feel free to contact Mr. Robert Elliott at (301) 415-1397 regarding suction strainer issues, Mr. C. E. (Gene) Carpenter, Jr. at (301) 415-2169 regarding BWRVIP issues, or Ms. Kerri Kavanagh at (301) 415-3743 regarding SSPV testing.

Sincerely,

Ashok C. Thadani, Associate Director  
for Technical Review

cc w/encls:  
Central File  
PUBLIC  
NRR/EMCB Reading

cc w/o encls:  
W. Russell/F. Miraglia  
M. E. Mayfield (RES)  
ACRS (4)  
D. S. Hood

R. P. Zimmerman  
E. L. Jordan (AEOD)  
OPA

B. K. Grimes  
R. B. Elliott  
K. A. Kavanagh

DOCUMENT NAME: G:\BWRVIP\CTERRY.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

EMCB:LPM	E	EMCB:BC	E	SRXB:BC	SCSB:BC	E
CECarpenter		JR Jones		RCJones	CHBerlinger	NB
06/18/96		6/18/96		6/20/96	6/19/96	BW
DSSA:D		DE:D		OGC	ADT:AD	
GMHolahan		BWSheron			ACThadani	
6/18/96		1/96		1/96	1/96	

RECORD COPY

cc:

J. T. Backham, Jr., BWRVIP Chairman  
Southern Nuclear Operating Co.  
Bin B052 P.O.Box 1295  
42 Inverness Center Parkway  
Birmingham, AL 35242

John Hosmer, Executive Chairman  
BWRVIP Integration Task  
Commonwealth Edison  
1400 Opus Place  
Downers Grove, IL 60515

Robert Keaten, Executive Chairman  
BWRVIP Inspection Task  
GPU Nuclear  
One Upper Pond Road, Bldg F  
Parsippany, NJ 07054

George Jones, Executive Chairman  
BWRVIP Mitigation Task  
Pennsylvania Power & Light  
A6-1  
Two North Ninth Street  
Allentown, PA 18101

Bill Campbell, Executive Chairman  
BWRVIP Repair Task  
Carolina Power and Light Company  
411 Fayetteville Street  
Raleigh, NC 27602

Robin Dyle, Technical Chairman  
BWRVIP Assessment Task  
Southern Nuclear Operating Co.  
Post Office Box 1295  
40 Inverness Center Parkway  
Birmingham, AL 35201

Vaughn Wagoner, Technical Chairman  
BWRVIP Integration Task  
Carolina Power & Light Company  
One Hanover Square 8C1  
P.O. Box 1551  
Raleigh, NC 27612

Steve Leonard, Technical Chairman  
BWRVIP Inspection Task  
Niagara Mohawk Power Company ESBI  
Post Office Box 63  
Lycoming, NY 13093

John Wilson, Technical Chairman  
BWRVIP Mitigation Task  
Public Service Electric & Gas Co.  
N51  
Post Office Box 236  
Hancocks Bridge, NJ 08038

Bruce McLeod, Technical Chairman  
BWRVIP Repair Task  
Southern Nuclear Operating Co.  
Post Office Box 1295  
40 Inverness Center Parkway  
Birmingham, AL 35201

cc:

Mike McDermott  
IES Utilities  
3277 DAEC Road  
Palo, IA 52324

John J. Kelly  
New York Power Authority  
123 Main Street  
White Plains, NY 10601

Vern Oheim  
Boston Edison Company  
600 Rocky Hill Road  
Plymouth, MA 02360

Wilfred Connell  
Illinois Power  
P.O. Box 678  
Clinton, IL 61727-0678

Guy Horn  
Nebraska PPD  
1414 15th Street  
Columbus, NE 68601

Vic Parrish  
Washington Public Power  
MD 1023  
P.O. Box 968  
Richland, WA 99352-0968

Wayne Romberg  
Detroit Edison Co.  
280F2 OBA  
6400 North Dixie Highway  
Newport, MI 48166

Steve Scace  
Northeast Utilities  
P.O. Box 128  
Waterford, CT 06385-0128

Rick Machon  
Tennessee Valley Authority  
M/C PAB 1E BFN  
P.O. Box 2000  
Decatur, AL 35609-2000

Edward Watzi  
Northern States Power  
414 Nicollet Mall, RS8  
Minneapolis, MN 55401

John B. Cotton  
PECO Energy  
M/C 63B1  
965 Chesterbrook Blvd.  
Wayne, PA 19087-5691

Steve Lewis  
Entergy Operations  
P.O. Box 756  
Port Gibson, MS 39150

Donald Shelton  
Cleveland Electric Illuminating  
P.O. Box 97  
Perry, OH 44081

Philip Graham  
NPPD  
P.O. Box 98  
Brownville, NE 68321

Elbert Simpson  
PSE&G  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Jay Thayer  
Yankee Atomic  
580 Main Street  
Bolton, MA 01740

Warren Bilanin, EPRI BWRVIP Manager  
Electric Power Research Institute  
3412 Hillview Ave.  
Palo Alto, CA 94304

Beth McAllister, GE Project Manager  
Mail Code 783  
175 Curtner Ave.  
San Jose, CA 95125