

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



LWP-96-051

June 27, 1996

U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 96-008, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(B). Licensees shall report: "Any operation or condition prohibited by the plant's Technical Specifications."

The following commitment is being made by this letter:

Procedure QCTS 0600-34 will be revised to ensure an appropriate vent path exists when leak rate testing the 2251(2)-81A/B panels. Due October 1, 1996.

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

L. W. Pearce
Station Manager

LWP/NC/plm
Enclosure

cc: P. Piet, Licensing, ComEd
C. Miller, Senior Resident Inspector, Quad Cities
INPO Records Center
H.J. Miller, Regional Administrator, Region III
R.J. Singer, Mid American Energy Company
D.C. Tubbs, Mid American Energy Company
R.M. Pulsifer, Project Manager, NRR

9607010358 960627
PDR ADOCK 05000254
S PDR

STMGR\05196.LWP
A Unicom Company

IE22/1