

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company  
Vogtle Units 1 and 2

Docket Nos. 50-424 and 50-425  
License Nos. CPPR-108 and CPPR-109

The following violation was identified during an inspection conducted on February 11-14, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Appendix B, Criterion III, as implemented by PSAR Chapter 17, Section 17.1.3, requires that measures shall be established to assure that applicable regulatory requirements and design basis for those structures, and components to which this appendix applies are correctly translated into specifications, drawings, procedures, and instructions. Bechtel Power Corporation Specification No. X4AZ01, Division P5, Section 5.9.2, requires documentation and revision of pipe support drawings to reflect "As-Built" conditions and that these drawings be submitted to the Project Engineer for review and acceptance.

Contrary to the above, pipe support drawings are not being revised to document the addition of filler plates and filler plate welds in conjunction with pipe straps. As a result, these design changes are not being submitted to the Project Engineer for review and acceptance.

This is a Severity Level IV violation (Supplement II.D).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: MAR 18 1985

8504150060 850318  
PDR ADOCK 05000424  
Q PDR

Service List for Vogtle

L. T. Gucwa, Chief  
Nuclear Engineer  
Georgia Power Company  
P.O. Box 4545  
Atlanta, Georgia 30302

Ruble A. Thomas  
Vice President-Licensing  
Vogtle Project  
Georgia Power Company/  
Southern Company Services, Inc.  
P.O. Box 2625  
Birmingham, Alabama 35202

J. A. Bailey  
Project Licensing Manager  
Southern Company Services, Inc.  
P.O. Box 2625  
Birmingham, Alabama 35202

George F. Trowbridge, Esq.  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

James E. Joiner  
Troutman, Sanders, Lockerman and Ashmore  
Candler Building  
127 Peachtree Street, N.E.  
Atlanta, Georgia 30303

James G. Ledbetter, Commissioner  
Department of Human Resources  
47 Trinity Avenue  
Atlanta, Georgia 30334

Charles H. Badger  
Office of Planning and Budget  
Management Review Division  
Room 608  
270 Washington Street, S.W.  
Atlanta, Georgia 30334

Deppish Kirkland, III, Counsel  
Office of the Consumers' Utility  
Council  
Suite 225  
32 Peachtree Street, N.W.  
Atlanta, Georgia 30303

Douglas C. Teper  
Georgians Against Nuclear Energy  
1253 Lenox Circle  
Atlanta, Georgia 30306

Laurie Fowler  
Legal Environmental Assistance  
Foundation  
1102 Healy Building  
Atlanta, Georgia 30303

Tim Johnson  
Executive Director  
Educational Campaign for  
a Prosperous Georgia  
175 Trinity Avenue, S.W.  
Atlanta, Georgia 30303