CA	CU	ATI	ON	CON	TR		SH	EET
A.L. 1	10. X. W.	See 111	014	~~!!	111	- In	1	Anno Inco I

Mod./Task No. N/A	ALC-HPCI-02094	Revision 0	IP3 🗆 JAF 🗰
QA Category of Calcu	lation: I Calculation 1	Type: Preliminary	Final X
Project/Task: System No./Name: Title:	Generic Letter 89-10 23/ High Pressure C Reduced Voltage An	MOV Analysis - Availa oolant Injection alysis for 23MOV-19	ble Voltage/ Motor Torque
	Name	Signature	Date
esign Eng.:	Paul Swinburne	Hand Similu	6/9/95
reparer:	Paul Swinburne	Hand Similar	6/9/95
hecker:	F.A. Mulcahy	7. a. Mulea	hey 6-9.95
erified:N/A 🗆	F.A. Mulcahy	1.a. Mulea	lig 6-9-85
pproved:	J. Cameron	filmilla	mero 6-12-95
PROBLEM / OBJEC	TIVE / METHOD	See Page 1	
DESIGN BASIS / AS	SUMPTIONS	See Page 1	
Minimum motor term 88-1 technique, avail to the rated start toro 1.0 (no credit for mor	inal voltage = 81.036 v able motor torque at m que, therefore the reduc re than rated start torq	olts. However, with the inimum voltage was ca ced voltage factor (RVF ue). See page 4 for ad	Elimitorque Maintenace Update loulated as greater than or equal) may be considered as equal to ditional discussion.
REFERENCES		See Page 1	
AFFECTED SYSTEM	IS / COMPONENTS /	DOCUMENTS	
MOV analysis performused to assess MOV	ned in accordance with capability.	n MES-6; the alternate	reduced voltage factor may be
VOIDED OR SUPERSEDED B	Y:(Calc. No.)	FOR REFER	ENCE ONLY
stribution: NED (V CM&EF	VPO); Technical Servic P/DBD (WPO); Other _	ces:IP3,JAF; Site	Engineering:IP3JAF;

9607030242 960627 PDR ADUCK 05000333 P PDR

٦

n

NewYorkPower Authority J.A.FitzPatrick Nuclear Power Plant Calculation No. JAF-CALC-HPCI-02094 Revision 0 Page 1 of 4 Subject: Reduced Voltage Analysis for 23MOV-19

Prepared by: Paul Swinburne 48 Checked by: F.A. Mulcahy 2011

Date: June 9, 1995 Date: 6-9-95

OBJECTIVE:

Determine motor terminal voltage and available motor torque under design basis degraded voltage conditions.

METHOD:

Determine minimum motor terminal voltage with the simple voltage divider analysis of the circuit model shown in the Figure 1 one line diagram. If the calculated motor terminal voltage is less than 90% of rated voltage then determine the reduced voltage factor (RVF). Calculate available motor torque from motor performance curve as described in Limitorque Maintenance Update 88-1 (ref. 13). This technique may be used to justify a higher RVF.

ASSUMPTIONS:

1. Assume cable temperature outside containment is 75°C (this assumption was used for the General Physics Generic Letter 89-10 analyses).

2. Assume EQ qualified BMCC temperatures for the thermal overload relay heaters (for BMCC-6: 131°F or 55°C).

3. Assume cable resistance from the National Electric Code (NEC).

4. Assume locked rotor current at rated voltage from motor nameplate or motor actuator data sheet. 5. Assume bus or BMCC source voltages from the battery duty cycle calculations (ref. 6) for MOVs in the battery duty cycle. Assume end of duty cycle battery voltage for MOVs which do not operate as part of the battery duty cycle (ref. 7).

Assume negligible effect from parallel current flow through high resistance shunt field winding.

7. Assume 10 ft length for unnumbered cable from junction box to MOV.

REFERENCES:

1. JAF Electrical Cable and Raceway Information System, Cable Schedule Report, Feb. 1, 1994. 2. Wiring Diagram Drawing SE-10AJ.

3. PEDB for Motor Controller, Equipment Name Plate Inquiry (overload heater number).

4. Earley, M.W. et al, Ed., National Electric Code 1990 Handbook, Chapter 9, Tables 8 and 9, National Fire Protection Association.

5. Marks, L.S., Standard Handb: rk for Mechanical Engineers, eighth edition, 1979.

6. Calculations JAF-CALC-ELEC-00426, Rev. 1 and JAF-CALC-ELEC-00427, Battery "A" and "B" 125 VDC Voltage Drop Analyses, approved 10/16/92 and 6/4/92.

7. NYPA Memorandum to P. Swinburne from T. Klein, NED-E-TK-92-162, DC MOV Degraded Voltage, dated August 25, 1992.

8. Limitorque Technical Update #92-02, Recommended Spring Pack Replacement Procedures for Limitorque SMB Actuators, issued October 9, 1992.

9. Fax Transmittal, C. Shirley (GE) to P. Swinburne (NYPA), CR123C,F,K,L size 1,2,3&4 Heater Resistances, March 22, 1993.

10. Limitorque Data Sheets for O/N 110119.01 (M1-87-026).

11. Peerless-Winsmith DC Motor Performance curves provided under P.O. S-91-12145.

12. JAF EQ Program, Environmental Parameters after Postulated LOCA and HELB Accidents, Rev. 3, October 1992, EQ Ref. #349.

13. Limitorgue Maintenance Update 88-1, "Notes from the Field", DC Motors, dated Aug. 17, 1988.

NewYorkPower Authority J.A.FitzPatrick Nuclear Power Plant Calculation No. JAF-CALC-HPCI-02094 Revision 0 Page 2 of 4 Subject: Reduced Voltage Analysis for 23MOV-19

Prepared by: Paul Swinburne

Checked by: F.A. Mulcahy 2014

Date: June 9, 1995 Date: <u>6-9-95</u>



Figure 1 - DC Motor Circuit One-Line Diagram

Motor Data (references 10 and 11):

Rated Voltage:	$V_r = 125 \cdot volt$	Frame: D225 F	PM: 1900
Locked Rotor Amps:	I lr = 810 amp	Rated run amps:	I run = 80 amp
Rated Start Torque:	T _{st} = 150 ft lbf	Curve: K-11216A	

Cable Data (references 1, 2 and 4):	Length	DC Resistance at 75°C
1HPIBBK042 (NFF-51, 1 cond. 750 MCM AI)	$L_1 = 110 \cdot ft$	$SR_1 = 0.0282 \cdot \frac{ohm}{ft \cdot 10^3}$
1HPIBBK041 (NFE-25, 3 cond. 500 MCM AI)	L ₂ = 120·ft	SR 2 = 0.0424 $\frac{\text{ohm}}{\text{ft} \cdot 10^3}$
JB to MOV (2 NFE-08, 4 cond. 8 AWG Cu)	L ₃ = 10-ft	SR 3 = 0.786 $\frac{\text{ohm}}{\text{ft} \cdot 10^3}$
Outside Containment Cable Temperature:	Temp _c = 75	

BMCC Minimum Voltage: V = 107.44 volt

Calculation JAF-CALC-ELEC-00427 determined the above BMCC voltage for 23MOV-19 based on operation at the 19th second of the two hour duty cycle.

Overload Heater Data (references 3, 5, 9 and 12):

Number:	F104C	Resistance:	R 25 = 9.49 10-4 oh	m(at 25°C)
		Temperature Coefficient:	TC _{oh} = $0.17 \cdot 10^{-3}$	(from Marks' for nichrome)
		Ambient Temperature (°C):	Temp oh = 55	(EQ temperature for BMCC-6)

NewYorkPower	Calculation No. JAF-CALC-HPCI-02094	Revision 0	Page 3 of 4		
Authority	Subject: Reduced Voltage Analysis for 2	3MOV-19			
J.A.FitzPatrick	Prepared by: Paul Swinburne 645	Date: Ju	ne 9, 1995		
Nuclear Power Plant	Checked by: F.A. Mulcahy 22%	Date: 6	6-9-95		

Total cable resistance (for four runs for armature and series field):

$$R_{c} = SR_{1}L_{1} + 3 SR_{2}L_{2} + 4 SR_{3}L_{3}$$
 $R_{c} = 0.0498 \cdot ohm$

Overload heater resistance (two heaters in parallel) corrected for temperature:

$$R_{oh} = \frac{R_{25}}{2} \left[1 + TC_{oh} \left(Temp_{oh} - 25 \right) \right]$$
 $R_{oh} = 4.769 \cdot 10^{-4} \cdot ohm$

Motor equivalent resistance:

$$R_{m} = \frac{r}{I_{lr}}$$

Maximum current:

$$I_{\max} = \frac{V_s}{R_m + R_c + R_{oh}} \qquad I_{\max} = 525.1 \text{-amp}$$

Minimum motor terminal voltage:

Percent rated voltage available:

Because percent rated voltage is less than 90%, we need calculate a reduced voltage factor (RVF). For DC motors the RVF is simply the percent of rated voltage expressed as a fraction (ref. 8).

V_{mt} = I_{max} R_m

Percent_rated = $\frac{V_{mt}}{V_{r}}$

Reduced voltage factor:

RVF = Percent_rated

RVF = 0.648

 $R_m = 0.154 \cdot ohm$

V mt = 81.036 •volt

Percent rated = 64.829 .%

Per LMU 88-1 maximum current as $I \max_{max} = 6.564$ Cable size does meet Limitorque'smultiples of rated FLA: $I \min$ recommendation to provide 5 times
rated current (FLA)

Evaluate torque available based on motor curve K-11216A. Apply conservative +15% to current vs. torque curve.

Motor curve K-11216A for 150 ft-lbf motor, as 3rd order polynomial:

Data points from recorded data files:

= 0., 20 (21 data)	points) X	=READPRN(tq150)	Y = READPRN(amps150)
---------------------	-----------	-----------------	----------------------



Available torque at Imax (with +15% allowance) is:

wance) is: $\tau_{avail} = root(1.15 \cdot I(t) \cdot amp - I_{max}, t) \cdot ft \cdot lbf$ $\tau_{avail} = 240.166 \cdot ft \cdot lbf$

The above torque is greater than the rated torque for this motor (150 ft-lbf). We should not take credit for more than rated torque capability but we need not apply an RVF.

CONCLUSION:

This analysis shows that 23MOV-19 has less than 90% of rated voltage available under degraded voltage conditions. If we consider the guidelines for motor torque capability provided in LMU 88-1 (ref. 13) and motor curve K-11216A (ref. 11) we can show more than rated torque capability at reduced voltage conditions. Therefore we can use RVF = 1.0.

JAF

INDEPENDENT DESIGN VERIFICATION CONTROL SHEET

VERIFICATION OF:	JAF-CALC-HP	CI-02094, Re	IV. 0			
			Docum	ent Title / N	umber	
SUBJECT:	Reduced Volta	ige Analysis I	for 23MOV-1	19 (Voltage)		
MOD/TASK NUMBER	R (If Applicable)	N/A				
QA CATEGORY:	1				an an Co Alcor And a second and a second	
DISCIPLINE:	ELEC	месн	C/S	1& C	FIRE PROTECT	OTHERS (SPECIFY)
Check as required:	x	Π		Π		
METHOD USED (1):	DR		-	-		
VERIFIER'S NAME:	F. A. Mulcahy					
VERIFIER'S INITIALS / DATE:	714 6-9-95		4		nan ala ayarida Jonesia aya ya ya	
APPROVED BY:	Ar	hmil	amer	-	DATE:	6/12/95
REMARKS / SCOPE	OF VERIFICA	TION:				
Г <u></u>				-		

 Method of Verification: Design Review (DR), Alternate Calculations (AC), Qualification Test (QT)

NYPA FORM DCM-4, ATTACHMENT 4.1 (NOVEMBER 1992)

IP3

DESIGN VERIFICATION CHECKLIST DESIGN REVIEW METHOD

.

VERIFICATION OF:	JAF-CALC-HPC	01-02094, Re	ev. 0				
			Documer	nt Title / N	umber	en de la companya de	
SUBJECT:	Reduced Voltag	e Analysis f	or 23MOV-19	(Voltage)			
MOD/TASK NUMBE	R (If Applicable):	N/A		and the second			
DESIGN VERIFIER:	F. A. Mulcahy	7.0.91	nulcaly	MOV	Engineer	6-9-95	
		Sigr	nature / Title /	Date		and the second secon	
DISCIPLINE:	ELEC	MECH	C/S	1& C	FIRE PROTECT	OTHERS (SPECIFY)	
Check as required:	Ø		Ľ		C		
						Yes	NA
1. Were the input	s correctly select	ed and inco	rporated into th	he design f	2	1X	Γ
2. Are the physica the approved d	al and functional d esign basis of the	characteristi e system(s)	cs of the propostructure(s) or	osed desig componer	n within ht(s) ?	1X	Π
3. Does the propo	osed design incon	porate licen	se commitmer	nts ?		X	
 Are assumption and reasonable reverification w 	ns necessary to p Where necessa when the detailed	erform the c ary, are the a design activ	design activity assumptions ic vities are comp	adequately lentified fo pleted ?	y described r subsquent	×	
5. Are the approp e.g., safety clas	riate quality and o ssification.	quality assu	rance requiren	nents spec	ified ?	R	
 Are the applica and agenda pro 	ble codes, standa openy identified a	ards and reg and are their	ulatory require requirements	ements inc for design	luding issue met ?	E	X
7. Have applicabl	e construction an	d operating	experience be	en consid	ered ?	n	X
NYPA FORM DCM-	, ATTACHMENT	4.2 (NOVE	MBER 1992)			PAGE	1 OF 3

DESIGN VERIFICATION CHECKLIST DESIGN REVIEW METHOD

.

		Yes	NA	
8.	Have the design interface requirements been satisfied ?	6		
9.	Was an appropriate design method used ?	R		
10.	Is the output reasonable compared to inputs ?	R	۵	
11.	Are the specified parts, equipment and processes suitable for the required application ?		X	
12.	Are the specified materials compatible with each other and the design environmental conditions to which the materials will be exposed ?		X	
13.	Have adequate maintenance features and requirements been satisfied ?	С	X	
14.	Are accessibility and other design provisions adequate for performance of needed maintenance and repair ?		X	
15.	Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life ?		X	
16.	Has the design properly considered radiation exposure to the public and plant personnel ? (ALARA / Cobalt Reduction)	C	X	
17.	Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have satisfactorily accomplished ?	R		
18.	Have adequate pre-operational and subsequent periodic test requirements been appropriately specified ?		X	
19.	Are adequate handling, storage, cleaning and shipping requirements specified ?	C	X	

NYPA FORM DCM-4, ATTACHMENT 4.2 (NOVEMBER 1992)

PAGE 2 OF 3

DESIGN VERIFICATION CHECKLIST DESIGN REVIEW METHOD

å

		Yes	NA
20.	Are adequate identification requirements specified ?	Γ	X
21.	Are conclusions drawn in the Safety Evaluation fully supported by adequate discussion in the test or Safety Evaluation itself ?		X
22.	Are necessary procedural changes specified, and are responsibilities for such changes clearly delinated ?		X
23.	Are requirements for records preparation, review, approval, retention, etc., adequately specified ?	C	X
24.	Have supplemental reviews by other engineering disciplines (seismic, electrical, etc.) been performed on the integrated design package.	Г	X
25.	Have the drawings, sketches, calculations, etc. included in the intergrated design package been reviewed ?	R	
26.	Have review been performed to identify any effect on the Check Valve Maintenance Program ?	Γ	X
27.	Does the design for check valves meet the intents of INPO SOER 86-03 ?		X
28.	Is the plant reference simulator physical and functional fidelity affected and it's design change been factored into the cost ?	٢	X
29.	References used as part of the design review which are not listed as part of the design calculation / analysis ?		X

NYPA FORM DCM-4, ATTACHMENT 4.2 (NOVEMBER 1992)

PAGE 3 OF 3