

Ponaid C. Shelton Vice President · Nuclear Davis-Besse 300 Madison Avenue Toledo, OH 43652-0001 (419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 2023

May 1, 1992

United States Nuclear Regulatory Commission Document Control Desk Washington, D. C. 20555

Subject: License Amendment Request to Revise Technical Specification 3/4.4.6.2, Reactor Coolant System - Operational Leakage, and its Bases

## Gentlemen:

Enclosed is an application for an amendment to Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1, Operating License Number NPF-3, Appendix A, Technical Specification (TS) 3/4.4.6.2, Reactor Coolant System - Operational Leakage and its Bases. This request proposes several changes to TS 3/4.4.6.2 and its Bases which involve clarifying the applicability of TS 4.0.4 exceptions, specifying allowed usage of the containment atmosphere gaseous relioactivity monitoring system as an alternate method of determining the presence of Reactor Coolant System leakage (consistent with existing TS 3/4.4.6.1, Reactor Coolant System Leakage - Leakage Detection Systems), and clarifying other existing wording. The proposed revisions to the Bases clarify that leakage from the Reactor Coolant System Pressure Isolation Valves is "identified leakage" under TS 3/4.4.6.2 and is considered a portion of the allowed limit. Toledo Edison requests that this amendment be issued by the NRC by October 30, 1992.

Docket Number 50-346 License Number NFF-3 Serial Number 2023 Page 2

Should further information b∈ required, please contact Mr. R. W. Schrauder. Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,

The for DC Shellon

ABB/dlm

ecolosure

cc: A. B. Davis, Regional Administrator, NRC Region III

J. B. Hopkins, NRC/NRR DB-1 Senior Project Manager

W. Levis, NRC Region III, DB-1 Senior Resident Inspector

J. R. Williams, Chief of Staff, Ohio Emergency Maragement Agency, State of Ohio (NRC Liaison)

Utility Radiological Safety Board