



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

August 6, 1992

Docket Nos. 50-498  
and 50-499

LICENSEE: Houston Lighting and Power Company

FACILITY: South Texas Project, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON JULY 23, 1992 TO DISCUSS PROPOSED  
TECHNICAL SPECIFICATION AMENDMENTS RELATED TO ALLOWED OUTAGE TIMES  
AND SURVEILLANCE TEST INTERVALS (TAC NOS. M76048 AND M76049)

On July 23, 1992, members of the NRC staff and a contractor from Brookhaven National Laboratories (BNL) met with representatives of Houston Lighting and Power Company to discuss proposed Technical Specification (TS) amendments related to allowed outage times (AOTs) and surveillance test intervals (STIs). A list of the attendees is provided as Enclosure 1. The slides used by the licensee during the meeting are provided as Enclosure 2.

The licensee's submittal of February 1, 1990, proposed to change the AOTs and STIs associated with several systems using the plant specific probabilistic safety assessment (PSA) as the primary justification for the revisions. A subsequent transmittal dated November 27, 1990, withdrew the proposed changes associated with those systems which were determined to be the most significant in terms of an increased risk of core damage resulting from an extension of the related system AOTs or STIs. In addition, several of the other proposed changes included in the initial submittal were superceded by subsequent licensee amendment requests. The NRC review of the internal events and fire protection portions of the plant specific PSA was documented in a safety evaluation which was issued on January 21, 1992.

Discussions during the meeting provided the staff and contractor with background information regarding the PSA and the analyses performed to justify the proposed Technical Specification changes. In response to questions regarding the incorporation of plant specific performance data into the PSA models, the licensee stated that, at this time, only the Essential Cooling Water (ESW) data has been compiled, incorporated, and verified to be conservative with respect to initial PSA assumptions. Plant specific performance data for other systems will be incorporated into the future updates of the PSA model assumptions. Several other questions and proposed actions were discussed and will be addressed by a formal request for additional information to be issued by the NRC.

NRC staff indicated their plans to obtain the Riskman computer code from Pickard, Lowe and Garrick, Inc. The staff expressed a desire to obtain the STP specific models after the initial familiarization with the Riskman code and related methodologies. The licensee stated that the possibility of supplying the STP models would be investigated as well as any necessary

9208100255 920806  
PDR ADOCK 05000498  
P PDR

NRC FILE CENTER COPY

DF01

constraints on the use of the models if they were provided. A conference call will be held in August or September 1992 to discuss the NRC's progress related to the acquisition of Riskman and the possible use of the STP models.

In a telephone conversation held subsequent to the meeting, the licensee proposed that the TSs related to the Reactor Protection System and Engineered Safety Features Actuation System changes be reviewed as soon as possible in order to support the facilities' trip reduction program. This request will be formally documented by a letter from the licensee and the NRC has given preliminary agreement to proceed with the separate review. The proposed changes to Reactor Protection System and Engineered Safety Features Actuation System specifications are similar to those approved for other facilities based upon analyses performed by Westinghouse.

Original Signed By

William D. Reckley, Project Manager  
 Project Directorate IV-2  
 Division of Reactor Projects III/IV/V  
 Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. Licensee Presentation

cc w/enclosure:  
 See next page

DISTRIBUTION:

Docket File WReckley  
 NRC/PDR GDick  
 Local PDR EPeyton  
 PDIV-2 RF CGC  
 PDIV-2 PF EJordan  
 TMurley ACRS (10)  
 FMiraglia SShankman  
 JPartlow AHowell  
 BBoger EChelliah  
 MVirgilio MWohl  
 REvans, Resident  
 Inspector

OFFICE	PDIV-2/LA	PDIV-2/PM	PDIV-2/D		
NAME	EPeyton	WReckley;nb	SBlack		
DATE	8/3/92	8/3/92	8/3/92	/ /	/ /

Document Name: M76048.MTG  
 c:\wp\stp

cc w/enclosure:

Mr. J. Tapia  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, Texas 77414

Mr. J. C. Lanier/M. B. Lee  
City of Austin  
Electric Utility Department  
P. O. Box 1088  
Austin, Texas 78767

Mr. K. J. Fiedler  
Mr. M. T. Hardt  
City Public Service Board  
P. O. Box 1771  
San Antonio, Texas 78296

Mr. D. E. Ward  
Mr. T. M. Puckett  
Central Power and Light Company  
P. O. Box 2121  
Corpus Christi, Texas 78403

INPO  
Records Center  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339-3064

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Joseph M. Hendrie  
50 Bellport Lane  
Bellport, New York 11713

Judge, Matagorda County  
Matagorda County Courthouse  
1700 Seventh Street  
Bay City, Texas 77414

Mr. William J. Jump  
Manager, Nuclear Licensing  
Houston Lighting and Power Company  
Box 289  
Houston, Texas 77483

Jack R. Newman, Esq.  
Newman & Holtzinger, P.C.  
1615 L Street, N.W.  
Washington, D.C. 20036

Licensing Representative  
Houston Lighting and Power Company  
Suite 610  
Three Metro Center  
Bethesda, Maryland 20814

Bureau of Radiation Control  
State of Texas  
1101 West 49th Street  
Austin, Texas 78756

Rufus S. Scott  
Associate General Counsel  
Houston Lighting and Power Company  
P. O. Box 618  
Houston, Texas 77208

Mr. Donald P. Hall  
Group Vice-President, Nuclear  
Houston Lighting & Power Company  
Houston, Texas 77251

ENCLOSURE 1

List of Attendees

Houston Lighting and Power

Richard Murphy  
Rick Grantom  
Sam Phillips

HRC

Erulappa Chelliah  
Millard Wohl  
William Reckley  
Robert Evans

Brookhaven National Laboratories

Pranab Samanta


# THREE TRAIN DESIGN



# SOUTH TEXAS PROJECT

- Three-train ESF systems
  - Physically segregated
  - Electrically independent

### THREE TRAIN DESIGN HEAT SINK AND ELECTRICAL DEPENDENCY




\* NOTE: AN ECW PUMP TRAIN CAN SERVE AS A HEAT SINK FOR TWO ECH TRAINS.

# PM Outages Typical for Unit 1 Systems

Week	Day						
	Sun.	Mon.	Tue.	Wed.	Thur.	Fri.	Sat.
1		CCW-A			ECW-A		
2							
3			AFW-C				
4							
5			AFW-A				
6		CCW-B			ECW-B		
7							
8			AFW-D				
9							
10			AFW-B				
11		CCW-C			ECW-C		
12							
1		CCW-A			ECW-A		





**INTERRELATIONSHIP OF ESF SYSTEMS IN  
THE THREE-TRAIN CONCEPT  
(Typical of Three)**

# SOUTH TEXAS PROJECT THREE TRAIN SYSTEMS

System	Trains Installed	Minimum number of trains required		
		Normal Operation / Shutdown	Large Breaks	Other Accidents
Diesel Generators	3	0/0	2	1
Essential Cooling Water	3	1/1	2	1
Component Cooling Water	3	1/1	2	1
Reactor Containment Fan Coolers	3 (2 RCFC Units per train)	2/2*	2 (3 RCFC Units)	1
Safety Injection	3	0/0	2**	1
Containment Spray	3	0/0	2	0
Residual Heat Removal Heat Exchangers	3	0/1	2	1
Auxiliary Feedwater	4	0/0	2	1

\* Normally supplied by RCB chilled water

\*\* Share RHR exchanger - RHR pumps not required

## CORE DAMAGE FREQUENCY

DESCRIPTION	CORE DAMAGE FREQUENCY
TOTAL INTERNAL INITIATING EVENTS	$1.7 \times 10^{-4}$
TOTAL EXTERNAL INITIATING EVENTS	$1.2 \times 10^{-6}$
TOTAL CORE DAMAGE FREQUENCY	$1.7 \times 10^{-4}$

Table 5.2-1 (Page 1 of 2). Initiating Event Categories Selected for Quantification of the South Texas Project Risk Model

Group	Initiating Event Categories Selected for Separate Quantification	Code Designator
Loss of Coolant Inventory	1. Excessive LOCA 2. Large LOCA 3. Medium LOCA 4. Small LOCA	ELOCA LLOCA MLOCA
Transients	4. Small LOCA a. Nonisolable b. Isolable 5. Interfaring Systems LOCA 6. Steam Generator Tube Rupture 7. Reactor Trip 8. Turbine Trip 9. Loss of Condenser Vacuum 10. Closure of All MSIVs 11. Steam Line Break Upstream of MSIVs a. Steam Line Break inside the Containment b. Main Steam Relief or Safety Valve Opening 12. Steam Line Break Downstream of MSIVs 13. inadvertent Safety Injection 14. Miscellaneous Transients a. Total Main Feedwater Loss (includes feedwater line break) b. Partial Main Feedwater Loss c. Excessive Feedwater d. Closure of One Main Steam Isolation Valve e. Core Power Excursion f. Loss of Primary Flow	SLOCA ILOCA V SGTR RT TT LCV AMSIV SLBI MSV SLBD SI TLMFW PLMFW EXFW 1MSIV CPEXC LOPF
Common Cause Initiating Events		
Support System Faults	15. Loss of Offsite Power a. Events External to Plant b. Transient-Induced Loss of Offsite Power 16. Loss of One DC Bus a. Loss of DC Bus E1A11 b. Loss of DC Bus E1B11	LOOP TLOOP L1DCA L1DCB

Table 5.2-1 (Page 2 of 2). Initiating Event Categories Selected for Quantification of the South Texas Project Risk Model

Group	Initiating Event Categories Selected for Separate Quantification	Code Designator
Seismic Events	17. Total Loss of Essential Cooling Water	LOECW
	18. Total Loss of Component Cooling Water	LOCCW
	19. Loss of Instrument Air	LOIA
	20. Loss of EAB HVAC	LOEAB
	21. Loss of Control Room HVAC	LOCR
	22. 0.1g Seismic	SEIS1
Fires	23. 0.2g Seismic	SEIS2
	24. 0.4g Seismic	SEIS4
	25. 0.6g Seismic	SEIS6
Flooding (External)	26. Control Room — Loss of All Three Motor-Driven AFW Pumps	FIRE10
	27. Control Room — Loss of Control Room HVAC and EAB HVAC	FIRE18
	28. Control Room — Loss of All AFW Pump Trains	FIRE23
	29. Loss of Offsite Power and PD Pump	FLOOD1
	30. Loss of Offsite Power, PD Pump, and All Three Emergency Diesel Generators	FLOOD2
	31. Loss of Offsite Power, PD Pump, and Loss of All ECW	FLOOD3
	32. Loss of Offsite Power, PD Pump, and Loss of All CCW	FLOOD4
Flooding (Internal)	None	
Others	33. Loss of Offsite Power, PD Pump, All CCW, and Train C Essential Chillers	FLOOD5
	34. Loss of Offsite Power, PD Pump, and Train/B RCFCs	FLOOD6
	35. Loss of Offsite Power, PD Pump, Train B, AC Power, and Main Control Room	FLOOD7
	36. Severe Wind (tornado) — Loss of Offsite Power, Loss of TSC Diesel Generator, and Plunging of ECW Pump Travelling Screen by Debris	FLECW

## STPEGS FRONTLINE AND SUPPORT SYSTEMS ANALYZED IN DETAIL

### 0 SUPPORT SYSTEMS

- ESSENTIAL CHILLED WATER SYSTEM
- ELECTRIC POWER (INCLUDING DIESEL GENERATORS)
- COMPONENT COOLING WATER SYSTEM
- ESSENTIAL COOLING WATER SYSTEM
- REACTOR TRIP SYSTEM
- SOLID STATE PROTECTION SYSTEM
- ENGINEERED SAFETY FEATURES ACTUATION SYSTEM
- QUALIFIED DISPLAY PROCESSING SYSTEM
- ELECTRICAL AUXILIARY BUILDING HVAC SYSTEM
- CONTROL ROOM HVAC SYSTEM

## STPEGS FRONTLINE AND SUPPORT SYSTEMS ANALYZED IN DETAIL

### 0 FRONTLINE SYSTEMS

- REACTOR CONTAINMENT FAN COOLERS
- CONTAINMENT ISOLATION SYSTEM
- EMERGENCY CORE COOLING SYSTEM
  - 0 REFUELING WATER STORAGE TANK AND SUCTION LINES
  - 0 CONTAINMENT PUMP SUCTION LINES
  - 0 HIGH HEAD SAFETY INJECTION
  - 0 LOW HEAD SAFETY INJECTION
- AUXILIARY FEEDWATER SYSTEM AND SECONDARY STEAM RELIEF
- CONTAINMENT SPRAY SYSTEM
- PRIMARY PRESSURE RELIEF
- MAIN STEAM ISOLATION SYSTEMS
- CHEMICAL AND VOLUME CONTROL
- RESIDUAL HEAT REMOVAL

## IMPACT OF TECH SPECS ON PLANT AVAILABILITY

- 0 LIMITED CREDIT IS GIVEN IN THE CURRENT STPEGS TECH SPECS FOR THE THREE TRAIN DESIGN AND THE ADDITIONAL SAFETY EQUIPMENT. WHEN A PUMP, FOR EXAMPLE, IS DECLARED INOPERABLE IN A "TWO TRAIN" PLANT ONLY ONE REMAINS AVAILABLE, WHEREAS AT STPEGS TWO MUST REMAIN AVAILABLE. THE PLANT CAN BE BROUGHT TO A STABLE CONDITION WITH ONE TRAIN AVAILABLE EXCEPT IN THE CASE OF THE LOW FREQUENCY DESIGN BASIS LARGE BREAK LOCA.
- 0 LCOs CONTRIBUTE TO PLANT UNAVAILABILITY.
- 0 THE MORE EQUIPMENT UNDER TECH SPECS, THE HIGHER THE PROBABILITY OF ENTERING AN LCO.
- 0 THE MORE LCOs A PLANT ENTERS, THE GREATER THE CHANCE FOR SHUTTING THE PLANT DOWN AND INCREASING PLANT UNAVAILABILITY.
- 0 THE STPEGS TECH SPECS REQUIRE TWO OUT OF THE THREE ESF TRAINS TO BE AVAILABLE BASED ON A LOW FREQUENCY POSTULATED DESIGN BASIS LARGE BREAK LOCA. IN THIS CASE, ONE TRAIN OF EQUIPMENT WILL BE EFFECTIVE EXCEPT IN THE INSTANCE IN WHICH THE AVAILABLE TRAIN FEEDS THE BROKEN LOOP, WHICH IS VERY UNLIKELY. STPEGS IS MORE LIKELY TO ENTER AN LCO DUE TO THE ADDITIONAL EQUIPMENT THAT MUST BE AVAILABLE.
- 0 AS A RESULT, STPEGS MAY EXPERIENCE A PLANT AVAILABILITY SOMEWHAT LESS THAN THE US AVERAGE BECAUSE IT HAS MORE SAFETY EQUIPMENT.



Table 2-1  
 List of Technical Specifications Evaluated

Technical Specification	System	Current		Proposed	
		AOT (Days)	STI (Days)	AOT (Days)	STI (Days)
3.1.2.4	Chemical and Volume Control (i.e. Charging Pumps)	3	N/C	10	N/C
4.3.1	Reactor Protection	N/C	62	N/C	92
4.3.2	Engineered Safeguard Features Actuation	N/C	62	N/C	92
3.4.2.2	Pressurizer Safety Valves	15 min	N/C	1 Hour	N/C
3.4.4	Pressurizer PORVs	1 Hour	N/C	6 Hours	N/C
3.5.1	Accumulators	1 Hour	N/C	12 Hours	N/C
3.5.2	Emergency Core Cooling	3	N/C	10	N/C
3/4.5.6	Residual Heat Removal	3	92	10	184
4.6.1.7	Containment Ventilation	N/C	31	N/C	92
3/4.6.2.1	Containment Spray	3	92	10	184
3.6.2.2	Containment Spray Additive	3	N/C	10	N/C
3/4.6.2.3	Reactor Containment Fan Coolers	3	31	10	92
3.6.3	Containment Isolation	4 Hours	N/C	24 Hours	N/C
3.7.1.1	Steam Generator Safety Relief Valves	4 Hours	N/C	24 Hours	N/C
3/4.7.1.2	Auxiliary Feedwater	3	31	10	92
3.7.3	Component Cooling Water	3	N/C	10	N/C

Table 2-1 (Cont'd)  
 List of Technical Specifications Evaluated

Technical Specification	System	Current		Proposed	
		AOT (Days)	STI (Days)	AOT (Days)	STI (Days)
3.7.4	Essential Cooling Water	3	N/C	10	N/C
3/4.7.7	Control Room HVAC	(1)	31	(2)	92
4.7.13	Electrical Auxiliary Building HVAC	N/C	12 Hours	N/C	24 Hours
3.7.14	Essential Chilled Water	3	N/C	10	N/C
3.8.1.1	Diesel Generators	(3)	N/C	(4)	N/C
3.8.2	DC Electrical Sources	(5)	N/C	(6)	N/C

NOTES:

- N/C No Change
- (1) 7 days for the first inoperable train of control room HVAC and 24 hours for the second train of three.
- (2) 10 days for the first inoperable train of control room HVAC and 72 hours for the second train of three.
- (3) 72 hours for the first inoperable standby diesel generator and 2 hours for the second diesel generator.
- (4) 10 days for the first inoperable standby diesel generator and 12 hours for the second diesel generator.
- (5) 24 hours for Channels I and IV battery chargers; and 2 hours for any battery and Channels II and III chargers.
- (6) 72 hours for any battery charger and 24 hours for any battery.

## Table 1-1

## Summary of Plant Level Results

Technical Specification	System	Change in Risk (%)
3.1.2.4	Chemical and Volume Control (i.e. Centrifugal Charging Pumps)	-0.7
4.3.1	Reactor Protection	0.2
4.3.2	Engineered Safety-Features Actuation	0.0
3.4.2.2	Pressurizer Safety Valves	*
3.4.4	Pressurizer PORVs	*
3.5.1	Accumulators	0.3
3.5.2	Emergency Core Cooling	1.3
3/4.5.6	Residual Heat Removal	0.0
4.6.1.7	Containment Ventilation	*
3/4.6.2.1	Containment Spray	0.0
3.6.2.2	Containment Spray Additive	0.0
3/4.6.2.3	Reactor Containment Fan Coolers	-0.1
3.6.3	Containment Isolation	*
3.7.1.1	Steam Generator Safety Valves	*
3/4.7.1.2	Auxiliary Feedwater	30.4
3.7.3	Component Cooling Water	1.4 (+)
3.7.4	Essential Cooling Water	23.8 (+)
3/4.7.7	Control Room HVAC	0.5
4.7.13	Electrical Auxiliary Building HVAC	*
3.7.14	Essential Chilled Water	0.7 (+)
3.8.1.1	Diesel Generators	24.8
3.8.2	Single DC Power Train	1.6

- \* Denotes that a qualitative analysis is performed.  
+ Denotes that the AOT for all dependent systems are also increased accordingly and the integrated change in risk is shown.