

Duke Power Company  
McGuire Nuclear Generation Department  
12700 Hagers Ferry Road (MG01A)  
Huntersville, NC 28078-8985

T. C. McMEEKIN  
Vice President  
(704)875-4800  
(704)875-4809 FAX



DUKE POWER

August 20, 1992

U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Document Control Desk

Subject: McGuire Nuclear Station, Units 1 and 2  
Docket Nos. 50-369 and 50-370  
Proposed Technical Specification Change

Gentlemen:

Pursuant to 10 CFR 50.4 and 50.90, attached is a proposed license amendment to Appendix A, Technical Specifications, of Facility Operating Licenses, NPF-9 AND NPF-17 for McGuire Nuclear Station Units 1 and 2, respectively.

The proposed change would eliminate the "during shutdown" restriction for the 60 month 125 volt battery surveillance 4.8.2.1.2.e.

Attachment 1 contains the proposed Technical Specification change. Attachment 2 contains the justification for the proposed change, and the analysis performed in accordance with the standards contained in 10 CFR 50.92, which concludes that the amendment does not involve a significant Hazards Consideration. Duke Power is forwarding a copy of this amendment request application and No Significant Hazards Consideration analysis to the appropriate North Carolina state officials. The proposed amendment has been reviewed and has been determined to have no adverse safety or environmental impact.

Should there be any questions concerning this proposed amendment or if additional information is required, please call L. J. Kunka at (704) 875-4000, Ext. 4032.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'T. C. McMeekin'.

T. C. McMeekin, Vice President  
McGuire Nuclear Site

9208310007 920820  
PDR ADDCK 05000369  
P PDR

Adol  
1/11

Document Control Desk  
Page Two  
August 20, 1992

Attachments:

1. Proposed Technical Specification Changes
2. Justification and Analysis of Significant Hazards Consideration.

xc:

(W/Attachments)

Mr. S. D. Ebnetter, Regional Administrator  
U.S. Nuclear Regulatory Commission, Region II

Mr. Dayne Brown, Chief  
Radiation Protection Branch  
Division of Facility Services  
Department of Human Services, State of NC

Mr. T. A. Reed, Project Manager  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission

Mr. P.K. VanDoorn  
NRC Resident Inspector  
McGuire Nuclear Station


American Nuclear Insurers

M & M Nuclear Consultants

INPO Records Center


Document Control Desk  
Page 3  
August 20, 1992

T.C. McMeekin, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the McGuire Nuclear Station License Nos. NPF-9 and NPF-17 and that all statements and matters set forth therein are true and correct to the best of his knowledge.



\_\_\_\_\_  
T.C. McMeekin, Vice President

Subscribed and sworn to before me this 20th day of August, 1992.



\_\_\_\_\_  
Notary Public

My Commission expires:

December 13, 1993