

Duke Power Company  
Catawba Nuclear Generation Department  
4800 Concord Road  
York, SC 29745

M.S. TUCKMAN  
Vice President  
(803)831-3205 Off.  
(803)831-3426 Fax



DUKE POWER

August 26, 1992

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

Subject: Catawba Nuclear Station  
Docket Nos. 50-413 and 50-414  
Supplement to Technical Specification Amendment  
Catawba Unit 1, Cycle 7 Reload

In a letter dated April 13, 1992, changes to the Catawba Technical Specifications to support Unit 1 Cycle 7 operation were submitted to the NRC. In a letter dated August 20, 1992, the NRC requested that Catawba submit revisions of an administrative and editorial nature to certain Technical Specification (TS) pages in the original application. Attachment I contains the list of requested revisions along with Catawba's response. The marked-up Technical Specification pages that reflect these revisions are included as Attachment II.

The original TS amendment application also contained changes to certain containment isolation valve maximum isolation times which are listed in Catawba TS Table 3.6-2a. Specifically, these changes were to the response times for the feedwater isolation valves, main steam isolation valves, and main steam isolation bypass valves. Based on discussions with the NRC Staff, Catawba is requesting that these changes to Table 3-6-2a be withdrawn. These changes will be resubmitted with additional justification at later date for both Units 1 and 2.

Per discussions with the NRC Staff, a revised mark-up for FSAR Table 15-26 is included in Attachment II.

Very truly yours,

M. S. Tuckman

CRL/RELOAD

Attachments

280039

9208310081 920826  
PDR ADOCK 05000413  
P PDR

*Handwritten notes:*  
Add. NRC/Chatterton  
A001  
11

U. S. Nuclear Regulatory Commission  
August 26, 1992  
Page 2

xc: S. D. Ebnetter  
Regional Administrator, Region II

W. T. Orders  
Senior Resident Inspector

R. E. Martin, ONRR

Heyward Shealy

American Nuclear Insurers

M & M Nuclear Consultants

## ATTACHMENT I

The original NRC questions and the response are as follows:

1. Proposed TS pages 3/4 A 3-4, -6, -9, -11, -12, 3/4 B 3-4, -6, -9, -11, and -12 are not based on the most recent TS amendment issued for these pages. Amendments 63 and 57 for Units 1 and 2 issued on May 9, 1989, provided the most recent amendment for these pages as well as page 3/4 A 3-12a.

The original mark-ups have been transferred to the TS pages containing the most recent amendment issued for these pages.

2. The FΔH (X,Y) SURV should be referenced as being identified in the COLR similar to the fashion for FΔH (X,Y) LCO on page 3/4 A 2-8.

The reference to the COLR has been added in the attached TS mark-ups.

3. A connecting term appears to be missing from the attachment to page 3/4 A 2-9.

The connecting term "and," has been added in the attached TS mark-ups.

4. The deletion marker on pages 3/4 A 3-35 and 3/4 B 3-35 inappropriately includes the Trip setpoint column.

The attached TS marked-up pages no longer include the Trip setpoint column in the deletion marker.

5. The phrase "three limiting" appears in four locations, but was proposed for deletion in only two locations on pages 3/4 5-1 and 3/4 5-2. Please clarify.

The two other locations of the phrase "three limiting" should also be deleted. This change is reflected in the attached TS mark-ups. Also included is the Bases mark-up for TS 3/4.5.1. This Bases page was inadvertently omitted from the original submittal.