



PRAIRIE ISLAND NUCLEAR GENERATING PLANT

Red Wing, Minnesota

UNITS 1 AND 2



INSERVICE INSPECTION - EXAMINATION SUMMARY

PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT 2

SEPTEMBER 5, 1984 THRU OCTOBER 2, 1984

8501290419 850122
PDR ADOCK 05000282
Q PDR

NORTHERN STATES POWER COMPANY
MINNEAPOLIS, MINNESOTA

Report Date:
January 3, 1985

Commercial Service Date:
December 16, 1973

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT 2
INSERVICE INSPECTION - EXAMINATION SUMMARY
SEPTEMBER 5, 1984 THRU OCTOBER 2, 1984
REFUELING OUTAGE 8
INSPECTION PERIOD 3

Report Date:
January 3, 1985

Prepared by: L C Dahlman
M&SP Specialist

Reviewed by:

Michael L. Anderson
M T Anderson
M&SP Engineer

Commercial Service Date:
December 16, 1973

Approved by:

G T Krause
G T Krause
Superintendent,
Materials and Special
Processes

INSERVICE INSPECTION - EXAMINATION SUMMARY
PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT II

- INDEX -

1.0 INTRODUCTION

2.0 INSPECTION SUMMARY

3.0 BALANCE OF PLANT

- 3.1 Examination Plan
- 3.2 Examination Methods
- 3.3 Examination Procedures
- 3.4 Equipment and Materials
- 3.5 Personnel
- 3.6 Evaluation
- 3.7 Examination Reports and Documentation
- 3.8 Summary of results

4.0 Examination of the Steam Generator Tubes

APPENDIX A - ASME Class 1 Examinations

Inservice Inspection	-Examination Summary Tables:
Table S1.1	-Reactor Vessels
Table S1.2	-Pressurizer
Table S1.3.1	-Steam Generators
Table S1.3.2	-Regenerative Heat Exchanger
Table S1.3.3	-Excess Letdown Heat Exchanger
Table S1.4	-Piping Pressure Boundary
Table S1.5	-Reactor Coolant Pumps
Table S1.6	-Valve Pressure Boundary
Table II	- Baseline Comparison Summary
Table III	- Isometric Summary

APPENDIX B - ASME Class 2 Examinations

Inservice Inspection	-Examination Summary Tables
Table S2.1	-Pressure Vessels - Steam Generators
Table S2.2.1	-Piping - Circumferential Butt Welds
Table S2.2.2	-Longitudinal Weld Joints in Fittings
Table S2.2.3	-Branch Pipe to Pipe Weld Joints
Table S2.2.4	-Piping - Pressure Retaining Bolting
Table S2.2.5	-Piping - Integrally Welded Supports
Table S2.2.6	-Piping - Nonwelded Supports
Table S2.3	-Pumps
Table S2.4	-Valves
Table II	- Baseline Comparison Summary
Table III	- Isometric Drawing Summary

APPENDIX C - FSAR Augmented Examination

-No Examinations Scheduled

APPENDIX D - Seismic Bolting Examination

Inservice Inspection	-Examination Summary Table:
Table SB	-Seismic Bolting
Table II	-Baseline Comparison Summary
Table III	-Isometric Summary

APPENDIX E

Table I	-Personnel Listing
Table II	-Ultrasonic Calibration Blocks
Table III	-Procedure Listing
Table IV	-Equipment and Materials

APPENDIX F - Steam Generator No. 21 and No. 22

Tube Sheet Maps of Plugged tubes

APPENDIX G - Steam Generator No. 21 and No. 22

Listing of Eddy Current indications and plugged tubes

APPENDIX H -

Form NIS-1, Owner's Data Report for Inservice Inspections

INSERVICE INSPECTION - EXAMINATION SUMMARY
PRAIRIE ISLAND NUCLEAR GENERATING PLANT - UNIT 2
SEPTEMBER 5, 1984 TO OCTOBER 2, 1984

1.0 INTRODUCTION

This report is a summary of the examinations performed during the eighth inservice inspection at the Prairie Island Nuclear Generating Plant - Unit 2. This was the third inservice inspection conducted for inspection period three. The examinations were performed during the plants eighth refueling outage from September 5, to October 2, 1984. Prairie Island - Unit 2 began commercial operation on December 16, 1973.

This report identifies the components examined, the examination methods used, the examination number, and summarizes the examination results of each of the following areas:

1. Balance of Plant
 - a) Pressure retaining components and supports of the reactor coolant and associated systems classified as ASME Class 1 and Class 2.
 - b) Seismic Bolting Program
2. Eddy current examination of steam generator tubing.

2.0 INSPECTION SUMMARY

The evaluation of the results from the inservice examination indicated that the integrity of the systems has been maintained. To assure continued integrity of the steam generators (S.G.), a total of 19 tubes in S.G. 21 and 15 tubes in S.G. 22 were mechanically plugged.

3.0 BALANCE OF PLANT

3.1 Examination Plan

The examination plan focused on the pressure-retaining components and their supports classified as ASME Class 1, Class 2, and Seismic Bolting.

The examination plan was based on the examination requirements of the ASME Boiler and Pressure Vessel Code Section XI, 1974 Edition through and including the Summer 1975 Addenda.

In addition, the examination complied with Prairie Island's Technical Specification, Section TS 4.2 and as required by Volume 6, Appendix I of the Prairie Island FSAR. The examination is in accordance with the

program submitted to the United States Nuclear Regulatory Commission on February 1, 1978, titled, "ASME Code Section XI Inservice Inspection and Testing Program and Information Required for NRC Review of Requests for Relief From ASME Code Section XI Requirements".

3.2 Examination Methods

Ultrasonic examination methods and techniques were used to perform the volumetric examinations. The ultrasonic test system consisted of an ultrasonic digital/analog tester and a two-channel strip chart recorder. One channel of the recorders was calibrated to reflect ultrasonic screen height (amplitude) and the second channel was calibrated to indicate metal path (range) to the reflector. This approach to the examination gives a permanent record to the extent possible.

Liquid penetrant or magnetic particle examination methods were used to perform the surface examinations. The liquid penetrant examinations were performed using color contrast-solvent removable materials. Magnetic particle examinations were performed using either a yoke with dry powder or an A-C L-10 coil with fluorescent prepared bath.

All visual examinations were aided, when necessary, with artificial lighting and verified for adequacy with an 18% neutral gray card containing a 1/32" black line.

3.3 Examination Procedures

The ultrasonic examination procedure for pipe welds complied with the requirements of Appendix III of ASME Section XI issued in the Winter 1974 Addenda. ET procedures per ASME Section XI 1980 Edition. All other examination procedures complied with the requirements of the 1974 Edition through and including the Summer 1975 Addenda of ASME Section XI. A listing of the procedures used for the examinations is shown in Table III of Appendix E.

3.4 Equipment and Materials

All equipment and expendable materials used in the examinations are listed either by serial number or type along with their respective calibration date or batch number in Table IV of Appendix E.

The ultrasonic calibration standards used in the examinations are listed in Table II of Appendix E. With the exception of ET, all standards are owned and maintained by Northern States Power Company at the plant site.

3.5 Personnel

Northern States Power Company Company contracted Lambert, MacGill, Thomas, Inc. and Hartford Steam Boiler Inspection and Insurance Company, representing ANI, provided the Authorized Inspection.

All personnel involved in the performance or evaluation of examinations are listed along with their title, organization, and ASNT Level of Certification in Table I of Appendix E.

Certifications for examination personnel are maintained on file by Northern States Power Company.

3.6 Evaluation

Any indications disclosed in the examinations were evaluated by the examiner at that time in accordance with the rules of the procedure and ASME Section XI.

The ultrasonic examiner was aided in his evaluation by a calibration performed on a (standard reference) before each day's examination, checked before and after each individual examination, and at intervals not exceeding four (4) hours. In addition, the ultrasonic data was recorded on strip charts which were made a part of the inspection report, and permitted further evaluation.

3.7 Examination Reports and Documentation

All examinations reports and documentation are maintained on file by Northern States Power Company. Table I of Appendices A, B, C, and D identifies the examination report number(s) for each item examined. Many of the items identify more than one examination report because of the different types of examinations performed on the item.

Table I of Appendices A, B, C, and D summarizes all the examinations performed to date and identifies the amount that will be examined in the future to complete the ten year examination requirements. For retrieval purposes, the prefix of the inspection report number corresponds with the year the inspection was performed. The examination report numbers for this outage are prefixed with "84".

Table II of Appendices A, B, C, and D compares the baseline examination results with the results obtained during this examination. Table II of Appendices A, B, C, and D identifies the isometric drawings that were used for the examinations. The personnel, ultrasonic calibration blocks, procedures, equipment and materials that were used for the inspection are identified in the tables of Appendix E. Appendix H contains the Form NIS-1, titled, "Owner's Data Report for Inservice Inspections".

3.8 Summary of Results

The following is a listing of all anomalies detected, with the exception of the steam generator eddy current tube examination which follows in Section 4.0.

<u>System</u>	<u>Item ID</u>	<u>Exam Method</u>	<u>Type and Number of Indications</u>
Feedwater A	FW-177	MT	3 Linears
Feedwater B	FW-133	MT	3 Linears
Reactor Coolant Pump - Seal House Bolts	Bolt 1	MT	3/4" Linear

<u>System</u>	<u>Item ID</u>	<u>Exam Method</u>	<u>Type and Number of Indications</u>
Reactor Vessel Conoseal Bolts	Marmon Clamp 37	VT	1 Bolt & 2 Nuts Eroded
Residual Heat Removal	Hanger M	PT	Porosity
	Hanger H	VT	Drawing Compliance
	Hanger B	PT	Porosity
	Hanger H	PT	Undercut
	Hanger J	PT	Porosity
Seismic Bolting S/G #21	Snubber Wall Bolt	VT	Washer Not Fully Contacted by Nut

All anomalies were corrected. The linear MT indications and pit undercut were removed by light hand grinding and blending the surface smooth.

The reactor vessel conoseal bolt and nuts and the reactor cooland pump seal house bolt were replaced with new bolts and nuts.

The snubber wall bolts were corrected by machining the washer to enable full contact between the nut and washer; straightening of the bolt was not performed due to the possibility of bolt deterioration.

The hangers with porosity were either found code acceptable or were analyzed for design load and found acceptable. The drawing compliance was determined, through magnification of the drawing, to be acceptable.

4.0 EXAMINATION OF THE STEAM GENERATOR TUBING

Multifrequency eddy current examinations of the tubing in steam generators No. 21 and No. 22 were performed during this outage. The program consisted of full length tube examinations including row 4 through the outer peripheral rows on S.G. No. 21 and No. 22. The remainder of the tubes in each generator were examined from the point of entry on the hot-leg side completely around the U-bend to the top support of the cold-leg. All examinations were conducted from the hot-leg (inlet) side of the generators.

Babcock & Wilcox, Special Products and Integrated Field Services Division, was contracted to perform and evaluate the data from the eddy current examinations. In addition, Conam Inspection was contracted to provide 100% second level review of all data. The examinations were performed using a standard Zetec Miz-12 multifrequency data acquisition system. The frequencies utilized for each examination were 400 KHz and 100 KHz in the differential mode, with 225 KHz and 100 KHz in the absolute mode. All primary and second level analyses were performed using Zetec digital data analysis (DDA-4) equipment.

A small sample (approximately 30 tubes) were examined in the AVB (U-bend) area with an 8 x 1, multicoil pancake-type probe, for supplemental information. The data on these examinations was acquired by use of the new Zetec Miz-18 digital data acquisition system.

Examinations performed during this outage reflected combined steam generator indication growth rates of 2.0% for cold leg (tube support plate) and 6.8% for anti-vibration bar (AVB) degradations over the last fuel cycle. The total number of tubes examined this outage is shown in Table I. A summary of the tubes exhibiting eddy current indications is shown in Table II and a cumulative listing is found in Appendices F and G for S.G. No. 21 and No. 22, respectively. Table III is a summary of those tubes which were mechanically plugged this outage. Table IV consists of the total numbers of tubes plugged in S.G. No. 21 and No. 22 to date with the location of these tubes being exhibited in Appendices F and G.

TABLE I

Examination Extent (Accessible Tubes)	S/G 21		S/G 22	
	Amount	%	Amount	%
Full Length	3073	91.4	3077	93.0
Around U-Bend	288	8.6	230	7.0

TABLE II

% of Wall Thinning	S/G 21	S/G 22
20	83	47
20-29	60	59
30-39	30	39
40	20	29

TABLE III

Summary of Plugged Tubes - 1984 Outage

Steam Generator	Tube		% Degradation	Indication Location	
	R	C			
21	20	87	52	#1 TSP - CL	
	25	34	50	#3 AVB	
	27	69	43	#3 AVB	
	29	37	41/42	#2/#3 AVB	
	36	44	42	#4 AVB	
	37	76	52	#1 TSP-CL	
	39	25	48	#1 TSP-CL	
	40	69	46	#1 TSP-CL	
	41	28	59	#1 TSP-CL	
	41	67	52	#1 TSP-CL	
	42	28	56	#2 TSP-CL	
	43	41	48	#1 TSP-CL	
	43	62	69	#1 TSP-CL	
	44	52	64	#1 TSP-CL	
	45	37	42/61	#2/#1 TSP-CL	
	45	40	47	#1 TSP-CL	
	45	46	50	#1 TSP-CL	
	45	54	48	#1 TSP-CL	
	44	54	48	#1 TSP-CL	
	#22	26	11	45	#1 TSP-CL
		31	16	47	#1 TSP-CL
31		82	46	#1 TSP-CL	
32		18	45	#1 TSP-CL	
33		16	53	#1 TSP-CL	
35		18	46	#1 TSP-CL	
36		20	48	# TSP-CL	
36		50	41	#2 AVB	
38		23	51	#1 TSP-CL	
40		54	52/41	#2/#3 AVB	
43		52	46	#1 TSP-CL	
43		62	47	#1 TSP-CL	
44		60	45	#1 TSP-CL	
46		41	46	#1 TSP-CL	

AVB = ANTI-VIBRATION BAR
TSP = TUBE SUPPORT PLATE
CL = COLD LEG
HL = HOT LEG

TABLE VI

Total Tubes Plugged to Date			
S/G 21		S/G 22	
Amount	%	Amount	%
46	1.4	95	2.8

APPENDIX A
ASME CLASS 1 EXAMINATIONS

INSERVICE INSPECTION-EXAMINATION SUMMARY

 TABLE S1.1
 PAGE 1 OF 5
 MAJOR ITEM: REACTOR VESSEL

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B1.1	B-A	<u>LONGITUDINAL AND CIRCUMFERENTIAL WELDS IN CORE REGION</u>					
		LONGITUDINAL WELDS	-	-	-	-NONE-	
		CIRCUMFERENTIAL WELDS	THREE	50%	-		
B1.2	B-B	<u>LONGITUDINAL AND CIRCUMFERENTIAL WELDS IN SHELL (OTHER THAN THOSE OF CATEGORY B-A AND B-C) AND MERIDINAL AND CIRCUMFERENTIAL SEAMWELDS IN BOTTOM HEAD AND CLOSURE HEAD (OTHER THAN THOSE AT CATEGORY B-C)</u>					
		LONGITUDINAL WELDS	-	-	-	-NONE-	
		MERIDIONAL WELDS	-	-	-	-NONE-	
		CIRCUMFERENTIAL WELDS	THREE	5%	-	WELD NO. 2	
				5%	-	WELD NO. 4	
				5%	-	WELD NO. 5	
B1.3	B-C	<u>VESSEL TO FLANGE AND HEAD TO FLANGE CIRCUMFERENTIAL WELDS</u>					
		VESSEL TO FLANGE WELD NO. 1	ONE	33%	33%	STUD HOLE: 12 TO 22 & 29 TO 35	77-W RPV REPORT
			TWO	30%	30%	9 TO 12 & 35 TO 46	81-W RPV REPORT
			THREE	36%	-		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE S1.1PAGE 2 OF 5

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: REACTOR VESSEL

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B1.3	B-C	(CONT'D) HEAD TO FLANGE WELD NO. 6	ONE	33%	33%	STUD HOLE: 1 THRU 16	77-W RPV REPORT & 77-74,73,75
			TWO	33%	33%	16 THRU 34	81-141,143,144
			THREE	33%	-		
B1.4	B-D	<u>PRIMARY NOZZLE-TO-VESSEL WELDS AND NOZZLE INSIDE RADIUSED SECTIONS</u> REACTOR CORE COOLANT NOZZLES					
		OUTLET NOZZLES	ONE	1	1	RCC-A-1	77-W RPV REPORT
			TWO	1	1	RCC-B-1	81- <u>W</u> RPV REPORT
		INLET NOZZLES	THREE	2	-		
		SAFETY INJECTION NOZZLES	THREE	1	-		
			THREE	1	-		
B1.5	B-E	<u>VESSEL PENETRATIONS, INCLUDING CONTROL ROD DRIVE AND INSTRUMENTATION PENETRATIONS</u> CONTROL ROD PENETRATIONS	ONE	3%	*3		*EACH ITEM INSPECTED BY PLANT PERSONNEL DURING EACH REACTOR VESSEL LEAKAGE TEST
			TWO	3%	*3		
			THREE	4%	-		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE S1.1PAGE 3 OF 5

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: REACTOR VESSEL

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B1.5	B-E	(CONT'D) INSTRUMENTATION PENETRATIONS	ONE TWO THREE	3% 3% 3%	*3 *3 -		*EACH ITEM INSPECTED BY PLANT PERSONNEL DURING EACH REACTOR VESSEL LEAKAGE TEST
		REACTOR VESSEL HEAD VENT	*-	1	*1	1-2RC-36 TO 2-RC-8-5	
B1.6	B-F	<u>NOZZLE TO SAFE END WELDS</u> REACTOR CORE COOLANT NOZZLES					
		OUTLET NOZZLES	ONE TWO	1 1	1 1	RCC-A-1 S.E. RCC-B-1 S.E.	77-W RPV REPORT & 77-020,112 81-W RPV REPORT & 81-21
		INLET NOZZLES	THREE	2	2	RCC-A-14 S.E. RCC-B-14 S.E.	83B-133 (PT ONLY) 83B-134 (PT ONLY)
		REACTOR VESSEL SAFETY INJECTION NOZZLES					
		NOZZLE A S.E.	ONE	1	1	NO. 1	77-W RPV REPORT & 77-023,113
		NOZZLE B S.E.	THREE	1	1	NO. 1	83B-047, 157
B1.8	B-G-1	<u>CLOSURE STUDS AND NUTS</u>	ONE TWO	16 16	16 16	#1 THRU #16 #1THRU #16 #17 THRU #32	77-W RPV REPORT & 77-106 78-84,99 (MT ONLY) 81-162,163,165,166

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE SJ.1PAGE 4 OF 5

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: REACTOR VESSEL

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
			THREE	16	16	#33 THRU #48 #33 THRU #48	83B-048, 061, 062 (STUDS ONLY) 84-038, 049 (NUTS)
B1.9	B-G-1	<u>LIGAMENTS BETWEEN THREADED STUD HOLES</u>	ONE	16	16	12-22 & 29-35	STUD HOLES: 77-W RPV REPORT
			TWO	14	14	9-11 & 36-46	81-W RPV REPORT
			THREE	18	-		
B1.10	B-G-1	<u>CLOSURE WASHERS AND BUSHINGS</u>					
		WASHERS	ONE	16	16	PAIRS, 1 THRU 16	77-W RPV REPORT
			TWO	16	16	PAIRS, 17 THRU 32	81-T64
			THREE	16	16	PAIRS, 33 THRU 48	84-039
		BUSHINGS	-	-	-	-NONE-	
B1.11	B-G-2	<u>PRESSURE RETAINING BOLTING</u>	ONE	3	9	ALL 9 BOLTS	77-W RPV REPORT
			TWO	3	9	ALL 9 BOLTS	81-T70
			THREE	3	9	ALL 9 BOLTS	84-064
B1.12	B-H	<u>INTEGRALLY WELDED VESSEL SUPPORTS</u>	THREE	2	-		
B1.13	B-I-1	<u>CLOSURE HEAD CLADDING</u>	ONE	2	2	HCP-1 & HCP-2	77-W RPV REPORT
			TWO	2	3	HCP-1, HCP-3 & HCP-4	81-T55
			THREE	2	2	HCP-5 & HCP-6	84-063
B1.14	B-I-1	<u>VESSEL CLADDING</u>	ONE	2	2	VCP-1 & VCP-2	76-W INTERNALS RPT
			TWO	2	2	VCP-3 (2 PATCHES)	81-W RPV REPORT
			THREE	2	-		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE SI.1PAGE 5 OF 5

MAJOR ITEM: REACTOR VESSEL

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B1.15	B-N-1	<u>VESSEL INTERIOR</u> UPPER INTERNALS AND LOWER INTERNALS	ONE TWO THREE	* * *	* * -	* * *	76-W INTERNALS RPT 80-W INTERNALS RPT *, REPRESENTATIVE REGIONS OF THOSE INTERIOR SURFACES AND INTERNALS MADE ACCESSIBLE BY THE REMOVAL OF COMPON- ENTS DURING NORMAL REFUELING OPERATION
B1.16	B-N-2	<u>INTERIOR ATTACHMENTS AND CORE SUPPORT STRUCTURES</u>	-	-	-	NOT APPLICABLE FOR PWR'S	
B1.17	B-N-3	<u>REMOVABLE CORE SUPPORT STRUCTURES</u>	THREE	*-	-	*100% OF THE VISU- ALLY ACCESSIBLE ATTACHMENT WELDS AND VISUALLY ACCES- SIBLE SURFACES OF THE CORE SUPPORT STRUCTURE	
B1.18	B-0	<u>CONTROL ROD DRIVE HOUSINGS</u> PERIPHERAL CRD HOUSINGS	THREE	2	-		
B1.19	B-P	<u>EXEMPTED COMPONENTS</u>	-	*-	-	*ALL COMPONENTS EXEMPTED FROM VOLUMETRIC AND SURFACE EXAMINA- TION BY IWB-1200	*PERFORMED BY PLANT PERSONNEL IN ACCORD- ANCE WITH IWA-5000 DURING EACH SYSTEM LEAKAGE TEST AND EACH SYSTEM HYDRO- STATIC TEST REQUIRED BY IWB-5000

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PRESSURIZER

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B2.1	B-B	<u>LONGITUDINAL AND CIRCUMFERENTIAL WELDS</u>					
		LONGITUDINAL WELDS					
		WELD NO. 1	THREE	5%	9%	W-3 UP 12"	82-197,217,251
			THREE	5%	12%	W-4 DOWN 15"	82-197,217,251
		WELD NO. 2	ONE	5%	5%	BOTTOM TO TOP	76-45,67
			TWO	5%	8%	W-5 DOWN 11"	78-104,112,118
						(CW)	
		CIRCUMFERENTIAL WELDS				FROM NAMEPLATE:	
		WELD NO. 3	ONE	1.7%	33%	+10' TO +18'	76-43,69
			TWO	1.7%	13%	+7'6" TO +10'8"	78-105,115,122
			THREE	1.8%	25%	-2' TO +4'	82-198,216,252
		WELD NO. 4	ONE	1.7%	33%	+8' TO 16'	76-44,66
			TWO	1.7%	6%	+8'4" TO +9'10"	78-103,114,119
			THREE	1.8%	25%	-1'10" TO +4'2"	82-196,208,253
		WELD NO. 5	ONE	1.7%	33%	+10' TO +18'	76-29,68
			TWO	1.7%	12%	+6'10" TO +9'9"	78-113,116,121
			THREE	1.8%	6.9%	0" TO 1'8"	82-195,209,254
B2.2	B-D	<u>NOZZLE TO VESSEL WELDS</u>	-	-	-	-NONE-	
B2.3	B-E	<u>HEATER PENETRATION</u>	*	25/10 YRS	*		*EACH ITEM INSPECTED BY PLANT PERSONNEL
B2.4	B-F	<u>NOZZLE TO SAFE END WELDS</u>	ONE	2	2	W-1A S.E. (8010A)	76-26,53
			TWO	5	5	W-1A S.E. (8010B)	76-61,52
						W-15 S.E.	78-31,100
						W-1A S.E. (RELIEF)	80-58,87,170
						W-22A S.E. (SPRAY)	80-57,85,168
						W-1A S.E. (8010A)	80-188,192,192R,192Ra
						W-1A S.E. (8010B)	80-189,191,191R
					2	W-1A S.E. (8010A)	81-6,6R,37,63
						W-1B S.E. (8010B)	81-23,23R,39,62

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PRESSURIZER

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
82.4	B-F	(CON'T)	THREE	2	2	W-1A S.E. W-22A S.E.	82-200,224,226 82-203,225,227
B2.5 B2.6 AND B2.7	B-C-1	PRESSURE-RETAINING BOLTS AND STUDS (2 IN. DIA.)	-	-	-	-NONE-	
B2.8	B-H	INTEGRALLY WELDED VESSEL WELD SKIRT WELD	ONE TWO THREE	3.3% 3.3% 3.4%	3.3% 23% 27%	(CW) FROM NAMEPLATE: +8" TO -8" +6' TO +11'9" +10' TO +16' 5"	76-77 78-106,107,117 82-231
B2.9	B-I-2	VESSEL CLADDING	THREE	36 SQ. IN. PATCH	-		
B2.10	B-P	EXEMPTED COMPONENTS					
		INSTRUMENT NOZZLE PENETRATIONS	*	-	-	NO. 5A THRU 5H	*EACH ITEM INSPECTED BY PLANT PERSONNEL
		SAMPLE NOZZLE PENETRATION	*	-	-	NO. 6	*EACH ITEM INSPECTED BY PLANT PERSONNEL
B2.11	B-G-2	PRESSURE RETAINING BOLTING					
		MANWAY BOLTS	ONE TWO THREE	5 5 6	5 5 16	BOLTS 1 THRU 6 BOLTS 6 THRU 10 BOLTS 1 THRU 16 BOLTS 1 THRU 16	76-30 78-82 81-60 82-232

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.3.1PAGE 1 OF 3MAJOR ITEM: STEAM GENERATORS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B3.1	B-B	<u>LONGITUDINAL AND CIRCUMFERENTIAL WELDS ON THE PRIMARY SIDE</u>					
		LONGITUDINAL WELDS	-	-	-	-NONE-	
		CIRCUMFERENTIAL WELDS STEAM GENERATOR NO. 21	ONE TWO THREE	1.9% 1.9% 1.8%	37% 8% 20%	(CW) FROM NAMEPLATE: +8" TO +13'8" +23'8" TO +26'8" -2'7" TO 4'6" -2'7" TO 4'6"	76-111,101,118 78-108,110,120 82-096,261,265 83B-188, 223, 225
		STEAM GENERATOR NO. 22	ONE TWO THREE	1.9% 1.9% 1.8%	31% 17% 10%	+2' TO +13' +21'10" TO +28' -13" TO 26" -13" TO 26"	76-112,102,119 78-109,111,123 82-095,256,266,271 83B-187, 224, 226
B3.2	B-D	<u>NOZZLE TO HEAD WELDS</u>	-	-	-	-NONE-	
B3.3	B-F	<u>NOZZLE TO SAFE END WELDS</u>					
		STEAM GENERATOR NO. 21	TWO THREE	1 1	1 1	RCC-A-5 S.E. RCC-A-4 S.E.	81-116,125 83B-143, 143R, 146
		STEAM GENERATOR NO. 22	ONE THREE	1 1	1 1	RCC-B-5 S.E. RCC-B-4 S.E.	81-116,125 83B-145, 151
B3.4 B3.5 AND B3.6	B-G-1	<u>PRESSURE RETAINING BOLTS AND STUDS (2 IN. DIA.)</u>	-	-	-	-NONE-	
B3.7	B-H	<u>INTEGRALLY WELDED VESSEL SUPPORTS</u>	-	-	-	-NONE-	

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE SI.3.1PAGE 2 OF 3MAJOR ITEM: STEAM GENERATORS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B3.8	B-I-2	<u>VESSEL CLADDING</u> STEAM GENERATOR NO. 21 INLET SIDE OUTLET SIDE STEAM GENERATOR NO. 22 INLET SIDE OUTLET SIDE	ONE ONE ONE ONE	36 SQ. IN. PATCH 36 SQ. IN. PATCH 36 SQ. IN. PATCH 36 SQ. IN. PATCH	36 SQ. IN. 36 SQ. IN. 36 SQ. IN. 36 SQ. IN.	CP-1, BELOW MANWAY CP-2, BELOW MANWAY CP-3, BELOW MANWAY CP-4, BELOW MANWAY	76-124 76-124 76-123 76-123
B3.9	B-P	<u>EXEMPTED COMPONENTS</u>	-	-	-	-NONE-	
B3.10	B-G-2	<u>PRESSURE RETAINING BOLTING (2 IN. DIA.)</u> STEAM GENERATOR NO. 21 MANWAY BOLTING INLET MANWAY	ONE TWO THREE	5 5 6	6 21 48	BOLTS 1 THRU 6 BOLTS 6 THRU 10 BOLTS 1 THRU 16 BOLTS 1 THRU 16 BOLTS 1 THRU 16 BOLTS 1 THRU 16	76-99 78-83 81-25,31,45 82-213,215 83B-060, 068, 170 84-014, 018

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

TABLE S1.3.1

PAGE 3 OF 3

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: STEAM GENERATORS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.	
B3.10	B-G-2	(CONT'D)						
		OUTLET MANWAY	ONE	5	6	BOLTS 1 THRU 6	76-99	
			TWO	5	21	BOLTS 6 THRU 10	78-83	
			THREE	6	48	BOLTS 1 THRU 15	81-25,31,45	
						BOLTS 1 THRU 16	82-213,215	
						BOLTS 1 THRU 16	83B-060,067,068,170	
						BOLTS 1 THRU 16	84-014, 018	
		STEAM GENERATOR NO. 22 MANWAY BOLTING						
		INLET MANWAY	ONE	5	6	BOLTS 1 THRU 6	76-120	
			TWO	5	16	BOLTS 6 THRU 10	78-77	
			THREE	6	46	BOLTS 1 THRU 16	81-29,44	
						BOLTS 1 THRU 14	82-212,215	
						BOLTS 1 THRU 16	83B-049, 066, 169	
						BOLTS 1 THRU 16	84-015, 019	
		OUTLET MANWAY	ONE	5	6	BOLTS 1 THRU 6	76-120	
			TWO	5	21	BOLTS 6 THRU 10	78-77	
			THREE	6	46	BOLTS 1 THRU 16	81-29,44	
						BOLTS 1 THRU 14	82-212,215	
				BOLTS 1 THRU 16	83B-049,052,066,169			
				BOLTS 1 THRU 16	84-015, 019			

INSERVICE INSPECTION - EXAMINATION SUMMARY

MAJOR ITEM: REGENERATIVE HEAT EXCHANGER

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B3.1	B-B	LONGITUDINAL AND CIRCUMFERENTIAL WELDS ON THE PRIMARY SIDE LONGITUDINAL WELDS CIRCUMFERENTIAL WELDS EXCHANGER A EXCHANGER B EXCHANGER C	- ONE TWO THREE	- 1 1 1	- 1 1 1	-NONE- NO. 1, SHELL WELD NO. 2, SHELL WELD NO. 3, SHELL WELD	 76-100 78-74 82-086
B3.2	B-D	NOZZLE TO HEAD WELD	-	-	-	-NONE-	
B3.4 B3.5 AND B3.6	B-G-1	PRESSURE RETAINING BOLTS AND STUDS (2 IN. DIA.)	-	-	-	-NONE-	
B3.7	B-H	INTEGRALLY WELDED VESSEL SUPPORTS	-	-	-	-NONE-	
B3.8	B-I-2	VESSEL CLADDING	-	-	-	-NONE-	
B3.9	B-P	EXEMPTED COMPONENTS	-	-	-	-NONE-	
B3.10	B-G-2	PRESSURE RETAINING BOLTING (2 IN. DIA.)	-	-	-	-NONE-	

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.3.3

PAGE 1 OF 1

MAJOR ITEM EXCESS LETDOWN HEAT EXCHANGERS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B3.1	B-B	<u>LONGITUDINAL AND CIRCUMFERENTIAL WELDS ON THE PRIMARY SIDE</u>					
		LONGITUDINAL WELDS	-	-	-	-NONE-	
		CIRCUMFERENTIAL WELDS	ONE	33%	-	(NOTE PERIOD TWO)	
			TWO	66%	100%	W-1, HEAD TO FLANGE	78-73
			THREE	34%	100%	W-1, HEAD TO FLANGE	82-087
B3.2	B-D	<u>NOZZLE TO VESSEL WELDS</u>	-	-	-	-NONE-	
B3.3	B-F	<u>NOZZLE TO SAFE END WELDS</u>	-	-	-	-NONE-	
B3.4 B3.5 AND B3.6	B-G-1	<u>PRESSURE RETAINING BOLTS AND STUDS (2 IN. DIA.)</u>	-	-	-	-NONE-	
B3.7	B-H	<u>INTEGRALLY WELDED VESSEL SUPPORTS</u>	-	-	-	-NONE-	
B3.8	B-I-1	<u>VESSEL CLADDING</u>	-	-	-	-NONE-	
B3.9	B-P	<u>EXEMPTED COMPONENTS</u>	-	-	-	-NONE-	
B3.10	B-G-2	<u>PRESSURE RETAINING BOLTING (2 IN. DIA.)</u>	ONE	4	-	(NOTE PERIOD TWO)	
			TWO	8	8	BOLTS 1 THRU 8	78-72
			THREE	4	12	BOLTS 1 THRU 12	82-112

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4PAGE 1 OF 19MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.1	B-F	SAFE END TO PIPING AND SAFE END IN BRANCH PIPING WELDS					
		REACTOR VESSEL					
		REACTOR CORE COOLANT SYSTEMS	ONE	1	1	W-1A, 29-2RC-1A	77-W RPV REPORT & 77-022,112
			TWO	1	1	RCC-B-1 S.E.	81-W RPV REPORT & 81-21
			THREE	2	2	RCC-A-14 S.E. RCC-B-14 S.E.	83B-155 (PT ONLY) 83B-156 (PT ONLY)
		SAFETY INJECTION SYSTEMS	ONE	1	1	W-2, 4-2RC-14A	77-W RPV REPORT & 77-024,113
			THREE	1	1	W-1	83B-047, 135
		STEAM GENERATOR NO. 21					
		REACTOR CORE COOLANT SYSTEM	TWO	1	1	RCC-A-5 S.E.	81-116,125
			THREE	1	1	RCC-A-4 S.E.	83B-143, 143R, 146
		STEAM GENERATOR NO. 22					
		REACTOR CORE COOLANT SYSTEM	ONE	1	1	W-5, 31-2RC-2B	76-136,139
			THREE	1	1	RCC-B-4 S.E.	83B-145, 151
		PRESSURIZER					
		SAFETY LINES	ONE	2	2	W-1, (8010A)	76-26,53
			TWO	2	2	W-1, (8010B) W-1, (8010A)	76-61,52 80-187, 192, 192R, 192Ra
					2	W-1, (8010B)	80-190,191,191R
						W-1, (8010A)	81-7,7R,38,61
						W-1, (8010B)	81-22,22R,40,64
		SURGE LINE	TWO	1	1	W-15 SE, 10-2RC-4	78-31,100

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.1	B-F	(CONT'D)					
		RELIEF LINE	TWO	1	1	W-1B	80-58,88,169
			THREE	1	1	W-1	82-201,222
		SPRAY LINE	TWO	1	1	W-22B	80-56,56R,86,167
			THREE	1	1	W-22B W-22	81-5,5R,24 82-202,223
B4.2 B4.3 AND B4.4	B-G-1	<u>PRESSURE REMAINING BOLTS AND STUDS (2 IN. DIA.)</u>	-	-	-	-NONE-	
B4.5	B-J	<u>CIRCUMFERENTIAL AND LONGITUDINAL PIPE WELDS</u>					
		LONGITUDINAL WELDS	-	-	-	-NONE-	
		CIRCUMFERENTIAL WELDS <u>(1.5 IN. NOM. DIA. SYS.)</u>					
		SEAL INJECTION A	ONE	-	-		
			TWO	1	1	W-4	78-12
			THREE	1	1	W-3	82-077
		SEAL INJECTION B	ONE	1	1	W-9	77-57
			TWO	-	-		
			THREE	1	1	W-4	84-061
		<u>(2.0 IN. NOM. DIA. SYS.)</u>					
		SEAL INJECTION A	ONE	3	3	W-21,22,24	77-18,19,20
			TWO	3	3	W-34,35,36	78-14,16,17
			THREE	4	4	W-8,52,53,54	82-076,230,229,228

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4

PAGE 3 OF 19

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.5	B-J	(CONT'D)					
		SEAL INJECTION B	ONE	4	4	W-54,55,58,59	77-10,11,13,12
			TWO	5	5	W-29,33,34,36,37	80-91,90,89,92,93
			THREE	4	4	W-11,16,17,18	82-072,073,074,075
		CHARGING LINE	ONE	6	6	W-81,82A,80,83B,	77-9,8,7,6,5,4
		CVCS	TWO	6	6	83A,83 W-32,33,36	78-20,21,22
			THREE	6	6	W-37,38,39 W-4,5,12,13,24,25	80-96,97,98 83B-009,008,007,006, 004,003
		LETDOWN LINE AND	ONE	1	1	W-22	77-27
		DRAIN LINE	TWO	2	2	W-6,7	80-94,95
			THREE	2	2	W-9,13	82-109,110
		AUXILIARY SPRAY	ONE	1	1	W-1	77-28
		TO PRESSURIZER	TWO	1	1	W-11	78-71
			THREE	2	2	W-12, 13	83B-115, 116
		RESIDUAL TEMPERATURE	ONE	1	1	W-20	77-42
		DETECTOR TAKE OFF-	TWO	1	1	W-6	80-177
		COLD LEG A	THREE	1	1	W-11	83B-014
		RESIDUAL TEMPERATURE	ONE	1	1	W-18	77-60
		DETECTOR TAKE OFF-	TWO	2	2	W-8,9	80-116,117
		COLD LEG B	THREE	1	1	W-13	83B-021
		RESIDUAL TEMPERATURE	ONE	1	1	W-24	77-58
		DETECTOR TAKE OFF-	TWO	1	1	W-29	80-178
		HOT LEG A	THREE	2	2	W-39, 40	83B-013, 012
		RESIDUAL TEMPERATURE	ONE	1	1	W-19	77-59
		DETECTOR TAKE OFF-	TWO	1	1	W-23	80-104
		HOT LEG B	THREE	2	2	W-37, 38	83B-020, 026

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4PAGE 4 OF 19MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.5	B-J	(CONT'D)					
		SAFETY INJECTION HIGH HEAD A	ONE TWO THREE	- 1 1	- 1 1	W-2 W-7	78-15 82-108
		SAFETY INJECTION HIGH HEAD B	ONE TWO THREE	1 - 1	1 - 1	W-7 W-2 W-2 (REPEAT)	77-43 82-262 83B-027
		DRAIN LINE ON CROSSOVER A	ONE TWO THREE	1 1 1	1 1 1	W-14 W-7 W-6	77-26 78-13 82-107
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A	ONE TWO THREE	1 1 1	1 1 1	W-12 W-9 W-2	77-17 78-19 82-092
		REACTOR VESSEL SAFETY INJECTION LOW HEAD B	ONE TWO THREE	- 1 1	- 1 1	W-2 W-1	78-23 82-091
		<u>(3.0 IN. NOM. DIA. SYS.)</u>					
		SPRAY TO PRESSURIZER BRANCH A	ONE TWO THREE	3 3 4	3 3 4	W-5,7,8 W-20,24,25 W-16,17 W-9, 11	77-38,40,39 80-121,120,119 82-220,218 83B-138, 139
		SPRAY TO PRESSURIZER BRANCH B	ONE TWO THREE	2 3 2	2 3 2	W-18,19 W-3,4,5 W-2, 3	77-48,46 80-118,122,103 83B-136, 137
		RESIDUAL TEMPERATURE DETECTOR RETURN A	ONE TWO THREE	1 1 1	1 1 1	W-5 W-2 W-3	77-41 78-66 84-062

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4

PAGE 5 OF 19

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.5	B-J	(CONT'D)					
		RESIDUAL TEMPERATURE DETECTOR RETURN B	ONE TWO THREE	1 1 1	1 1 1	W-7 W-6 W-3	77-56 78-85 83B-029
		PRESSURIZER RELIEF LINE A	ONE TWO THREE	- - 1	- - 1	W-5	82-221
		PRESSURIZER RELIEF LINE B	ONE TWO THREE	1 1 1	1 1 1	W-4 W-9 W-10	77-47 80-99 83B-120
		<u>(4.0 IN. NOM. DIA. SYS.)</u>					
		SAFETY INJECTION LOW HEAD A	ONE TWO THREE	1 - -	- - -	NONE OF THESE WELDS ARE ACCESSIBLE; THEY ARE LOCATED WITHIN THE CONCRETE SHIELD WALL	
		SAFETY INJECTION LOW HEAD B	ONE TWO THREE	- - 1	- - 1	W-2	83B-120
		<u>(6.0 IN. NOM. DIA. SYS.)</u>					
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A	ONE TWO THREE	- 1 1	- 1 2	W-6 W-5, 4	80-100 83B-092, 091
		REACTOR VESSEL SAFETY INJECTION LOW HEAD B	ONE TWO THREE	1 - 1	1 - 2	W-9 (+W-8) W-4, 3	76-37 (+76-38) 83B-090, 093

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4
 PAGE 6 OF 19
 MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.5	B-J	(CONT'D)					
		SAFETY INJECTION HIGH HEAD A	ONE TWO THREE	- - 1	- - 1	W-2	83B-010
		SAFETY INJECTION HIGH HEAD B	ONE TWO THREE	1 - -	1 - -	W-1	76-143
		PRESSURIZER SAFETY LINE A	ONE TWO THREE	- 3 1	- 3 -	W-8/W-3,4	80-102/81-59,58
		PRESSURIZER SAFETY LINE B	ONE TWO THREE	2 2 1	2 2 1	W-1,2 W-6,7 W-4	76-54,61 81-57,56 83B-089
		PLO-CAP A	ONE TWO THREE	- - 1	- - 1	W-1	83B-011
		PLO-CAP B	ONE TWO THREE	- 1 -	- 1 -	W-1	80-101
		<u>(8.0 IN. NOM. DIA. SYS.)</u>					
		RESIDUAL HEAT REMOVAL TAKE OFF A	ONE TWO THREE	2 3 3	2 3 3	W-11,12 W-5,6,8 W-2,3,4	77-33,32 78-90,94,92 82-078,079,082
		RESIDUAL HEAT REMOVAL TAKE OFF B	ONE TWO THREE	3 2 3	8 2 3	W-25,27,28 (+W-8,10,11,12,26) W-12,14 W-5,6,7	76-74,58,56 (+76-70,71,72,73,58) 78-95,91 82-083,084,085

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4

PAGE 7 OF 19

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.5	B-J	(CONT'D)					
		<u>(10.0 IN. NOM. DIA. SYS.)</u>					
		RESIDUAL HEAT REMOVAL RETURN B	ONE TWO THREE	1 1 1	2 1 1	W-1 (+W-9) W-7 W-9	76-9 (+76-7) 78-102 83B-019
		PRESSURIZER SURGE LINE B	ONE TWO THREE	1 1 2	4 1 2	W-12 (+W-11,13,14) W-14 W-1, 2	76-81 (+76-78,81,79) 78-101 83B-165, 166
		<u>(12.0 IN. NOM. DIA. SYS.)</u>					
		ACCUMULATOR DISCHARGE A	ONE TWO THREE	1 1 1	1 1 1	W-11 W-7 W-3	77-35 80-35,36 83B-173
		ACCUMULATOR DISCHARGE B	ONE TWO THREE	2 1 2	5 1 2	W-1,15 (+W-13,14 16) W-13 W-2, 3	76-146,18 (+76-20 21,19) 80-34,37 83B-174, 175
		<u>(27.5 IN. NOM. DIA. SYS.)</u>					
		REACTOR CORE COOLANT COLD LEG (INLET) A	ONE TWO THREE	- - 1	- - 1	 RCC-A-11	 83B-015, 017, 017R
		<u>(29.0 IN. NOM. DIA. SYS.)</u>					
		REACTOR CORE COOLANT COLD LEG (INLET) B	ONE TWO THREE	- 1 -	- 1 -	 RCC-B-12 	 81-87,94

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.5	B-J	(CONT'D)					
		REACTOR CORE COOLANT HOT LEG (OUTLET) A	ONE TWO THREE	1 - -	1 - -	W-3, 29-2RC-1A	77-044
		REACTOR CORE COOLANT HOT LEG (OUTLET) B	ONE TWO THREE	- - 1	- - 1	RCC-B-3	83B-147, 150
		<u>(31.0 IN. NOM. DIA. SYS.)</u>					
		REACTOR CORE COOLANT CROSSOVER A	ONE TWO THREE	- 2 -	- 2 -	RCC-A-7 RCC-A-7	81-115,115R,152 81-117,124
		REACTOR CORE COOLANT CROSSOVER B	ONE TWO THREE	1 - 1	3 - 1	W-6 (+W-7,8) RCC-B-10	76-140 (+76-141,142) 83B-016, 018
B4.6	B-J	<u>BRANCH PIPE CONNECTION WELDS EXCEEDING SIX INCH DIAMETER</u>					
		ACCUMULATOR DISCHARGE A	-	-	-		
		ACCUMULATOR DISCHARGE B	ONE	1	1	W-R	76-145,137
		RESIDUAL HEAT REMOVAL TAKE OFF A	-	-	-		
		RESIDUAL HEAT REMOVAL TAKE OFF B	TWO	1	1	W-ROOT	81-113,121,126
		PRESSURIZER SURGE LINE B	THREE	1	1	W-R	83B-160, 167

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.7	B-J	BRANCH PIPE CONNECTION <u>WELDS SIX INCH DIAMETER AND SMALLER</u>					
		<u>(6.0 IN. NOM. DIA. SYSTEMS)</u>					
		PLO-CAP A	-	-	-		
		PLO-CAP B	-	-	-		
		SAFETY INJECTION HIGH HEAD A	-	-	-		
		SAFETY INJECTION HIGH HEAD B	ONE	1	1	W-R	76-138,144
		<u>(3.0 IN. NOM. DIA. SYSTEMS)</u>					
		SPRAY TO PRESSURIZER BRANCH A	-	-	-		
		SPRAY TO PRESSURIZER BRANCH B	THREE	1	1	W-R	83B-149
		RESIDUAL TEMPERATURE DETECTOR RETURN A	-	-	-		
		RESIDUAL TEMPERATURE DETECTOR RETURN B	-	-	-		
		<u>(2.0 IN. NOM. DIA. SYSTEMS)</u>					
RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG A	-	-	-				

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.7	B-J	(CONT'D)					
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG A	TWO	1	1	W-ROOT	81-89
		DRAIN LINE ON CROSSOVER A	-	-	-		
		DRAIN LINE ON CROSSOVER B	ONE	1	1	W-R	76-131
		CHARGING LINE CVCS	-	-	-		
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A	-	-	-		
		REACTOR VESSEL SAFETY INJECTION LOW HEAD B	THREE	1	1	W ?	82-144
B4.8	B-J	<u>SOCKET WELDS</u>					
		<u>(2.0 IN. NOM. DIA. SYSTEMS)</u>					
		SEAL INJECTION A	ONE	-	-		
			TWO	1	1	SW-9	78-25
			THREE	1	1	W-10	82-099
		SEAL INJECTION B	ONE	1	1	SW-64	76-5
			TWO	-	-		
			THREE	1	1	W-12	82-097

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4PAGE 11 OF 19

MAJOR ITEM:

PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.8	B-J	(CONT'D)					
		CHARGING LINE B	ONE	1	1	SW-54 (+SW-57,87)	76-49 (+76-49,6)
			TWO	1	1	SW-27	78-28
			THREE	1	1	W-26	83B-098
		DRAIN LINE AND LETDOWN LINE B	ONE	1	1	SW-1 (+SW-24)	76-131 (+76-40)
			TWO	1	1	SW-10	80-158
			THREE	1	1	W-17	83B-101
		AUXILLIARY SPRAY	ONE	1	1	SW-4	76-42
			TWO	-	-		
			THREE	-	-		
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG A	ONE	1	1	SW-13	77-117
			TWO	1	1	SW-4	78-27
			THREE	1	1	W-12	83B-059
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG B	ONE	1	1	SW-15	77-120
			TWO	1	1	SW-4	78-26
			THREE	1	1	SW-14	84-050
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF HOT LEG A	ONE	-	-		
			TWO	1	1	SW-31	80-154
			THREE	1	1	W-38	83B-038
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF HOT LEG B	ONE	-	-		
			TWO	1	1	SW-29	80-157
			THREE	1	1	W-36	83B-039
		SAFETY INJECTION HIGH HEAD A	ONE	-	-		
			TWO	-	-		
			THREE	1	1	W-8	82-145

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.8	B-J	(CONT'D)					
		SAFETY INJECTION HIGH HEAD B	ONE TWO THREE	1 - -	1 - -	SW-8	77-110
		DRAIN LINE ON CROSSOVER A	ONE TWO THREE	1 - -	1 - -	SW-13	77-114
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A	ONE TWO THREE	1 - -	1 - -	SW-13	77-111
		REACTOR VESSEL SAFETY INJECTION LOW HEAD B	ONE TWO THREE	- - 1	- - 1	W-6	82-143
B4.9	B-K-1	<u>INTEGRALLY WELDED SUPPORTS</u>					
		SEAL INJECTION A	TWO	1	1	H	78-18,30,39
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF HOT LEG A	-	-	-		
		SAFETY INJECTION HIGH HEAD A	-	-	-		
		SPRAY TO PRESSURIZER BRANCH A	TWO	1	1	L	80-76,123,156
		BRANCH B	THREE	1	1	I	82-204,206,219

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4

PAGE 13 OF 19

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.9	B-K-1	(CONT'D)					
		RESIDUAL HEAT REMOVAL TAKE OFF A	TWO	1	1	U	78-29,50,93
		ACCUMULATOR DISCHARGE A	-	-	-		
		SEAL INJECTION B	TWO	1	1	A	80-49,105,155
		CHARGING LINE CVCS	ONE	1	2	Z (+X)	76-109,106(+76-110-6)
			TWO	-	-		
			THREE	1	1	L	83B-005, 124, 125
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG B	-	-	-		
		RESIDUAL HEAT REMOVAL TAKE OFF B	ONE	1	1	Q	76-60,59
		RESIDUAL HEAT REMOVAL RETURN B	THREE	1	1	D	82-123,140,255
		ACCUMULATOR DISCHARGE B	ONE	1	1	B1	76,39-3
		SAFETY INJECTION HIGH HEAD B	-	-	-		
		AUXILLIARY SPRAY CVCS	-	-	-		
		REACTOR VESSEL SAFETY INJECTION A	THREE	1	1	C	82-098,139,146

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

 TABLE S1.4
 PAGE 14 OF 19
 MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.10	B-K-2	(CONT'D)					
4.10	B-K-2	<u>SUPPORT COMPONENTS</u>					
		SEAL INJECTION A	ONE	4	3	A1, N/G (HGR J ADDED, PER. 2)	76-96/77-133
			TWO	5	6	F, I, J	78-38, 40, 65
			THREE	6	5	A, B, C L, M, N, O, P	80-148, 147 82-114, 116, 117, 113, 115
		DRAIN LINE ON CROSSOVER A	ONE	-	-		
			TWO	-	-		
			THREE	1	1	A	82-118
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG A	ONE	1	1	A	76-97
			TWO	1	1	B1	80-144, 144R
			THREE	2	2	B1 A1 B	81-139, 139R 83B-070 83B-109
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF HOT LEG A	ONE	2	2	C, D	77-144
			TWO	2	2	G, H	80-146
			THREE	3	3	C1, C2, E	83B-071, 073, 033
		SAFETY INJECTION HIGH HEAD A	ONE	1	1	C	77-131
			TWO	1	1	D	80-132
			THREE	1	1	A A (REPEAT)	82-257 83B-077
		RESIDUAL TEMPERATURE DETECTOR RETURN A	ONE	1	1	C	76-98
			TWO	1	1	B	78-41
			THREE	1	1	A	83B-072

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4PAGE 15 OF 19MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.	
B4.10	B-K-2	(CONT'D)						
		SPRAY TO PRESSURIZER BRANCH A	ONE	4	4	J,M,N,O	76-107/77-151	
			TWO	5	5	B,C,D,H	78-42,43,44,45	
			THREE	5	5	V	80-135	
						P	82-205	
						P (REPEAT)	83B-164	
						Q, R, S, U, V	83B-081, 082, 083, 075, 076	
			SPRAY TO PRESSURIZER BRANCH B	ONE	3	3	G,H,F	76-107
				TWO	3	3	D,E,F1	80,129,130,131
				THREE	3	3	B,C,C1	82-163,162,161
			RESIDUAL HEAT REMOVAL TAKE OFF A	ONE	5	5	O,P,Q,S,T	76-41
				TWO	5	5	B.C.D.H,	78-46,47,48,49
				THREE	6	6	C,E	80-54,23
							I,J,L,M,	82-247,155,156,157
							R,V	82-121,154
			ACCUMULATOR DISCHARGE A	ONE	2	2	H,I	76-33
				TWO	3	3	D,E,G	80-25,50,51
				THREE	3	3	A,B,C	83B-079, 078, 080
			SEAL INJECTION B	ONE	4	4	O,P,N/Q	76-32/77-157
				TWO	4	4	D,E,K,M	80,53,52,47,46
				THREE	5	5	F,H,I,J	82-122,158,119,120
					B	83B-159		
	CHARGING LINE CVCS	ONE	5	5	R,S,V,W,Y	76-51,85		
		TWO	7	7	K,M,N,O	78-53,53,52,51		
		THREE	8	8	O,Q,T,V	80-80,127,126,125		
					B,B1,C,D	83B-158,163,102, 153,153R		
					F,H,J,P	83B-154,154R,123, 114,114R,126		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4PAGE 16 OF 19MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.10	B-K-2	(CONT'D)					
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF COLD LEG B	ONE TWO THREE	2 2 2	2 2 2	A,A1 B,C/C C1,E	77-156 78-54,55/80-145 83B-074,074R,045,045R
		RESIDUAL TEMPERATURE DETECTOR TAKE OFF HOT LEG B	ONE TWO THREE	1 2 2	1 2 2	A2 A1,A A1 C,D	77-134 80-73, 73R,72 81-140 83B-034,046
		DRAIN LINE AND LETDOWN LINE B	ONE TWO THREE	2 2 2	2 2 2	E/C A,B A1,A2	77-135/76-108 80-79,78 82-244,245
		RESIDUAL TEMPERATURE DETECTOR RETURN B	ONE TWO THREE	- 1 -	- 1 -	A	78-56
		RESIDUAL HEAT REMOVAL TAKE OFF B	ONE TWO THREE	5 5 6	5 5 6	H/L,M,N,O A,B,C C,D,K F,G,I,J, P,P	76-63/77-145,149 78-57,57,58 80-65,64,133 82-149,150,147,148, 148R 82-137,138
		RESIDUAL HEAT REMOVAL RETURN B	ONE TWO THREE	1 1 1	1 1 1	A B C	77-132 78-59 83B-069
		ACCUMULATOR DISCHARGE B	ONE TWO THREE	3 3 4	3 3 4	E,F,C B,B1/A A1,A2,D1,D2	77-138 78-60/80-48 83B-094,095,097,096
		SAFETY INJECTION HIGH HEAD B	ONE TWO THREE	1 - 1	1 - 1	C A	77-127 83B-085

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.4

PAGE 17 OF 19

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.10	B-K-2	(CONT'D)					
		AUXILLIARY SPRAY TO PRESSURIZER	ONE TWO THREE	1 1 2	1 1 2	A B C,E	76-46 78-61 83B-128,127
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A	ONE TWO THREE	1 - -	1 - -	A	77-128
		REACTOR VESSEL SAFETY INJECTION LOW HEAD B	ONE TWO THREE	- 1 -	- 1 -	A	
		PRESSURIZER RELIEF LINE B	ONE TWO THREE	- - 1	- - 1	A	82-159
		REACTOR VESSEL SAFETY INJECTION LOW HEAD B (6 X 4")	ONE TWO THREE	1 1 2	1 1 2	D B A,C	77-130 78-62 82-249,141
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A (6 X 4")	ONE TWO THREE	1 1 2	1 1 2	D A B,C	77-129 80-75 83B-152,103
		PRESSURIZER SAFETY LINES A & B	ONE TWO THREE	1 1 -	1 1 -	A1 A2	77-152 80-128
		PRESSURIZER SURGE B	ONE TWO THREE	3 4 5	3 4 5	K,J,I A,B/C,D E,F,G,H,H1	76-48 78-64,63/80-70,71 83B-043,043R,084, 084R,040,041,042

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM:

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.10	B-K-2	(CONT'D)					
		REACTOR CORE COOLANT CROSSOVER A	ONE TWO THREE	- 1 1	- 1 2	A1 A2,A3	81-138 83B-162,107,107R
		REACTOR CORE COOLANT CROSSOVER B	ONE TWO THREE	1 - 1	1 - 2	B1 B2,B3	76-106 83B-161,106
B4.11	B-P	<u>EXEMPT AND NON-EXEMPT COMPONENTS</u>	-	*	-	*ALL COMPONENTS EXAMINED IN ACCORDANCE WITH IWA-5000 AND IWB-5000 DURING SYSTEM LEAKAGE TEST	PERFORMED BY PLANT PERSONNEL
		HYDROSTATICALLY PRESSURE TESTED TO IWA-500) AT END OF TEN YEAR INTERVAL PLUS SYSTEM LEAKAGE EXAM EACH SCHEDULED REFUELING OUTAGE					
		EXEMPT:					
		RESISTANCE TEMPERATURE DETECTOR TAKE OFF 1-2RC-7A					
		EXCESS LETDOWN LINE A 1-2RC-8 1-2VC-7 1-2VC-9					
		RESISTANCE TEMPERATURE DETECTOR TAKE OFF 1-2RC-7B					

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE SI.4
PAGE 19 OF 19
MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.11	B-P	(CON'T) REACTOR VESSEL CLOSURE HEAD VENT 1-2RC-36 REACTOR VESSEL CLOSURE HEAD FLANGE 1-2RC-9A 1-2RC-9B					
B4.12	B-G-2	<u>PRESSURE RETAINING BOLTING</u> (ONLY SYSTEMS APPLICABLE TO THIS ITEM ARE LISTED)					
		SEAL INJECTION A	ONE	4	4	BOLTS 1-4 @ W-2	76-76
			TWO	4	4	BOLTS 1-4 @ W-4	78-81
		RESISTANCE TEMPERATURE DETECTOR RETURN A	THREE	8	8	BOLTS 1-8 @ W-7	83B-037
		PRESSURIZER SAFETY LINE A	TWO	12	12	BOLTS 1-12 @ 2-8010A	80-135
		SEAL INJECTION B	TWO	4	4	BOLTS 1-4 @ W-2	80-172
			THREE	4	4	BOLTS 1-4 @ W-4	82-100
		RESISTANCE TEMPERATURE DETECTOR RETURN B	THREE	8	-		
		PRESSURIZER SAFETY LINE B	ONE	12	12	BOLTS 1-12	76-17

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.5PAGE 1 OF 3

MAJOR ITEM: REACTOR CORE COOLANT PUMPS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B5.1 AND B5.3	B-G-1	PRESSURE RETAINING BOLTS AND STUDS, IN PLACE (2 IN. DIA.) FLANGE BOLTS PUMP A PUMP B SEAL HOUSE BOLTING PUMP A PUMP B	ONE TWO THREE ONE TWO THREE ONE TWO THREE ONE TWO THREE	8 8 8 8 8 ITEM B5.2 4 4 4 4 4 4	8 8 8 8 8 8 4 4 12 4 4 12	BOLTS 1 THRU 8 BOLTS 9 THRU 16 BOLTS 17 THRU 24 BOLTS 1 THRU 8 BOLTS 9 THRU 16 BOLTS 17 THRU 24 BOLTS 1 THRU 4 BOLTS 5 THRU 8 BOLTS 1 THRU 12 BOLTS 1 THRU 4 BOLTS 5 THRU 8 BOLTS 1 THRU 12	76-87 78-67 83B-213 76-86 78-68 83B-214 76-89 78-69 83B-200 76-88 78-70 83B-192
B5.2 AND B5.3	B-G-1	PRESSURE RETAINING BOLTS AND STUDS, WHEN REMOVED (2 IN. DIA.) PUMP A SEAL HOUSE BOLTING FLANGE BOLTING	TWO THREE TWO	12 24 24	12 24 24 24	BOLT 1 THRU 12 BOLT 1 THRU 24 BOLT 1 THRU 24 BOLT 1 THRU 24	81-46,47/81A-4,7 83B-105, 186, 104 84-054,054R,055, 057, 058 81A-1,2,3,5,6,6R

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: REACTOR CORE COOLANT PUMPS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B5.2 AND B5.3	B-G-1	(CON'T) PUMP B FLANGE BOLTING SEAL HOUSE BOLTING	THREE THREE	24 12	- 24 24	BOLT 1 THRU 24 BOLT 1 THRU 24	83B-050,063,064, 051,065 84-016,017,020,021
B5.4	B-K-1	<u>INTEGRALLY WELDED SUPPORTS</u> PUMP A PUMP B	TWO TWO THREE	3 3 3	3 3 -	SUPPORT A,B,C SUPPORT A,B,C	RELIEF NO. 47 81-129,131,130 81-132,134,137
B5.5	B-K-2	<u>SUPPORT COMPONENTS*</u> PUMP A COLUMN AND LATERAL SUPPORTS PUMP B COLUMN AND LATERAL SUPPORTS	ONE TWO THREE ONE TWO THREE	1 1 1 1 1 1	1 1 - 1 1 -	COLUMN 1 COLUMN 2 COLUMN 1 COLUMN 2	*COINCIDENT WITH SEISMIC BOLTING 77-67,163,158 80-181,107,174 77-64,162,161 80-181,107,108
B5.6	B-L-1	<u>PUMP CASING WELDS</u> PUMP A PUMP B	- -	- -	- -	-NONE- -NONE-	

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.5PAGE 3 OF 3

MAJOR ITEM: REACTOR CORE COOLANT PUMPS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B5.7	B-L-2	<u>PUMP CASINGS</u> PUMP A or B PUMP A	THREE TWO	1 1	- 1	PUMP CASING	81A-8
B5.8	B-P	<u>EXEMPTED COMPONENTS</u>	-	-	-	-NONE-	
B5.9	B-G-2	<u>PRESSURE RETAINING BOLTING (2 IN. DIA.)</u>	-	-	-	-NONE-	
-	-*	<u>PUMP FLYWHEELS</u> PUMP A & B	ONE TWO THREE	2 2 2	2* 2 2	PUMP-21, FLYWHEEL PUMP-22, FLYWHEEL PUMP-21, FLYWHEEL PUMP-22, FLYWHEEL PUMP-21, FLYWHEEL PUMP-22, FLYWHEEL	76-113,117,116 76-93,82,92 80-141,142,143 80-124,139,140 83B-176,177,178 83B-179,180,181
							*BOTH FLYWHEELS WERE REMOVED AS A RESULT OF MODIFICATION TO THE PUMP LUBRICATION SYSTEM THE BORE AND KEYWAY'S WERE PT EXAMINED & THE REMAINING SURFACES WERE MT EXAMINED. U.T. WAS USED TO VOLUMETRICALLY EXAMINE THE FLYWHEELS (NOTE TECH SPEC 4.2-1)

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.6
PAGE 1 OF 4
MAJOR ITEM: VALVE PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.1 B6.2 AND B6.3	B-G-1	PRESSURE RETAINING BOLTS AND STUDS (<u>2 IN. DIA.</u>)	-	-	-	-NONE-	
B6.4	B-K-1	INTEGRALLY WELDED SUPPORTS	-	-	-	-NONE-	
B6.5	B-K-2	SUPPORT COMPONENTS	-	*	-	*INCLUDE IN TABLE 1.4 UNDER B4.10	
B6.6	B-M-1	VALVE BODY WELDS	-	-	-	-NONE-	
B6.7	B-M-2	VALVE BODIES (<u>4 IN. NOM. PIPE SIZE</u>)					
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A	THREE	1	-		
		RESIDUAL HEAT REMOVAL TAKE OFF A	THREE	1	-		
		PRESSURIZER SAFETY LINE A	THREE	1	-		
		RESIDUAL HEAT REMOVAL RETURN B	THREE	1	-		
		ACCUMULATOR DISCHARGE A	THREE	1	1	2-8841A	84-013
B6.8	B-P	EXEMPTED COMPONENTS	*	100%	*	ITEMS INSPECTED DURING EACH LEAKAGE TEST	INSPECTED BY PLANT PERSONNEL

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: VALVE PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.9	B-G-2	PRESSURE RETAINING BOLTING *					*NOTE SUPPLEMENT B6.9 AT 3.4.3
		ACCUMULATOR DISCHARGE LOOP A - 12"	ONE THREE	16 16	16 16	CHECK, 2-8841A CHECK, 2-8840A	76-12 82B-054
		ACCUMULATOR DISCHARGE LOOP B - 12"	TWO THREE	16 16	16 16	CHECK, 2-8841B CHECK, 2-8840B	80-82 84-070
		RESIDUAL HEAT REMOVAL RETURN B-10"	ONE	16	16	M.O. GATE, 2-8703	76-13
		RESIDUAL HEAT REMOVAL TAKE OFF A-8"	TWO THREE	16 16	16 16	M.O. GATE, 2-8701A M.O. GATE, 2-8702A	78-80 82-167
		RESIDUAL HEAT REMOVAL TAKE OFF B-8"	ONE ONE	16 16	16 16	M.O. GATE, 2-8701B M.O. GATE, 2-8702B	76-16 76-16
		SAFETY INJECTION HIGH HEAD A - 6"	TWO	12	12	CHECK, 2-8842A	80-166
		SAFETY INJECTION HIGH HEAD B - 6"	THREE	12	12	CHECK, 2-8842B	83B-058
		PRESSURIZER SPRAY LOOP A - 3"	THREE	8	8	GLOBE(2-PCV-431A)	83B-055
		LOOP B - 3"	ONE THREE	8 8	8 8	GLOBE(2-PCV-431B) GLOBE(2-PVC-431B)	76-28 82-166
		RESISTANCE TEMPERATURE DETECTOR RETURN LOOP A - 3"	TWO	12	12	GATE, 2-8001A	78-79
		RESISTANCE TEMPERATURE DETECTOR RETURN LOOP B - 3"	TWO	12	12	GATE, 2-8001B	78-78

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.6PAGE 3 OF 4MAJOR ITEM: VALVE PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.9	B-G-2	(CONT'D)					
		RESISTANCE TEMPERATURE DETECTOR TAKE OFF COLD LEG A - 2"	ONE TWO THREE	2 2 2	2 2 2	2T58, 2RC-1-6 2T58, 2RC-1-7 2T58, 2RC-1-8	76-95 80-152 83B-099
		RESISTANCE TEMPERATURE DETECTOR TAKE OFF COLD LEG B - 2"	TWO TWO THREE	2 2 2	2 2 2	2T58, 2RC-1-15 2T58, 2RC-1-16 2T58, 2RC-1-17	80-137 80-165 83B-056
		RESISTANCE TEMPERATURE DETECTOR TAKE OFF HOT LEG A - 2"	TWO TWO THREE	2 2 2	2 2 2	2T58, 2RC-1-12 2T58, 2RC-1-10 2T58, 2RC-1-11	80-150 80-151 83B-100
		RESISTANCE TEMPERATURE DETECTOR TAKE OFF HOT LEG B - 2"	ONE TWO THREE	2 2 2	2 2 2	2T58, 2RC-1-12 2T58, 2RC-1-13 2T58, 2RC-1-14	76-103 80-136 83B-053
		PRESSURIZER RELIEF LINES 3"	ONE ONE TWO THREE	12 6 6 12	12 6 6 6	M.O. GATE, 2-8000B GLOBE, 2PCV-431C GLOBE, 2PCV-430 M.O. GATE, 2-8000A	76-14 76-14 80-149 82-165
		REACTOR VESSEL SAFETY INJECTION LOW HEAD A - 6"	ONE TWO THREE	12 12 -	12 12 12	CHECK, 2-8843A CHECK, 2-8844A CHECK, 2-8844A	76-91 80-171 83B-086, 086R
		LOW HEAD B - 6"	ONE THREE	12 12	12 12	CHECK, 2-8843B CHECK, 2-8844B	76-36 83B-087
		AUXILIARY SPRAY CVCS - 2"	THREE	6	6	GLOBE 2-8143	83B-121

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S1.6

PAGE 4 OF 4

MAJOR ITEM: VALVE PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.0	B-G-2	(CONT'D)					
		DRAIN LINE ON CROSSOVER B	ONE THREE	2 2	2 2	2T58, 2RC-1-3 2T58, 2RC-1-4 2T58, 2RC-1-4 (REPEAT)	76-11 82-259, 259R 83B-057
		DRAIN LINE ON CROSSOVER A - 2"	ONE THREE	2 2	2 2	2T58, 2RC-1-2 2T58, 2RC-1-1 2T58, 2RC-1-1 (REPEAT)	76-15 82-258 83B-148
		LETDOWN LINE B - 2	ONE	8	8	A.O. GLOBE, 2LCV-427	76-10
			TWO THREE	2 8	2 8	2T58, 2RC-1-5 A.O. GLOBE, 2LCV-428	80-81 82-164
		CHARGING LINE B - 2"	TWO	6	6	A.O. GLOBE, 2-8142	78-24
		SEAL INJUNCTION A - 2"	ONE	2	2	2T58, 2VC-7-18	76-94
		SEAL INJUNCTION B - 2"	ONE	2	2	2T58, 2VC-7-19	76-84

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>REACTOR VESSEL</u>							
<u>B1.8 CLOSURE STUDS AND NUTS</u>							
NUTS	39	UT MT	#33 - 48	84-049 84-038	NONE NONE	NONE NONE	NONE NONE
<u>B1.10 CLOSURE WASHERS</u>							
WASHERS	39	VT	#33 - 48	84-039	NONE	NONE	NONE
<u>B1.11 PRESSURE RETAINING BOLTING</u>							
MARMON CLAMP	38	VT	CLAMP #34 CLAMP #35 CLAMP #37	84-064 84-064 84-064	NONE NONE NONE	NONE NONE 1 BOLT & 2 NUTS ERRODED - ITEMS REPLACED	NONE NONE NONE
<u>B1.13 CLOSURE HEAD CLADDING</u>							
CLADDING PATCH	47	VT	HCP-5 HCP-6	84-063 84-063	NONE NONE	NONE NONE	NONE NONE
<u>STEAM GENERATOR</u>							
<u>B3.10 PRESSURE RETAINING BOLTING</u>							
S/G #21	37	UT MT	INLET MANWAY	84-014 84-018	NONE NONE	NONE NONE	NONE NONE
	37	UT MT	OUTLET MANWAY	84-014 84-018	NONE NONE	NONE NONE	NONE NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
S/G #22	37	UT MT	INLET MANWAY	84-015 84-019	NONE NONE	NONE NONE	NONE NONE
	37	UT MT	OUTLET MANWAY	84-015 84-019	NONE NONE	NONE NONE	NONE NONE
<u>PIPING</u>							
B4.5 <u>CIRCUMFERENTIAL AND LONGITUDINAL WELDS</u>							
SEAL INJECTION LOOP B	12C	UT	W-4	84-061	NONE	NONE	S-2,3,4 LIMITED @ 1:30, 4:30, 7:30 AND 10:30 BY FLANGE BOLTS
RTD RETURN LOOP A	6	UT	W-3	84-062	NONE	NONE	NO S-1 VALVE; S-2,3,4 LIMITED FROM 2:00 and 10:00 BY HANGER
B4.8 <u>SOCKET WELDS</u>							
RTD COLD LEG B	14	PT	W-14	84-050	NONE	NONE	LIMITED BY HANGER (APPROX. 60% COVERAGE)
<u>REACTOR CORE COOLANT PUMPS</u>							
B5.2 <u>PRESSURE RETAINING BOLTING, WHEN REMOVED</u>							
PUMP #21	43	UT MT	SEAL HOUSE UPPER	84-058 84-055	NONE NONE	NONE NONE	NONE NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
PUMP #22	43	UT MT	SEAL HOUSE LOWER	84-057	NONE	NONE 1 BOLT = 3/4" LINEAR REPLACEMENT BOLT/NONE	NONE
				84-054	NONE		NONE
				84-054R	N/A		NONE
PUMP #22	43	UT MT	SEAL HOUSE UPPER	84-020	NONE	NONE NONE	NONE
				84-016	NONE		NONE
PUMP #22	43	UT MT	SEAL HOUSE LOWER	84-020	NONE	NONE NONE	NONE
				84-017	NONE		NONE
<u>VALVES</u>							
B6.7 <u>VALVE INTERIORS</u>							
ACCUMULATOR DISCHARGE	75	VT	2-8841A	84-013	NONE	NONE	NONE
B6.9 <u>PRESSURE RETAINING BOLTING</u>							
ACCUMULATOR DISCHARGE	22	VT	2-8840B	84-070	NONE	NONE	NONE

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 ISOMETRIC SUMMARY CLASS 1

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
2-ISI-1	0	SEAL INJECTION (GENERAL VIEW)	A	1½" x 2"	-	-
2-ISI-1A	0		A	1½"	1½-2VC-21A	1
2-ISI-1B	0		A	2"	2-2VC-21A	3
2-ISI-1C	0		A	2"	2-2VC-21A	3
2-ISI-2	0		CROSSOVER DRAIN	A	2"	2-2RC-10A
2-ISI-3	0	A		2"	2-2RC-11A	3
2-ISI-4	0	A		2"	2-2RC-8A	3
2-ISI-5	0	RTD TAKEOFF COLD LEG	A	2"	2-2RC-7A	3
2-ISI-6	0	RTD TAKEOFF HOT LEG	A	2"	2-2SI-35A	3
2-ISI-7	0	SAFETY INJECTION HIGH HEAD	A	3"	3-2RC-6A	4
2-ISI-7A	0		A&B	3"	-	-
2-ISI-7B	0		A	3"	3-2RC-5	4
2-ISI-7C	0		A	3"	3-2RC-5	4
2-ISI-7D	0		B	3"	3-2RC-5	4
2-ISI-8	0	RTD RETURN	A	6"	6-2RC-13B	6
2-ISI-9	0	SAFETY INJECTION HIGH HEAD	A	6"	6-2RC-13A	6
2-ISI-10	0	PLO-CAP	A	8"	-	-
2-ISI-10A	0		A	8"	8-2RC-15A	8
2-ISI-10B	0		A	8"	8-2RH-1A	8
2-ISI-10C	0		A	8"	8-2RH-1A	8
2-ISI-11	0	RHR TAKE OFF (GENERAL VIEW)	A	12"	12-2RC-16A	11
		ACCUMULATOR DISCHARGE			12-2SI-27A	11

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 ISOMETRIC SUMMARY

TABLE 3

PAGE 2 OF 4

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
2-ISI-12	0	SEAL INJECTION (GENERAL VIEW)	B	1½" & 2"	-	-
2-ISI-12A	0		B	2"	2-2VC-21B	3
2-ISI-12B	0		B	2"	2-2VC-21B	3
2-ISI-12C	0		B	1½"	1½-2VC-21B	1
2-ISI-13	0	CHARGING LINE (GENERAL VIEW)	B	2"	-	-
2-ISI-13A	0		B	2"	2-2RC-17	3
2-ISI-13B	0		B	2"	2-2VC-5	3
2-ISI-13C	0		B	2"	2-2VC-6	3
2-ISI-13D	0		B	2"	2-2VC-6	3
2-ISI-14	0	RTD TAKEOFF COLD LEG	B	2"	2-2RC-8B	3
2-ISI-15	0	RTD TAKEOFF HOT LEG	B	2"	2-2RC-7B	3
2-ISI-16	0	CROSSOVER DRAIN AND LETDOWN	B	2"	2-2RC-10B	3
					2-2RC-11B	3
					2-2RC-12	3
2-ISI-17	0	RTD RETURN	B	3"	3-2RC-6B	4
2-ISI-18	0	SAFETY INJECTION HIGH HEAD	B	6"	6-2RC-13D	6
2-ISI-19	0	PLO-CAP	B	6"	6-2RC-13C	6
2-ISI-20	0	RHR TAKEOFF (GENERAL VIEW)	B	8"	-	-
2-ISI-20A	0		B	8"	8-2RC-15B	8
2-ISI-20B	0		B	8"	8-2RH-1B	8
2-ISI-20C	0		B	8"	8-2RH-1B	8
2-ISI-21	0	RHR RETURN	B	10"	10-2SI-26	10
2-ISI-22	0	ACCUMULATOR DISCHARGE	B	12"	12-2RC-16B	11
					12-2SI-27B	11

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 ISOMETRIC SUMMARY

TABLE 3

PAGE 3 OF 4

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
2-1SI-23	0	SAFETY INJECTION HIGH HEAD	B	2"	2-2SI-35B	3
2-1SI-24	0	AUXILIARY SPRAY	-	2"	2-2RC-19 2-2VC-4	3 3
2-1SI-25	0	REACTOR VESSEL SAFETY INJECTION	A	2"	2-2SI-24A	3
2-1SI-26	0	REACTOR VESSEL SAFETY INJECTION	B	2"	2-2SI-24B	3
2-1SI-27	0	PRESSURIZER RELIEF	A&B	3"	3-2RC-21	4
2-1SI-28	0	REACTOR VESSEL SAFETY INJECTION	B	4"	4-2RC-14B	5
			B	6"	6-2RC-14B	6
			B	6"	6-2SI-25B	6
2-1SI-29	0	REACTOR VESSEL SAFETY INJECTION	A	4"	4-2RC-14A	5
			A	6"	6-2RC-14A	6
			A	6"	6-2SI-25A	6
2-1SI-30	0	PRESSURIZER SAFETY	A	6"	6-2RC-20A	6
			B	6"	6-2RC-20B	6
2-1SI-31	0	PRESSURIZER SURGE	B	10"	10-2RC-4	10
2-1SI-32	1	REACTOR COOLANT	A	29"	29-2RC-1A	15
			A	31"	31-2RC-2A	15
			A	27½"	27½-2RC-3A	15
2-1SI-33	1	REACTOR COOLANT	B	29"	29-2RC-1B	15
			B	31"	31-2RC-2B	15
			B	27½"	27½-2RC-3B	15
2-1SI-34	0	REGENERATIVE HEAT EXCHANGER	-	-	-	6
2-1SI-35	0	PRESSURIZER SAFETY AND RELIEF NOZZLES	-	-	-	-

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 ISOMETRIC SUMMARY

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
2-ISI-36	0	PRESSURIZER	-	-	-	25A/16
2-ISI-37	0	STEAM GENERATORS	A&B	-	-	25A
2-ISI-38	0	REACTOR VESSEL CONOSEAL BOLTING	-	-	-	-
2-ISI-39	0	REACTOR VESSEL STUDS, NUTS & WASHERS	-	-	-	STUDS-17
2-ISI-40	1	REACTOR VESSEL NOZZLES	-	-	-	-
2-ISI-41	0	REACTOR VESSEL HEAD WELD	-	-	-	25A
2-ISI-42	0	REACTOR VESSEL SHELL WELDS	-	-	-	-
2-ISI-43	0	RC PUMP SEAL HOUSING BOLTING	A&B	-	-	-
2-ISI-44	0	RC PUMP FLANGE BOLTING	A&B	-	-	-
2-ISI-45	0	RC PUMP FLYWHEEL	A&B	-	-	-
2-ISI-46 CL-1	0	EXCESS LETDOWN HEAT EXCHANGER	-	-	-	6
2-ISI-47 CL-1	0	REACTOR VESSEL CLOSURE HEAD CLAD PATCHES	-	-	-	-
2-ISI-48 CL-1	0	REACTOR VESSEL CLAD PATCH IDENTIFICATION	-	-	-	-

APPENDIX B
ASME CLASS 2 - EXAMINATION

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PRESSURE VESSELS-STEAM GENERATOR

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C1.1	C-A	<u>CIRCUMFERENTIAL BUTT WELDS *</u>				*(3 AREAS, EQUALLY DIVIDED)	
		STEAM GENERATOR NO. 21					
		WELD B	TWO	82"	180.5"	0" TO 48", 129" TO 189", 270" TO 330" & 439 TO 0"	81-127,128,133
		WELD F	THREE	111"	1085.4"	W-F 100%	82-241,242,243,250
		STEAM GENERATOR NO. 22					
		WELD C	-	82"			
		WELD E	-	82"			
		WELD F	THREE	-	1085.4"	W-F 100%	82-267,268,269,270
C1.2	C-B	<u>NOZZLE TO VESSEL WELDS</u>					
		STEAM GENERATOR NO. 21					
		MAIN STEAM NOZZLE	-	-	-		
		FEEDWATER NOZZLE	-	-	-		
		STEAM GENERATOR NO. 22					
MAIN STEAM NOZZLE	THREE	1	1	N-4	83B-110 (45° ONLY)		
FEEDWATER NOZZLE	-	-	-	N-4	84-007, 008, 006		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.1PAGE 2 OF 2MAJOR ITEM: PRESSURE VESSELS-STEAM GENERATOR

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C1.3	C-C	<u>INTEGRALLY WELDED SUPPORTS</u>	-	-	-	-NONE-	
C1.4	C-D	<u>PRESSURE RETAINING BOLTING</u>					
		STEAM GENERATOR NO. 21					
		MANWAY A BOLTING	TWO	20	17	(V)(MT)	81-70
				2(MIN)	17	(U.T.)	81-78
			THREE	-	20	(V)	82-237
		MANWAY B BOLTING	TWO	20	20	(V)(MT)	81-69
				2(MIN)	20	(U.T.)	81-77
			THREE	-	20	(V)	82-234
		STEAM GENERATOR NO. 22					
		MANWAY A BOLTING	TWO	20	18	(V)(MT)	81-71
				2(MIN)	18	(U.T.)	81-75
			THREE	-	18	(V)	82-239
		MANWAY B BOLTING	TWO	20	18	(V)(MT)	81-47,46
				2(MIN)	18	(U.T.)	81-47
			THREE	18	18	(V)	82-238
				2(MIN)	-	(U.T.)	
					20	(U.T. & V.T.)	83B-216

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

TABLE S2.1.2

PAGE 1 OF 1

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PRESSURE VESSELS-ACCUMULATORS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C1.1	C-A	<u>CIRCUMFERENTIAL BUTT WELDS</u> *				*(3 AREAS, EQUALLY DIVIDED)	
		ACCUMULATOR NO. 21	THREE	20%	100%	W-6	84-059, 060, 069
		ACCUMULATOR NO. 22	-	-	-		
C1.2	C-B	<u>NOZZLE TO VESSEL WELDS</u>					
		ACCUMULATOR NO. 21	-	-	-		
		ACCUMULATOR NO. 22	-	-	-		
C1.3	C-C	<u>INTERNALLY-WELDED-SUPPORTS</u>					
		ACCUMULATOR NO. 21	-	-	-		
		ACCUMULATOR NO. 22	-	-	-		
C1.4	C-D	<u>PRESSURE-RETAINING-BOLTING</u>					
		ACCUMULATOR NO. 21	-	-	-		
		ACCUMULATOR NO. 22	THREE	24	24	(U.T. & V.T.)	83B-117

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PRESSURE VESSELS-RHR HEAT EXCHANGER

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C.1.1	C-A	<u>CIRCUMFERENTIAL BUTT WELDS</u> *				*(3 AREAS EQUALLY DIVIDED)	
		RHR HEAT EXCHANGER NO. 21	-	-	-		
		RHR HEAT EXCHANGER NO. 22	-	-	-		
C1.2	C-B	<u>NOZZLE TO VESSEL WELDS</u>					
		RHR HEAT EXCHANGER NO. 21	-	-	-		
		RHR HEAT EXCHANGER NO. 23	-	-	-		
C1.3	C-C	<u>INTERNALLY WELDED SUPPORTS</u>					
		RHR HEAT EXCHANGER NO. 21	THREE	1	1	SUPPORT A	83B-258, 245
		RHR HEAT EXCHANGER NO. 22	-	-	-		
C1.4	C-D	<u>PRESSURE RETAINING BOLTING</u>					
		RHR HEAT EXCHANGER NO. 21	-	-	-	28 FLANGE BOLTS	82-070
		RHR HEAT EXCHANGER NO. 22	THREE	1	1		

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C1.1	C-A	<u>CIRCUMFERENTIAL BUTT WELDS</u> *	-	-	-	*(3 AREAS EQUALLY DIVIDED)	82-042,042R,043
		BORIC ACID TANK NO. 21	-	-	-		
C1.2	C-B	<u>NOZZLE TO VESSEL WELDS</u>	-	-	-		
C1.3	C-C	<u>INTERNALLY WELDED SUPPORTS</u>	THREE	1	1		
C.14	C-D	<u>PRESSURE RETAINING BOLTS</u>	THREE	16	16	BOLTS 1 THRU 16	82-069
		BORIC ACID TANK No. 21					

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION--EXAMINATION SUMMARY

TABLE S2.2.1PAGE 1 OF 7

MAJOR ITEM: PIPING-CIRCUMFERENTIAL BUTT WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.1	C-G	<u>CIRCUMFERENTIAL BUTT WELDS</u>					
		MAIN STEAM A 32-2MS-1	-	-	-		
		MAIN STEAM B 32-2MS-2	-	-	-		
		MAIN STEAM A 30-2MS-1	TWO	1	1	MS-11	81-123
		MAIN STEAM B 30-2MS-2	THREE	1	1	MS-15	82-124,136
		MAIN STEAM A 30-2MS-1	TWO	1	1	MS-83	81-43,55
		MAIN STEAM B 30-2MS-2					
		MAIN STEAM A 31-2MS-1	ONE	1	1	MS-17	77-101,31
		MAIN STEAM B 31-2MS-2	TWO	1	6	MS-16,17,18	81-52,83,4,54,85
		MAIN STEAM A RELIEF HDR., 30-2MS-1	TWO	1	1	MS-19,20,174	81-50,84,51,92,53,86
		MAIN STEAM B RELIEF HDR., 30-2MS-2	TWO	1	1	MS-117	81-93
		MAIN STEAM A RELIEF HDR., 30-2MS-1	ONE	1	1	MS-188	77-99,15
		MAIN STEAM B RELIEF HDR., 30-2MS-2	-	-	-		
		MAIN STEAM A 6-2MS-1	-	-	-		
		MAIN STEAM B 6-2MS-2	ONE	1	1	MS-113	77-96,37
		FEEDWATER A 16-2FW-13	ONE	1	1	FW-161	77-45,55
		16-2FW-12	TWO	2	2	FW-161	80-20,27,83,185
		16-2FW-11	-	-	-	FW-174	80-18,31,84,160
						FW-177	80-19,29,40,162
						FW-177	81-10,32,36,42,42R
						FW-177	82-081,081A,089,089A
							094
						FW-177	83B-022,025,035,001
							001R,198
						FW-177	84-002,002R,009,012

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.1PAGE 2 OF 7

MAJOR ITEM:

PIPING-CIRCUMFERENTIAL BUTT WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.1	C-G	(CONT'D)					
		FEEDWATER B					
		16-2FW-16	ONE	1	1	FW-116	77-97,3
		16-2FW-15	TWO	1	1	FW-133	80,21,38,41,161
						FW-133	81-11,33,35,41,41R
						FW-133	82-080,080R,088,088A,
							090,090A
						FW-133	83B-023,024,036,002,
							002R,002R1,199
						FW-133	84-001,001R,010,011
		FEEDWATER A					
		(8 in) 3-2AF-11	-	-	-		
		FEEDWATER B					
		(8 in) 3-2AF-12	-	-	-		
		REFUELING WATER STORAGE					
		TANK DISCHARGE					
		14-2SI-1	TWO	1	1	W-58 (Pt only)	79-41
		14-2SI-1	THREE	1	1	W-49	82-040,040A
		12-2SI-3A	TWO	1	1	W-60	79-83
			THREE	-	3	W-59	83A-002, 060
						W-60	83A-001, 079
						W-61	83A-031, 059
		12-2SI-3B	THREE	-	3	W-57	83A-019, 055
						W-54	83A-030, 058
						W-55	83A-020, 054
		12-2SI-11	THREE	1	1	W-37	82-044,044A
				-	2	W-46	83A-017, 078
						W-47	83A-016, 056
		12-2SI-4	THREE	1	1	W-69W	82-005
		10-2SI-8	TWO	1	1	W-68W	79-84
		STREAM 1	THREE	1	1	W-75	82-016
		STREAM 2	TWO	2	2	W-88,289	79-77, 76

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.1
PAGE 3 OF 7
MAJOR ITEM: PIPING-CIRCUMFERENTIAL BUTT WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.1	C-G	(CONT'D)					
		CONTAINMENT SUMP B DISCHARGE LINES					
		14-2SI-33A	-	-	-		
		14-2SI-33B	-	-	-		
		12-2SI-34A	TWO	1	1	W-17	79-25
		12-2SI-34B	TWO	1	1	W-5	79-26
		12-2RH-6A	THREE	1	1	W-18	82-018,018A
		12-2RH-6B	-	-	-		
		SAFETY INJECTION PUMP NO. 21 SUCTION					
		6-2RH-10A					
		BRANCH 1	TWO	5	5	W-285,93,161,96,95	79-59,78,79,82,80
		BRANCH 2	THREE	1	1	W-108	82-037
		SAFETY INJECTION PUMP NO. 22 SUCTION					
		6-2RH-10B					
		BRANCH 1	TWO	2	2	W-286, 135	79-57, 81
		BRANCH 2	THREE	1	2	W-148, 157	82-038,062
		RESIDUAL HEAT REMOVAL DISCHARGE					
		8-2RH-9A	TWO	1	1	W-68	79-67
		8-2RH-9A	THREE	1	1	W-154	82-045
		8-2RH-9B	THREE	1	1	W-71	82-024
			TWO	1	1	W-53	79-65

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.1	C-G	(CONT'D)					
		8-2RH-7A	THREE	1	1	W-192	82-046
		8-2RH-7B	TWO	1	1	W-201	79-63
		BORIC ACID SUPPLY TO SAFETY INJECTION					
		6-2SI-13A	TWO	1	1	W-272R	79-53
			THREE	1	3	W-127	82-041,041A
						W-126,W-127	83B-254,255
		6-2SI-13B	TWO	1	1	W-271	79-52
		8-2SI-17	THREE	-	1	W-35	83A-077, 097
		8-2SI-18	TWO	1	1	W-85	79-94
			THREE	5	5	W-2,26,32,34	82-060,060A,061,061A
						W-27R	051,051A,050,050A
					51	W-34, 85	83A-070, 100
						W-26	83A-076,098,071,099
						W-25, 24	83A-072, 105
						W-23, 22	83A-073,106,091,116
						W-33, 32	83A-090,115,087,110
						W-31, 30	83A-069,101,074,104
						W-29W, 28	83A-075,107,089,102
						W-21, 20	83A-088,103,086,108
						W-19, 18	83A-085,109,034,117
						W-17X, 16	83A-033,118,029,124
						W-280, 292	83A-035,125,036,128
						W-279, 278	83A-037,129,038,130
						W-12, 277	83A-044,138,053,137
						W-294,10	83A-045,136,046,132
						W-276, 275	83A-050,133,047,134
						W-7, 274	83A-048,135,049,127
						W-13, 273	83A-051,126,052,123
						W-4, 3	83A-061,122,063,121
							83A-064,120,065,119

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.	
C2.1	C-G	(CONT'D)						
		8-2SI-18				W-2, 1 W-83X, 290 W-82, 81 W-80, 79 W-78, 77 W-76, 75 W-353W, 74 W-73, 44 W-2, 3, 25 W-31, 32	83A-066, 114, 067, 113 83A-068, 112, 062, 111 83A-095, 131, 094, 139 83A-093, 140, 092, 141 83A-028, 155, 027, 156 83A-026, 157, 025, 158 83A-024, 159, 023, 160 83A-022, 161, 021, 162 83B-236, 237, 249 83B-228, 229	
		12-2SI-11	THREE	1 -	1 7	W-40 W-37, 38 W-39, 40 W-41, 44 W-45 W-40	82-068 83A-039, 084, 040, 083 83A-043, 081, 042, 080 83A-041, 082, 032, 096 83A-018, 057 83B-234	
		RESIDUAL HEAT REMOVAL SUCTION						
		10-2SI-9A	TWO	1	1	W-212	79-54	
		10-2SI-9B	TWO	1	1	W-143	79-55	
		BORIC ACID SUPPLY						
		8-VC-71C	THREE	-	2	W-38, 39	83A-011, 142, 012, 143	
		8-2SI-18	THREE	2	11	W-40, 271 W-272, 273 W-274, 275 W-276, 41 W-42, 43 W-45	83A-013, 144, 014, 145 83A-015, 146, 008, 147 83A-007, 148, 006, 149 83A-010, 150, 005, 151 83A-004, 153, 009, 152 83A-003, 154	
						1	W-271	83B-235

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.1
PAGE 6 OF 7
MAJOR ITEM: PIPING-CIRCUMFERENTIAL BUTT WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.1	C-F	ACCUMULATOR DISCHARGE LINES					
		12-2SI-28A	-	-	-		
		12-2SI-28B	-	-	-		
		12-2SI-29A	-	-	-		
		12-2SI-29B	ONE	1	1	S1-316	77-49
		RESIDUAL HEAT REMOVAL DISCHARGE					
		10-2RH-11	ONE	1	1	RH-294	77-33
			TWO	1	1	W-176	79-30
			THREE	3	3	W-177,178,1411	82-006,003,127
		6-2RH-12	TWO	1	1	W-331	81-66
		6-2SI-10B	THREE	3	3	W-90,96,97	82-026,026A,025,256
		RESIDUAL HEAT REMOVAL SUCTION					
		12-2RH-5A	TWO	1	1	W-105	79-27
			THREE	2	1	119	82-052,052A
		12-2RH-5B	TWO	1	1	W-142	79-47,50
			THREE	2	2	W-139,153	82-035,035A,036,036A
		8-2RH-4A	TWO	1	1	W-100	79-68
		8-2RH-4B	THREE	1	1	W-134	82-039
		10-2RH-3	ONE	2	2	RH-255,RH-256	77-50,51
			TWO	2	2	W-225,226	79-28,29
	THREE	2	2	W-120,123	82-002,001		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.1PAGE 7 OF 7MAJOR ITEM: PIPING-CIRCUMFERENTIAL BUTT WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.1	C-F	(CONT'D)					
		8-2RH-5A	TWO	1	1	W-104	79-69
		8-2RH-5B	TWO	1	1	W-138	79-64
		REACTOR VESSEL SAFETY INJECTION					
		6-2SI-25A	ONE	1	1	S1-332	77-52
			TWO	1	1	W-349	81-65
			THREE	1	1	W-349	82-235
6-2SI-25B	ONE	1	1	S1-26	77-46A		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE S2.2.2PAGE 1 OF 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: LONGITUDINAL WELD JOINTS IN FITTINGS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.2	C-G	<u>LONGITUDINAL WELD JOINTS IN FITTINGS</u>					
		MAIN STEAM A 32-2MS-1	-	-	-		
		MAIN STEAM B 32-2MS-2	-	-	-		
		MAIN STEAM A 30-2MS-1	TWO	1	1	MS-11 TO MS-12	81-123
		MAIN STEAM B 30-2MS-2	-	-	-		
		MAIN STEAM A 31-2MS-1	ONE	1	1	MS-17 TO MS-18	77-93,30 (+93R)
		MAIN STEAM B 31-2MS-2	-	-	-		
		MAIN STEAM A RELIEF HDR., 30-2MS-1	-	-	-		
		MAIN STEAM B RELIEF HDR., 30-2MS-2	-	-	-		
		REFUELING WATER STORAGE TANK DISCHARGE 12-2SI-4	THREE	1	1	W-68W TO 69W	82-004
		RHR PUMP DISCHARGE 8-2RH-7B	-	-	-		
		8-2RH-7A	THREE	1	1	W-188 TO 189WR	83B-195, 196
		8-2RH-9B	THREE	1	1	W-72 TO 73	83B-193, 194
		8-2RH-9A	-	-	-		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE S2.2.2PAGE 2 OF 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: LONGITUDINAL WELD JOINTS IN FITTINGS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
		CONTAINMENT SUMP B DISCHARGE 12-2RH-6A	THREE	1	1	W-19 TO 20R	82-017
		SAFETY INJECTION PUMPS SUCTION 6-2SI-13A 6-2SI-13B	THREE -	1 -	1 -	W-126 TO 127	83B-253
		BORIC ACID SUPPLY TO SAFETY INJECTION 12-2SI-11 8-2SI-18	- THREE	- 3	- 3	W-2 TO 3 W-25 TO 26 W-31 TO 32	83B-230 83B-211 83B-227
		BORIC ACID SUPPLY 8-2SI-18	THREE	1	1	W-40 TO 271	83B-233
	C-F	RHR PUMP SUCTION 10-2RH-3	THREE	2	2	W-121 TO 122 W-123 TO 124	83B-191 83B-189,190
		12-2RH-5B	THREE	1	1	W-139 to 140 to 216	84-056, 056A
		RHR PUMP DISCHARGE 10-2RH-11	THREE	2	2	W-176 TO 177 W-1411 TO 291	82-007 82-126

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.3

PAGE 1 OF 1

PIPING- MAJOR ITEM: BRANCH PIPE TO PIPE WELD JOINTS

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.3	C-G	<u>BRANCH PIPE TO PIPE WELD JOINTS - (SWEEPOLETS)</u> MAIN STEAM A RELIEF HDR., 30-2MS-1 MAIN STEAM B RELIEF HDR., 30-2MS-2 FEEDWATER A 16-2FW-13 (8", 3-2AF-11) FEEDWATER B 16-2FW-16 (8", 3-2AF-12)	ONE - - -	1 - - -	1 - - -	MS-186A	77-100,16

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION - EXAMINATION SUMMARY

TABLE S2.2.4

PAGE 1 OF 1

MAJOR ITEM: PIPING-PRESSURE RETAINING BOLTING

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.4	C-D	<p><u>PRESSURE RETAINING BOLTING</u></p> <p>RESIDUAL HEAT REMOVAL PUMP SUCTION 12-2RH-5B 12-2RH-5A</p> <p>RESIDUAL HEAT REMOVAL PUMP DISCHARGE 10-2RH-11</p>	<p>THREE</p> <p>-</p> <p>THREE</p>	<p>20</p> <p>-</p> <p>16</p>	<p>20</p> <p>-</p> <p>16</p>	<p>BOLTS 1 THRU 20 FLANGE @ 151</p> <p>BOLTS 1 THRU 16 FLANGE @ 172</p>	<p>83B-252</p> <p>83B-250</p>

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.5

PAGE 1 OF 4

MAJOR ITEM: PIPING-INTEGRALLY WELDED SUPPORTS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT N ^o .
C2.5	C-E-1	<u>INTEGRALLY WELDED SUPPORTS</u>					
		MAIN STEAM A	TWO	2	2	F,H,A	81-16,48,48R,14,74,74R,16
		30-2MS-1	THREE	2	2	D,I	83B-129,113,130,122
		MAIN STEAM B	ONE	1	1	I	77-147
		30-2MS-2	TWO	2	2	A,H	81-13,30,15,34
			THREE	3	2	B,G	82-214,184,102
		MAIN STEAM A	ONE	3	3	J,K,M,	77-154,140
		31-2MS-1	TWO	1	1	S	81-2,3
		MAIN STEAM B					
		31-2MS-2	THREE	2	2	J,K,	82-101,125,160,199
		MAIN STEAM A					
		30-2MS-1 (R-HDR)	THREE	1	1	P	83B-172,168
		MAIN STEAM B					
		30-2MS-2 (R-HDR)	-	-	-		
		MAIN STEAM A					
		6-2MS-1	-	-	-		
		MAIN STEAM B					
			ONE	1	1	P	77-103
		FEEDWATER A					
		16-2FW-13	ONE	1	1	K	77-105
		16-2FW-12	TWO	10	10	A	80-5,5R,32
						B,C	80-5,5R,32
						E,F	80-1,28,68,63
						H,I	80-67,61,66,59
						J,K,L	80-77,60,3,3R,44
							80-8,26
			THREE	3	3	A,K	81-19,67,67R,20,68
						F,I	82-103,135,104,134
						J	82-105,133

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE S2.2.5PAGE 2 OF 4

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PIPING-INTEGRALLY WELDED SUPPORTS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.	
C2.5	C-E-1	(CONT'D)						
		FEEDWATER B						
		16-2FW-16	ONE	2	2	G,H	77-104,148	
		16-2FW-15	TWO	8	8	A B,C,D,E,F G,H A,G	80-16,16R 80-9,10,42,74 80-11,11R,12 81-18,17	
			THREE	1	1	C	82-106	
		REFUELING WATER STORAGE TANK DISCHARGE						
		12-2SI-4	TWO	1	1	C	79-42,34	
		CONTAINMENT SUMP B DISCHARGE LINES						
		12-2SI-33A	-	-	-			
		12-2SI-33B	-	-	-			
		SAFETY INJECTION PUMP NO. 21 SUCTION BRANCH 1						
		6-2RH-10A	ONE	1	1	B	77-119	
		BRANCH 2						
6-2RH-10A	ONE	1	1	G	77-119			
SAFETY INJECTION PUMP NO. 22 SUCTION BRANCH 1								
6-2RH-10B	TWO	1	1	D	79-35,38,38R			
BRANCH 2								
6-2RH-10B	TWO	1	1	E	82-019,021,021R			
RESIDUAL HEAT REMOVAL SUCTION PUMP A								
8-2RH-4A	TWO	1	1	A	79-19,44			

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.5	C-E-1	(CONT'D)					
		RESIDUAL HEAT REMOVAL DISCHARGE PUMP B 8-2RH-9B 6-2SI-10B	THREE THREE	1 3	1 3	M F,H,J H,J	84-028, 029 83B-243,242,210,209 84-022,027,023,026
		RESIDUAL HEAT REMOVAL DISCHARGE PUMP A 10-2RH-11 8-2RH-7A	ONE THREE THREE	1 3 1	1 3 1	L G,J,K/J B/B	77-115 83B-259,208,184,184R, 153,182/84-024,025 83B-246/84-030,031
		RESIDUAL HEAT REMOVAL DISCHARGE PUMP B 6-2SI-10B	-	-	-	-NONE-	
		RESIDUAL HEAT REMOVAL SUCTION PUMP B 10-2RH-3 8-2RH-4B	ONE TWO THREE TWO	1 1 1 1	1 1 1 1	C E D J	77-118 79-37,40,40R 83B-241, 257 79-36,39,39R
		REACTOR VESSEL SAFETY INJECTION A 6-2SI-25A	ONE TWO THREE	1 1 1	1 1 1	A B G	77-109 81-27,49,49R 83B-232,231,231R
		REACTOR VESSEL SAFETY INJECTION B 6-2SI-25B	ONE	1	1	A	77-108

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

TABLE S2.2.5
 PAGE 4 OF 4
 MAJOR ITEM: PIPING-INTEGRALLY WELDED SUPPORTS

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
		BORIC ACID SUPPLY TO SAFETY INJECTION					
		12-2SI-11	THREE	1	1	A	84-036, 037
		8-2SI-18	THREE	2	2	D, 0	84-032,033,034,035

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.6
PAGE 1 OF 4
MAJOR ITEM: PIPING-NON WELDED SUPPORTS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.6	C-E-2	<u>SUPPORT COMPONENTS</u>					
		MAIN STEAM A 31-2MS-1	THREE	1	-		
		MAIN STEAM B 31-2MS-2	THREE	1	1	Q	82-207
		MAIN STEAM A 30-2MS-1	TWO	1	-	G	81-12,12R
		MAIN STEAM B 30-2MS-2	THREE	1	1	E	83B-108
		MAIN STEAM A RELIEF HDR., 30-2MS-1	ONE	1	1	O	77-140
		MAIN STEAM B RELIEF HDR., 30-2MS-2	TWO	1	1	O	81-1,1R
		FEEDWATER A 16-2FW-13	TWO THREE	2 1	2 1	D,G D	80-4,69 83B-112
		REFUELING WATER STORAGE TANK DISCHARGE 12-2SI-4	TWO	1	1	B	79-45
		RESIDUAL HEAT REMOVAL DISCHARGE 8-2RH-7B	THREE	1	1	B	82-065
		8-2RH-7A	THREE	1	1	A	82-064
		10-2RH-11	THREE	2	2	H,I	82-048,047
		10-2SI-8 BRANCH 1	THREE	1	1	D	82-014
		BRANCH 2	-	-	-		

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM:

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.6	C-E-2	(CONT'D)					
		SAFETY INJECTION PUMP NO. 21 SUCTION BRANCH 1 6-2RH-10A	-	-	-	-NONE-	
		SAFETY INJECTION PUMP NO. 21 SUCTION BRANCH 2 6-2RH-10A	TWO THREE	1 1	1 -	E	79-46
		SAFETY INJECTION PUMP NO. 22 SUCTION BRANCH 1 6-2RH-10B-	-	-	-NONE-		
		SAFETY INJECTION PUMP NO. 22 SUCTION BRANCH 2 6-2RH-10B	TWO THREE	1 1	1 -	A	79-33,33R
		RESIDUAL HEAT REMOVAL DISCHARGE PUMP A 6-2RH-12	ONE	1	1	M	77-136
		RESIDUAL HEAT REMOVAL DISCHARGE PUMP B 6-2S1-10B	THREE	1	1	I	82-063
		RESIDUAL HEAT REMOVAL SUCTION PUMP B 10-2RH-3	ONE TWO THREE	2 1 2	2 1 3	A,B F D,G,H	77-155 79-9 82-020,022,023
		PUMP A 8-2RH-4A	TWO	1	1	B	79-18
		PUMP B 8-2RH-4B	THREE	1	1	L	82-013
		12-2RH-5B	THREE	1	1	N	82-010
		12-2RH-5A	THREE	1	1	D	82-011

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.2.6
PAGE 3 OF 4
MAJOR ITEM: PIPING-NON WELDED SUPPORTS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.6	C-E-2	(CONT'D)					
		RESIDUAL HEAT REMOVAL DISCHARGE PUMP A					
		8-2RH-9A	THREE	2	2	C,D	83B-284,244
		PUMP B					
		8-2RH-9B	THREE	2	2	L/C	82-257/83B-247
		ACCUMULATOR DISCHARGE LINES					
		LINE A					
		12-2SI-28A	ONE	1	1	B	77-137
		12-2SI-29A	-	-	-		
		LINE B					
		12-2SI-28B	THREE	1	1	C	84-003
		12-2SI-29B	-	-	-		
		REFUELING WATER STORAGE TANK DISCHARGE					
		10-2SI-8	THREE	1	1	O	82-
		BORIC ACID SUPPLY TO SAFETY INJECTION					
		6-2SI-13A	ONE	1	1	B	77-153
		6-2SI-13B	-	-	-		
		8-2SI-18	THREE	5	5	C,E,F I,N	82-059,055,056 82-057,058
		REACTOR VESSEL SAFETY INJECTION					
		LINE A					
		6-2SI-25A	ONE	1	1	H	77-150
		LINE B					
		6-2SI-25B	TWO	1	1	B	

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.6	C-E-2	(CONT'D) CONTAINMENT SUMP DISCHARGE LINES LINE A LINE B	THREE THREE	1 1	1 1	D E	82-049 82-054

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: PUMPS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.1	C-G	<p><u>PUMP CASING WELDS</u></p> <p>SAFETY INSPECTION PUMPS CASING TO FLANGE WELD ON DISCHARGE</p> <p>#21 PUMP #22 PUMP</p> <p>CASING TO FLANGE WELD ON SUCTION</p> <p>#21 PUMP #22 PUMP</p>	-	-	-		
C3.2	C-D	<p><u>PRESSURE RETAINING BOLTING</u></p> <p>RHR PUMPS</p> <p>#21 FLANGE BOLTS #22 FLANGE BOLTS</p> <p>SAFETY INJECTION PUMPS #21 DISCH FLANGE BOLTS #22 DISCH FLANGE BOLTS</p> <p>#21 DRIVE END COVER #22 DRIVE END COVER</p> <p>#21 OUTBOARD COVER #22 OUTBOARD COVER</p>	THREE - THREE - THREE -	24 - 8 - 16 16	24 - 8 - 16 16	BOLTS, 1 THRU 24 BOLTS, 1 THRU 8 BOLTS, 1 THRU 16 BOLTS, 1 THRU 16	82-053 82-067 82-071 82-066

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.3PAGE 2 OF 2MAJOR ITEM: PUMPS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.3	C-E-1	<u>INTEGRALLY WELDED SUPPORTS</u>					
		RHR PUMPS					
		#21	THREE	1	1	Q	82-008
		#22	-	-	-		
C3.3	C-E-1	SAFETY INJECTION PUMPS					
		#21	THREE	3	3	A,B,E	32-027,028,029,030
		#22	THREE	3	3	C,D,F	82-031,032,033,034
C3.4	C-E-2	<u>SUPPORT COMPONENTS</u>					
		RHR PUMPS					
		#21	THREE	1	1	P	82-009
		#22	THREE	1	2	E,F	82-015,012

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.4PAGE 1 OF 2MAJOR ITEM: VALVES

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C4.1	C-F AND C-G	<u>VALVE BODY WELDS</u>	-	-	-	-NONE-	
C4.2	C-D	<u>PRESSURE RETAINING BOLTING</u>					
		MAIN STEAM A 31-2MS-1	TWO	26 3(MIN)	26 26	(V) (UT)	81-9 81-9
		MAIN STEAM B 31-2MS-2	-	-	-		
		MAIN STEAM A (6") (OFF) RELIEF HDR 30-2MS-1	ONE	12 2(MIN)	12 2	(V) RS-21-11 (UT) RS-2-11	77-54 77-54
			TWO	12 2(MIN)	12 12	(V) RS-21-14 (UT) RS-21-14	81-73 81-73
		MAIN STEAM B (6") (OFF) RELIEF HDR 30-2MS-2	TWO	12 2(MIN)	12 12	(V) RS-21-20 (UT) RS-21-20	81-8 81-8
			THREE	24 4(MIN)	24 42	(V) RS-21-17, RS-21-19 (UT) RS-21-17, RS-21-19	82-211,210 82-211,210
		RESIDUAL HEAT REMOVAL PUMP A 6-2RH-12	-	-	-		
		PUMP B 6-2S1-10B	ONE	12 2(MIN)	12 2	(V) 2-8803B (UT) 2-8803B	77-63 77-63

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S2.4

PAGE 2 OF 2

MAJOR ITEM: VALVES

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C4.2	C-D	(CONT'D) ACCUMULATOR DISCHARGE LINES 12-2S1-29A 12-2S1-29B	THREE -	16 2(MIN) -	16 16 -	(V) 2-8800A (UT) 2-8800A	82-236 82-236
C4.3	C-E-1	<u>INTEGRALLY WELDED SUPPORTS</u>	-	-	-	-NONE-	
C4.4	C-E-2	<u>SUPPORT COMPONENTS</u>	-	-	-	-NONE-	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
C1.1 <u>CIRCUMFERENTIAL BUTT WELDS</u>							
ACCUMULATOR #21	76	UT	W-6	84-059	NONE	NONE	LIMITED SCANS OVER LONGITUDINAL WELDS SAME NONE
		UT		84-060	NONE	NONE	
		UT		84-069	NONE	NONE	
C1.2 <u>NOZZLE TO VESSEL WELD</u>							
S/G #22	37	UT	W-N4	84-007	NONE	NONE	NONE S-2 BEST EFFORT NOZZLE S-2 B.E. NOZZLE
		UT		84-006	NONE	NONE	
		UT		84-008	NONE	NONE	
C2.1 <u>CIRCUMFERENTIAL BUTT WELDS</u>							
FEEDWATER A	48A	UT	FW-177	84-009	S-2 ID GEO 70%	S-2 OD GEO, 20% S-2 ID GEO, 45%	NO. S-1 DIFF CAL
		UT		84-012	S-2 OD GEO 100%	S-1 OD GEO 45%	NO S-2 DIFF CAL
		MT		84-002	NONE	LINEARS NONE-INDICATIONS BUFFED OUT	NONE
				84-002R	N/A		NONE
FEEDWATER B	49A	UT	FW-133	84-010	S-2 ID GEO 80%	S-2 OD GEO, 30%	NO. S-1 DIFF CAL
					S-2 OD GEO 80%	S-2 ID GEO, 25%	
		UT		84-011	S-1 ID GEO 20%	S-1 ID GEO, 40%	NO S-2 DIFF CAL
					S-1 OD GEO 20%	S-1 OD GEO, 40%	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
		MT		84-001 84-001R	NONE N/A	LINEARS NONE-INDICATIONS BUFFED OUT	NONE NONE
C2.2 <u>LONGITUDINAL WELDS IN FITTINGS:</u>							
RHR PUMP SUCTION	50	UT	W-139 to 140 to 216	84-056 84-056A	N/A N/A	NONE NONE	NONE NONE
C2.5 <u>WELDED SUPPORTS</u>							
RHR PUMP DISCHARGE	57	PT	B	84-030	N/A	POROSITY, CODE ACCEPTABLE	NONE
		VT		84-031	N/A	NONE	NONE
	55	PT	M	84-028	N/A	POROSITY, ENGR ANALYSIS ACCEPTED	NONE
		VT		84-029	N/A	NONE	NONE
	55	PT	H	84-022 84-022R	N/A N/A	UNDERCUT INDICATION BLENDED OUT/NONE	NONE NONE
		VT		84-027	N/A	NONE	NONE
	55	PT	J	84-023	N/A	POROSITY, CODE ACCEPTABLE	NONE
		VT		84-026	N/A	NONE	NONE
	57	PT	J	84-024	N/A	NONE	NONE
		VT		84-025	N/A	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
BORIC ACID SUPPLY TO SAFETY INJECTION	61	PT	A	84-036	N/A	NONE	NONE
		VT		84-037	N/A	NONE	NONE
	61	PT	D	84-032	N/A	NONE	NONE
		VT		84-033	N/A	NONE	NONE
	61	PT	0	84-034	N/A	NONE	NONE
		VT		84-035	N/A	NONE	NONE
	75	VT	C	84-003	N/A	NONE	NONE
C2.6 SUPPORT COMPONENTS							
ACCUMULATOR DISCHARGE							

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 1
 ISOMETRIC SUMMARY

TABLE III
 PAGE 1 OF 3

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
ISI-43	0	STEAM GENERATORS	A & B	-	-	26
ISI-51	0	MAIN STEAM (GENERAL VIEW)	A	-	-	-
ISI-51A	0		A	32"	32-MS-1	NO _____
ISI-51B	0		A	31"	31-MS-1	24
				30"	30-MS-1	23
				6"	6-MS-1	7
ISI-52	0	FEEDWATER (GENERAL VIEW)	A	-	-	-
ISI-52A	1		A	16"	16-FW-13	13
ISI-52B	0		A	16"	16-FW-8	13
			A	8"	3-AF-11	NO _____
ISI-53	2	RHR PUMP A SUCTION (WELDS)	A	10"	10-RH-3	22
ISI-54	2	RHR PUMP A SUCTION (HANGERS)	A	8"	8-RH-4A	29
			A	8"	8-RH-5A	29
			A	12"	12-RH-5A	32
			A	12"	12-RH-6A	32
			A	10"	10-SI-9A	22
ISI-55	2	RHR PUMP A DISCHARGE (WELDS)	A	8"	8-RH-7A	29
ISI-56	0	RHR PUMP A DISCHARGE (HANGERS)	A	8"	8-RH-9A	29
			A	6"	6-RH-10A	27
			A	6"	6-SI-10A	27
			A	6"	6-SI-10B	6
ISI-68	0	MAIN STEAM (GENERAL VIEW)	B	-	-	-
ISI-68A	0		B	32"	32-MS-2	NO _____
ISI-68B	0		B	31"	31-MS-2	24
				30"	30-MS-2	23
				6"	6-MS-2	7
ISI-69	0	FEEDWATER (GENERAL VIEW)	B	-	-	-
ISI-69A	1		B	16"	16-FW-16	13
ISI-69B	0		B	16"	16-FW-15	13
				8"	3-AF-12	NO _____

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 1
 ISOMETRIC SUMMARY

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
ISI-76	2	RHR PUMP B SUCTION (WELDS)	B	8"	8-RH-4B	29
ISI-77	1	RHR PUMP B SUCTION (HANGERS)	B	8"	8-RH-5B	29
			B	12"	12-RH-5B	32
			B	12"	12-RH-6B	32
			B	10"	10-SI-9B	22
ISI-78	1	RHR PUMP B DISCHARGE (WELDS)	B	8"	8-RH-7B	29
ISI-79	0	RHR PUMP B DISCHARGE (HANGERS)	B	8"	8-RH-9B	29
			B	6"	6-RH-10B	27
			B	10"	10-RH-11	22
			B	6"	6-RH-12	27
ISI-80	1	REFUELING WATER STORAGE (WELDS)	-	14"	14-SI-1	34
		TANK DISCHARGE		12"	12-SI-3A	33
ISI-81	0	REFUELING WATER STORAGE (HANGERS)		12"	12-SI-3B	33
		TANK DISCHARGE		12"	12-SI-4	33
				10"	10-SI-8	31
				12"	12-SI-11	33
ISI-82	1	SAFETY INJECTION PUMPS' SUCTION	-	12"	12-SI-11	33
				8"	8-SI-17	30
				9"	8-SI-18	30
ISI-83	1	SAFETY INJECTION PUMPS' SUCTION AND		6"	6-SI-13A	28
		SAFETY INJECTION PUMPS		6"	6-SI-13B	28
			#11 & #12	-	-	NO _____
ISI-84	1	BORIC ACID SUPPLY	-	8"	8-SI-18	30
ISI-85	1	ACCUMULATOR DISCHARGE	A	12"	12-SI-28A	11
			A	12"	12-SI-29A	11
			B	12"	12-SI-28B	11
			B	12"	12-SI-29B	11
ISI-86	1	ACCUMULATOR TANKS	#11 & #12	-	-	NO _____

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 1
 ISOMETRIC SUMMARY

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
ISI-87	1	CONTAINMENT SUMP B DISCHARGE (WELDS)	A	14"	14-SI-33A	34
ISI-88	0	CONTAINMENT SUMP B DISCHARGE (HANGERS)	A	12"	12-SI-34A	32
			B	14"	14-SI-33B	34
			B	12"	12-SI-34B	32
ISI-89	1	REACTOR VESSEL SAFETY INJECTION (WELDS)	A	6"	6-SI-25A	6
ISI-90	0	REACTOR VESSEL SAFETY INJECTION (HANGERS)	B	6"	6-SI-25B	6
ISI-91	1	ALTERNATVE CONTAINMENT SPRAY (WELDS) PUMP SUCTION	A	6"	6-RH-10A	27
ISI-92	0	ALTERNATE CONTAINMENT (HANGERS) SPRAY PUMP SUCTION	B	6"	6-RH-10B	27
ISI-93	0	RESIDUAL HEAT EXCHANGER	#11 & #12	-	-	NO _____
ISI-94	0	BORIC ACID TANKS	#11 & #12	-	-	NO _____

APPENDIX C
FSAR AUGMENTED EXAMINATION

APPENDIX C

FSAR AUGMENTED EXAMINATIONS

NO EXAMINATIONS SCHEDULED THIS OUTAGE

APPENDIX D

SEISMIC BOLTING EXAMINATIONS

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION--EXAMINATION SUMMARY

TABLE SB
PAGE 1 OF 7MAJOR ITEM: SEISMIC BOLTING

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
N/A	N/A	<u>STEAM GENERATORS</u>					
		<u>STEAM GENERATOR NO. 21</u>					
		UPPER RING GIRDER (SNUBBER PINS)	ONE TWO THREE	2 2 4	2 2 4	SNUBBER 1 SNUBBER 2 SNUBBER 1 THRU 4 SNUBBER 3 & 4	77-72 80-180 81-97 83B-119
		UPPER RING GIRDER (SNUBBER WALL BOLTS)	ONE TWO THREE	5 5 5	5 5 5 15 5 5	TOP ROW CENTER ROW ALL BOLTS BOTTOM ROW BOTTOM ROW	77-143 80-110 81-106 83B-204 84-004, 004R
		UPPER RING GIRDER (SNUBBER BOLTS)	ONE TWO THREE	8 8 16	8 8 - 32	TOP ROW ON GIRDER TOP ROW ON WALL ALL BOLTS	77-143 80-176 81-98
		UPPER RING GIRDER (RING CONNECT BOLTS)	ONE TWO THREE	10 10 20	10 10 - 40	RING CON. 2 RING CON. 1 PAD 1 THRU 4	77-159 80-110 81-119,114,114R
		UPPER RING GIRDER (RING WALL BOLTS)	ONE TWO THREE	10 10 10	10 10 - 30	10 EXAMINED 10 EXAMINED PAD 1 THRU 4 (REPEAT INSP.) PAD 2 & 4	77-159 80-110 81-107,108,109,110 83B-202
		COLUMN PINS	ONE TWO	2 2	2 2	BOT COL 1/ TOP COL 4 BOT & TOP COL 2 COLUMN 1 THRU 4 TOP & BOTTOM	77-69,70 80-182 81-135

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE SBPAGE 2 OF 7

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: SEISMIC BOLTING

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
N/A	N/A	(S.G. NO. 21 CONT'D)					
			THREE	4	3	TOP COL 1 BOT COL 3 & 4	84-067 84-068, 042
		BASE ANCHOR BOLTS	ONE TWO	8 8	8 8 32	BASE OF COLUMN 1 BASE OF COLUMN 2 BASE OF COLUMN 1 THRU 4	77-143 80-106 81-80
			THREE	16	16	BASE OF COL. 3&4	83B-028
		TOP COLUMN CONNECTING BOLTS	ONE TWO	4 4	4 4 16	TOP OF COLUMN 1 TOP OF COLUMN 2 TOP OF COLUMN 1 THRU 4	77-165 80-173 81-136,149
			THREE	8	16	TOP OF COLUMN 1 THRU 4	83B-217
		UPPER RING GIRDER (SPRING HANGER)			2	SGH-2,SGH-4	81-111,112
		SUPPORT PAD HELI-COIL SCREWS	ONE TWO	6 6	6 6 24	COLUMN 1 COLUMN 2 ALL HELICOIL SCREWS	77-62 80-183 81-122
			THREE	12	24	ALL HELICOIL SCREWS	82-111
		<u>STEAM GENERATOR NO. 22</u>					
		UPPER RING GIRDER (SNUBBER PINS)	ONE TWO	2 2	2 2 8	SNUBBER 1 SNUBBER 2 SNUBBER 1 THRU 4	77-71 80-180 81-96
			THREE	4	4	SNUBBER 3 & 4	83B-118

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE SB

PAGE 3 OF 7

MAJOR ITEM: SEISMIC BOLTING

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
N/A	N/A	(S.G. NO. 22 CONT'D)					
		UPPER RING GIRDER (SNUBBER WALL BOLTS)	ONE TWO THREE	5 5 5	5 5 15 5	TOP ROW CENTER ROW ALL BOLTS BOTTOM ROW	77-142 80-111 81-99 84-005
		UPPER RING GIRDER (SNUBBER BOLTS)	ONE TWO THREE	8 8 16	8 8 32 -	TOP ROW ON GIRDER TOP ROW ON WALL ALL BOLTS	77-142 80-112 81-95
		UPPER RING GIRDER (RING CONNECT BOLTS)	ONE TWO THREE	10 10 20	10 10 40 -	RING CON. 4 RING CON. 1 PAD 1 THRU 4	77-160 80-111 81-118,120
		UPPER RING GIRDER (RING WALL BOLTS)	ONE TWO THREE	10 10 10	10 10 30 20	10 EXAMINED 10 EXAMINED PAD 1 THRU 4 (REPEAT INSP.) PAD 2 & 4	77-160 80-111 81-102,103,104,105 83B-205
		BASE ANCHOR BOLTS	ONE TWO THREE	8 8 16	8 8 32 16	BASE OF COLUMN 1 BASE OF COLUMN 2 BASE OF COLUMN 1 THRU 4 BASE OF COLUMN 3 & 4	77-160 80-106 81-79 83B-144
		UPPER RING GIRDER (SPRING HANGER)			2	SGH-2,SGH-4	81-100,101
		TOP COLUMN CONNECTING BOLTS	ONE TWO	4 4	4 4 16	TOP OF COLUMN 1 TOP OF COLUMN 2 TOP OF COLUMN 1 THRU 4	77-165 80-113 81-137,148

INSERVICE INSPECTION-EXAMINATION SUMMARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
N/A	N/A	(S.G. NO. 22 CONT'D)					
			THREE	8	16	TOP OF COLUMN 1 THRU 4	83B-218
		COLUMN PINS	THREE	4	4	TOP COL 3 & 4 BOT COL 3 & 4	84-065, 066 84-043, 044
		SUPPORT PAD	ONE	6	6	COLUMN 1	77-61
		HELI-COIL SCREWS	TWO	6	6	COLUMN 2	80-184
					24	ALL HELICOIL SCREWS	81-151
			THREE	12	24	ALL HELICOIL SCREWS	82-260
		<u>PRESSURIZER</u>					
		BASE ANCHOR BOLTS	ONE	8	8	1-8 BOLTS	77-146
			TWO	8	8	9-16 BOLTS	80-114
					24	ALL BOLTS	81-91
			THREE	8	8	17-24 BOLTS	83B-022
		<u>ACCUMULATOR A</u>					
		BASE ANCHOR BOLTS	ONE	8	8	1-8 BOLTS	77-141
			TWO	8	8	9-16 BOLTS	80-115
					24	ALL BOLTS	81-90
			THREE	8	8	17-24 BOLTS	83B-131
		<u>ACCUMULATOR B</u>					
		BASE ANCHOR BOLTS	ONE	8	8	1-8 BOLTS	77-141
			TWO	8	8	9-16 BOLTS	80-115
					24	ALL BOLTS	81-88
			THREE	8	8	17-24 BOLTS	83B-132

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE SB
PAGE 5 OF 7
MAJOR ITEM: SEISMIC BOLTING

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
N/A	N/A	<u>REACTOR COOLANT PUMPS</u>					
		<u>PUMP NO. 21</u>					
		COLUMN PINS	ONE	2	2	COLUMN 1	77-67
			TWO	2	2	COLUMN 2	80-181
			THREE	2	6	COLUMN 1 THRU 3	81-135
					2	COLUMN 3	84-041, 048
		BASE ANCHOR BOLTS	ONE	8	8	BASE OF COLUMN 1	77-158
			TWO	8	8	BASE OF COLUMN 2	80-107
					24	BASE OF COLUMN 1 THRU 3	81-82
			THREE	8	8	BASE OF COLUMN 3	84-052
		COLUMN CONNECTING BOLTS	ONE	6	6	TOP OF COLUMN 1	77-163
			TWO	6	6	TOP OF COLUMN 2	80-174
					18	TOP OF COLUMN 1 THRU 3	81-154, 156
			THREE	6	6	TOP OF COLUMN 3	84-053
		TIE BACK BOLTS	ONE	1	1	PAD 1	77-77
			TWO	1	1	PAD 2	80-179
			THREE	1	3	PAD 1 THRU 3	81-150, 157, 160, 161
					1	PAD 3	82-093
		TIE BACK PINS	ONE	1	1	PAD 1	77-68
			TWO	1	1	PAD 2	80-186
			THREE	1	3	PAD 1 THRU 3	81-135
					1	PAD 3	84-047
		THROUGH ANCHOR BOLTS	ONE	2	2	PAD 1, SOUTH 2	77-161
			TWO	2	2	PAD 1, CENTER 2	80-175
			THREE	2	6	PAD 1, ALL BOLTS	81-157, 168
					-		

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2

INSERVICE INSPECTION-EXAMINATION SUMMARY

 TABLE SB
 PAGE 6 OF 7
 MAJOR ITEM: SEISMIC BOLTING

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
		<u>PUMP NO. 21 (CONT'D)</u>					
		LATERAL SUPPORT AND WALL BOLTS	ONE	4	4	PAD 2	77-158
			TWO	3	3	PAD 3, TOP ROW	80-175
					10	PAD 2 & 3, ALL BOLTS	81-160, 161
			THREE	3	3	PAD 3, BOTTOM ROW	83B-221
		<u>PUMP NO. 22</u>					
		COLUMN PINS	ONE	2	2	COLUMN 1	77-64
			TWO	2	2	COLUMN 2	80-181
					6	COLUMN 1 THRU 3	81-135
			THREE	2	2	COLUMN 3	84-040, 046
		BASE ANCHOR BOLTS	ONE	8	8	BASE OF COLUMN 1	77-161
			TWO	8	8	BASE OF COLUMN 2 THRU 3	80-107
					24	BASE OF COLUMN 1 THRU 3	81-81
			THREE	8	8	BASE OF COLUMN 3	84-051
		COLUMN CONNECTING BOLTS	ONE	6	6	TOP OF COLUMN 1	77-162
			TWO	6	6	TOP OF COLUMN 2	80-108
					18	TOP OF COLUMN 1 THRU 3	81-142, 153
			THREE	6	18	TOP OF COLUMN 1 THRU 3	83B-219
		TIE BACK BOLTS	ONE	1	1	PAD 1	77-76
			TWO	1	1	PAD 2	80-179
					3	PAD 1 THRU 3	81-145, 147, 158, 159
			THREE	1	1	PAD 3	83B-171

NORTHERN STATES POWER CO.

PRAIRIE ISLAND UNIT 2TABLE SBPAGE 7 OF 7

INSERVICE INSPECTION-EXAMINATION SUMMARY

MAJOR ITEM: SEISMIC BOLTING

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
		<u>PUMP NO. 22 (CONT'D)</u>					
		TIE BACK PINS	ONE	1	1	PAD 1	77-66
			TWO	1	1	PAD 2	80-186
					3	PAD 1 THRU 3	81-135
			THREE	1	1	PAD 3	84-045
		THROUGH ANCHOR BOLTS	ONE	2	2	PAD 1, SOUTH 2	77-158
			TWO	2	2	PAD 1, CENTER 2	80-109, 109R
					6	PAD 1, ALL BOLTS	81-145, 168
			THREE	2	2	PAD 1, NORTH 2	83B-220
		LATERAL SUPPORT AND WALL BOLTS	ONE	4	4	PAD 2	77-161
			TWO	3	3	PAD 3, TOP ROW	80-109
					10	PAD 2 & 3, ALL BOLTS	81-158, 159
			THREE	3	3	PAD 3, BOTTOM ROW	83B-238

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>SEISMIC BOLTING</u>							
STEAM GENERATOR NO 21							
SNUBBER BOLTS	85	VT	BOTTOM ROW	84-004	NONE	WASHER NOT IN FULL CONTACT NONE - WASHER BEVELED FOR FULL CONTACT	NONE
				84-004R	N/A		NONE
COLUMN PINS	77	UT	TOP COL 1	84-067	NONE	NONE	NONE
	78	UT	BOT COL 3	84-068	NONE	NONE	NONE
		UT	BOT COL 4	84-042	NONE	NONE	NONE
STEAM GENERATOR NO 22							
SNUBBER BOLTS	85	VT	BOTTOM ROW	84-005	NONE	NONE	NONE
COLUMN PINS	77	UT	TOP COL 3	84-066	NONE	NONE	NONE
		UT	TOP COL 4	84-065	NONE	NONE	NONE
		UT	BOT COL 3	84-043	NONE	NONE	NONE
		UT	BOT COL 4	84-044	NONE	NONE	NONE
REACTOR CORE COOLANT PUMP 21							
COLUMN PINS	79	UT	TOP COL 3	84-048	NONE	NONE	NONE
	80	UT	BOT COL 3	84-041	NONE	NONE	NONE
BASE ANCHOR BOLTS	79	VT	COL 3	84-052	NONE	NONE	NONE
TOP COLUMN CONNECTING BOLTS	80	VT	COL 3	84-053	NONE	NONE	NONE
TIE BACK PIN	84	UT	PAD 3	84-047	NONE	NONE	NONE

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	W BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
REACTOR CORE COOLANT PUMP 22							
COLUMN PINS	79 80	UT UT	TOP COL 3 BOT COL 3	84-046 84-040	NONE NONE	NONE NONE	NONE NONE
BASE ANCHOR BOLTS	79	VT	COL 3	84-051	NONE	NONE	NONE
TIE BACK PIN	81	UT	PAD 3	84-045	NONE	NONE	NONE

NORTHERN STATES POWER CO.
 PRAIRIE ISLAND UNIT 2
 ISOMETRIC SUMMARY - SEISMIC BOLTING AUGMENTED

TABLE 3
 PAGE 1 OF 1

NSP ISO NUMBER	REVISION	COMPONENT OR SYSTEM	LOOP	LINE SIZE	LINE NUMBER	UT - CAL. STANDARD
2-ISI-77	0	STEAM GENERATOR SUPPORT BASE	A&B	-	4/GENERATOR	-
2-ISI-78	0	STEAM GENERATOR SUPPORT TOP	A&B	-	4/GENERATOR	-
2-ISI-79	0	REACTOR COOLANT PUMP SUPPORT BASE	A&B	-	3/PUMP	-
2-ISI-80	0	REACTOR COOLANT PUMP SUPPORT TOP	A&B	-	3/PUMP	-
2-ISI-81	0	R.C. PUMP #22 LOWER LATERAL SUPPORT	B	-	-	-
2-ISI-84	0	R.C. PUMP #21 LOWER LATERAL SUPPORT	A	-	-	-
2-ISI-85	0	STEAM GENERATOR UPPER SUPPORT	A&B	-	-	-
2-ISI-86	0	STEAM GENERATOR UPPER SUPPORT SNUBBERS	A&B	-	-	-
2-ISI-87	0	STEAM GENERATOR SUPPORT PAD	A&B	-	4/GENERATOR	37/38
2-ISI-88	0	PRESSURIZER BASE	-	-	-	-
2-ISI-89	0	ACCUMULATOR BASE	A&B	-	-	-

APPENDIX E

TABLE I	-	PERSONNEL LISTING
TABLE II	-	ULTRASONIC CALIBRATION BLOCKS
TABLE III	-	PROCEDURE LISTING
TABLE IV	-	EQUIPMENT AND MATERIALS

PERSONNEL LISTING

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL					RT
			UT	PT	MT	VT	ET	
ALLER, R G	TECHNICIAN	LMT (2)	II	II	II	II ^(1b)	-	-
CAPPELL, R M	TECHNICIAN	LMT	I	II	II	II ^(1a,b)	-	-
KELLERHALL, R A	SUPERVISOR	LMT	III	III	III	III ^(1a,b)	-	-
MACGILL, D B	SUPERVISOR	LMT	III	III	III	III ^(1a,b)	-	-
SEVERTSON, R J	TECHNICIAN	LMT	I	-	-	-	-	-
ABELL, G E	ANALYST	B & W (3)	-	-	-	-	III	-
AKERLUND, B E	TECHNICIAN	B & W	-	-	-	-	II	-
BOWLER, S R	TECHNICIAN	B & W	-	-	-	-	I	-
COCKLIN, P R	TECHNICIAN	B & W	-	-	-	-	II	-
FUNG, G P	TECHNICIAN	B & W	-	-	-	-	II	-
GLADNEY, A C	ANALYST	B & W	-	-	-	-	II	-
HACKER, M	ANALYST	B & W	-	-	-	-	IIA	-
LOER, M S	TECHNICIAN	B & W	-	-	-	-	II	-
MARINAK, E A	SUPERVISOR	B & W	-	-	-	-	II	-
MUNSON, E J	TECHNICIAN	B & W	-	-	-	-	I	-
NAVRATIL, G	SUPERVISOR	B & W	-	-	-	-	II	-
O'BRIEN, T K	TECHNICIAN	B & W	-	-	-	-	TRAINEE	-
O'GRADY, P W	TECHNICIAN	B & W	-	-	-	-	II	-

FOOTNOTES:

(1a) Certified by NSP to perform visual determination of structural integrity for hanger assemblies in accordance with NSP-VT-2.

(1b) Inspection experience and NDE qualifications were judged to be adequate to perform visual examinations in accordance with NSP-VT-1.

NORTHERN STATES POWER COMPANY
PRAIRIE ISLAND - UNIT II

PERSONNEL LISTING

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL					
			UT	PT	MT	VT	ET	RT
PERSINGER, W J	SUPERVISOR	B & W	-	-	-	-	II	-
PORTER, J	TECHNICIAN	B & W	-	-	-	-	I	-
REDNER, S A	COORDINATOR	B & W	-	-	-	-	II	-
RICHARDS, T	ANALYST	B & W	-	-	-	-	III	-
SCHWENN, J S	TECHNICIAN	B & W	-	-	-	-	II	-
SPENCER, J L	TECHNICIAN	B & W	-	-	-	-	I	-
STOREY, M M	SUPERVISOR	B & W	-	-	-	-	II	-
TERNING, G A	ANALYST	B & W	-	-	-	-	IIA	-
U'REN, T J	TECHNICIAN	B & W	-	-	-	-	II	-
WASHBURN, T G	TECHNICIAN	B & W	-	-	-	-	I	-
WEBER, D D	ANALYST	B & W	-	-	-	-	III	-
WEBBER, C B	TECHNICIAN	B & W	-	-	-	-	II	-
BANDY, C L	TECHNICIAN	CONAM (4)	-	-	-	-	IIB	-
CHAMBERS, D M	ANALYST	CONAM	-	-	-	-	IIA	-
DOBSON, M E	ANALYST	CONAM	-	-	-	-	IIA	-
FUNANICH, J	SUPERVISOR	CONAM	-	-	-	-	III	-
LOFGREN, R H	ANALYST	CONAM	-	-	-	-	IIA	-

FOOTNOTES:

(2) Organization: (LMT) Lambert, MacGill, Thomas, Inc.
515 Aldo Avenue
Santa Clara, CA 95050

(3) Organization: (B&W) Babcock & Wilcox
Special Productions & Integrated Field Services
3110 Odd Fellows Road
Lynchburg, VA 24501

PERSONNEL LISTING

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL					
			UT	PT	MT	VT	ET	RT
ANDERSON, M T	M & S P ENGINEER	NSP	III	III	II	III ^(1b)	-	III
DAHLMAN, L C	M & S P	NSP	II	III	III	III ^(1a,b)	-	III
BRUSSEAU, F	ANI	HARTFORD STEAM BOILER INSPECTION AND INSURANCE CO						
CHRISTIE, G	ANI	HARTFORD STEAM BOILER INSPECTION AND INSURANCE CO						

FOOTNOTES:

(4) Organization: (Conam) Conam Inspection
 660 South 31st Street
 Richmond, CA 94804

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND UNIT II
 ULTRASONIC CALIBRATION BLOCKS

APPENDIX E
 TABLE II
 PAGE 1 of 1

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
3	2"	Sch.160 .344	A312,TP-304	2P4659	RGA-013	9-18-84
4	3"	Sch.160 .438	A376,TP-316	M5900	RGA-014	9-18-84
26	-	6" X 12" 3.500	A533,GR.A CL.2	52391	RGA-001 RGA-002 RGA-003	9-8-84 9-7-84 9-8-84
32	12"	Sch.40 .375	A312,TP-304	F41542	RGA-012 RGA-015	9-17-84 9-22-84
36	16"	Sch.100 1.031 X.585	A106,GR.C	45124A	RGA-004 RGA-005	9-10-84 9-10-84
37	-	6" x 12" 1.500 + CLAD	SA516 GR.70	8733967	RGA-016 RAK-003 RAK-004	9-24-84 9-18-84 9-18-84

PROCEDURE LISTING

PROCEDURE NUMBER AND REVISION	FIELD CHANGE	PROCEDURE TITLE	PLANT APPROVAL DATE	FIELD CHANGE REMARKS	CHANGE DESCRIPTION
NSP-MT-1, REV 2	NONE	MAGNETIC PARTICLE EXAM	6-22-83	NONE	
NSP-MT-2, REV 0	NONE	WET MAGNETIC PARTICLE EXAM	6-22-83	NONE	
NSP-PT-1, REV 2	NONE	LIQUID PENETRANT EXAM	6-22-83	NONE	
NSP-PT-2, REV 0	NONE	HIGH TEMPERATURE LIQUID PENETRANT EXAMINATION	6-22-83	NONE	
NSP-UT-1, REV 1	NONE	ULTRASONIC EXAMINATION OF PIPE WELDS	6-22-83	NONE	
NSP-UT-2, REV 1	NONE	AUTOMATIC DATA RECORDING	6-22-83	NONE	
NSP-UT-3, REV 1	1	ULTRASONIC EXAMINATION OF FERRITIC VESSELS			ALLOW EXAMINATION OF VESSELS WITH ≥ 1 " WALL THICKNESS
NSP-UT-4, REV 1	NONE	ULTRASONIC EXAMINATION OF STUDS, BOLTS, & NUTS	6-22-83	NONE	
NSP-VT-1, REV 2	NONE	VISUAL EXAMINATION	6-22-83	NONE	
NSP-VT-2, REV 2	NONE	VISUAL EXAMINATION OF HANGER ASSEMBLIES	6-22-83	NONE	
NSP-VT-3, REV 1	NONE	VISUAL EXAMINATION OF PUMP AND VALVE INTERNAL PRESSURE BOUNDARY SURFACES	6-22-83	NONE	
ISI-428, REV 2	1	MULTIFREQUENCY EDDY CURRENT EXAMINATION OF RSG TUBING IN SERIES 51 STEAM GENERATORS	8-31-84		CHANGE EXAMINATION MIX (CHANNEL 3) FREQUENCY FROM 210 KHz to 225 KHz ± 25 KHz

PROCEDURE LISTING

PROCEDURE NUMBER AND REVISION	FIELD CHANGE	PROCEDURE TITLE	PLANT APPROVAL DATE	FIELD CHANGE REMARKS	CHANGE DESCRIPTION
	2				ALLOWS LOWER GAIN SETTINGS TO BE USED ON SMALL RADIUS U-BENDS TO ELIMINATE SATURATION
ISI-425, REV 7	NONE	EDDY CURRENT EXAMINATION OF TUBING BY THE ABSOLUTE MULTICOIL (8x1) TECHNIQUE	8-31-84	NONE	
ISI-460, REV 7	NONE	TECHNICAL PROCEDURE FOR THE EVALUATION OF EDDY CURRENT DATA OF NUCLEAR GRADE STEAM GENERATOR TUBING	8-31-84	NONE	
ISI-463, REV 3	NONE	TECHNICAL PROCEDURE FOR THE EVALUATION OF EDDY CURRENT DATA GENERATED FROM THE MULTIELEMENT PROBE	8-31-84	NONE	
ISI-464	NONE	TECHNICAL PROCEDURE FOR THE EVALUATION OF EDDY CURRENT BOBBIN COIL FOR WEAR FRETTING AND AVB WEAR	8-31-84	NONE	
ISI-467	NONE	TECHNICAL PROCEDURE FOR THE EVALUATION OF EDDY CURRENT DATA OF NUCLEAR GRADE STEAM GENERATOR TUBING FOR INTERGRANULAR ATTACK	8-31-84	NONE	

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND - UNIT II
 EQUIPMENT AND MATERIALS

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC:</u>			
NORTEC 131D	S/N 409	CAL. 08/16/84	
NORTEC 131D	S/N 371	CAL. 08/17/84	
NORTEC 131D	S/N 167	CAL. 08/23/84	
<u>RECORDERS:</u>			
BRUSH 220	S/N 18687	CAL. 08/07/84	
BRUSH 220	S/N 18940	CAL. 06/22/84	
<u>TEMP. GAUGES:</u>			
PTC MODEL 310F	S/N 623	CAL. 05/11/84	
PTC MODEL 310F	S/N 627	CAL. 07/19/84	
PTC MODEL 310F	S/N 641	CAL. 07/19/84	
PTC MODEL 310F	S/N 649	CAL. 07/19/84	
PTC MODEL 310F	S/N 619	CAL. 05/11/84	
PTC MODEL 310F	S/N 630	CAL. 07/19/84	
<u>MAGNETIC PARTICLE:</u>			
MAGNUFLUX, Y-6	S/N LMT-002	CAL. 09/06/84	ON SITE QUALIFICATION
MAGNUFLUX, L-10	S/N GTL-004	CAL. 09/12/84	ON SITE QUALIFICATION
BLACK LITE METER	S/N 24779	CAL. 05/17/84	TYPE J221
<u>ROMPAS BLOCKS:</u>			
ROMPAS, S/S	S/N 046	CERT 10/28/83	EARLE M JORGENSEN CO
ROMPAS, C/S	S/N 012	CERT 09/08/77	ORLA'S MACHINE SHOP INC
	S/N 018	CERT 01/03/79	ORLA'S MACHINE SHOP INC
<u>IIW BLOCKS:</u>			
NONE			
<u>MATERIALS:</u>			
SPOT CHECK PENETRANT	PENETRANT	BATCH 83F038	TYPE: SKL-HF/S
	DEVELOPER	BATCH 83E020	TYPE: SKD-NF/ZP-9B
	CLEANER	BATCH 83F047	TYPE: SKC-NF/ZC-7B
ULTRASONIC COUPLANT	LMT-GEL	BATCH 1110812	
		BATCH 12484	

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC TRANSDUCERS:</u>	<u>S/N:</u>	<u>SIZE:</u>	<u>FREQUENCY:</u>
AEROTECH	C18085	1/2" DIA	2.25 MHZ
AUTOMATION	23311	1/2" x 1"	2.25 MHZ
HARISONIC	V6271	3/4" DIA	2.25 MHZ
HARISONIC	T3156	1/2" DIA	2.25 MHZ
HARISONIC	LC1	1/2" x 1"	2.25 MHZ
HARISONIC	A52	1/2" x 1"	2.25 MHZ
HARISONIC	W8560	.375" x .375"	2.25 MHZ
HARISONIC	W8562	.375" x .375"	2.25 MHZ
HARISONIC	8041	1/2" x 1/2"	5.0 MHZ
HARISONIC	V12038	1/4" x 1/4"	2.25 MHZ
HARISONIC	V3380	1/4" x 1/4"	2.25 MHZ
HARISONIC	8403	1/4" x 1/4"	5.0 MHZ
HARISONIC	8404	1/4" x 1/4"	5.0 MHZ
HARISONIC	V12539	1/4" x 1/4"	5.0 MHZ
HARISONIC	R941	1/4" x 1/4"	5.0 MHZ
HARISONIC	P366	1/2" x 1/2"	5.0 MHZ
HARISONIC	R2147	1/2" x 1/2"	2.25 MHZ
<u>B&W EDDY CURRENT EQUIPMENT:</u>			
TM503 MAIN FRAMES	24105	08-03-84	
	24120	08-09-84	
	24121	07-20-84	
	24139	07-27-84	
	24187	08-14-84	
	24620	08-09-84	
MIZ-12 DISPLAY SCOPES	24080	07-23-84	
	24169	08-14-84	
	24185	07-24-84	
	24137	08-16-84	
	24156	07-23-84	
MIZ-12 DISPLAY MODULES	24138	07-23-84	
	24170	08-14-84	
	24186	07-24-84	
	24103	08-17-84	
	24130	07-23-84	
MIZ-12 FREQUENCY/MIXER MODULES	24092	08-14-84	
	24093	08-03-84	
	24106	07-20-84	
	24107	08-13-84	

NORTHERN STATES POWER COMPANY
 PRAIRIE ISLAND - UNIT IX
 EQUIPMENT AND MATERIALS


MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
MIXERS (CONT'D)	24108	08-13-84	
	24112	08-14-84	
	24115	08-15-84	
	24116	08-03-84	
	24117	08-15-84	
	24118	08-13-84	
	24119	08-14-84	
	24142	08-14-84	
	24143	07-23-84	
	24150	07-23-84	
	24163	07-20-84	
	24164	08-15-84	
	24176	08-03-84	
	24189	08-14-84	
	24177	07-20-84	
	24095	08-13-84	
	24110	07-24-84	
	24111	08-14-84	
	24127	08-03-84	
	24128	08-03-84	
24145	08-14-84		
24154	07-24-84		
24178	08-15-85		
24192	08-15-84		
24193	08-13-84		
HP3968AZ FM TAPE RECORDERS	24134	07-26-84	
	24135	08-10-84	
	24172	08-10-84	
	24148	08-08-84	
	24184	08-03-84	
GOULD BRUSH 260 STRIP CHART RECORDERS	04708	08-27-84	
	24146	07-05-84	
	24147	07-06-84	
CALIBRATION STANDARDS	AVB 49087	INCONEL 600	
	AVB 49098	INCONEL 600	
	ASME 49088	INCONEL 600	
	ASME 49098	INCONEL 600	
	8 x 1 49081	INCONEL 600	
<u>CONAM EDDY CURRENT EQUIPMENT:</u>			
HP3968AZ FM TAPE RECORDERS	1940A01024	CAL DUE 06-22-85	
	2105A01693	05-23-85	

APPENDIX F

STEAM GENERATOR NO. 21 AND NO. 22


TUBE SHEET MAPS OF PLUGGED TUBES

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51



***** PLUGGED TUBES *****
 ***** GENERATOR NO. *****
 ***** OR OUTLET *****
 ***** INSPECTION MAPPED *****
 ***** REGION MAPPED *****
 ***** THROUGH 99-9 *****
 ***** TUBE SHEET *****
 ***** AROUND U-BEND *****

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51




MANWAY SIDE

DEGRADED TUBES (ALL)

D STEAM GENERATOR NO. 1
 DD STEAM GENERATOR NO. 2
 D INLET (HOT LEG)
 DD INLET THROUGH 99-9
 D TUBE SHEET
 DD TUBE SHEET
 D AROUND U-BEND
 DD AROUND U-BEND

NOZZLE SIDE ROWS

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTYNGHOUSE SERIES 51




MANWAY SIDE

PLUGGED TUBES

 STEAM GENERATOR NO. 21
 INLET OR OUTLET REGION MAPPED THROUGH 99-9
 INSPECT IONS MAPPED TUBE SHEET
 REGION MAPPED AROUND U-BEND

NOZZLE SIDE ROWS

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51



MANWAY SIDE

DEGRADED TUBES (ALL)

1 TUBES (ALL)

2 OUTLET (COLD LEG)

3 OUTLET THROUGH SHEET

4 TUBE AROUND U-BEND


STEAM GENERATOR NO. 1

INSPECTIONS MAPPED

REGION MAPPED TO

NOZZLE SIDE

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51




MANWAY SIDE

PLUGGED TUBES

STEAM GENERATOR NO. 222
 INLET (HOT LEG)
 INSPECTION MAPPED TO
 REGION MAPPED TO
 90-9 THROUGH 99-9
 TUBE SHEET
 AROUND U-BEND


NOZZLE SIDE ROWS

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51




DEGRADED TUBES (ALL) #####
 ##### STEAM GENERATOR NO. 2 #####
 ##### INLET OR OUTLET INLET (HOT LEG) #####
 ##### INSPECTIONS MAPPED THROUGH 99-9 #####
 ##### REGION MAPPED TUBE SHEET AROUND U-BEND #####

NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51



NORTHERN STATES POWER COMPANY
 POWER PRODUCTION MATERIALS AND SPECIAL PROCESSES SECTION
 PRAIRIE ISLAND NUCLEAR GENERATING PLANT STEAM GENERATOR TUBE MAP - WESTINGHOUSE SERIES 51



***** DEGRADED TUBES (ALL) *****
 STEAM GENERATOR NO. 2
 TUBES MAPPED TO REGION MAPPED TO OUTLET (COLD LEG)
 THROUGH TUBE SHEET AROUND U-BEND

APPENDIX G

STEAM GENERATOR NO. 21 AND NO. 22

LISTING OF EDDY CURRENT INDICATIONS & PLUGGED TUBES

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS			
21	INLET	21	64	83		3RD	AVB	THINNING	20			
			65	83		3RD	AVB	THINNING	27			
			66	83		3RD	AVB	THINNING	00			
			67	83		3RD	AVB	THINNING	00			
			68	83		3RD	AVB	THINNING	00			
			69	83		3RD	AVB	THINNING	00			
		22	54	22	78	83		3RD	AVB	THINNING	00	
					79	83		3RD	AVB	THINNING	00	
					80	83		3RD	AVB	THINNING	00	
					81	83		3RD	AVB	THINNING	00	
					82	83		3RD	AVB	THINNING	00	
					83	83		3RD	AVB	THINNING	00	
23	53	23	53	83		3RD	AVB	THINNING	00			
			54	83		3RD	AVB	THINNING	00			
			55	83		3RD	AVB	THINNING	00			
			56	83		3RD	AVB	THINNING	00			
			57	83		3RD	AVB	THINNING	00			
			58	83		3RD	AVB	THINNING	00			
24	50	24	50	83		4TH	AVB	THINNING	00			
			51	83		4TH	AVB	THINNING	00			
			52	83		4TH	AVB	THINNING	00			
			53	83		4TH	AVB	THINNING	00			
			54	83		4TH	AVB	THINNING	00			
			55	83		4TH	AVB	THINNING	00			
			56	83		4TH	AVB	THINNING	00			
			57	83		4TH	AVB	THINNING	00			
			58	83		4TH	AVB	THINNING	00			
			59	83		4TH	AVB	THINNING	00			
			60	83		4TH	AVB	THINNING	00			
			25	50	25	50	83	42" ABOVE	1ST	AVB	THINNING	00
51	83					2ND	AVB	THINNING	00			
52	83					3RD	AVB	THINNING	00			
53	83					4TH	AVB	THINNING	00			
54	83					1ST	SUP	THINNING	00			
55	83					1ST	AVB	THINNING	00			
56	83					1ST	AVB	THINNING	00			
57	83					1ST	AVB	THINNING	00			
58	83					2ND	AVB	THINNING	00			
59	83					3RD	AVB	THINNING	00			
60	83					4TH	AVB	THINNING	00			
26	71	26				71	83	5" ABOVE	4TH	AVB	THINNING	00
			72	83		1ST	AVB	THINNING	00			
			73	83		1ST	AVB	THINNING	00			
			74	83		2ND	AVB	THINNING	00			
			75	83		3RD	AVB	THINNING	00			
			76	83		4TH	AVB	THINNING	00			
			77	83		4TH	AVB	THINNING	00			
			78	83		4TH	AVB	THINNING	00			
			79	83		4TH	AVB	THINNING	00			
			80	83		4TH	AVB	THINNING	00			
			81	83		4TH	AVB	THINNING	00			
			27	48	27	48	83		TUBE SH	THINNING	00	
49	83					1ST	AVB	THINNING	00			
50	83					1ST	AVB	THINNING	00			
51	83					2ND	AVB	THINNING	00			
52	83					3RD	AVB	THINNING	00			
53	83					4TH	AVB	THINNING	00			
27	69	27	69	83		4TH	AVB	THINNING	00			
			70	83		4TH	AVB	THINNING	00			
			71	83		4TH	AVB	THINNING	00			
			72	83		4TH	AVB	THINNING	00			
			73	83		4TH	AVB	THINNING	00			
			74	83		4TH	AVB	THINNING	00			

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS
21	INLET	27	49	84-	17" ABOVE	4TH AVB	THINNING	0	
						1ST AVB	THINNING	0	
		28	45		2ND AVB	THINNING	0		
					3RD AVB	THINNING	0		
		29	44		4TH AVB	THINNING	0		
					TUBE SH	THINNING	0		
		30	50		1ST AVB	THINNING	0		
					2ND AVB	THINNING	0		
		31	51		3RD AVB	THINNING	0		
					4TH AVB	THINNING	0		
		35	48		2ND AVB	THINNING	0		
					TUBE SH	THINNING	0		
		36	43		1ST AVB	THINNING	0		
					2ND AVB	THINNING	0		
		37	44		3RD AVB	THINNING	0		
					4TH AVB	THINNING	0		
		39	46		1ST AVB	THINNING	0		
					2ND AVB	THINNING	0		
		40	47		3RD AVB	THINNING	0		
					4TH AVB	THINNING	0		
		40	52		12" ABOVE	3RD SUP	THINNING	0	
					3RD AVB	THINNING	0		
		40	53		4TH AVB	THINNING	0		
					1ST AVB	THINNING	0		

DEC 13, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS			
21	INLET	41	UN	84		2ND	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		2ND	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		TH	AVB	TH	NN	ING	<	00
	OUTLET	42	UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
		43	UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
		44	UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
			UN	84		1ST	AVB	TH	NN	ING	<	00
	1	46	84		6TH	TH	SUP	TH	NN	ING	<	00
		79	84		TUBE	SH	TH	NN	ING	<	00	
		80	84		3RD	AVB	TH	NN	ING	<	00	
		81	84		3RD	AVB	TH	NN	ING	<	00	
		82	84		3RD	AVB	TH	NN	ING	<	00	
		83	84		3RD	AVB	TH	NN	ING	<	00	
		84	84		3RD	AVB	TH	NN	ING	<	00	
		85	84		3RD	AVB	TH	NN	ING	<	00	
		86	84		3RD	AVB	TH	NN	ING	<	00	
		87	84		3RD	AVB	TH	NN	ING	<	00	
	4	94	84		1ST	AVB	TH	NN	ING	<	00	
		95	84		1ST	AVB	TH	NN	ING	<	00	
		96	84		1ST	AVB	TH	NN	ING	<	00	
		97	84		1ST	AVB	TH	NN	ING	<	00	
		98	84		1ST	AVB	TH	NN	ING	<	00	
	5	99	84		1ST	AVB	TH	NN	ING	<	00	
		100	84		1ST	AVB	TH	NN	ING	<	00	
		101	84		1ST	AVB	TH	NN	ING	<	00	
		102	84		1ST	AVB	TH	NN	ING	<	00	
		103	84		1ST	AVB	TH	NN	ING	<	00	
6	104	84		1ST	AVB	TH	NN	ING	<	00		
	105	84		1ST	AVB	TH	NN	ING	<	00		
	106	84		1ST	AVB	TH	NN	ING	<	00		
	107	84		1ST	AVB	TH	NN	ING	<	00		
	108	84		1ST	AVB	TH	NN	ING	<	00		
7	109	84		1ST	AVB	TH	NN	ING	<	00		
	110	84		1ST	AVB	TH	NN	ING	<	00		
	111	84		1ST	AVB	TH	NN	ING	<	00		
	112	84		1ST	AVB	TH	NN	ING	<	00		
	113	84		1ST	AVB	TH	NN	ING	<	00		
8	114	84		1ST	AVB	TH	NN	ING	<	00		
	115	84		1ST	AVB	TH	NN	ING	<	00		
	116	84		1ST	AVB	TH	NN	ING	<	00		
	117	84		1ST	AVB	TH	NN	ING	<	00		
	118	84		1ST	AVB	TH	NN	ING	<	00		
9	119	84		1ST	AVB	TH	NN	ING	<	00		
	120	84		1ST	AVB	TH	NN	ING	<	00		
	121	84		1ST	AVB	TH	NN	ING	<	00		
	122	84		1ST	AVB	TH	NN	ING	<	00		
	123	84		1ST	AVB	TH	NN	ING	<	00		
10	124	84		1ST	AVB	TH	NN	ING	<	00		
	125	84		1ST	AVB	TH	NN	ING	<	00		
	126	84		1ST	AVB	TH	NN	ING	<	00		
	127	84		1ST	AVB	TH	NN	ING	<	00		
	128	84		1ST	AVB	TH	NN	ING	<	00		
11	129	84		1ST	AVB	TH	NN	ING	<	00		
	130	84		1ST	AVB	TH	NN	ING	<	00		
	131	84		1ST	AVB	TH	NN	ING	<	00		
	132	84		1ST	AVB	TH	NN	ING	<	00		
	133	84		1ST	AVB	TH	NN	ING	<	00		
12	134	84		1ST	AVB	TH	NN	ING	<	00		
	135	84		1ST	AVB	TH	NN	ING	<	00		
	136	84		1ST	AVB	TH	NN	ING	<	00		
	137	84		1ST	AVB	TH	NN	ING	<	00		
	138	84		1ST	AVB	TH	NN	ING	<	00		
13	139	84		1ST	AVB	TH	NN	ING	<	00		
	140	84		1ST	AVB	TH	NN	ING	<	00		
	141	84		1ST	AVB	TH	NN	ING	<	00		
	142	84		1ST	AVB	TH	NN	ING	<	00		
	143	84		1ST	AVB	TH	NN	ING	<	00		
14	144	84		1ST	AVB	TH	NN	ING	<	00		
	145	84		1ST	AVB	TH	NN	ING	<	00		
	146	84		1ST	AVB	TH	NN	ING	<	00		
	147	84		1ST	AVB	TH	NN	ING	<	00		
	148	84		1ST	AVB	TH	NN	ING	<	00		

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS											
21	OUTLET	25	32	1	36 " ABOVE	JRD	AVB	TH	NN	NC	V									
			33	1		IST	AVB	TH	NN	NC	V									
			58	1		NZD	AVB	TH	NN	NC	V									
			55	1		NZD	AVB	TH	NN	NC	V									
			28	11		86	1	1	NZD	AVB	TH	NN	NC	V						
							5	1	NZD	AVB	TH	NN	NC	V						
							11	1	NZD	AVB	TH	NN	NC	V						
							5	1	NZD	AVB	TH	NN	NC	V						
							29	13	37	1	1	NZD	AVB	TH	NN	NC	V			
										4	1	NZD	AVB	TH	NN	NC	V			
										5	1	NZD	AVB	TH	NN	NC	V			
										8	1	NZD	AVB	TH	NN	NC	V			
										30	12	14	1	1	NZD	AVB	TH	NN	NC	V
													4	1	NZD	AVB	TH	NN	NC	V
			5	1		NZD							AVB	TH	NN	NC	V			
			8	1		NZD							AVB	TH	NN	NC	V			
			31	14		79							1	1	NZD	AVB	TH	NN	NC	V
													5	1	NZD	AVB	TH	NN	NC	V
							8	1	NZD				AVB	TH	NN	NC	V			
							12	1	NZD				AVB	TH	NN	NC	V			
							32	16	78				1	1	NZD	AVB	TH	NN	NC	V
													5	1	NZD	AVB	TH	NN	NC	V
										8	1	NZD	AVB	TH	NN	NC	V			
										12	1	NZD	AVB	TH	NN	NC	V			
										34	18	76	1	1	NZD	AVB	TH	NN	NC	V
													5	1	NZD	AVB	TH	NN	NC	V
			8	1		NZD							AVB	TH	NN	NC	V			
			12	1		NZD							AVB	TH	NN	NC	V			
			16	1		NZD							AVB	TH	NN	NC	V			
			20	1		NZD							AVB	TH	NN	NC	V			

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS
21	OUTLET	34	76	84-	ND	SUP	THINNING	0	
				80-	ND	SUP	THINNING	0	
		35	17	81-	ND	SUP	THINNING	0	
				82-	ND	SUP	THINNING	0	
				83-	ND	SUP	THINNING	0	
				84-	ND	SUP	THINNING	0	
				85-	ND	SUP	THINNING	0	
				86-	ND	SUP	THINNING	0	
		18	77	87-	ND	SUP	THINNING	0	
				88-	ND	SUP	THINNING	0	
				89-	ND	SUP	THINNING	0	
				90-	ND	SUP	THINNING	0	
				91-	ND	SUP	THINNING	0	
				92-	ND	SUP	THINNING	0	
		36	78	93-	ND	SUP	THINNING	0	
				94-	ND	SUP	THINNING	0	
				95-	ND	SUP	THINNING	0	
				96-	ND	SUP	THINNING	0	
				97-	ND	SUP	THINNING	0	
				98-	ND	SUP	THINNING	0	
		19	21	99-	ND	SUP	THINNING	0	
				00-	ND	SUP	THINNING	0	
				01-	ND	SUP	THINNING	0	
				02-	ND	SUP	THINNING	0	
				03-	ND	SUP	THINNING	0	
				04-	ND	SUP	THINNING	0	
		63	76	05-	ND	SUP	THINNING	0	
				06-	ND	SUP	THINNING	0	
				07-	ND	SUP	THINNING	0	
				08-	ND	SUP	THINNING	0	
				09-	ND	SUP	THINNING	0	
				10-	ND	SUP	THINNING	0	
		37	72	11-	ND	SUP	THINNING	0	
				12-	ND	SUP	THINNING	0	
				13-	ND	SUP	THINNING	0	
				14-	ND	SUP	THINNING	0	
				15-	ND	SUP	THINNING	0	
				16-	ND	SUP	THINNING	0	
		74	75	17-	ND	SUP	THINNING	0	
				18-	ND	SUP	THINNING	0	
19-	ND			SUP	THINNING	0			
20-	ND			SUP	THINNING	0			
21-	ND			SUP	THINNING	0			
22-	ND			SUP	THINNING	0			
76	38	23-	ND	SUP	THINNING	0			
		24-	ND	SUP	THINNING	0			
		25-	ND	SUP	THINNING	0			
		26-	ND	SUP	THINNING	0			
		27-	ND	SUP	THINNING	0			
		28-	ND	SUP	THINNING	0			
39	25	29-	ND	SUP	THINNING	0			
		30-	ND	SUP	THINNING	0			
		31-	ND	SUP	THINNING	0			
		32-	ND	SUP	THINNING	0			
		33-	ND	SUP	THINNING	0			
		34-	ND	SUP	THINNING	0			
26	70	35-	ND	SUP	THINNING	0			
		36-	ND	SUP	THINNING	0			
		37-	ND	SUP	THINNING	0			
		38-	ND	SUP	THINNING	0			
		39-	ND	SUP	THINNING	0			
		40-	ND	SUP	THINNING	0			
63	71	41-	ND	SUP	THINNING	0			
		42-	ND	SUP	THINNING	0			
		43-	ND	SUP	THINNING	0			
		44-	ND	SUP	THINNING	0			
		45-	ND	SUP	THINNING	0			
		46-	ND	SUP	THINNING	0			
72	73	47-	ND	SUP	THINNING	0			
		48-	ND	SUP	THINNING	0			
		49-	ND	SUP	THINNING	0			
		50-	ND	SUP	THINNING	0			
		51-	ND	SUP	THINNING	0			
		52-	ND	SUP	THINNING	0			
40	25	53-	ND	SUP	THINNING	0			
		54-	ND	SUP	THINNING	0			
		55-	ND	SUP	THINNING	0			
		56-	ND	SUP	THINNING	0			

multiple indio.

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS		
21	OUTLET	40	30	83	UP	ST	TH	100			
			66	83	UP	ST	TH	100			
				83	UP	ST	TH	100			
				83	UP	ST	TH	100			
				69	83	UP	ST	TH	100		
					70	83	UP	ST	TH	100	
			41		70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
			42		70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
			43		70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
			44		70	83	UP	ST	TH	100	
					70	83	UP	ST	TH	100	
	70	83		UP	ST	TH	100				
	70	83		UP	ST	TH	100				
	70	83		UP	ST	TH	100				
	70	83		UP	ST	TH	100				
	70	83		UP	ST	TH	100				
	70	83		UP	ST	TH	100				

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS																																																																																																																																																																																																																																																																																																																																																																																																										
21	OUTLET	44	45	83	1	S	T	S	U	P	THINNING	20																																																																																																																																																																																																																																																																																																																																																																																																							
														84	1	S	T	S	U	P	THINNING	24																																																																																																																																																																																																																																																																																																																																																																																													
																								85	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																																			
																																		86	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																									
																																												87	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																															
																																																						88	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																					
																																																																89	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																											
																																																																										90	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																	
																																																																																				91	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																							
																																																																																														92	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																													
																																																																																																								93	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																			
																																																																																																																		94	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																									
																																																																																																																												95	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																															
																																																																																																																																						96	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																					
																																																																																																																																																97	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																											
																																																																																																																																																										98	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																	
																																																																																																																																																																				99	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																							
																																																																																																																																																																														100	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																													
																																																																																																																																																																																								101	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																			
																																																																																																																																																																																																		102	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																									
																																																																																																																																																																																																												103	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																															
																																																																																																																																																																																																																						104	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																					
																																																																																																																																																																																																																																105	1	S	T	S	U	P	THINNING	33																																																																																																																																																																											
																																																																																																																																																																																																																																										106	1	S	T	S	U	P	THINNING	33																																																																																																																																																																	
																																																																																																																																																																																																																																																				107	1	S	T	S	U	P	THINNING	33																																																																																																																																																							
																																																																																																																																																																																																																																																														108	1	S	T	S	U	P	THINNING	33																																																																																																																																													
																																																																																																																																																																																																																																																																								109	1	S	T	S	U	P	THINNING	33																																																																																																																																			
																																																																																																																																																																																																																																																																																		110	1	S	T	S	U	P	THINNING	33																																																																																																																									
																																																																																																																																																																																																																																																																																												111	1	S	T	S	U	P	THINNING	33																																																																																																															
																																																																																																																																																																																																																																																																																																						112	1	S	T	S	U	P	THINNING	33																																																																																																					
																																																																																																																																																																																																																																																																																																																113	1	S	T	S	U	P	THINNING	33																																																																																											
																																																																																																																																																																																																																																																																																																																										114	1	S	T	S	U	P	THINNING	33																																																																																	
																																																																																																																																																																																																																																																																																																																																				115	1	S	T	S	U	P	THINNING	33																																																																							
																																																																																																																																																																																																																																																																																																																																														116	1	S	T	S	U	P	THINNING	33																																																													
																																																																																																																																																																																																																																																																																																																																																								117	1	S	T	S	U	P	THINNING	33																																																			
																																																																																																																																																																																																																																																																																																																																																																		118	1	S	T	S	U	P	THINNING	33																																									
																																																																																																																																																																																																																																																																																																																																																																												119	1	S	T	S	U	P	THINNING	33																															
																																																																																																																																																																																																																																																																																																																																																																																						120	1	S	T	S	U	P	THINNING	33																					
																																																																																																																																																																																																																																																																																																																																																																																																121	1	S	T	S	U	P	THINNING	33											
																																																																																																																																																																																																																																																																																																																																																																																																										122	1	S	T	S	U	P	THINNING	33	
124	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																																																											
										125	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																																																	
																				126	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																																							
																														127	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																													
																																								128	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																																			
																																																		129	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																																									
																																																												130	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																															
																																																																						131	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																																					
																																																																																132	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																											
																																																																																										133	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																																	
																																																																																																				134	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																																							
																																																																																																														135	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																													
																																																																																																																								136	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																																			
																																																																																																																																		137	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																																									
																																																																																																																																												138	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																															
																																																																																																																																																						139	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																																					
																																																																																																																																																																140	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																											
																																																																																																																																																																										141	1	S	T	S	U	P	THINNING	33																																																																																																																																																																																																																																	

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS
21	OUTLET	45	41	83-	2ND	SUP	THINNING	0	
			42	83-	2ND	SUP	THINNING	0	
			43	83-	2ND	SUP	THINNING	0	
			44	83-	2ND	SUP	THINNING	0	
			45	83-	2ND	SUP	THINNING	0	
			46	83-	2ND	SUP	THINNING	0	
			47	83-	2ND	SUP	THINNING	0	
			48	83-	2ND	SUP	THINNING	0	
			49	83-	2ND	SUP	THINNING	0	
			50	83-	2ND	SUP	THINNING	0	
		46	51	83-	2ND	SUP	THINNING	0	
			52	83-	2ND	SUP	THINNING	0	
			53	83-	2ND	SUP	THINNING	0	
			54	83-	2ND	SUP	THINNING	0	
			55	83-	2ND	SUP	THINNING	0	
			56	83-	2ND	SUP	THINNING	0	
			57	83-	2ND	SUP	THINNING	0	
			58	83-	2ND	SUP	THINNING	0	
			59	83-	2ND	SUP	THINNING	0	
			60	83-	2ND	SUP	THINNING	0	
22	INLET	10	23	83-	4TH	SUP	THINNING	0	
			24	83-	4TH	SUP	THINNING	0	
			25	83-	4TH	SUP	THINNING	0	
			26	83-	4TH	SUP	THINNING	0	
			27	83-	4TH	SUP	THINNING	0	
			28	83-	4TH	SUP	THINNING	0	
			29	83-	4TH	SUP	THINNING	0	
			30	83-	4TH	SUP	THINNING	0	
			31	83-	4TH	SUP	THINNING	0	
			32	83-	4TH	SUP	THINNING	0	
		23	33	83-	4TH	SUP	THINNING	0	
			34	83-	4TH	SUP	THINNING	0	
			35	83-	4TH	SUP	THINNING	0	
			36	83-	4TH	SUP	THINNING	0	
			37	83-	4TH	SUP	THINNING	0	
			38	83-	4TH	SUP	THINNING	0	
			39	83-	4TH	SUP	THINNING	0	
			40	83-	4TH	SUP	THINNING	0	
			41	83-	4TH	SUP	THINNING	0	
			42	83-	4TH	SUP	THINNING	0	
44	43	83-	4TH	SUP	THINNING	0			
	44	83-	4TH	SUP	THINNING	0			
	45	83-	4TH	SUP	THINNING	0			
	46	83-	4TH	SUP	THINNING	0			
	47	83-	4TH	SUP	THINNING	0			
	48	83-	4TH	SUP	THINNING	0			
	49	83-	4TH	SUP	THINNING	0			
	50	83-	4TH	SUP	THINNING	0			
	51	83-	4TH	SUP	THINNING	0			
	52	83-	4TH	SUP	THINNING	0			

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS
22	OUTLET	11	91	88	6" ABOVE	UP	TH	100	
				89			TH	100	
		12	93	88			TH	100	
				89			TH	100	
		14	88	88			TH	100	
				89			TH	100	
		15	91	88			TH	100	
				89			TH	100	
		16	4	88			TH	100	
				89			TH	100	
		17	5	89			TH	100	
				90			TH	100	
		18	90	89			TH	100	
				90			TH	100	
		19	89	89			TH	100	
				90			TH	100	
		20	6	89			TH	100	
				90			TH	100	
		22	86	89			TH	100	
				90			TH	100	
		23	85	89			TH	100	
				90			TH	100	
		25	9	89			TH	100	
				90			TH	100	
				11					

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS
22	OUTLET	25	11	1	1	1	TH	100	
			85	1	1	1	TH	100	
			10	1	1	1	TH	100	
			11	1	1	1	TH	100	
			86	1	1	1	TH	100	
			11	1	1	1	TH	100	
			11	1	1	1	TH	100	
			12	1	1	1	TH	100	
			13	1	1	1	TH	100	
			15	1	1	1	TH	100	
			85	1	1	1	TH	100	
			12	1	1	1	TH	100	
			13	1	1	1	TH	100	
			82	1	1	1	TH	100	
			83	1	1	1	TH	100	
			12	1	1	1	TH	100	
			13	1	1	1	TH	100	
			14	1	1	1	TH	100	

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS	
22	OUTLET	30	15	1	1	1	1	1	1	
			16	1	1	1	1	1	1	
			17	1	1	1	1	1	1	1
			18	1	1	1	1	1	1	1
			19	1	1	1	1	1	1	1
			20	1	1	1	1	1	1	1
			21	1	1	1	1	1	1	1
			22	1	1	1	1	1	1	1
			23	1	1	1	1	1	1	1
			24	1	1	1	1	1	1	1
		25	1	1	1	1	1	1	1	
		26	1	1	1	1	1	1	1	
		27	1	1	1	1	1	1	1	
		28	1	1	1	1	1	1	1	
		29	1	1	1	1	1	1	1	
		30	1	1	1	1	1	1	1	
		31	1	1	1	1	1	1	1	1
		32	1	1	1	1	1	1	1	1
		33	1	1	1	1	1	1	1	1
		34	1	1	1	1	1	1	1	1
		35	1	1	1	1	1	1	1	1
		36	1	1	1	1	1	1	1	1
37	1	1	1	1	1	1	1	1		
38	1	1	1	1	1	1	1	1		
39	1	1	1	1	1	1	1	1		
40	1	1	1	1	1	1	1	1		
41	1	1	1	1	1	1	1	1		
42	1	1	1	1	1	1	1	1		
43	1	1	1	1	1	1	1	1		
44	1	1	1	1	1	1	1	1		
45	1	1	1	1	1	1	1	1		
46	1	1	1	1	1	1	1	1		
47	1	1	1	1	1	1	1	1		
48	1	1	1	1	1	1	1	1		
49	1	1	1	1	1	1	1	1		
50	1	1	1	1	1	1	1	1		
51	1	1	1	1	1	1	1	1		
52	1	1	1	1	1	1	1	1		
53	1	1	1	1	1	1	1	1		
54	1	1	1	1	1	1	1	1		
55	1	1	1	1	1	1	1	1		
56	1	1	1	1	1	1	1	1		
57	1	1	1	1	1	1	1	1		
58	1	1	1	1	1	1	1	1		
59	1	1	1	1	1	1	1	1		
60	1	1	1	1	1	1	1	1		
61	1	1	1	1	1	1	1	1		
62	1	1	1	1	1	1	1	1		
63	1	1	1	1	1	1	1	1		
64	1	1	1	1	1	1	1	1		
65	1	1	1	1	1	1	1	1		
66	1	1	1	1	1	1	1	1		
67	1	1	1	1	1	1	1	1		
68	1	1	1	1	1	1	1	1		
69	1	1	1	1	1	1	1	1		
70	1	1	1	1	1	1	1	1		
71	1	1	1	1	1	1	1	1		
72	1	1	1	1	1	1	1	1		
73	1	1	1	1	1	1	1	1		
74	1	1	1	1	1	1	1	1		
75	1	1	1	1	1	1	1	1		
76	1	1	1	1	1	1	1	1		
77	1	1	1	1	1	1	1	1		

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS		
22	OUTLET	32	77	83-	ND	SUP	THI	NN	NN		
				81-	ND	SUP	THI	NN	NN		
			79	82-	ND	SUP	THI	NN	NN		
				80-	1ST	SUP	THI	NN	NN		
			33	16	81-	ND	SUP	THI	NN	NN	
					80-	ND	SUP	THI	NN	NN	
		81-			ND	SUP	THI	NN	NN		
		83-			1ST	SUP	THI	NN	NN		
		84-			1ST	SUP	THI	NN	NN		
		80-			1ST	SUP	THI	NN	NN		
		17		16	81-	ND	SUP	THI	NN	NN	
					82-	ND	SUP	THI	NN	NN	
					84-	ND	SUP	THI	NN	NN	
				46	17	83-	ND	SUP	THI	NN	NN
						83-	ND	SUP	THI	NN	NN
						80-	1ST	SUP	THI	NN	NN
		34	46	81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
			56	49	81-	ND	AVB	THI	NN	NN	
					81-	ND	AVB	THI	NN	NN	
					81-	ND	AVB	THI	NN	NN	
				57	56	81-	ND	AVB	THI	NN	NN
						81-	ND	AVB	THI	NN	NN
						81-	ND	AVB	THI	NN	NN
		59	57	81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
			67	59	81-	ND	AVB	THI	NN	NN	
					81-	ND	AVB	THI	NN	NN	
					81-	ND	AVB	THI	NN	NN	
		35	75	81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
			76	75	81-	ND	AVB	THI	NN	NN	
					81-	ND	AVB	THI	NN	NN	
81-	ND				AVB	THI	NN	NN			
77	76			81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
				81-	ND	AVB	THI	NN	NN		
78	77	81-	ND	AVB	THI	NN	NN				
		81-	ND	AVB	THI	NN	NN				
		81-	ND	AVB	THI	NN	NN				
	79	78	81-	ND	AVB	THI	NN	NN			
			81-	ND	AVB	THI	NN	NN			
			81-	ND	AVB	THI	NN	NN			
19	79	81-	ND	AVB	THI	NN	NN				
		81-	ND	AVB	THI	NN	NN				
		81-	ND	AVB	THI	NN	NN				
	77	79	81-	ND	AVB	THI	NN	NN			
			81-	ND	AVB	THI	NN	NN			
			81-	ND	AVB	THI	NN	NN			

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS
22	OUTLET	35 36	78	0	12" ABOVE TUBE SHEETS	SH	THINNING	46	
			18	0		SUP	THINNING	33	
			19	0		SUP	THINNING	47	
			20	0		SUP	THINNING	28	
			21	0		SUP	THINNING	43	
			22	0		SUP	THINNING	44	
			23	0		SUP	THINNING	220	
			24	0		SUP	THINNING	33	
			25	0		SUP	THINNING	39	
			26	0		SUP	THINNING	34	
			27	0		SUP	THINNING	33	
			28	0		SUP	THINNING	33	
			29	0		SUP	THINNING	33	
			30	0		SUP	THINNING	33	
			31	0		AVB	THINNING	33	
			32	0		AVB	THINNING	33	
			33	0		AVB	THINNING	33	
			34	0		AVB	THINNING	33	
			35	0		AVB	THINNING	33	
			36	0		AVB	THINNING	60	
			37	0		SUP	THINNING	43	
			38	0		SUP	THINNING	73	
			39	0		SUP	THINNING	49	
			40	0		SUP	THINNING	51	
			41	0		SUP	THINNING	46	
			42	0		SUP	THINNING	51	
			43	0		SUP	THINNING	56	
			44	0		SUP	THINNING	45	
			45	0		SUP	THINNING	58	
			46	0		SUP	THINNING	57	
			47	0		SUP	THINNING	49	
			48	0		SUP	THINNING	48	
			49	0		SUP	THINNING	22	
			50	0		SUP	THINNING	99	
			51	0		SUP	THINNING	7	
		52	0	SUP	THINNING	1			
		53	0	SUP	THINNING	1			
		54	0	SUP	THINNING	1			
		55	0	SUP	THINNING	1			
		56	0	SUP	THINNING	1			
		57	0	SUP	THINNING	1			
		58	0	SUP	THINNING	1			
		59	0	SUP	THINNING	1			
		60	0	SUP	THINNING	1			
		61	0	SUP	THINNING	1			
		62	0	SUP	THINNING	1			
		63	0	SUP	THINNING	1			
		64	0	SUP	THINNING	1			
		65	0	SUP	THINNING	1			
		66	0	SUP	THINNING	1			
		67	0	SUP	THINNING	1			
		68	0	SUP	THINNING	1			
		69	0	SUP	THINNING	1			
70	0	SUP	THINNING	1					
71	0	SUP	THINNING	1					
72	0	SUP	THINNING	1					
73	0	SUP	THINNING	1					
74	0	SUP	THINNING	1					
75	0	SUP	THINNING	1					
76	0	SUP	THINNING	1					
77	0	SUP	THINNING	1					
78	0	SUP	THINNING	1					
79	0	SUP	THINNING	1					
80	0	SUP	THINNING	1					
81	0	SUP	THINNING	1					
82	0	SUP	THINNING	1					
83	0	SUP	THINNING	1					
84	0	SUP	THINNING	1					
85	0	SUP	THINNING	1					
86	0	SUP	THINNING	1					
87	0	SUP	THINNING	1					
88	0	SUP	THINNING	1					
89	0	SUP	THINNING	1					
90	0	SUP	THINNING	1					
91	0	SUP	THINNING	1					
92	0	SUP	THINNING	1					
93	0	SUP	THINNING	1					
94	0	SUP	THINNING	1					
95	0	SUP	THINNING	1					
96	0	SUP	THINNING	1					
97	0	SUP	THINNING	1					
98	0	SUP	THINNING	1					
99	0	SUP	THINNING	1					
100	0	SUP	THINNING	1					

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS	
22	OUTLET	37	74	81	ND	UP	TH	20		
			75	82	ND	UP	TH	20		
			76	80	1	ND	UP	TH	40	
				81	1	ND	UP	TH	40	
				82	1	ND	UP	TH	40	
				83	1	ND	UP	TH	40	
				84	1	ND	UP	TH	40	
				85	1	ND	UP	TH	40	
				86	1	ND	UP	TH	40	
				87	1	ND	UP	TH	40	
				88	1	ND	UP	TH	40	
				89	1	ND	UP	TH	40	
			90	1	ND	UP	TH	40		
			38	22	1	ND	UP	TH	44	
		23		1	ND	UP	TH	44		
		25		1	ND	UP	TH	44		
				2	ND	UP	TH	44		
				3	ND	UP	TH	44		
		47		1	ND	UP	TH	44		
				2	ND	UP	TH	44		
				3	ND	UP	TH	44		
		71	72	1	ND	UP	TH	44		
				2	ND	UP	TH	44		
				3	ND	UP	TH	44		
				4	ND	UP	TH	44		
				5	ND	UP	TH	44		
			73	1	ND	UP	TH	44		
				2	ND	UP	TH	44		
3	ND			UP	TH	44				
4	ND			UP	TH	44				
5	ND			UP	TH	44				
99	74	1	ND	UP	TH	44				
		2	ND	UP	TH	44				
		3	ND	UP	TH	44				
		4	ND	UP	TH	44				
		5	ND	UP	TH	44				
	24	1	ND	UP	TH	44				
		2	ND	UP	TH	44				
		3	ND	UP	TH	44				
		4	ND	UP	TH	44				
		5	ND	UP	TH	44				
64	25	1	ND	UP	TH	44				
		2	ND	UP	TH	44				
		3	ND	UP	TH	44				
		4	ND	UP	TH	44				
	27	1	ND	UP	TH	44				
		2	ND	UP	TH	44				
		3	ND	UP	TH	44				
		4	ND	UP	TH	44				
66	67	1	ND	UP	TH	44				
		2	ND	UP	TH	44				
		3	ND	UP	TH	44				
		4	ND	UP	TH	44				
		5	ND	UP	TH	44				

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS	
22	OUTLET	39	68	1	N	N	T			
			72	1	N	N	T			
			73	1	N	N	T			
		40	24	1	N	N	T			
				1	N	N	T			
			25	1	N	N	T			
				1	N	N	T			
			26	1	N	N	T			
				1	N	N	T			
			27	1	N	N	T			
				1	N	N	T			
			51	1	N	N	T			
				1	N	N	T			
			56	1	N	N	T			
				1	N	N	T			
		60	1	N	N	T				
			1	N	N	T				
		61	1	N	N	T				
			1	N	N	T				
		41	28	1	N	N	T			
				1	N	N	T			
			60	1	N	N	T			
				1	N	N	T			
			61	1	N	N	T			
1	N			N	T					
65	1	N	N	T						
66	1	N	N	T						
67	1	N	N	T						

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS		
22	OUTLET	41	68	83-	ND	SUP	THINNING	0			
				84-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				42	32	83-	ND	SUP	THINNING	0	
						80-	ND	SUP	THINNING	0	
						81-	ND	SUP	THINNING	0	
						82-	ND	SUP	THINNING	0	
						83-	ND	SUP	THINNING	0	
		80-	ND			SUP	THINNING	0			
		81-	ND			SUP	THINNING	0			
		82-	ND			SUP	THINNING	0			
		83-	ND			SUP	THINNING	0			
		80-	ND			SUP	THINNING	0			
		43	34	83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
		43	36	83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
		43	37	83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
		43	55	83-	ND	SUP	THINNING	0			
				80-	ND	SUP	THINNING	0			
				81-	ND	SUP	THINNING	0			
				82-	ND	SUP	THINNING	0			
				83-	ND	SUP	THINNING	0			
80-	ND			SUP	THINNING	0					
81-	ND			SUP	THINNING	0					
82-	ND			SUP	THINNING	0					
83-	ND			SUP	THINNING	0					
80-	ND			SUP	THINNING	0					
43	58	83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
43	60	83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
43	62	83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
43	63	83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
43	65	83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					
		81-	ND	SUP	THINNING	0					
		82-	ND	SUP	THINNING	0					
		83-	ND	SUP	THINNING	0					
		80-	ND	SUP	THINNING	0					

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS		
22	OUTLET	43	35	1	ND	ND	TH	00			
			36	1	ND	ND	TH	00			
		44	35	1	ND	ND	TH	00			
			36	1	ND	ND	TH	00			
					37	1	ND	TH	00		
					38	1	ND	TH	00		
					40	1	ND	TH	00		
					41	1	ND	TH	00		
					42	1	ND	TH	00		
					47	1	ST	ST	TH	00	
					48	1	ST	ST	TH	00	
					53	1	ST	ST	TH	00	
					54	1	ND	ND	TH	00	
					55	1	ND	ND	TH	00	
					56	1	ST	ST	TH	00	
					57	1	ST	ST	TH	00	
					58	1	ST	ST	TH	00	
					59	1	ND	ND	TH	00	
					60	1	ND	ND	TH	00	
					41	1	ND	ND	TH	00	
					42	1	ND	ND	TH	00	

45

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF IMPERFECT, DEGRADED, AND DEFECTIVE TUBES

GEN NO.	SIDE	ROW	COL	YEAR	FROM	TO	DEFECT OR OBS	%	REMARKS/COMMENTS		
22	OUTLET	45	44	83	ND	UU	THINNING	1			
				84	ND	UU	THINNING	1			
				81	ND	UU	THINNING	1			
			82	ND	UU	THINNING	1				
			48	84	ST	UU	THINNING	1			
				83	ND	UU	THINNING	1			
				84	ND	UU	THINNING	1			
			49	84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
			46	57	41	83	ND	UU	THINNING	1	
						84	ND	UU	THINNING	1	
						81	ND	UU	THINNING	1	
		42		84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
		43		84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
		45		84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
				84	TT	UU	THINNING	1			
		48		49	84	TT	UU	THINNING	1		
					84	TT	UU	THINNING	1		
					84	TT	UU	THINNING	1		
		50	84	TT	UU	THINNING	1				
			84	TT	UU	THINNING	1				
			84	TT	UU	THINNING	1				
54	84	TT	UU	THINNING	1						
	84	TT	UU	THINNING	1						
	84	TT	UU	THINNING	1						

7TSP CRACKED HL

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF PLUGGED STEAM GENERATOR TUBES

GEN NO.	SIDE	ROW	COL	YEAR	REMARKS/COMMENTS
21	INLET	1	1	1	PREVENTIVE (R1/C1)
		1	2	1	PREVENTIVE
		1	3	1	PREVENTIVE
		1	4	1	PREVENTIVE
		1	5	1	PREVENTIVE
		1	6	1	PREVENTIVE
		1	7	1	PREVENTIVE
		1	8	1	PREVENTIVE
		1	9	1	PREVENTIVE
		1	10	1	PREVENTIVE
	OUTLET	1	1	1	PREVENTIVE
		1	2	1	PREVENTIVE
		1	3	1	PREVENTIVE
		1	4	1	PREVENTIVE
		1	5	1	PREVENTIVE
		1	6	1	PREVENTIVE
		1	7	1	PREVENTIVE
		1	8	1	PREVENTIVE
		1	9	1	PREVENTIVE
		1	10	1	PREVENTIVE
		1	11	1	PREVENTIVE

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATOR PLANT
LIST OF PLOGGED STEAM GENERATOR TUBES

GEN NO.	SIDE	ROW	COL	YEAR	REMARKS/COMMENTS
21	OUTLET	44	2	88	////
			3	89	////
			4	90	////
45			5	91	////
			6	92	////
			7	93	////
			8	94	////
			9	95	////
			10	96	////
			11	97	////
			12	98	////
			13	99	////
			14	00	////
			15	01	////
			16	02	////
22	INLET	1	1	00	PREVENTIVE
			2	01	PREVENTIVE
			3	02	////
17			4	03	////
18			5	04	////
19			6	05	////
20			7	06	////
30			8	07	////
31			9	08	////
			10	09	////
			11	10	////
32			12	11	////
			13	12	////
			14	13	////
			15	14	////
			16	15	////
			17	16	////
			18	17	////
			19	18	////
			20	19	////
			21	20	////
			22	21	////
			23	22	////
			24	23	////
			25	24	////
			26	25	////
			27	26	////
			28	27	////
			29	28	////
			30	29	////
			31	30	////
			32	31	////
			33	32	////
			34	33	////
			35	34	////
			36	35	////
			37	36	////
			38	37	////
			39	38	////
			40	39	////
			41	40	////
			42	41	////
			43	42	////
			44	43	////
			45	44	////
			46	45	////
			47	46	////
			48	47	////
			49	48	////
			50	49	////
			51	50	////
			52	51	////
			53	52	////
			54	53	////
			55	54	////
			56	55	////
			57	56	////
			58	57	////
			59	58	////
			60	59	////
			61	60	////
			62	61	////
			63	62	////
			64	63	////
			65	64	////
			66	65	////
			67	66	////
			68	67	////
			69	68	////
			70	69	////
			71	70	////
			72	71	////
			73	72	////
			74	73	////
			75	74	////
			76	75	////
			77	76	////
			78	77	////
			79	78	////
			80	79	////
			81	80	////
			82	81	////
			83	82	////
			84	83	////
			85	84	////
			86	85	////
			87	86	////
			88	87	////
			89	88	////
			90	89	////
			91	90	////
			92	91	////
			93	92	////
			94	93	////
			95	94	////
			96	95	////
			97	96	////
			98	97	////
			99	98	////
			00	99	////

1981 HRG LOC 81-1

LOC PLUG LOC 81-1

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF PLUGGED STEAM GENERATOR TUBES

GEN NO.	SIDE	ROW	COL	YEAR	REMARKS/COMMENTS		
22	INLET	38	74	80-	S/O		
			27	82-	S/O		
		39	28	81-	S/O		
			67	81-	S/O		
			68	81-	S/O		
		40	94	82-	S/O		
			51	81-	S/O		
			54	84-	AVB		
			60	81-	S/O		
			61	81-	S/O		
		41	28	83-	S/O		
			67	83-	S/O		
		42	32	83-	S/O		
			33	81-	S/O		
		43	34	80-	S/O		
			37	80-	S/O		
			52	84-	S/O		
		44	53	81-	S/O		
			62	84-	S/O		
			33	82-	S/O		
			35	81-	S/O		
			37	80-	S/O		
			41	80-	S/O		
			54	82-	S/O		
			56	83-	S/O		
			57	83-	S/O		
			58	83-	S/O		
		45	59	82-	S/O		
			60	84-	S/O		
			36	81-	S/O		
		46	37	80-	S/O		
			41	84-	S/O		
			43	81-	S/O		
		OUTLET	1	48	80-	S/O	
				54	82-	S/O	
				1	80-	PREVENTIVE	
				94	80-	PREVENTIVE	
				13	83-		
				17	47	77-	S/I
				18	91	83-	
				25	90	83-	
				26	85	83-	
				30	11	84-	
					19	82-	
					13	83-	
31	16			84-			
	78			81-			
	79			83-			
	81	82-					
	82	84-					
32	17	81-					
	18	84-					
	19	84-					
	62	81-	AVB				
	63	81-	AVB				
33	65	82-	AVB				
	77	83-					
	79	81-					
	16	84-					
	46	81-	AVB				
	49	81-	AVB				
	56	81-	AVB				
	57	81-	AVB				
34	59	81-	AVB				
	67	81-					
	78	80-					
	79	80-					
	18	80-					
35	20	81-					
	76	80-					
	77	82-					
	79	80-	PULLED FOR ANALYSIS				
	18	84-					
36	19	81-					
	77	83-					
	78	80-					
	18	81-					

DEC 18, 1984

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
LIST OF PLUGGED STEAM GENERATOR TUBES

GEN NO.	SIDE	ROW	COL	YEAR	REMARKS/COMMENTS
22	OUTLET	36	20	84-	
			35	81-	AVB
			50	84-	
			51	81-	AVB
			52	81-	AVB
		37	59	81-	AVB
			60	81-	AVB
			76	81-	
			81	81-	2 PLUG CORRECTION
			96	81-	AVB
		38	46	81-	AVB
			49	81-	AVB
			75	82-	
			82	82-	
			84	84-	
		39	55	81-	AVB
			55	81-	AVB
			58	81-	AVB
			74	80-	
			77	82-	
40	78	81-			
	8	81-	AVB		
	68	81-	AVB		
	44	82-			
	11	81-	AVB		
41	44	84-			
	60	81-	AVB		
	81	81-	AVB		
	88	83-			
	97	83-			
42	97	83-			
	99	83-			
	99	81-			
	44	80-			
	47	80-			
43	55	80-			
	55	81-			
	59	81-			
	64	84-			
	66	82-			
44	66	81-			
	69	80-			
	77	80-			
	41	80-			
	44	82-			
45	44	83-			
	66	83-			
	66	84-			
	96	81-			
	97	80-			
46	97	84-			
	41	84-			
	49	81-			
	48	80-			
	54	82-			

APPENDIX H
FORM NIS - 1
OWNERS' DATA REPORT FOR INSERVICE INSPECTION

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B1.0 REACTOR VESSEL</u>	CREUSOT-LOIRE	687	MINN 200-51	--
<u>B1.8 CLOSURE STUDS AND NUTS</u> NUTS 33 THRU 48	CREUSOT-LOIRE	--	--	--
<u>B1.10 CLOSURE WASHERS</u> WASHERS 33 THRU 48	CREUSOT-LOIRE	--	--	--
<u>B1.11 PRESSURE RETAINING BOLTING</u> CONOSEAL MARMON CLAMP #34, #35, & #37	CREUSOT-LOIRE	--	--	--
<u>B1.13 CLOSURE HEAD CLADDING</u> HEAD CLADDING HCP-5, HCP-6	CREUSOT-LOIRE	--	--	--
<u>B3.10 PRESSURE RETAINING BOLTING</u> S/G NO 21 MANWAY BOLTS INLET 1 THRU 16	WESTINGHOUSE	1181	--	68-39
S/G NO 21 OUTLET 1 THRU 16	WESTINGHOUSE	1181	--	68-39

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
S/G NO 22 MANWAY BOLTS INLET 1 THRU 16	WESTINGHOUSE	1182	--	68-40
S/G NO 22 MANWAY BOLTS OUTLET 1 THRU 16	WESTINGHOUSE	1182	--	68-40
<u>STEAM GENERATOR TUBING</u>				
<u>B4.0 PIPING PRESSURE BOUNDARY</u>				
<u>B4.5 CIRCUMFERENTIAL AND LONGITUDINAL WELDS</u>				
SEAL INJECTION LOOP B W-4	NAVCO	--	--	--
RTD RETURN LOOP A W-3	NAVCO	--	--	--
<u>B4.8 SOCKET WELDS</u>				
RTD COLD LEG LOOP B W-14	NAVCO	--	--	--
<u>B5.0 REACTOR CORE COOLANT PUMPS</u>				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B5.2 PRESSURE RETAINING BOLTING, WHEN REMOVED</u>				
PUMP NO 21 SEAL HOUSE BOLTS 1 THRU 12	WESTINGHOUSE	W510	--	--
PUMP NO 22 SEAL HOUSE BOLTS 1 THRU 12	WESTINGHOUSE	W515	--	--
<u>B6.7 VALVE BODIES</u>				
ACCUMULATOR DISCHARGE LOOP A 2-8841A	NAVCO	--	--	--
<u>B6.9 PRESSURE RETAINING BOLTING</u>				
ACCUMULATOR DISCHARGE LOOP B 2-8840B				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: 1I 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

ASME CLASS IIPRESSURE VESSELS - ACCUMULATORC1.1 CIRCUMFERENTIAL BUTT WELDS

ACCUMULATOR NO 21 W-6	DELTA SOUTHERN	41037-69-1	--	2575
-----------------------------	----------------	------------	----	------

PRESSURE VESSELS - STEAM GENERATORSC1.2 NOZZLE TO VESSEL WELD

STEAM GENERATOR NO 22 N-4	WESTINGHOUSE	1182	--	68-40
---------------------------------	--------------	------	----	-------

C2.0 PIPINGC2.1 CIRCUMFERENTIAL BUTT WELDS

FEEDWATER A FW-177	NAVCO	--	--	--
-----------------------	-------	----	----	----

FEEDWATER B FW-133	NAVCO	--	--	--
-----------------------	-------	----	----	----

C2.2 LONGITUDINAL WELDS IN FITTINGS

RHR PUMP DISCHARGE LOOP B W-139 TO 140 TO 216	NAVCO	--	--	--
---	-------	----	----	----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C2.5 INTEGRALLY WELDED SUPPORTS</u>				
RHR PUMP DISCHARGE B, RHRH-61 M, RHRH-36 H, RHRH-43 J, RHRH-46 J, RHRH-24	NAVCO	--	--	--
<u>C2.6 SUPPORT COMPONENT</u>				
ACCUMULATOR DISCHARGE LOOP B C, RHRRH-21				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>SEISMIC BOLTING</u>				
<u>STEAM GENERATOR NUMBER 21</u>	WESTINGHOUSE	1181	--	68-39
<u>SNUBBER BOLTS BOTTOM ROW 5 BOLTS</u>	--	--	--	--
<u>COLUMN PINS TOP COL 1 BOT COL 3 & 4 3 PINS</u>	--	--	--	--
<u>STEAM GENERATOR NUMBER 22</u>	WESTINGHOUSE	1182	--	68-40
<u>SNUBBER BOLTS BOTTOM ROW 5 BOLTS</u>	--	--	--	--
<u>COLUMN PINS COL 3 & 4 4 PINS</u>	--	--	--	--
<u>REACTOR CORE COOLANT PUMP NUMBER 21</u>	WESTINGHOUSE	W150	--	--
<u>COLUMN PINS COLUMN 3 2 PINS</u>	--	--	--	--

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: PRAIRIE ISLAND NUCLEAR GENERATING PLANT
 Address: WELCH, MINNESOTA
- 3.) Plant Unit: II 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 12-21-74 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>RCP #21 CONT'D</u>				
BASE ANCHOR BOLTS COLUMN 3 8 BOLTS	--	--	--	--
COLUMN CONNECTING BOLTS COLUMN 3 4 BOLTS	--	--	--	--
TIE BACK PIN PAD 3 1 PIN	--	--	--	--
REACTOR CORE COOLANT PUMP NUMBER 22	WESTINGHOUSE	W515	--	--
COLUMN PINS COLUMN 3 2 PINS	--	--	--	--
BASE ANCHOR BOLTS COLUMN 3 8 BOLTS	--	--	--	--
TIE BACK PIN PAD 3 1 PIN	--	--	--	--

FORM NIS-1 (back)

8.) Examination Dates 9-5-84 to 10-2-84 9.) Inspection Interval 12-21-74 to 12-21-84

10.) Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval.

This was the second inservice inspection conducted for inspection period three. The examinations completed approximately 80% of the required pressure retaining components and their supports of the reactor coolant and associated auxillary systems classified as ASME Class 1 and Class 2; 100% of the FSAR Augmented examinations of main steam and feedwater systems transversing the Auxillary Building; and 80% of the Seismic Bolting Program. Eddy Current examinations requirements for steam generator tubes were also completed during this outage in accordance with Prairie Island Technical Specification, Section T.S.4.12.

11.) Abstract of Conditions Noted.

Other than steam generator (S.G.) tubes, there were no signs of degradation to systems scheduled for examinations.

The Eddy Current inspection revealed 66 and 21 new tubes for S.G. No. 21 and No. 22, respectively, which exhibited wall thinning. There were a total of five and 15 tubes for S.G. No. 21 and No. 22, respectively, that required corrective action.

The following is a list of all anomalies detected:

<u>System</u>	<u>Item ID</u>	<u>Exam Method</u>	<u>Type and Number of Indications</u>
Feedwater A	FW-177	MT	3 Linears
Feedwater B	FW-133	MT	3 Linears
Reactor Coolant Pump - Seal House Bolts	Bolt 1	MT	3/4" Linear
Reactor Vessel Conoseal Bolts	Marmon Clamp 37	VT	1 Bolt & 2 Nuts Eroded
Residual Heat Removal	Hanger M	PT	Porosity
	Hanger H	VT	Drawing Compliance
	Hanger B	PT	Porosity
	Hanger H	PT	Undercut
	Hanger J	PT	Porosity
Seismic Bolting S/G #21	Snubber Wall Bolt	VT	Washer Not Fully Contacted by Nut

c.) Abstract of Corrective Measures Recommended and Taken.

All degraded S.G. tubes with wall thinning of 45% at the tube support plates and 38% in the tube sheet were mechanically plugged; a total of 5 for S.G. No. 21 and 15 for S.G. No. 22.

All anomalies were corrected. The linear MT indications and PT undercut were removed by light hand blending and blending the surface smooth.

The reactor vessel conoseal bolt and nuts and the reactor coolant pump seal house bolt were replaced with new bolts and nuts.

The snubber wall bolt was corrected by machining the washer to enable full contact between the nut and washer; straightening of the bolt was not performed due to the possibility of bolt deterioration.

The hangers with porosity were either found code acceptable or were analyzed for design load and found acceptable. The drawing compliance was determined, through magnification of the drawing, to be acceptable as noted.

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date 1-3 19 85 Signed Northern States Power Company By Lay D. Dawson
Owner

Certificate of Authorization No. (if applicable) NA Expiration Date NA

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MINN and employed by HARTFORD STEAM BOILER of HARTFORD CONN have inspected the components described in this Owner's Data Report during the period 9/5/84 to 10/2/84, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 1/3 19 85

Jain P. Burson
 Inspector's Signature

Commissions MINN 238 NR 8828
 National Board, State, Province & No