



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DETROIT EDISON COMPANY

FERMI-2

DOCKET NO. 50-341

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 84  
License No. NPF-43

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Detroit Edison Company (the licensee) dated January 28, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-43 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 84, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. DECo shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance with full implementation within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Ledyard B. Marsh, Director  
Project Directorate III-1  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 25, 1992

## PLANT SYSTEMS

### 3/4.7.5 SNUBBERS

#### LIMITING CONDITION FOR OPERATION

---

3.7.5 All\* hydraulic and mechanical snubbers shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3. OPERATIONAL CONDITIONS 4 and 5 for snubbers located on systems required OPERABLE in those OPERATIONAL CONDITIONS.

#### ACTION:

With one or more snubbers inoperable on any system, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.5g on the attached component or declare the attached system inoperable and follow the appropriate ACTION statement for that system.

#### SURVEILLANCE REQUIREMENTS

---

4.7.5 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program in addition to the requirements of Specification 4.0.5.

a. Inspection Types

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

b. Visual Inspections

Snubbers are categorized as inaccessible or accessible during reactor operation. Each of these categories (inaccessible and accessible) may be inspected independently according to the schedule determined by Table 4.7.5-1. The visual inspection interval for each category of snubber shall be determined based upon the criteria provided in Table 4.7.5-1. The first inspection interval determined using this criteria shall be based upon the previous inspection interval as established by the requirements in effect before Amendment 84.

---

\*As described in the bases.