

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

January 25, 1985

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

SUBJECT: Limerick Generating Station, Units 1 and 2
HPCI/RCIC Turbine Taper Pin Installation

REFERENCE: Letter from J. S. Kemper to A. Schwencer
dated September 10, 1984

FILE: GOVT 1-1 (NRC)

Dear Mr. Schwencer:


The reference letter provided information for the Equipment Qualification Branch/Seismic Qualification Review Team regarding the threaded taper pins used in the HPCI and RCIC turbine assemblies. The reference letter committed to installing the taper pins before the RP steam dome pressure exceeded 150 psig.

NUREG-0991, Supplement 3, Limerick SER, accepted our justification and commitment for deferred installation of the taper pins and stated that the installation of the taper pins must be confirmed in writing.

In accordance with our commitment, and NUREG-0991 Supplement 3, pages 3-7 and 3-9, the threaded taper pins for the HPCI and RCIC turbines have been installed.

Should you require additional information, please do not hesitate to contact us.

Sincerely,



RDC/dg/01148506

Copy to: (See Attached Service List)

8501310371 850125
PDR ADOCK 05000352
E PDR

A048
/10

cc: Judge Helen F. Hoyt
Judge Jerry Harbour
Judge Richard F. Cole
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Ms. Phyllis Zitzer
Charles W. Elliot, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency Management Agency
Angus R. Love, Esq.
David Wersan, Esq.
Robert J. Sugarman, Esq.
Martha W. Bush, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing Appeal Board
Atomic Safety & Licensing Board Panel
Docket & Service Section
Mr. James Wiggins
Mr. Timothy R. S. Campbell