

NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT NUCLEAR STATION UNIT #1  
NARRATIVE OF OPERATING EXPERIENCE

The station operated during the month of December 1984 with a Unit Availability Factor of 91.1% and a Net Design Electrical Capacity Factor of 87.7%. There were 0 challenges to Electromatic Relief Valves. Reductions in Capacity Factor were due to #12 Backup Scram Solenoid Valve failure and Control Rod Pattern Exchange.

CLASS I WORK - MECHANICAL MAINTENANCE - DECEMBER 1984

WR# 26050	Rebuild CRD 42-35, S/N#6810
WR# 26047	Rebuild CRD 14-35, S/N#6874
WR# 26044	Rebuild CRD 14-39, S/N#71617
WR# 26049	Rebuild CRD 22-47, S/N#71417
WR# 24589	Rebuild CRD 22-35, S/N#71463
WR# 26042	Scrapped CRD 10-31, S/N#71529
WR# 26040	Scrapped CRD 26-27, S/N#71430
WR# 24587	Rebuild CRD 10-35, S/N#71659
WR# 21225	Rebuild CRD S/N#71551
WR# 29991	Repair CRD HCU 10-35, Leaky foot valve
WR# 30258	Repair Scram Outlet Valve HCV 18-07
WR# 30254	Repair Scram Outlet Valve HCV 26-51
WR# 30260	Repair Scram Outlet Valve HCV 26-31
WR# 30256	Repair Scram Outlet Valve HCV 26-03
WR# 30255	Repair Scram Outlet Valve HCV 30-11
WR# 30259	Repair Scram Outlet Valve HCV 26-11
WR# 28579	Repair Oil Leak on Coupling to 12 Feedwater Pump
WR# 26272	Repaired Hydraulic Snubber 51-HS-12
WR# 26273	Installed pipe hanger on 44-H-101

CLASS I WORK - ELECTRICAL MAINTENANCE - DECEMBER 1984

MO 1927

This major order involves updating station equipment for Equipment Qualification. The work performed includes wiring position limit switches, wiring solenoid valves and a transmitter and taping motor leads. In addition, condulets were sealed with Bisco Seal for temperature elements in the Emergency Condensate Makeup System. The systems involved are Post Accident Sampling, Reactor Building Cooling Water, Reactor Containment Air Purge and Fill and Reactor Containment N<sub>2</sub> Purge and Fill.

8501310485 841231  
PDR ADOCK 05000220  
R PDR


FE 24  
||

CLASS I WORK - INSTRUMENTATION & CONTROL - DECEMBER 1984

WR# 30026 CRD-43 Backup Scram Solenoid NC16B is leaking air  
off the air header.  
(installed new SOV at CRD-44) CRD 43 was found  
working properly.

OPERATING DATA REPORT

DOCKET NO 50-220  
 DATE 1/7/85  
 COMPLETED BY T. W. Roman  
 TELEPHONE (315) 349-2422



OPERATING STATUS

1. Unit Name: Nine Mile Point Unit #1
2. Reporting Period: December 1984 12/1/84 - 12/31/84
3. Licensed Thermal Power (MWt): 1850
4. Nameplate Rating (Gross MWe): 640
5. Design Electrical Rating (Net MWe): 630
6. Maximum Dependable Capacity (Gross MWe): 620
7. Maximum Dependable Capacity (Net MWe): 610
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

- 
- 
9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
  10. Reasons For Restrictions, If Any: \_\_\_\_\_
- 
- 

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>8785</u>	<u>134,065.2</u>
12. Number Of Hours Reactor Was Critical	<u>692</u>	<u>6414.2</u>	<u>92715.7</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1204.2</u>
14. Hours Generator On-Line	<u>678</u>	<u>6317.0</u>	<u>89805.3</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>20.4</u>
16. Gross Thermal Energy Generated (MWH)	<u>1224598.0</u>	<u>11195010.0</u>	<u>149289450.0</u>
17. Gross Electrical Energy Generated (MWH)	<u>416991.0</u>	<u>3749007.0</u>	<u>49380788.0</u>
18. Net Electrical Energy Generated (MWH)	<u>404597.0</u>	<u>3635235.0</u>	<u>47829994.0</u>
19. Unit Service Factor	<u>91.1</u>	<u>71.9</u>	<u>67.0</u>
20. Unit Availability Factor	<u>91.1</u>	<u>71.9</u>	<u>67.0</u>
21. Unit Capacity Factor (Using MDC Net)	<u>89.1</u>	<u>67.8</u>	<u>58.5</u>
22. Unit Capacity Factor (Using DER Net)	<u>87.7</u>	<u>66.7</u>	<u>57.5</u>
23. Unit Forced Outage Rate	<u>8.9</u>	<u>1.8</u>	<u>16.4</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each)			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: \_\_\_\_\_

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-220

UNIT 9 Mile Pt. #1

DATE 1/7/85

COMPLETED BY T.W. Roman *TR*

TELEPHONE (315) 349-2422

MONTH December 1984

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	612
2	611
3	613
4	611
5	613
6	612
7	601
8	562
9	613
10	611
11	613
12	611
13	612
14	613
15	613
16	351

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	0
18	0
19	219
20	498
21	591
22	604
23	578
24	612
25	612
26	610
27	610
28	612
29	613
30	614
31	612

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH December 1984

DOCKET NO. 50-220  
 UNIT NAME 9 Mile Pt. #1  
 DATE 1/7/85  
 COMPLETED BY TW Roman  
 TELEPHONE (315) 349-2422

*Jan*

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
84-17	12/8/84	S	7	H					Load reduction to 71% CTP for Control Rod Pattern Adjustment.
84-18	12/16/84	F	99.5	A	1				Failure of #12 Backup Scram Solenoid Valve during surveillance testing, replaced #12 Backup Scram Solenoid Valve.*
84-19	12/20/84	S	9.5	H					Load reduction to 69% CTP for Control Rod Pattern Adjustment.
84-20	12/23/84	S	13	H					Load reduction to 85% CTP for Control Rod Pattern Adjustment.

1  
 F: Forced  
 S: Scheduled

2  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance of Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

4  
 Exhibit C - Instructions for Preparation of Data Entry Sheet for Licensee Event Report (LER) File (NUREG-0161)

5  
 Exhibit I - Same Source



*Designated Original*  
*TC*

NMP-10287

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD WEST  
SYRACUSE, N. Y. 13202

January 10, 1985

Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Attn: Document and Control Desk

Re: Docket No. 50-220  
DPR-63

Dear Sir:

Submitted herewith is the Report of Operating Statistics  
and Shutdown for December 1984 for the Nine Mile Point Nuclear  
Station Unit #1.

Also included is a narrative report of Operating Experience  
for December 1984.

Very truly yours,

*Thomas E. Lempges*

Thomas E. Lempges  
Vice President  
Nuclear Generation

TEL/lo  
attachments  
cc: Director, Office of I&E (10 copies)

*IE24*  
*1/1*