

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P A B V S L | 2 0 0 - 0 0 0 0 0 - 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 9 14 15 25 26 37 CAT 58

CON'T
0 1 | REPORT SOURCE | L 6 | 0 5 0 0 0 3 3 4 | 7 0 6 2 1 7 9 | 8 0 7 0 6 7 9 | 9
7 8 9 14 15 26 27 38 39 40 41 42 43 44 45 46 47 48 49 50

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | The NSSS vendor has notified BVPS that a high energy line break inside containment
0 3 | could result in a potential steam generator level bias due to the heatup of the
0 4 | steam generator level measurement reference leg. This potential level bias could
0 5 | result in delayed protection signals (reactor trip and auxiliary feedwater
0 6 | initiation) which are based on low-low steam generator water level.
0 7 |
0 8 |
0 9 |

0 9 | SYSTEM CODE | I A | 11 | CAUSE CODE | B | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | Z Z Z Z Z Z | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 | LER/RO REPORT NUMBER | 7 9 | 21 | EVENT YEAR | 7 9 | 22 | SEQUENTIAL REPORT NO. | 0 1 5 | 24 | OCCURRENCE CODE | / | 27 | REPORT TYPE | T | 30 | REVISION NO. | 0 | 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
33 | ACTION TAKEN | X | 18 | 34 | FUTURE ACTION | Z | 19 | 35 | EFFECT ON PLANT | Z | 20 | 36 | SHUT-DOWN METHOD | Z | 21 | 37 | HOURS | 0 0 0 0 | 22 | 38 | ATTACHMENT SUBMITTED | Y | 23 | 39 | NRC-4 FORM SUB. | N | 24 | 40 | PRIME COMP. SUPPLIER | Z | 25 | 41 | COMPONENT MANUFACTURER | Z 9 9 9 | 26 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | An investigation is being conducted to determine what adverse condition would exist
1 1 | for cases which rely on low-low steam generator level as being the primary actuating
1 2 | signal. When the investigation is complete, the steam generator water level
1 3 | setpoints will be corrected to account for any possible bias. If the problem is not
1 4 | resolved prior to plant startup, administrative controls (continued on attached)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 5 | FACILITY STATUS | G | 28 | 9 | % POWER | 0 0 0 | 29 | 10 | OTHER STATUS | N/A | 30 | 11 | METHOD OF DISCOVERY | D | 31 | 12 | DISCOVERY DESCRIPTION | Vendor notification | 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | 9 | AMOUNT OF ACTIVITY | N/A | 35 | 10 | LOCATION OF RELEASE | N/A | 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 7 | PERSONNEL EXPOSURES NUMBER | 0 0 0 | 37 | 9 | TYPE | Z | 38 | 10 | DESCRIPTION | N/A | 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 4 | PERSONNEL INJURIES NUMBER | 0 0 0 | 40 | 9 | DESCRIPTION | N/A | 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 7 | LOSS OF OR DAMAGE TO FACILITY TYPE | 2 | 42 | 9 | DESCRIPTION | N/A | 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
2 7 | PUBLICITY ISSUED DESCRIPTION | N | 44 | 9 | DESCRIPTION | N/A | 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

7907110447

ROOM 6710797
NRC USE ONLY

478

NAME OF PREPARER J. A. Werling PHONE 412-643-1258

Attachment To LER 79-15/01T
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

Cause Description And Corrective Actions (continued)

will be invoked to prevent operation in a nonconservative manner.

The NSSS vendor has notified BVPS that a high energy line break inside containment could result in a potential steam generator level bias due to the heatup of the steam generator level measurement reference leg. This potential level bias could result in delayed protection signals (reactor trip and auxiliary feedwater initiation) which are based on low-low steam generator water level. The high energy line break in containment will result in an increased reference leg water column temperature which in turn results in a decrease of water column density with a consequent apparent increase in the indicated steam generator water level (i.e., apparent level exceeding actual level). In the case of a feedline rupture, this adverse environment could be present and could delay or prevent the primary signal arising from declining steam generator water level (low-low steam generator level). Back-up signals which may be available include the following: overtemperature delta T, high pressurizer pressure, containment pressure, and safety injection. For other high energy line breaks which could introduce a similar positive bias to the steam generator water level measurement, steam generator level does not provide the primary trip function and the potential bias would not interfere with needed protective system actuation. By way of example, a containment temperature of 180F could result in a 3% bias in steam generator level. Referring to the attached figures (Figure 14.3-57 and Figure 14.3-58 from the BVPS FSAR for a Hot Leg DER) a containment pressure in excess of 1.5 psig (which in turn actuates safety injection, auxiliary feedwater and reactor trip) occurs prior to the containment atmosphere being heated up to 180F. Thus, the possibility of a greater bias of the steam generator level signal above 180F for this particular case is not relevant to protection system actuation. In correcting the steam generator water level setpoint for this bias, the reference leg bias is additive to the existing setpoint.

An investigation is being conducted to determine what adverse conditions would exist for cases which rely on low-low steam generator level as being the primary actuating signal. When the investigation is complete, the steam generator water level setpoints will be corrected to account for any possible bias. If the problem is not resolved prior to plant startup, administrative controls will be invoked to prevent operation in a nonconservative manner.

6/7/74




FIG. 14.3-57
 CONTAINMENT PRESSURE FOR 1 DAY FOLLOWING
 ACCIDENT—HOT LEG DER—MINIMUM SAFEGUARDS
 BEAVER VALLEY POWER STATION
 FINAL SAFETY ANALYSIS REPORT

POOR ORIGINAL

478

199




FIG. 14.3-58
TEMPERATURES FOR 1 DAY FOLLOWING
ACCIDENT-HOT LEG DER - MINIMUM SAFEGUARDS
BEAVER VALLEY POWER STATION
FINAL SAFETY ANALYSIS REPORT

FOR ORIGINAL

428 200