



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

June 19, 1996

Mr. William T. Cottle  
Executive Vice-President &  
General Manager, Nuclear  
Houston Lighting & Power Company  
South Texas Project Electric  
Generating Station  
P. O. Box 289  
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT - REVISIONS TO TECHNICAL SPECIFICATION BASES  
(TAC NOS. M94134 AND M94135)

Dear Mr. Cottle:

In your letter dated November 13, 1995, you notified the staff of changes to the South Texas Project (STP) Technical Specification (TS) Bases for TS Bases 3/4.2.5, DNB Parameters, 3/4.4.9, Pressure Temperature Limits, and 3/4.7.1.3, Auxiliary Feedwater Storage Tank (AFST).

The Commission has incorporated the revision of the DNB parameter for pressurizer pressure from 2198 psig to 2189 psig. The value of 2189 psig is the value used in the accident analyses. The 2198 psig value was a typographical error submitted by STP in a letter dated May 27, 1993, which resulted in TS Amendment Nos. 61 and 50. The NRC staff has reviewed the changes to the facility and concur that the Bases to TS 3/4.2.5 should be changed to correct the typographical error. The revisions to the Bases of TS 3/4.2.5 are acceptable to the staff.

The Commission has incorporated the revision to TS Bases Section 3/4.4.9 to delete reactor vessel material data that are duplicated in the STP Updated Final Safety Analysis Report, add the reference to Regulatory Guide 1.99 which is used to calculate changes in the nil-ductility reference temperature (RT<sub>NDT</sub>) for reactor vessel materials, and delete old information on fast neutron fluence as a function of full power service life used for initial predictions of an adjusted RT<sub>NDT</sub>. The staff has reviewed the changes to the facility and concur that the Bases to TS 3/4.4.9 should be changed and that those changes are acceptable.

The Commission has incorporated the revision to TS Bases Section 3/4.7.1.3 to change the description of the limiting design bases accident from a main feedline break to an automatic recirculation control valve failure when determining the minimum water volume for OPERABILITY of the Auxiliary

DFCI 1/1

9606270054 960619  
PDR ADOCK 05000498  
P PDR

NRC FILE CENTER COPY

Mr. William T. Cottle

-2-

Feedwater Storage Tank. The staff has reviewed the changes to the facility and concur that the Bases to TS 3/4.7.1.3 should be changed. Therefore, the revisions to the Bases of TS 3/4.7.1.3 are acceptable.

Enclosed are revised TS Bases pages D 3/4 2-6, B 3/4 4-7, B 3/4 4-8, B 3/4 4-9, B 3/4 4-10, B 3/4 4-11, and B 3/4 7-2. The revised pages contain marginal lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

Sincerely,



Thomas W. Alexion, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures: TS Bases pages B 3/4 2-6, B 3/4 4-7,  
B 3/4 4-8, B 3/4 4-9, B 3/4 4-10,  
B 3/4 4-11, and B 3/4 7-2

cc w/encls: See next page

Mr. William T. Cottle

-2-

June 19, 1996

Feedwater Storage Tank. The staff has reviewed the changes to the facility and concur that the Bases to TS 3/4.7.1.3 should be changed. Therefore, the revisions to the Bases of TS 3/4.7.1.3 are acceptable.

Enclosed are revised TS Bases pages B 3/4 2-6, B 3/4 4-7, B 3/4 4-8, B 3/4 4-9, B 3/4 4-10, B 3/4 4-11, and B 3/4 7-2. The revised pages contain marginal lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

Sincerely,

Original signed by George Kalman for  
Thomas W. Alexion, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures: TS Bases pages B 3/4 2-6, B 3/4 4-7,  
B 3/4 4-8, B 3/4 4-9, B 3/4 4-10,  
B 3/4 4-11, and B 3/4 7-2

cc w/encls: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f	TMarsh
JRoe	EAdensam (EGA1)	WBeckner	GHill (4)
PNoonan	TAlexion	OGC	CGrimes
ACRS	JDyer, RIV	JKennedy	RJones

Document Name: STP91434.LTR

\*SEE PREVIOUS CONCURRENCE

OFC	LA/PD4-1	PM/PD4-1	PM/PD4-1	BC/EMCB	*BC/SRXB	*BC/SPLB
NAME	PNoonan	JKennedy	TAlexion	JStrosnider	RJones	TMarsh
DATE	6/16/96	6/16/96	6/19/96	6/14/96	05/06/96	06/03/96
COPY	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY #1 *George Kalman*

Mr. William T. Cottle  
Houston Lighting & Power Company

South Texas, Units 1 & 2

cc:

Mr. David P. Loveless  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77414

Jack R. Newman, Esq.  
Morgan, Lewis & Bockius  
1800 M Street, N.W.  
Washington, DC 20036-5869

Mr. J. C. Lanier/M. B. Lee  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, TX 78704

Mr. Lawrence E. Martin  
General Manager, Nuclear Assurance Licensing  
Houston Lighting and Power Company  
P. O. Box 289  
Wadsworth, TX 77483

Mr. M. T. Hardt  
Mr. W. C. Gunst  
Central Public Service Board  
P. O. Box 1771  
San Antonio, TX 78296

Rufus S. Scott  
Associate General Counsel  
Houston Lighting and Power Company  
P. O. Box 61867  
Houston, TX 77208

Mr. G. E. Vaughn/C. A. Johnson  
Central Power and Light Company  
P. O. Box 289  
Mail Code: N5012  
Wadsworth, TX 74483

Joseph R. Egan, Esq.  
Egan & Associates, P.C.  
2300 N Street, N.W.  
Washington, DC 20037

INPO  
Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-3064

Office of the Governor  
ATTN: Andy Barrett, Director  
Environmental Policy  
P. O. Box 12428  
Austin, TX 78711

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Arthur C. Tate, Director  
Division of Compliance & Inspection  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756

Mr. Joseph M. Hendrie  
50 Bellport Lane  
Bellport, NY 11713

J. W. Beck  
Little Harbor Consultants, Inc.  
44 Nichols Road  
Cohasset, MA 02025-1166

Judge, Matagorda County  
Matagorda County Courthouse  
1700 Seventh Street  
Bay City, TX 77414

## POWER DISTRIBUTION LIMITS

### BASES

#### HEAT FLUX HOT CHANNEL FACTOR and NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR (Continued)

When an  $F_Q$  measurement is taken, an allowance for both experimental error and manufacturing tolerance must be made. An allowance of 5% is appropriate for a full-core map taken with the Incore Detector Flux Mapping System, and a 3% allowance is appropriate for manufacturing tolerance.

The Radial Peaking Factor,  $F_{xy}(Z)$ , is measured periodically to provide assurance that the Hot Channel Factor,  $F_Q(Z)$ , remains within its limit. The  $F_{xy}$  limit for RATED THERMAL POWER ( $F_{xy}^{RTPQ}$ ) as provided in the Core Operating Limits Report (COLR) per Specification 6.9.1.6 was determined from expected power control maneuvers over the full range of burnup conditions in the core.

#### 3/4.2.4 QUADRANT POWER TILT RATIO

The QUADRANT POWER TILT RATIO limit assures that the radial power distribution satisfies the design values used in the power capability analysis. Radial power distribution measurements are made during STARTUP testing and periodically during power operation.

The limit of 1.02, at which corrective action is required, provides DNB and linear heat generation rate protection with x-y plane power tilts. A limit of 1.02 was selected to provide an allowance for the uncertainty associated with the indicated power tilt.

The 2-hour time allowance for operation with a tilt condition greater than 1.02 is provided to allow identification and correction of a dropped or misaligned control rod. In the event such action does not correct the tilt, the margin for uncertainty on  $F_Q$  is reinstated by reducing the maximum allowed power by 3% for each percent of tilt in excess of 1.

For purposes of monitoring QUADRANT POWER TILT RATIO when one excore detector is inoperable, the moveable incore detectors are used to confirm that the normalized symmetric power distribution is consistent with the QUADRANT POWER TILT RATIO. The incore detector monitoring is done with a full incore flux map or two sets of four symmetric thimbles. The two sets of four symmetric thimbles is a unique set of eight detector locations. These locations are C-8, E-5, E-11, H-3, H-13, L-5, L-11, N-8.

#### 3/4.2.5 DNB PARAMETERS

The limits on the DNB-related parameters assure that each of the parameters are maintained within the normal steady-state envelope of operation assumed in the transient and accident analyses. The limits are consistent with the

## POWER DISTRIBUTION LIMITS

### BASES

---

#### 3/4.2.5 DNB PARAMETERS (Continued)

initial FSAR assumptions and have been analytically demonstrated adequate to maintain a minimum DNBR of greater than or equal to the design limit throughout each analyzed transient. The  $T_{avg}$  value of 598°F and the pressurizer pressure value of 2189 psig are analytical values. The readings from four channels will be averaged and then adjusted to account for measurement uncertainties before comparing with the required limit. The flow requirement (392,300 gpm) includes a measurement uncertainty of 2.8%.

The 12-hour periodic surveillance of these parameters through instrument readout is sufficient to ensure that the parameters are restored within their limits following load changes and other expected transient operation.

## REACTOR COOLANT SYSTEM

### BASES

---

#### PRESSURE TEMPERATURE LIMITS (Continued)

- a. Allowable combinations of pressure and temperature for specific temperature changes rates are below and to the right of the limit lines shown. Limit lines for cooldown rates between those presented may be obtained by interpolation; and
  - b. Figures 3.4-2 and 3.4-3 define limits to assure prevention of non-ductile failure only. For normal operation, other inherent plant characteristics, e.g., pump heat addition and pressurizer heater capacity, may limit the heatup and cooldown rates that can be achieved over certain pressure-temperature ranges.
2. These limit lines shall be calculated periodically using methods provided below,
  3. The secondary side of the steam generator must not be pressurized above 200 psig if the temperature of the steam generator is below 70°F,
  4. The pressurizer heatup and cooldown rates shall not exceed 100°F/h and 200°F/h, respectively. The spray shall not be used if the temperature difference between the pressurizer and the spray fluid is greater than 621°F, and
  5. System preservice hydrotests and inservice leak and hydrotests shall be performed at pressures in accordance with the requirements of ASME Boiler and Pressure Vessel Code, Section XI.

The fracture toughness properties of the ferritic materials in the reactor vessel are determined in accordance with the NRC Standard Review Plan, ASTM E185-73, and in accordance with additional reactor vessel requirements. These properties are then evaluated in accordance with Appendix G of the 1976 Summer Addenda to Section III of the ASME Boiler and Pressure Vessel Code and the calculation methods described in WCAP-7924-A, "Basis for Heatup and Cooldown Limit Curves," April 1975.

Heatup and cooldown limit curves are calculated using the most limiting value of the nil-ductility reference temperature,  $RT_{NDT}$ , at the end of 32 effective full power years (EFPY) of service life. The 32 EFPY service life period is chosen such that the limiting  $RT_{NDT}$  at the 1/4T location in the core region is greater than the  $RT_{NDT}$  of the limiting unirradiated material. The selection of such a limiting  $RT_{NDT}$  assures that all components in the Reactor Coolant System will be operated conservatively in accordance with applicable Code requirements.

The reactor vessel materials have been tested to determine their initial  $RT_{NDT}$ . Reactor operation and resultant fast neutron (E greater than 1 MeV)

## REACTOR COOLANT SYSTEM

### BASES

#### PRESSURE/TEMPERATURE LIMITS (Continued)

irradiation can cause an increase in the  $RT_{NDT}$ . Therefore,  $\Delta RT_{NDT}$  and an adjusted reference temperature, based upon the fluence, copper content, and nickel content of the materials in question were computed using the method described in Regulatory Guide 1.99, Revision 1, "Effects of Residual Elements on Predicted Radiation Damage to Reactor Vessel Materials." The heatup and cooldown limit curves of Figures 3.4-2 and 3.4-3 include predicted adjustments for this shift in  $RT_{NDT}$  at the end of 32 EFPY as well as adjustments for possible errors in the pressure and temperature sensing instruments.

Values of  $\Delta RT_{NDT}$  determined in this manner may be used until the results from the material surveillance program, evaluated according to ASTM E185, are available. Capsules will be removed in accordance with the requirements of ASTM E185-73 and 10 CFR Part 50, Appendix H and new values of  $\Delta RT_{NDT}$  will be computed using the method described in Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials." The results obtained from the surveillance specimens can be used to predict future radiation damage to the reactor vessel material by using the lead factor and the withdrawal time of the capsule. The heatup and cooldown curves must be recalculated when the  $\Delta RT_{NDT}$  determined from the surveillance capsule exceeds the calculated  $\Delta RT_{NDT}$  for the equivalent capsule radiation exposure.

Allowable pressure-temperature relationships for various heatup and cooldown rates are calculated using methods derived from Appendix G in Section III of the ASME Boiler and Pressure Vessel Code as required by Appendix G to 10 CFR Part 50, and these methods are discussed in detail in WCAP-7924-A.

The general method for calculating heatup and cooldown limit curves is based upon the principles of the linear elastic fracture mechanics (LEFM) technology. In the calculation procedures a semielliptical surface defect with a depth of one-quarter of the wall thickness,  $T$ , and a length of  $3/2T$  is assumed to exist at the inside of the vessel wall as well as at the outside of the vessel wall. The dimensions of this postulated crack, referred to in Appendix G of ASME Section III as the reference flaw, amply exceed the current capabilities of inservice inspection techniques. Therefore, the reactor operation limit curves developed for this reference crack are conservative and provide sufficient safety margins for protection against nonductile failure. To assure that the radiation embrittlement effects are accounted for in the calculation of the limit curves, the most limiting value of the nil-ductility reference temperature,  $RT_{NDT}$ , is used and this includes the radiation-induced shift,  $\Delta RT_{NDT}$ , corresponding to the end of the period for which heatup and cooldown curves are generated.

The ASME approach for calculating the allowable limit curves for various heatup and cooldown rates specifies that the total stress intensity factor,  $K_I$ , for the combined thermal and pressure stresses at any time during heatup or cooldown cannot be greater than the reference stress intensity factor,  $K_{IR}$ , for the metal temperature at that time.  $K_{IR}$  is obtained from the reference

TABLE B 3/4.4-1a  
(This table number not used)

TABLE B 3/4.4-1b  
(This table number not used)

SOUTH TEXAS - UNITS 1 & 2

B 3/4 4-10

Unit 1 - Amendment No. 4

Revised by letter dated: June 19, 1996

FIGURE B 3/4.4-1  
(This figure number not used)

## REACTOR COOLANT SYSTEM

### BASES

#### PRESSURE/TEMPERATURE LIMITS (Continued)

fracture toughness curve, defined in Appendix G to the ASME Code. The  $K_{IR}$  curve is given by the equation:

$$K_{IR} = 26.78 + 1.223 \exp [0.0145(T - RT_{NDT} + 160)] \quad (1)$$

Where:  $K_{IR}$  is the reference stress intensity factor as a function of the metal temperature  $T$  and the metal nil-ductility reference temperature  $RT_{NDT}$ . Thus, the governing equation for the heatup-cooldown analysis is defined in Appendix G of the ASME Code as follows:

$$C K_{IM} + K_{It} \leq K_{IR} \quad (2)$$

Where:  $K_{IM}$  = the stress intensity factor caused by membrane (pressure) stress,

$K_{It}$  = the stress intensity factor caused by the thermal gradients,

$K_{IR}$  = constant provided by the Code as a function of temperature relative to the  $RT_{NDT}$  of the material,

$C = 2.0$  for level A and B service limits, and

$C = 1.5$  for inservice hydrostatic and leak test operations.

At any time during the heatup or cooldown transient,  $K_{IR}$  is determined by the metal temperature at the tip of the postulated flaw, the appropriate value for  $RT_{NDT}$ , and the reference fracture toughness curve. The thermal stresses resulting from temperature gradients through the vessel wall are calculated and then the corresponding thermal stress intensity factor,  $K_{IT}$ , for the reference flaw is computed. From Equation (2) the pressure stress intensity factors are obtained and, from these, the allowable pressures are calculated.

#### COOLDOWN

For the calculation of the allowable pressure versus coolant temperature during cooldown, the Code reference flaw is assumed to exist at the inside of the vessel wall. During cooldown, the controlling location of the flaw is always at the inside of the wall because the thermal gradients produce tensile stresses at the inside, which increase with increasing cooldown rates. Allowable pressure-temperature relations are generated for both steady-state and finite cooldown rate situations. From these relations, composite limit curves are constructed for each cooldown rate of interest.

The use of the composite curve in the cooldown analysis is necessary because control of the cooldown procedure is based on measurement of reactor coolant temperature, whereas the limiting pressure is actually dependent on the material temperature at the tip of the assumed flaw. During cooldown, the

### 3/4.7 PLANT SYSTEMS

#### BASES

#### 3/4.7.1 TURBINE CYCLE

#### 3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam line Code safety valves ensures that the Secondary System pressure will be limited to within 110% (1413.5 psig) of its design pressure of 1285 psig during the most severe anticipated system operational transient. The maximum relieving capacity is associated with a Turbine trip from 100% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink (i.e., no steam bypass to the condenser).

The specified valve lift settings and relieving capacities are in accordance with the requirements of Section III of the ASME Boiler and Pressure Code, 1971 Edition. The total relieving capacity for all valves on all of the steam lines is  $20.65 \times 10^6$  lbs/h which is 122% of the total secondary steam flow of  $16.94 \times 10^6$  lbs/h at 100% RATED THERMAL POWER. A minimum of two OPERABLE safety valves per steam generator ensures that sufficient relieving capacity is available for the allowable THERMAL POWER restriction in Table 3.7-1.

STARTUP and/or POWER OPERATION is allowable with safety valves inoperable within the limitations of the ACTION requirements on the basis of the reduction in Secondary Coolant System steam flow and THERMAL POWER required by the reduced Reactor trip settings of the Power Range Neutron Flux channels. The Reactor Trip Setpoint reductions are derived on the following bases:

$$Hi\phi = \frac{(100)}{Q} \frac{(w_s h_{fg} N)}{K}$$

Where:

- Hi  $\phi$  = Safety analysis power range high neutron flux setpoint, percent
- Q = Nominal NSSS power rating of the plant (including reactor coolant pump heat), Mwt
- K = Conversion Factor, 947.82 (BTU/sec)/Mwt
- $w_s$  = Minimum total steam flow rate capability of the operable MSSVs on any one steam generator at the highest MSSV opening pressure, including tolerance and accumulation, as appropriate, in lbm/sec. For example, if the maximum number of inoperable MSSVs on any one steam generator is one, then  $w_s$  should be a summation of the capacity of the operable MSSVs at the highest operable MSSV operating pressure, excluding the highest capacity MSSV. If the maximum number of inoperable MSSVs per steam generator is three, then  $w_s$  should be a summation of capacity of the operable MSSVs at the highest operable MSSV operating pressure, excluding the three highest capacity MSSVs.
- $h_{fg}$  = Heat of vaporization for steam at the highest MSSV operating pressure including allowances for tolerance, drift, and accumulation, as appropriate, Btu/lbm
- N = Number of loops in the plant.

The calculated values are lowered an additional 9% full power to account for instrument and channel uncertainties.

## PLANT SYSTEMS

### BASES

---

#### 3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the Auxiliary Feedwater System ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss-of-offsite power.

Each auxiliary feedwater pump is capable of delivering a total feedwater flow of 500 gpm at a pressure of 1363 psig to the entrance of the steam generators. This capacity is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F when the Residual Heat Removal System may be placed into operation. The AFW pumps are tested using the test line back to the AFST and the AFW isolation valves closed to prevent injection of cold water into the steam generators. The STPEGS isolation valves are active valves required to open on an AFW actuation signal. Specification 4.7.1.2.1 requires these valves to be verified in the correct position.

#### 3/4.7.1.3 AUXILIARY FEEDWATER STORAGE TANK (AFST)

The OPERABILITY of the auxiliary feedwater storage tank with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 4 hours with steam discharge to the atmosphere concurrent with total loss-of-offsite power and failure of the AFW automatic recirculation control (ARC) valve followed by a cooldown to 350°F at 25°F per hour. The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

#### 3/4.7.1.4 SPECIFIC ACTIVITY

The limitations on Secondary Coolant System specific activity ensure that the resultant offsite radiation dose will be limited to a small fraction of 10 CFR Part 100 dose guidelines values in the event of a steam line rupture. This dose also includes the effects of a coincident 1 gpm primary-to-secondary tube leak in the steam generator of the affected steam line. These values are consistent with the assumptions used in the safety analyses.

#### 3/4.7.1.5 MAIN STEAM LINE ISOLATION VALVES

The OPERABILITY of the main steam line isolation valves ensures that no more than one steam generator will blow down in the event of a steam line rupture. This restriction is required to: (1) minimize the positive reactivity effects of the Reactor Coolant System cooldown associated with the blowdown, and (2) limit the pressure rise within containment in the event the steam line rupture occurs within containment. The OPERABILITY of the main steam isolation valves within the closure times of the Surveillance Requirements are consistent with the assumptions used in the safety analyses.