

APR 03 1985

DMB-016

Docket No. 50-289

Mr. Henry D. Hukill, Vice President
and Director - TMI-1
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

DISTRIBUTION

Docket File

NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD

EJordan Gray File
BGrimes DBeckham
JPartlow RKarsch
ACRS-10 RAuluck
RIngram JStevens
OThompson JHopkins
JThoma NKadambi

Dear Mr. Hukill:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION FOLLOWING PRELIMINARY STAFF
REVIEW OF LICENSEE RESPONSES TO GENERIC LETTER 83-28

Re: Three Mile Island Nuclear Station, Unit

The staff has completed a preliminary review to assess the completeness and adequacy of licensee responses to Generic Letter 83-28 Items 2.1, 2.2, 3.1.3, 3.2.3, 4.4 and 4.5. For TMI-1, your responses were found to be incomplete for Items 2.1, 2.2, and 4.5.3. Brief descriptions of the deficiencies are given as guidelines for corrective action in the enclosed request for additional information. Efforts by Owners Groups, INPO and NSSS Vendors have been or are being made to product generic responses that may be useful in meeting the requirements of Generic Letter 83-28 Items 2.1, 2.2 and 4.5.3. You may wish to contact your Owner's Group or INPO regarding the applicability of such generic responses to TMI-1.

In order to preserve our present review schedule, the staff needs to have the supplementary information within 60 days for Items 2.1, 2.2, and within 90 days for Item 4.5.3. We request your cooperation in meeting this schedule.

This request for additional information was approved by the Office of Management and Budget under clearance number 3150-0011 which expires April 30, 1985. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management Room 3208, New Executive Office Building, Washington, D. C. 20503.

Sincerely,

*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
Request for Additional
Information

cc: w/enclosures:
See next page

ORB#4:DL
OThompson,cr
4/1/85

ORB#4:DL
JThoma
4/2/85

ORB#4:DL
JStolz
4/3/85

8504170341
PDR ADOCK
P
850403
05000289
PDR

Mr. R. J. Toole
O&M Director, TMI-1
GPU Nuclear Corporation
Middletown, Pennsylvania 17057

Board of Directors
P. A. N. E.
P. O. Box 268
Middletown, Pennsylvania 17057

Docketing and Service Section
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Chauncey Kepford
Judith H. Johnsrud
Environmental Coalition on Nuclear Power
433 Orlando Avenue
State College, Pennsylvania 16801

Judge Reginald L. Gotchy
Atomic Safety & Licensing Appeal Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Thomas E. Murley, Regional Administrator
U. S. N. R. C., Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ANGRY/TMI PIRC
1037 Maclay Street
Harrisburg, Pennsylvania 17103

John Levin, Esq.
Pennsylvania Public Utilities
Commission
Box 3265
Harrisburg, Pennsylvania 17120

Marvin I. Lewis
6504 Bradford Terrace
Philadelphia, Pennsylvania 19149

Jordan D. Cunningham, Esq.
Fox, Farr and Cunningham
2320 North 2nd Street
Harrisburg, Pennsylvania 17110

Ms. Louise Bradford
TMIA
1011 Green Street
Harrisburg, Pennsylvania 17102

Mrs. Marjorie M. Aamodt
Mr. Norman Aamodt
200 North Church Street
Parkesburg, Pennsylvania 19365

Earl B. Hoffman
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Streets
Harrisburg, Pennsylvania 17101

Ellyn R. Weiss
Harmon, Weiss & Jordan
2001 S. Street
Suite 430
Washington, DC 20009

Ivan W. Smith, Esq., Chairman
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Gary J. Edles, Chairman
Atomic Safety & Licensing Appeal
Board
U.S. Nuclear Regulatory Commission

General Counsel
Federal Emergency Management Agency
ATTN: Docket Clerk
1725 I Street, NW
Washington, DC 20472

Karin W. Carter, Esq.
505 Executive House
P. O. Box 2357
Harrisburg, Pennsylvania 17120

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Richard J. McGoey
Manager, PWR Licensing
GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Ad Crable
Lancaster New Era
8 West King Street
Lancaster, Pennsylvania 17602 .

Dr. David Hetrick
Professor of Nuclear Energy
University of Arizona
Tucson, Arizona 85721

Mr. David D. Maxwell, Chairman
Board of Supervisors
Londonderry Township
RFD#1 - Geyers Church Road
Middletown, Pennsylvania 17057

Regional Radiation Representative
EPA Region III
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. Richard Conte
Senior Resident Inspector (TMI-1)
U.S.N.R.C.
P. O. Box 311
Middletown, Pennsylvania 17057

Ms. Jane Perkins
City Government Center
10 North Market Square
Harrisburg, Pennsylvania 17101

Dr. James Lamb
313 Woodhaven Road
Chapel Hill, North Carolina 27514

Dauphin County Office Emergency
Preparedness
Court House, Room 7
Front & Market Streets
Harrisburg, Pennsylvania 17101

Christine N. Kohl, Esq.
Atomic Safety & Licensing Appeal
Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Gustave A. Linenberger, Jr.
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. C. W. Smyth
TMI-1 Licensing Manager
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Sheldon J. Wolfe, Esq., Chairman
Atomic Safety & Licensing Board
Washington, DC 20555

Jane Lee
183 Valley Road
Etters, Pennsylvania 17319

Bruce Molholt
Haverford College
Haverford, Pennsylvania 19041

Michael McBride, Esq.
LeBoeuf, Lamb, Leiby & McRae
Suite 1100
1333 New Hampshire Avenue, N.W.
Washington, DC 20036

Beverley Davis
200 Gettysburg Pike
Mechanicsburg, Pennsylvania 17055

James B. Hurst
617 Briarcliff Road
Middletown, Pennsylvania 17057

Donald E. Hossler
501 Vine Street
Middletown, Pennsylvania 17057

REQUEST FOR ADDITIONAL INFORMATION
RESPONSE TO GENERIC LETTER 83-28
FOR
THREE MILE ISLAND NUCLEAR STATION, UNIT 1

THREE MILE ISLAND, UNIT 1:

Item 2.1(1) - Response appears complete.

(2) - Response appears incomplete. Licensee needs to describe his program for periodically contacting vendors to ensure that all vendor technical information is being received, how maintenance information is developed for components whose vendors are no longer available, how maintenance and test procedures are revised to incorporate up-to-date vendor technical information, and how the performance of these procedures is controlled.

Item 2.2.1.1 - Response appears complete.

2.2.1.2 - Response appears complete.

2.2.1.3 - Response should indicate how the procedures in these documents are applied to safety-related components.

2.2.1.4 - Response should provide appropriate extracts that describe the management controls and their application.

2.2.1.5 - Response should provide examples of how these procedures and reviews are applied to procurements.

Item 2.2.2 - Response appears incomplete in that contact with the vendor by the licensee to ascertain that the licensee's file of vendor information and documentation is complete and current has not been described. The program for initiating and maintaining such contact should be described.

Item 4.5.3 - Response is incomplete. Licensee shall describe the program, discuss the results, and furnish plant specific information regarding how the results will be implemented at TMI-1.