

181 ac B

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-85-18 Date: 3/29/85

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Pacific Gas & Electric Company Diablo Canyon Unit 1 Docket No. 50-275 San Luis Obispo County, California	Licensee Emergency Classification <input type="checkbox"/> Notification of Unusual Event <input type="checkbox"/> Alert <input type="checkbox"/> Site Area Emergency <input type="checkbox"/> General Emergency <input checked="" type="checkbox"/> Not Applicable
---	---

SUBJECT: COMPLETION 100 HOURS WARRANTY RUN

Diablo Canyon Unit 1 successfully completed the power ascension test program and 100 hour warranty run on March 28, 1985, with a turbine trip/reactor trip from 100%, followed by a natural circulation-boron injection mixing test that was terminated at 1:13 a.m., PST, on March 29, 1985. A maintenance outage is planned before return to power and scheduled commercial operation.

power

This information is current as of 9:30 a.m., PST, March 29, 1985.

CONTACT: R. T. Dodds FTS 463-3720	M. Mendonca (805) 595-2354
--------------------------------------	-------------------------------

DISTRIBUTION

H St. <u>11:09</u>	MNBB <u>10:54</u>	Phillips	E/W <u>10:56</u>	Willste <u>10:57</u>	Air Rights <u>4:09</u>	Mail:
Chairman Pallidino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Zech	PA		OIA	RES		DOT:Trans
Comm. Bernthal	MPA		AEOD			Only
Comm. Roberts	ELD					
Comm. Asselstine			Regions: <u>RI - RII-2:19, RIII-2:21, RTIV-3:01</u>			
SECY			INPO <u>10:02</u> NSAC			
ACRS			Licensee:			
CA			(Reactor Licensees)			REGION V: FORM 211
PDR			Resident Inspector <u>10:44</u>			(Revised 3/14/83)

8504180022 850329
PDR I&E
PNO-V-85-018 PDR

IE-34
9/1