

NOTICE OF VIOLATION

Union Electric Company
Callaway Nuclear Power Station

Docket No. 50-483
License No. NPF-30

During an NRC inspection conducted on August 1, 1992 through September 30, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:


Technical Specification (TS) 6.8.1.a requires that written procedures be established, implemented, and maintained covering the applicable procedures recommended in Appendix A of Regulatory Guide (RG) 1.33, Revision 2, February 1978. Item 1.c of RG 1.33 requires administrative procedures on equipment controls (e.g. locking and tagging). Operations Department Procedure ODP-ZZ-00004, Revision 13, "Locked Component Control" was instituted to implement this requirement.

Contrary to the above, on September 2, 1992, damper GK D0325 and the upper cable spreading room exhaust register were not locked as required by ODP-ZZ-00004.

This is a severity level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Union Electric Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the U.S. Nuclear Regulatory Commission, Region III, 795 Roosevelt Road, Glen Ellyn, Illinois 60137, and a copy to the NRC Resident Inspector at the Callaway Nuclear Power Station within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to the Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, a demand for information may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Glen Ellyn, Illinois
this 17th day of October 1992


L. Robert Greger