

ELECTRICAL POWER SYSTEMSLIMITING CONDITION FOR OPERATION (Continued)ACTION (Continued)

restore the diesel generator to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

- c. With one offsite circuit of the above required A.C. sources and diesel generator Div 1 or Div 2 of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. If a diesel generator became inoperable due to any cause other than preplanned preventive maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE diesel generators separately for each diesel generator by performing Surveillance Requirements 4.8.1.1.2.a.4 and 4.8.1.1.2.a.5 within 8 hours* for each diesel generator which has not been successfully tested within the past 24 hours. Restore at least one of the inoperable A.C. sources to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. Restore at least two offsite circuits and diesel generators Div 1 and Div 2 to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With diesel generator Div 3 of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the offsite A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. If the diesel generator became inoperable due to any cause other than preplanned preventive maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE diesel generators separately by performing Surveillance Requirements 4.8.1.1.2.a.4 and 4.8.1.1.2.a.5 within 24 hours*. Restore diesel generator Div 3 to OPERABLE status within 72 hours or declare the HPCS system and the C ESW pump inoperable and take the ACTION required by Specifications 3.5.1 and 3.7.1.1.
- e. With diesel generator Div 1 or Div 2 of the above required A.C. electrical power sources inoperable, in addition to ACTION b or c, as applicable, verify within 2 hours that all required systems, subsystems, trains, components and devices that depend on the remaining OPERABLE diesel generator as a source of emergency power are also OPERABLE* otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

*This test is required to be completed regardless of when the inoperable diesel generator is restored to OPERABILITY. The provisions of Specification 3.0.2 are not applicable.

*Except that valves E51-F064 and G33-F004 may be inoperable (only for reasons as described in the basis for Amendment _____). This exception is effective until startup from the fourth refuel outage.

PERRY - UNIT 1

3/4 8-2

9210200111 921013
PDR ADOCK 05000440
P PDR