



P.O. Box 300
Seabrook, NH 03874
Telephone (603) 474-9521
Facsimile (603) 474-2987

Ted C. Feigenbaum
Senior Vice President and
Chief Nuclear Officer

NYN- 92141

October 14, 1992

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

- References:
- (a) Facility Operating License No. NPF-86, Docket No. 50-443
 - (b) North Atlantic Letter NYN-92121 dated September 4, 1992 "Licensee Event Report 92-11; Inoperable Cooling Tower Fans", T. C. Feigenbaum to USNRC
 - (c) North Atlantic Letter NYN-92127 dated September 30, 1992 "Licensee Amendment Request 92-13; Manual Operation of Cooling Tower Fans and Sprays", T. C. Feigenbaum to USNRC

Subject: License Amendment Request 92-13: Request for Additional Information

Gentlemen:

North Atlantic Energy Service Corporation (North Atlantic) submitted License Amendment Request 92-13 [Reference (b)] to revise the operation of the Seabrook Station cooling tower fans and sprays from automatic to manual. In the License Amendment Request, North Atlantic referred to an analysis of cooling tower basin heatup that was available for NRC review at Seabrook Station.

NRC Staff personnel have requested that the analysis be made available for the review. In order to facilitate the review of License Amendment Request 92-13, North Atlantic is providing the cooling tower basin heatup evaluation in Enclosure 1.

Should you have any questions regarding this matter please contact Mr. Terry L. Harpster, Director of Licensing Services at (603) 474-9521, extension 2765.

Very truly yours,

Ted C. Feigenbaum
Ted C. Feigenbaum

TCF:JMP/ss/tad

Enclosure(s)

160000

9210200320 921014
PDR ADDCK 05000443
P PDR

a member of the Northeast Utilities system

ADD 1/1

United States Nuclear Regulatory Commission
Attention: Document Control Desk

October 14, 1992
Page two

cc: Mr. Thomas T. Martin
Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Gordon E. Edison, Sr. Project Manager
Project Directorate I-3
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Noel Dudley
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874

Mr. John Shedlosky, Acting Section Chief
Project Section 3B
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

North Atlantic
October 14, 1992

ENCLOSURE 1 TO NYN-92141

"Evaluation of Cooling Tower Basin Heatup Analysis
With Sprays and Fans Manually Controlled"