



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
476 ALLENDALE ROAD
KING OF PRUSSIA, PENNSYLVANIA 19406

JUN 13 1989

Docket No. 50-336
File No. RI-A-88-0003 (B.16.01)

[REDACTED]

Dear [REDACTED]

Subject: Allegation Concerning Millstone Unit 2

The NRC Region I office has completed its followup in response to the concerns you brought to our attention in November 1, 1988. You expressed dissatisfaction with the NRC followup and disposition of allegations, specifically the NRC inspection teams disposition of your concerns relating to the SP-EE-076 Electric Code and the use of electrical metallic tubing (EMT), as documented in inspection report 50-336/89-13.

The NRC has subsequently reviewed your concerns again and concluded that the evaluation and disposition of your concerns in inspection report 50-336/89-13 was correct.

The inspection team determined that SP-EE-076, as a specification, does not apply to Unit 2. It is a specification developed by Stone and Webster and used in the construction of Millstone Unit 3, the plant for which Stone and Webster was the architect and engineer. SP-EE-076 has been distributed to the other nuclear generating stations operated by the licensee as a reference and general guidance document. The inspection team reviewed licensee internal memoranda that promulgated the use of SP-EE-076 at these plants, and no discrepancies were noted.

The inspection team also concluded that your allegation that EMT is used in applications other than lighting installations at Millstone Unit 2 is substantiated. These applications, however, are clearly allowed for and controlled by the applicable specification, Bechtel drawing 25203-34001, and, therefore, pose no safety hazard to the plant.

We appreciate your informing us of your concerns and feel that our actions in this matter have been responsive to those concerns. Should you have any additional questions, or if I can be of further assistance in this matter, please call me collect at (215) 337-5120.

Sincerely,

William J. Raymond

for Donald R. Haverkamp, Chief
Reactor Projects Section 4A

Allegation File RI-88-0003
W. Raymond
A. Vogel

9210260148 920325
PDR FOIA
GUILD91-162 PDR

M/55

ALLEGATION RECEIPT REPORT

Date/Time Received: 7/10/90

Allegation No. B. 24.01
(leave blank)

Name: [REDACTED]

Address: [REDACTED]

Phone: _____

City/State/Zip: [REDACTED]

Confidentiality:

| | | |
|--|-----------|--|
| Was it requested? | Yes _____ | No <input checked="" type="checkbox"/> |
| Was it initially granted? | Yes _____ | No <input checked="" type="checkbox"/> |
| Was it finally granted by the allegation panel | Yes _____ | No <input checked="" type="checkbox"/> |
| Does a confidentiality agreement need to be sent to allee? | Yes _____ | No <input checked="" type="checkbox"/> |
| Has a confidentiality agreement been signed? | Yes _____ | No <input checked="" type="checkbox"/> |
| Memo documenting why it was granted is attached? | Yes _____ | No <input checked="" type="checkbox"/> |

Allee's Employer: Northeast Utilities Position/Title: Electrician

Facility: Millstone 2 Docket No.: 50-336

(Allegation Summary (brief description of concern(s)): See attached

MEMO

Number of Concerns: 1

Employee Receiving Allegation: PJ Habighorst
(first two initials and last name)

Type of Regulated Activity (a) ☒ Reactor (d) ☐ Safeguards
(b) ☐ Vendor (e) ☐ Other: _____
(c) ☐ Materials (Specify)

Materials License No. (if applicable): _____

Functional Area(s): ☒ (a) Operations (e) ☐ Emergency Preparedness
☐ (b) Construction (f) ☐ Onsite Health and Safety
☐ (c) Safeguards (g) ☐ Offsite Health and Safety
☐ (d) Transportation (h) ☐ Other: _____

(NRC Region I Form 207
Revised 10/89)

To Rg I on 7/16/90.

M/56