

October 19, 1992

Mr. William L. Beckman, Plant Manager
 Big Rock Point Plant
 Consumers Power Company
 10269 U.S. 31 North
 Charlevoix, Michigan 49201

Dear Mr. Beckman:

SUBJECT: BIG ROCK POINT PLANT - AMENDMENT NO. 108 TO FACILITY OPERATING LICENSE
 NO. DPR-6 (TAC NO. M82998)

The Commission has issued the enclosed Amendment No. 108 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated May 24, 1991.

This amendment revises TS 9.0, "Inservice Inspection and Testing," by adding statement 9.3.e, which requires that the Big Rock Point Inservice Inspection Program be performed in accordance with the Big Rock Point Intergranular Stress Corrosion Cracking (IGSCC) Program.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by
 Robert Stransky, Project Manager
 Project Directorate III-1
 Division of Reactor Projects III/IV/V
 Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 108 to DPR-6
2. Safety Evaluation

cc w/enclosures:
 See next page

OFFICE	LA:PD31	PM:PD31	EMBE EMLB	OGC	D:PD31
NAME	MShuttleworth	RStransky	J STROSNICK		LMarsh
DATE	9/12/92	7/27/92	10/6/92	10/14/92	10/14/92

OFFICIAL RECORD COPY

FILENAME: C:\WP\WPDOCS\BIGROCK\BRP82998.amd

29:100

9210190349 921019
 PDR ADOCK 05000155
 P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
October 19, 1992

Docket No. 50-155

Mr. William L. Beckman, Plant Manager
Big Rock Point Plant
Consumers Power Company
10269 U.S. 31 North
Charlevoix, Michigan 49201

Dear Mr. Beckman:

SUBJECT: BIG ROCK POINT PLANT - AMENDMENT NO. 108 TO FACILITY OPERATING LICENSE
NO. DPR-6 (TAC NO. M82998)

The Commission has issued the enclosed Amendment No. 108 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated March 9, 1992.

This amendment revises TS 9.0, "Inservice Inspection and Testing," by adding statement 9.3.e, which requires that the Big Rock Point Inservice Inspection Program be performed in accordance with the Big Rock Point Intergranular Stress Corrosion Cracking (IGSCC) Program.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to read "Robert Stransky", written over a horizontal line.

Robert Stransky, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 108 to DPR-6
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. William L. Beckman

Big Rock Point Nuclear Plant

cc:

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Jane E. Brannon, County Clerk
County Building
Charlevoix, MI 49720

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
Big Rock Point Plant
10253 U.S. 31 North
Charlevoix, Michigan 49720

Mr. David P. Hoffman, Vice President
Nuclear Operations
Big Rock Point Plant
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201