

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
Duquesne Light Company )  
Beaver Valley Power Station )

UNIT NO. 1  
Docket No. 50-334  
License No. DPR-66

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the technical specifications set forth in Appendix A to this license be amended to change the overpressure protection system enable temperature to 329°F.

The proposed technical specification change is set forth in Attachment A to this application. A safety analysis and no significant hazard evaluation is set forth in Attachment B. Typed replacement pages for the technical specification are included in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.


WHEREFORE, Applicant respectfully requests that Appendix A to the operating license be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J.D. Sieber  
J.D. Sieber  
Vice President  
Nuclear Group

Subscribed and sworn to before me  
on this 2<sup>nd</sup> day of November, 1992

Tracey A. Baczek



Member, Pennsylvania Association of Notaries

9211090151 921102  
PDR ADDCK 05000334  
PDR  
P