

ORIGINAL

UNITED STATES
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF:

COMMISSION MEETING

DOCKET NO:

LOCATION: WASHINGTON, D. C.

PAGES: 1-78

DATE: WEDNESDAY, APRIL 17, 1985

8504300611 850417
PDR 10CFR
PT9.7 PDR

ACE-FEDERAL REPORTERS, INC.

Official Reporters
444 North Capitol Street
Washington, D.C. 20001
(202) 347-3700

50-289

DISCLAIMER

This is an unofficial transcript of a meeting of the United States Nuclear Regulatory Commission held on April 17, 1985 in the Commission's office at 1717 H Street, N.W., Washington, D. C. The meeting was open to public attendance and observation. This transcript has not been reviewed, corrected, or edited, and it may contain inaccuracies.

The transcript is intended solely for general informational purposes. As provided by 10 CFR 9.103, it is not part of the formal or informal record of decision of the matters discussed. Expressions of opinion in this transcript do not necessarily reflect final determination or beliefs. No pleading or other paper may be filed with the Commission in any proceeding as the result of or addressed to any statement or argument contained herein, except as the Commission may authorize.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

- - -

BRIEFING ON TMI-1 STEAM GENERATOR
AND OTHER PLANT MATTERS

- - -

PUBLIC MEETING

Room 1130
1717 H Street, N.W.
Washington, D.C.

Wednesday, April 17, 1985

The Commission met, pursuant to notice, at 2:32 p.m.

COMMISSIONERS PRESENT:

- NUNZIO PALLADINO, Chairman of the Commission
- THOMAS ROBERTS, Commissioner
- JAMES ASSELSTINE, Commissioner
- FREDERICK BERNTHAL, Commissioner
- LANDO ZECH, Commissioner

STAFF AND PRESENTERS SEATED AT COMMISSION TABLE:

- J. HOYLE
- B. JOHNSTON
- T. MURLEY
- J. ROE
- H. THOMPSON
- D. EISENHUT
- R. STAROSTECKI
- H. PLAINE

AUDIENCE SPEAKERS:

- G. SHEA
- R. CONTE
- C. MCCracken
- B. SHERON
- J. STOLZ
- B. LAGRANGE
- W. JENSEN

P R O C E E D I N G S

1
2 CHAIRMAN PALLADINO: Good afternoon, ladies and
3 gentlement. The purpose of today's meeting is to receive a
4 briefing from the NRC staff on the status of the steam generators
5 at the Three Mile Island Unit 1 plant, as well as other aspects
6 of the status of the Unit 1 plant.

7 Tomorrow, beginning at 9:30 a.m., we will hear the
8 responses of other interested participants to the NRC staff
9 comments on the steam generators.

10 I suggest that in view of the importance of the
11 steam generator questions, the staff take them up first and
12 address other questions after that. We have a limited amount
13 of time so, without further delay, I would like to turn the
14 meeting over to the NRC staff.

15 First, however, do other Commissioners have any
16 opening remarks they would like to make?

17 COMMISSIONER ASSELSTINE: No.

18 CHAIRMAN PALLADINO: Okay. Jack?

19 MR. ROE: Thank you, Mr. Chairman.

20 We have six areas one of which will be, as you
21 requested, focused on steam generator operability, tube
22 plugging issue to address today. We will do them in summary
23 fashion with the focus being on steam generators.

24 I will now turn the meeting over to Darrell Eisenhut
25 who has some additional comments.

1 CHAIRMAN PALLADINO: Let me suggest that we do the
2 steam generators and then open up for discussion on that and
3 then pick up the other items.

4 MR. ROE: Fine.

5 MR. EISENHUT: Mr. Chairman, that is basically what
6 we propose. As way of background, recall that the steam
7 generator is one of the earliest that we briefed you on on
8 several occasions. In the remaining portion, we will address
9 what the general overall status is of the other issues on what
10 we call the "Certification List," and other issues at the site,
11 at the plant.

12 Obviously, we won't be coming down and recommending
13 any action until we think all the aspects are resolved to our
14 satisfaction. Today, we are going to be focusing on the few
15 remaining issues and we try to keep it in the context that of
16 the hundreds and hundreds of issues we looked at, we have a
17 few we are focusing on, will go through today.

18 Hugh Thompson is going to be making the briefing,
19 along with Tom Murley, the Region I Director, who is here with
20 us today. With that, Hugh, why don't you go ahead?

21 MR. THOMPSON: Thank you, Darrell.

22 We will probably want to highlight just a few of the
23 items that we that we would cover, as we talked about earlier.
24 As a general overview, if we can have Slide 2, then.

25 Since TMI and since 1979 -- I think Slide 2, the next

1 slide -- we have completed a considerable number of multi-
2 plan actions and TMI Action Plan items, as well as license
3 amendments. Many things have occurred on this plant. For the
4 multi-plan items such as the Salem ATWS issues, the plan
5 is generally on scheduled. For the TMI Action Plan items, the
6 plan is generally ahead of schedule, and we see that there are
7 no open licensing actions that would remain prior to restart.

8 I would like to turn to the next slide, which is the
9 TMI-1 steam generator chronology, and it really addressed the
10 three major issues that we see with respect to the generators
11 at TMI.

12 I would like to ask Dr. Bill Johnston, who is the
13 Assistant Director for Materials, Chemistry, and Technology
14 in the Division of Engineering to come to the table and give
15 us a detailed briefing on those issues. At that time, we will
16 be prepared to respond to any questions that the Commissioners
17 may have. Bill?

18 MR. JOHNSTON: Thank you very much, Hugh.

19 I would like to talk to the issues that are on the
20 slide, on the screen, and emphasize that there have been three
21 areas of interest in that steam generator.

22 The first one, the kinetic expansion repair, I think,
23 has been discussed fairly extensively with the Commission on
24 previous occasions. The essence of it is that following hot
25 functional tests at the end of 1981, they discovered a large

1 number of defects in the steam generators. Extensive study
2 was done. They concluded that it was a corrosion problem
3 occasioned apparently by thiosulfate coming into the system
4 as it was cooling down and that, coupled with the stress on
5 the steam generator tubes in that once through design as it
6 cools down, contributed to cause the stress corrosion cracking,
7 it was intergranular stress corrosion cracking.

8 Also identified at the time, there was some inter-
9 granular attack. It was not deep, it was relatively minor
10 and relative to the stress corrosion cracking which were
11 circumferential-type cracks whereas these were patches or
12 small, pitted-type areas, less attention was paid to them.

13 But the repair, using the kinetic expansion method,
14 proceeded. All of the tubes in the steam generator -- some
15 30,000 of them -- were subjected to the kinetic expansion
16 repair. The only ones that were not, were those that had been
17 previously plugged in its previous service.

18 COMMISSIONER ASSELSTINE: Bill, I'm sorry, did you
19 say that you did recognize, did identify the intergranular
20 attack at that time and recognize the connection with the
21 sulfur --

22 MR. JOHNSTON: It was identified at the time and was
23 in the reports.

24 COMMISSIONER ASSELSTINE: Okay.

25 MR. JOHNSTON: The difference, of course, between the

1 IGSCC and IGA is whether there is a stress component --

2 COMMISSIONER ASSELSTINE: Right.

3 MR. JOHNSTON: -- apparent, and it was readily easy
4 to see when you look at the IGSCC that there was a crack, if
5 you like, running right straight through.

6 COMMISSIONER ASSELSTINE: Okay.

7 MR. JOHNSTON: Whereas the morphology of the other
8 type is a different morphology.

9 COMMISSIONER ASSELSTINE: So, in actuality, like
10 when the staff responded to my questions on January 15 and
11 said you had not ruled out the role of the sulfur in the inter-
12 granular attack, it's even more than that. In fact, you
13 know that there is a direct connection.

14 MR. JOHNSTON: Yes, we suspected that to be the
15 case at the time we wrote you a letter, and that's why we
16 said we suspected that was the case. That has been subsequently
17 borne out. You know, we have just issued what I would
18 like to say is a final SER on the matter which draws that
19 conclusion.

20 It's not new attack, it's previously existing
21 attack which has become more readily identifiable.

22 The rest of the first section of the slide simply
23 indicates the process that was gone through in the adjudicatory
24 sense of presenting this material to the Board, having it
25 adjudicated. The tech spec amendment was issued. There was

1 an appeal and a motion to re-open the record to bring up the
2 status of the kinetic expansion.

3 Later on, following some further operation of the --
4 not operation but further examination of the plant, there was
5 discovered that some of the plugs that had been put in at the
6 time of the kenetic expansion were missing. One was missing
7 from the upper tube sheet and subsequent examination discovered
8 that there were six missing from the lower tube sheet.

9 The investigation and subsequent SER that we issued
10 indicated that in putting the plugs in, there is a certain
11 amount of torque that is required on the roller switches
12 which expand the plugs into the tube sheet. And because they
13 were using a universal joint, the force that they put onto
14 the plugs that were located near the outside edges of the
15 steam generator, were not sufficient to firmly place the plugs
16 in. So, they went back and went through all of the plugs that
17 they had formerly put in, over a thousand of them, and dis-
18 covered that several hundred of them were indeed loose and they
19 re-torqued them with a device located right on the torquing
20 device so they knew exactly what they were actually putting on
21 the tube.

22 So, we felt that this issue was completed and --

23 CHAIRMAN PALLADINO: Though, they did find a number
24 of them loose. Now, how do we know for sure or with reasonable
25 assurance that what they did now will cause them not to be loose

1 again? I'm not sure we know why they got loose, or do we?

2 MR. JOHNSTON: Well, hes, we feel that we know they
3 were loose because the torque was insufficient to hold them
4 in place. They need a minimum of 90 pounds --

5 COMMISSIONER ASSELSTINE: So, they weren't installed
6 properly.

7 MR. JOHNSTON: They weren't installed properly. So,
8 they went back, you might say, and re-installed them properly,
9 knowing the torque that was actually applied to the plugs
10 rather than --

11 CHAIRMAN PALLADINO: You mean they didn't measure
12 the torque the first time?

13 MR. JOHNSTON: They measured the torque that was
14 applied to the torquing device, but that was on the outside
15 of the universal joint, and where they were working with the
16 outside edges --

17 CHAIRMAN PALLADINO: Were all the loose ones on
18 the outside edges?

19 MR. JOHNSTON: That's my understanding, they tended
20 to be there. It was because of the angle of the universal
21 joint.

22 COMMISSIONER BERNTHAL: So, how do you know that
23 there aren't others that are --

24 MR. JOHNSTON: Well, a thousand of them are re-done.

25 COMMISSIONER BERNTHAL: Oh, they were all redone.

1 MR. JOHNSTON: Yes.

2 CHAIRMAN PALLADINO: And I gather any new plugging
3 will take advantage of whatever they learned from the old.

4 MR. JOHNSTON: Yes.

5 COMMISSIONER BERNTHAL: What is the distribution of
6 the plug tubes, are they sort of randomly distributed throughout
7 the generator, or is there a --

8 MR. JOHNSTON: It's my understanding, and I'll ask
9 Conrad McCracken who is our expert in this area to verify what
10 I say. But it's my understanding that they are relatively
11 random. But I would -- he says they tend to be more in the
12 outer circumference.

13 MR. MCCRACKEN: They are primarily in the outer
14 circumference because the outer tubes are in more tension than
15 the inner tubes at the center of the tube sheet where you
16 get a slight amount of bowing. So, there is more tension
17 there.

18 COMMISSIONER ASSELSTINE: That's what they found.

19 MR. MCCRACKEN: Yes.

20 CHAIRMAN PALLADINO: How many plugs are in the
21 system loops, six?

22 MR. JOHNSTON: Approximately six.

23 COMMISSIONER ZECH: Are those the missing plugs you
24 are talking about?

25 MR. JOHNSTON: Yes.

1 COMMISSIONER ROBERTS: Where are they?

2 MR. JOHNSTON: They are probably sitting in the
3 bottom of the reactor vessel. Now, when we talk about plugs,
4 we are talking about an item that is about three and-a-half
5 inches long, about the size of this pencil, 6/10 of an inch,
6 and they weight just about an ounce and-a-half. So, we are
7 talking a small piece, light.

8 COMMISSIONER ZECH: Have you analyzed that to see
9 whether that would do any harm during operation?

10 MR. JOHNSTON: That was analyzed as part of the SER
11 that was written at that time by the technical branches
12 involved and they concluded that there was no problem.

13 CHAIRMAN PALLADINO: They couldn't get anywhere and
14 carried up.

15 MR. JOHNSTON: They considered that possibility,
16 including the possibility they might get up into the bottom of
17 the control rod drive tubing and things of that sort. But
18 the conclusion in the SER was that that would not interfere
19 with the operation.

20 CHAIRMAN PALLADINO: Could they get in and block
21 any flow passages, block the flow around fuel elements?

22 MR. JOHNSTON: That was, as I understand it, also
23 included and because it's a PWR, it has the opportunity for
24 cross-flow. So, that there is a small location that readily
25 moves around behind it and doesn't result in any volume that

1 is significant.

2 COMMISSIONER ZECH: But you did a good analysis,
3 and your analysis shows that even though you have some of these
4 missing plugs in the bottom of the vessel, I guess, right?

5 MR. JOHNSTON: That's where we think they are, we
6 don't know.

7 COMMISSIONER ZECH: That that's not a problem. Is
8 that what your analysis shows?

9 MR. JOHNSTON: That's the conclusion of the analysis.

10 COMMISSIONER ZECH: Okay.

11 CHAIRMAN PALLADINO: I presume you looked at the
12 possibility of things just beating around the area and
13 possibly damaging some other flow passage?

14 MR. JOHNSTON: I'm not sure that person -- I think
15 I would like to ask the person behind me that knows more
16 about that than I do.

17 CHAIRMAN PALLADINO: What is the likelihood that
18 they just bang around in the flow?

19 MR. JOHNSTON: I think my first -- I'm going to get
20 somebody to answer that. Brian Sheron or Gene Shea? Gene,
21 why don't you come to the microphone?

22 CHAIRMAN PALLADINO: And repeat your name for the
23 transcriber.

24 MR. SHEA: This is Gene Shea from the Core Performance
25 Branch.

1 MR. SHEA: This is Gene Shea.

2 We analyzed that the plug, there is a blockage --
3 the partial blockage would not affect the DNB because the
4 configuration of the fuel is -- so the diverging cross-flow
5 will result in fore flow within a short period of distance
6 up to the blockage.

7 And also, if there is a small fragment that gets
8 into the core, we may have -- it might wedge it at the fuel.
9 As a result of that, the worst condition is, they might have
10 a fuel -- and the freezing gas release would be gradual
11 because you don't expect to have -- and the tech spec has a
12 surveillance requirement that will monitor the activity.

13 So, we think the effect on safety is not significant.

14 CHAIRMAN PALLADINO: Okay, thank you.

15 MR. JOHNSTON: There was a tech spec requirement
16 that they do a periodic eddy current examination of all of
17 the tubes in the steam generator, and this time period came
18 up late last summer. So that they did begin to do an examination
19 using eddy current techniques last fall and late summer. In
20 the course of that eddy current examination, they discovered
21 another 300-some tubes which had defects through the wall or
22 defects in the wall which were greater than 40 percent of the
23 wall thickness.

24 This was identified as the IGA component that we
25 had talked about previously. The bottom line is that all of the

1 tubes have been plugged that exceeded the 40-percent limit
2 which is the tech spec requirement. The steam generator has
3 now been put back into its licensed condition. The indication
4 is that the leak rate is less than one and-a-half gallons per
5 hour, which is a very small leak rate, and it's been declared
6 operable.

7 Altogether, there are now 1,542 tubes that have been
8 plugged.

9 COMMISSIONER ASSELSTINE: How accurate is the
10 eddy current testing for identifying these kinds of defects
11 as opposed to the intergranular stress cracks?

12 MR. JOHNSTON: It's more difficult to find the IGA
13 defects because -- I guess the best way to describe it, that
14 the eddy current technique looks at -- it's a volumetric
15 thing and if there is no loss of volume, in other words, if a
16 crack is very tight it will not see it.

17 When we do see it is when the -- we get what we
18 call a grain fallout because this type of attack essentially
19 isolates the grains. So that if you get an operating
20 condition which puts a strain -- thermal or mechanical -- that
21 tends to open things up a little bit, grains can fall out
22 and we then see the -- well, then the eddy current device
23 sees the lack of the grain and says there is a volumetric loss
24 there.

25 COMMISSIONER ASSELSTINE: Why didn't you find these

1 things, say, back in -- or the licensee find these things back
2 in what, '81 to '82?

3 MR. JOHNSTON: They did detect them, as I indicated
4 previously. I have a backup viewgraph that shows what was
5 actually seen back in that time. It might be instructive if
6 I show that. I believe it's back-up Slide No. 5.

7 I Want to show back-up Slide Nos. 5, 6 and 7.

8 COMMISSIONER ASSELSTINE: Also, did these things
9 get worse?

10 MR. JOHNSTON: No. Our conclusion is that they did
11 not get worse. We have run in parallel a corrosion program
12 that uses fresh tubes which uses tubes that were in the
13 steam generator at the time of the first set of defects. They
14 have been running through a similar water chemistry and
15 they have shown no changes.

16 The tubes that were not plugged which had some
17 defects in them, in other words, there were less than 40, had
18 been monitored both then and at the more recent, and they have
19 seen no change in the depth there.

20 So, the conclusion is that the corrosion mechanism
21 is not presently active and these are pre-existent defects
22 which have now become visible.

23 COMMISSIONER ASSELSTINE: Okay. Why weren't these
24 plugged earlier on, then, if you knew about them at the time?

25 MR. JOHNSTON: The depth was indicated, I'll show that

1 in the next two slides after this one.

2 COMMISSIONER ASSELSTINE: Okay.

3 MR. JOHNSTON: But it was just in the grass.

4 COMMISSIONER ASSELSTINE: Okay.

5 MR. JOHNSTON: What I would like to show here first
6 is an example of the intergranular IGSCC, intergranular
7 stress corrosion cracking. That crack goes all -- that's the
8 actual wall of the -- steam generator tube and that crack
9 goes all the way through the sample. That's relatively easy
10 to be seen by the eddy current device. Yes, it shows on there.

11 And the next one, then, is what was also --

12 COMMISSIONER ASSELSTINE: Is that the outside of the
13 tube, or is that a cross-section?

14 MR. JOHNSTON: The upper is the inner, is the
15 inside, and the bottom of it is the outer.

16 COMMISSIONER ASSELSTINE: Okay.

17 MR. JOHNSTON: You notice if you look at the inner,
18 you see a little more broader band, and if you'll focus on
19 that in the next viewgraph, you'll see the IGA.

20 CHAIRMAN PALLADINO: Are we looking at a cut
21 through --

22 MR. JOHNSTON: You are looking at a cross-section
23 through the wall of a steam generator tube at 100 X magnification

24 Look at the bottom rather than the upper, and you
25 note that region that is roughly where the pencil is, you see

1 the region where some grain boundaries are outlined in the
2 dark, and that is the region of IGA. You notice it does not
3 have the same kind of orientation through the wall that the
4 previous viewgraph, previous slide had.

5 But that is the kind of indication that one would
6 get from a cross-sectional examination. Now, if we did eddy
7 current on that tube, you'll notice that there is no loss of
8 volume and, consequently, it doesn't show up well in the eddy
9 current examination. The black spots that you see are grains
10 that fell out during the metallurgical preparation. So, it
11 wouldn't be that way in the actual tube.

12 The next one, I believe, will show a little bit of
13 what would have been seen at the time. If you look at the one
14 at the top, you will see where -- the dark stuff up at the
15 top -- that there have been some grain fall-outs and that
16 would be detected by the eddy current as less than a full
17 thickness of the wall. That would trigger in general a more
18 detailed examination.

19 Now, after this more recent episode, they went back
20 and looked at all of the data that was taken during the previous
21 examination and after the fact, knowing it's there, they
22 could see indications in the background, a scatter of the
23 data, that would say, "Yes," there was something there. But
24 the indication was not indicating the kinds of depths and
25 so forth that would have necessitated taking any action at that

1 time.

2 CHAIRMAN PALLADINO: Bill, can I ask a question on
3 a different subject? Are you through, Jim?

4 COMMISSIONER ASSELSTINE: I guess the only other
5 question I had on this was, to what extent, given the fact
6 that it's tougher to spot this kind of corrosion as opposed
7 to the cracking, how confident are you that this latest round
8 of eddy current tests has identified all of these kinds of
9 areas, particularly given where they are located. I gather
10 this is in a tougher part to spot this than the kind of
11 cracking you normally see in the tube sheets.

12 MR. JOHNSTON: Well, this is in the span part of
13 the tubing, it's not -- in itself it's not particularly
14 difficult to get to to do the examination. I think one can
15 never say that there will be no further evidence of this
16 sort.

17 The reason that we think we got so many of them
18 this time is that as a part of the checking out of the
19 kinetic expansion work the steam generator was given a special
20 rapid cooldown to put a maximum amount of stress on the tubing
21 to make -- essentially to continue to verify that the expansion
22 process was successful and no tubes would be pulled out under
23 what would be a rather extreme stress condition.

24 That mechanical and thermal stress did put these
25 portions of the tube on tension and make it possible, more

1 possible, for the grains to drop out than would happen in a
2 normal cooldown or a normal situation. So, we think we found
3 most of them this way. But we would guess that there -- we
4 would anticipate that there will probably be some more that
5 would come about later.

6 The point, I think, I should that I hadn't made yet,
7 and that is that the intergranular stress corrosion cracking
8 is of the nature of a crack which tends to run circumferentially
9 and it's essentially like pulling down on my pencil and getting
10 that type of a defect.

11 This is a -- because it's a patchy type of defect
12 is not prone to run in a circumferential sense. And the
13 eddy current devices that they have now, it's called an
14 8 x 1, but what it really means is that they have essentially
15 eight little coils, each acting independently. So, they can
16 break up the circumference into eight pieces and determine
17 then when they see a defect how much of the circumference it
18 is, and the ones that we were examining here which had been
19 plugged, they were all either once segment or two segments
20 which is, they were less than 2/8 or 25 percent of the
21 circumference. So, most all of them were then a matter of,
22 I think, less than ten, were all just one segment wide which
23 meant they were twelve and-a-half degrees -- I'm sorry, what
24 is it, 45 degrees? No, 22 and-a-half degrees, just 1/8
25 of the circumference of the tube. So, they are short.

1 If we missed some, then the consequence is only a
2 very small leak and there are several other safeguards that
3 we have built into the SER and the licensing requirements that
4 will ensure better control of the water chemistry, better
5 control of the contaminants, and an examination after a very
6 short running period which will get us another chance to see
7 if anything has changed.

8 COMMISSIONER ASSELSTINE: Is there a possibility
9 for the same kind of intergranular attack on any other parts
10 of the primary system? Are the tubes the only things that
11 were susceptible or are susceptible to this kind of attack
12 from the sulfur, or could the sulfur have affected anything
13 else?

14 MR. JOHNSTON: No. At the time it was first
15 identified, an extensive examination was made of the whole
16 primary system. The places that are most susceptible are
17 those places that would be at an air-water interface.

18 COMMISSIONER ASSELSTINE: Okay.

19 MR. JOHNSTON: It was portions of the plant which
20 might have been exposed to air when the steam generator was
21 open. So, it's basically air-water interface and slightly
22 above it.

23 COMMISSIONER ASSELSTINE: So, anything submerged would
24 not have been --

25 MR. JOHNSTON: Those things submerged are not so much

1 of a problem. The whole plant was gone over, all of the
2 internal structure and the core itself, and so forth, was
3 examined at the time. Recalling, there were one or two places
4 where they found it. There were some safety valves, I think,
5 which the bonnet had some indications of attack on it which
6 were replaced. But generally speaking, it was all concentrated
7 in the steam generator.

8 MR. THOMPSON: But I would say where we are right
9 now, it's the staff's position that the TMI-1 steam generators
10 have been repaired to their original licensing condition.

11 CHAIRMAN PALLADINO: That's my question.

12 MR. THOMPSON: And that these repairs were done
13 consistent with criteria approved and used for the repairs in
14 other steam generators. So, we see that there is no licensing
15 problem with the steam generators at this time.

16 CHAIRMAN PALLADINO: Let me ask you a question. I
17 just want to make sure that I understand the situation right.
18 There had been a request by GPU to operate without plugging
19 some of these tubes that were at the 40 percent limit.

20 MR. THOMPSON: That's right. There was a --

21 CHAIRMAN PALLADINO: But he staff did not act on
22 that.

23 MR. THOMPSON: That's right.

24 CHAIRMAN PALLADINO: But GPU came back and said, "Well,
25 we might as well go plug it," and they plugged them, and they

1 did; is that right?

2 MR. THOMPSON: That is correct, they have plugged
3 those steam generators which the revised tech spec plugging
4 criteria would have applied to. So, they do intend to proceed
5 with that. We have indicated that that will require a license
6 amendment, be noticed --

7 CHAIRMAN PALLADINO: What will require a license
8 amendment?

9 MR. THOMPSON: Their request to modify the tech
10 specs, those will require a normal licensing.

11 CHAIRMAN PALLADINO: What requests are they making
12 to modify the tech specs?

13 MR. THOMPSON: They will request a revision to the
14 plugging criteria based on their ability to identify this
15 intergranular attack, such that there is a different plugging
16 criterion from the one they presently have.

17 MR. EISENHUT: For future, is the key.

18 MR. THOMPSON: For future, you know, that is a
19 process. Their current plugging criterion is the one that
20 was previously developed, originally, for the plugging of
21 tubes and their tubes have been plugged. If they did not meet
22 their criteria.

23 MR. JOHNSTON: It applies to all plants.

24 CHAIRMAN PALLADINO: What sort of criteria are they
25 going to change?

1 MR. THOMPSON: Well, they have requested the
2 capability to have a more focused -- rather than the 40 percent,
3 I think there is a 70-percent corrosion identification,
4 indication of the 70-percent through wall where we normally
5 expect 40 percent to 360 degree.

6 Now, our staff has not agreed with that, that's a
7 process that is under review and we are still evaluating that.
8 I think they have not even formally submitted their licensing --

9 COMMISSIONER ZECH: But do I understand that doesn't
10 have anything to do with the current status, that's something
11 that is planned for the future?

12 MR. THOMPSON: That is for the future, has nothing
13 to do with the current license and tech specs.

14 CHAIRMAN PALLADINO: Now, we plug more tubes, and
15 I don't know how many tubes have been plugged. Must there
16 be an evaluation made on the capability of this steam
17 generator to handle full load, or any other evaluation?

18 MR. THOMPSON: The previous evaluation with the
19 effect of the plugged tubes was made assuming 1,500 tubes were
20 plugged. Currently, they plugged a few more than that. I
21 believe the number is 1,542, is approximately that number.
22 We have asked the utility to provide us an analysis on the
23 effects of transient accident response with more than 1,500
24 tubes plugged. We expect to receive that late this week or
25 early next week, and we will evaluate that in early May.

1 COMMISSIONER ASSELSTINE: What's the plugging limit
2 for this plant?

3 MR. THOMPSON: There is no plugging limit per se.
4 That is, what you have to evaluate, the impact that it may
5 have on flow set points or any of the type set points, or
6 your power limitations --

7 COMMISSIONER ASSELSTINE: Okay.

8 MR. THOMPSON: -- on just heat transfer with the
9 number -- accident conditions with the number of tubes plugged.
10 We anticipate they may be coming in with a bounding analysis
11 that would identify some larger number than the current
12 number. It may be 2,000 or 2,500, or 3,000 tubes plugged
13 and be able to identify the additional margin that the plant
14 has built into it with the anticipation of some tubes plugged.

15 CHAIRMAN PALLADINO: That's one of the questions --
16 maybe you are going to cover this later. Have we put, or
17 have they committed to making more frequent inspections than
18 usual as a result of the experience with these particular
19 steam generator tubes?

20 MR. JOHNSTON: At the present time, there is a
21 license condition that after the initial period of operation,
22 something like 90 to 120 days, there will be a complete re-
23 inspection of all of the steam generator, all portions of it.
24 That is presently a license condition.

25 What kind of inspection would be required after that

1 is not determined yet because it will hinge in part upon the
2 results of that inspection. They do have also the requirement
3 for a very small -- they are permitted only a very small
4 increment in leakage rate before they have to shut down and
5 do an examination as well. It's 1/10 of a gallon per minute,
6 which is very sensitive.

7 COMMISSIONER BERNTHAL: Yes, I had one question.
8 We have roughly five percent, I guess, of the tubes plugged
9 now. Is that extraordinary as compared with other PWRs and
10 BWRs -- not that it matters, I guess? San Onofre-1, I guess,
11 is derated because of tube pluggings. Where does this fall
12 in the spectrum of plugged tubes?

13 MR. JOHNSTON: We have some plants that are up as
14 high, I think, as ten percent of their tubes plugged. We
15 have many that have less than one percent. So, these people
16 are in the middle.

17 COMMISSIONER BERNTHAL: How many plants have been
18 derated for tube plugs?

19 MR. JOHNSTON: To my knowledge, none.

20 MR. EISENHUT: Well, there were actually brought
21 down in power. Recall, there were several plants that
22 replaced the steam generators. I think the first one was
23 the Surry facility where the net effect is, you can keep
24 plugging tubes.

25 COMMISSIONER BERNTHAL: Right.

1 MR. EISENHUT: And to stay within the safety limit,
2 what you eventually do is start bringing down the power.

3 As I recall, the Surry plant, as I remember a few
4 years ago, was actually in the 90-some percent power. The
5 Turkey Point plants were getting close.

6 MR. JOHNSTON: Robinson.

7 MR. EISENHUT: Robinson may have gotten close. So,
8 there were several plants. And I think if you look at the
9 overall approach here, it's been to, when the tube gets in
10 question you remove it from service by plugging. So, you in
11 effect maintain the integrity of the steam generator.

12 The second thing that's here is, on this plant we
13 are keeping the same plugging limit in terms of criteria.
14 The utility is preserving his option and wants to come back
15 in for a longer-term approach for when not to plug things.

16 The third thing is, we think it looks like not
17 outside the realm of what we have seen in other steam
18 generators in terms of numbers of tubes that are plugged.

19 So, I'm not sure it's actually a license condition
20 yet or one of the proposed license conditions. I forget who
21 is taking action on which ones. But we would put on this
22 plant the condition for shorter-term inspections to ensure
23 that there is a good understanding of what's happened in the
24 steam generator -- or rather what is happening in the future.

25 So, we think it's this set of these things that gives

1 us confidence that the tubes in service are in fact going to be
2 adequately safe and not significantly degraded as we would go
3 forth with operation of the facility.

4 COMMISSIONER BERNTHAL: But just on the face of it --
5 I'm sure it isn't this simple -- but you would say that
6 five-percent of the heat exchanger tubes are plugged, then
7 unless there is a significant margin you would derate the plant
8 five percent?

9 MR. EISENHUT: That's right. And in fact, you can
10 generally sharpen your pencil on an ECCS-type evaluation
11 and show that you can tolerate more tubes plugged, up to some
12 limit, and then at some point what you would do is drop the
13 power level a couple of percent so you get a power flow
14 consideration.

15 So, I guess it would be our approach to -- we would
16 set the limits and if that means the plant comes down eventually
17 to 95, 93, 92 or whatever power level, so be it.

18 But as long as we maintain these limits, we think
19 the steam generators are adequately safe.

20 CHAIRMAN PALLADINO: Commissioner Zech?

21 COMMISSIONER ZECH: Just another question on the
22 missing plugs. Have there been any other plants that we have
23 had the same problem with in the past, and do you have any
24 history or any analysis that has been gotten, or is this
25 unique?

1 MR. EISENHUT: Bill, do you want to --

2 MR. JOHNSTON: Yes, I want to think about that for
3 just a minute. To answer the question directly, whether you
4 mean plugs as such or whether you mean operation of plants
5 with other small pieces --

6 COMMISSIONER ZECH: Loose parts.

7 MR. JOHNSTON: The loose parts, definitely, plants
8 have been operating with loose parts.

9 MR. EISENHUT: Yes, I think it has actually been
10 both.

11 MR. JOHNSTON: Oh, yes.

12 MR. EISENHUT: Conrad, you probably can remember the
13 details. But there were actually plants where plugs had
14 fallen out previously, that is, they weren't properly inserted
15 when they were explosive plugs or mechanical plugs. As Bill
16 Johnston said, there were numbers of cases where there were
17 actually loose parts which were significantly bigger than these
18 very small steam plugs, that were in plants. And albeit, if
19 you go back to the Ginna event, that in fact was a very large
20 hunk of steel, a loose part, that vibrated.

21 COMMISSIONER ASSELSTINE: Yes.

22 MR. EISENHUT: So, what we look for is the kinds of
23 things that Bill mentioned earlier. We look at, where can it
24 get lodged; can it affect some hydraulic considerations; can
25 it vibrate to the point where it would cause a problem. But

1 you basically go through that consideration. And again, that
2 kind of evaluation is not unique, we have done that on a number
3 of other plants.

4 COMMISSIONER ZECH: Thank you.

5 CHAIRMAN PALLADINO: You want to go ahead?

6 COMMISSIONER ASSELSTINE: I had a couple of others
7 on steam generators.

8 CHAIRMAN PALLADINO: He is not leaving steam generators.

9 COMMISSIONER ASSELSTINE: Okay, go ahead, then.

10 MR. THOMPSON: No, the only other thing I was going
11 to say, that there is one other item that we have, the April 5
12 letter from UCS which has been directed to the staff for
13 response. We have that under review right now. Generally,
14 they cover areas that we have looked at before, but we want
15 to prepare a detailed response back to you and we have that
16 response under preparation at this time.

17 CHAIRMAN PALLADINO: When might we expect that
18 response? Should I not ask any questions about the letter?

19 MR. THOMPSON: We have some individuals in the
20 audience who can probably respond to the details. We would
21 anticipate completing that by early May.

22 CHAIRMAN PALLADINO: Let me just ask one about the
23 letter, since you brought it up.

24 (Laughter)

25 CHAIRMAN PALLADINO: It says, "Based on the information

1 available to us, UCS has concluded that a safety evaluation
2 of the steam generator tube rupture accident at TMI-1 has
3 not been performed in accordance with the Commission's safety
4 requirements for the design basis accidents."

5 Is that true or not?

6 MR. THOMPSON: I think I'd like to ask Dr. Sheron,
7 Brian Sheron, to respond to that. Maybe if you could identify
8 the page for us.

9 CHAIRMAN PALLADINO: It was the last page. There
10 are others along the way.

11 MR. SHERON: Brian Sheron, Chief of the Reactor
12 Systems Branch.

13 The steam generator tube rupture analysis that was
14 performed by GPU for TMI-1 was done back in the FSAR when the
15 plant was licensed. This plant was licensed, I think, right
16 at the time the general design criteria were being promulgated
17 and, I believe, it was not necessarily required to meet the
18 general design criteria.

19 The staff did do a review at that time, which was
20 around 1971, and concluded that analysis -- I'm sorry, that
21 the plant design did meet the intent of the general design
22 criteria.

23 Since that time, obviously the staff interpretation
24 of the regulations and alike has led to analyses for steam
25 generator tube ruptures being done differently than they were

1 at that time. We have not gone back and asked TMI to re-do
2 their entire steam generator tube rupture analysis according
3 to assumptions that are made today.

4 The issue would be generic since it would affect a
5 lot of plants, and we would treat it on a generic basis for
6 that reason.

7 CHAIRMAN PALLADINO: I don't know what to get from
8 that. It means that either a) you don't think it's necessary
9 to do it or, b) it takes too much trouble to do it or, c) we
10 ought to do it?

11 COMMISSIONER ASSELSTINE: Why couldn't you do an
12 up-to-date analysis for this plant now, recognizing that you
13 may want to approach it generically for everything else. But
14 why couldn't you do one for this one now, using current
15 assumptions?

16 MR. SHERON: When you say "we," you mean the staff
17 do one, or to ask GPU to do one?

18 CHAIRMAN PALLADINO: Well, whoever would normally
19 do it.

20 COMMISSIONER ASSELSTINE: I guess the licensee --

21 MR. SHERON: We would normally ask a licensee or
22 an applicant to do an analysis if one was required.

23 CHAIRMAN PALLADINO: And I don't have an appreciation
24 of why that's so difficult to do or why it shouldn't be done.

25 MR. EISENHUT: Well, just a couple of comments on it.

1 One is, a lot of these older plants do not have a complete
2 Chapter 15 analysis of a lot of accidents like we would do today.

3 Number one, it's an extensive evaluation to be done
4 to re-do the -- basically, you re-do a number of the accident
5 evaluations.

6 Number two, we have not adopted that as a generic
7 requirement and it would be just as easy if we tried to treat
8 this as any other operating plant. We thought that was
9 basically the Commission's guidance which would say we would
10 not levy that kind of a requirement on the plant unless there
11 is a reason to do it, or the Commission chose to do it.

12 So, it is certainly something that could be done.

13 CHAIRMAN PALLADINO: Is it a big thing to do? For
14 the steam generator, just let's take the steam generator.

15 MR. EISENHUT: The steam generator? We'd have to get
16 an estimate.

17 CHAIRMAN PALLADINO: Maybe tomorrow we might get
18 such an estimate from GPU. Okay.

19 The reason I ask is, this steam generator -- these
20 steam generators had sodium thiosulfate, I believe, introduced
21 and so they are not the normal kinds of steam generator
22 problems. If there is any contemplation that plants start up,
23 any kind of a significant event such as even a single tube
24 rupture would be viewed with great consternations in a lot of
25 areas, including here.

1 So, a little bit of extra care on the physical
2 hardware, it seems to me, would be prudent. And I don't know
3 what the balance against that prudence.

4 MR. EISENHUT: Yes, and I didn't mean to be
5 argumentative, except we tried to follow the Commission's
6 guidance and treat them like every other operating plant. Which
7 meant we went in the direction of ensuring the tubes' integrity
8 was up to the standard which we would maintain at every other
9 plant, such that you would not be led to require an additional
10 different evaluation, different analysis.

11 It is something that certainly could be done.

12 MR. MURLEY: Darrell, could I add a point there? We
13 are going to talk in just a moment about the training of the
14 operators. But they all have had training on the new procedures
15 down at the Lynchburg simulator, B&W simulator.

16 And one of the accidents that they are trained on is
17 a steam generator tube rupture accident. We have observed
18 some of those training cases. I am certain that B&W has done
19 an updated analysis using the latest --

20 MR. EISENHUT: Yes, they have.

21 MR. MURLEY: -- criteria. So, I'm certain that the
22 accident has been analyzed by B&W and that these operators
23 have been trained using the latest analysis. Basically, I think
24 we are talking about GDC-17, aren't we, whether you require
25 loss of off-site power at the same time as you have a tube

1 rupture accident.

2 CHAIRMAN PALLADINO: Well, I have some questions that
3 were raised by this letter with regard to training.

4 MR. MURLEY: We will get to that in a minute.

5 MR. EISENHUT: I think there is a generic evaluation
6 that was done by B&W.

7 MR. MURLEY: Yes.

8 MR. EISENHUT: That has been factored into the B&W
9 program and in fact factored into the emergency procedures, I
10 believe, and all operators have now been trained on it, that
11 generic evaluation.

12 CHAIRMAN PALLADINO: Well, I want to come back to the
13 training later. Okay, thank you.

14 MR. THOMPSON: If there are any other specific
15 questions on the steam generator, we can entertain those now.
16 If not, I guess I'd like to turn it over to Dr. Murley to
17 give you an up-to-date status on --

18 CHAIRMAN PALLADINO: I have two questions, and then
19 others may have questions as well.

20 With regard to training, I think UCS says in here
21 that at the hearings they asked questions -- I forgot the
22 statistics of who didn't know what. But I think there were
23 in the order of four of them quizzed and only one knew one
24 condition and none of them knew the other condition, implying
25 that maybe the training isn't all that effective.

1 MR. MURLEY: We'll talk about that, if we could,
2 later.

3 CHAIRMAN PALLADINO: All right.

4 MR. MURLEY: We've got a presentation on training.

5 CHAIRMAN PALLADINO: All right. Oh, I thought you
6 were through with steam generators.

7 MR. THOMPSON: Well, they are talking about the
8 operators and the operator readiness. That is one of the
9 issues that is going to be covered by Dr. Murley.

10 CHAIRMAN PALLADINO: -- another one, improvisation
11 that I presume you will cover because they say these things
12 are complex and I am sure they are complex. But it was not
13 apparent to me that improvisation was such an important
14 aspect.

15 (Commissioner Bernthal leaves meeting.)

16 MR. MURLEY: Yes. The general answer to that, Mr.
17 Chairman, is that these people are going to have procedures and
18 these procedures have been -- oh, yes. And they have been
19 well thought out. I have seen the procedures myself in the
20 control room and they are not going to be operating blind.

21 CHAIRMAN PALLADINO: The impression on improvisation
22 is that there comes a point where the procedures run out of
23 guidance and you are on your own.

24 COMMISSIONER ASSELSTINE: Yes.

25 MR. THOMPSTON: There is a point in any of these

1 emergency operating procedures, and that's the whole basis for
2 the new operating procedures, that they allow you the freedom
3 to use what equipment and hardware is available in an analyzed
4 way so that the operator is not flying blind like he had been
5 in the previous where he only had one set of steps to address
6 a particular transient or emergency operation.

7 That's what you make use of, any available equipment
8 and it's analyzed, and that is part of the whole basis for
9 moving to the symptom-based procedures.

10 CHAIRMAN PALLADINO: But that's an option sort of
11 program and not an improvisation.

12 MR. THOMPSON: That's correct. That is an intended
13 approach to provide that flexibility.

14 CHAIRMAN PALLADINO: All right, other questions?

15 COMMISSIONER ZECH: No.

16 COMMISSIONER ASSELSTINE: I had just a couple. You
17 talked about the license condition for an additional inspection
18 within what, 90 or 120 days, however it finally comes out.

19 What was the motivation for that extra license
20 condition, the extra inspections? Was it questions about the
21 effectiveness of the tube plugging program, or continued
22 questions about this intergranular attack?

23 MR. JOHNSTON: That was added or put in at the time
24 of the kinetic expansion program and was simply to give us
25 additional assurance that after a period of operation the

1 kinetic expansion remains effective.

2 COMMISSIONER ASSELSTINE: Okay.

3 MR. JOHNSTON: And indeed, it would pick up any
4 continuation of any corrosive attack that might still be going
5 on. It's an added measure of assurance and margin, if you
6 like. It's our conclusion that the plant meets its licensing
7 basis now and it is no more likely to have these kinds of
8 events than any other plant that meets its license condition.

9 COMMISSIONER ASSELSTINE: You mentioned that the
10 tube plugging level is about five percent now. Can you give
11 me a feel for what the tube plugging level was at, say,
12 Surry and Turkey Point when those utilities decided to replace?

13 MR. JOHNSTON: I'm guessing it's 10 or 12 percent
14 because I don't have the book back here that tells us.

15 MR. EISENHUT: As I recall, it was a lot higher.
16 If it interpreted Conrad's saying it was something over 20
17 percent and was told it got actually up to maybe 25 percent
18 on those plants.

19 MR. JOHNSTON: Okay, 25 percent.

20 MR. EISENHUT: But it went through, again, like it
21 did here. As I recall, we went through step-wise more and
22 more ECCS evaluations in more depth, higher priced evaluations
23 to show that it was acceptable up to that level. And at some
24 point, it got to the point it actually started impacting
25 power operation. But it's some quite high number.

1 COMMISSIONER ASSELSTINE: Have there been any
2 indications that GPU is considering replacing the steam
3 generators? Are they talking to anybody about finding steam
4 generators or looking in any way, any signs at all that that's
5 under consideration?

6 MR. JOHNSTON: Not on the record, not any.

7 MR. EISENHUT: Not that I am aware of.

8 COMMISSIONER ASSELSTINE: Okay. The only other
9 question I had, had to do with the UCS letter that the
10 Chairman mentioned.

11 Bill, you said that the objective here was to bring
12 the conditions of these tubes up to the original licensing
13 basis so that they are in as good a shape as the tubes at any
14 other plant. And yet, the sense I get from reading the UCS
15 letter is that because of the degraded condition of the
16 tubes there have to be a number of changes to the emergency
17 procedures, changes that would complicate what is already a
18 response to a very complicated transient and would make it
19 more difficult to handle a tube rupture at this plant than at
20 other plants. There is a whole variety of things that are
21 described in the letter, some of which sound pretty serious
22 to me.

23 But am I missing the point of the letter?

24 MR. EISENHUT: Two comments. I'm not sure I said up to
25 the original level, someone may have. Obviously, up to the

1 original level they are brand-new, virgin tubes, undegraded.
2 But we think it was up to a level where we think the tubes
3 were adequately safe, they are not significantly degraded and
4 you don't really, of course, bring the tubes up. What you
5 do is, any tube that is in question you remove from service
6 by plugging it.

7 COMMISSIONER ASSELSTINE: Right.

8 (Commissioner Bernthal rejoins meeting.)

9 MR. EISENHUT: So that only the tubes that are left,
10 only tubes that are acceptable are left and by "acceptable"
11 we maintain the plugging limit for waste -- tube material
12 removal. That has been used in many, many plants; has been
13 shown to be a reliable plugging limit. It is one that gives
14 you an adequate margin. It gives you adequate margin even
15 for degradation through a fuel cycle was the way it was
16 designed, for a degradation mechanism. You plug at the
17 beginning of the cycle, you have degradation through the end.
18 So, even at the end of the cycle with various degradation
19 means at work, you still have an adequate margin on the tube.

20 Bill, would you care to elaborate? Basically, we
21 think the tubes are maintained at an adequately safe level
22 with this kind of an approach in place, as I see it.

23 MR. JOHNSTON: Yes. There is an assumption, I
24 guess, that the UCS letter contains which would be contrary
25 to the record that has been established over the last several

1 years. The staff has supplied substantive information. We
2 have issued several NUREGs. We have had several hearings before
3 the Boards. We have issued summary disposition motions, pre-
4 filed testimony. There is a hearing record, all of which at
5 the end concluded that the steam generator was indeed brought
6 back to the licensing, the original licensing basis. That's
7 what the substance of the staff position is, that we believe
8 that that's the case.

9 I just looked up and got some additional information
10 that deals with what percentage of tubes are plugged in some
11 other operating plants.

12 We have one plant that's running with 22 percent of
13 the tubes plugged, and two others that have more than ten
14 percent that are currently operating plants. And that is not
15 including the Robinsons, or Surrys, and the ones that have
16 actually -- and the Point Beach which have actually changed
17 out their steam generators.

18 So that these people are not in that ball park yet.

19 COMMISSIONER ASSELSTINE: Let me ask you on the
20 comparison, though, with other plants. If the tubes are not
21 degraded below what is provided at other plants, first of all,
22 is UCS right in saying that the ^{shell-to-} ~~sheater~~ tube temperature
23 difference for this plant is lower than for others, and that
24 they are asking to use a lower sub-cooling margin.

25 And if so, if they are right on that, if these tubes

1 are just as good as at other plants, why are they proposing
2 using both of those numbers in those two areas?

3 MR. JOHNSTON: Well, those are choices, those are
4 prudent choices which the utility makes. The design basis
5 is still 150 degrees in this plant as it is in the other
6 B&W plants. Some of the B&W plant owners have chosen, on their
7 own decision, to use lower numbers.

8 COMMISSIONER ASSELSTINE: And why did they do that?

9 MR. JOHNSTON: A&O-1 is using 50 degrees.

10 COMMISSIONER ASSELSTINE: And why did they do that?

11 MR. JOHNSTON: Because any time that you cool down
12 a B&W plant, you do indeed put the tubes under tension, and
13 prudent operation would say, let's put out tubes under less
14 stress than, you know, just operate them in a more conservative
15 manner. And this plant has chosen to do that, too. But they
16 are not the only one. It is not something, at least as we
17 understand it, is something that they had to do. It is
18 something a prudent operator might choose to do and some others
19 have, indeed, also done.

20 But the design is still 150.

21 CHAIRMAN PALLADINO: But there is the implication
22 in the UCS letter that this is dissimilar from other similar
23 plants.

24 COMMISSIONER ASSELSTINE: That's right.

25 CHAIRMAN PALLADINO: And you are saying it really

1 isn't.

2 MR. JOHNSTON: Well, it's their prerogative to make
3 that claim.

4 MR. EISENHUT: No, he is saying the design is the
5 same.

6 MR. JOHNSTON: I'm saying the design --

7 MR. EISENHUT: The design for 150 degree temperature
8 differential in an emergency. You can therefore -- you can
9 cool it down slower which puts less stress on the tubes.

10 CHAIRMAN PALLADINO: But the implication was that
11 here the situation is different because something is different
12 from other PWR systems.

13 MR. MURLEY: The allowable sub-cooling margin,
14 Darrell, they have chosen to go to 25 degrees.

15 MR. JOHNSTON: Again, that was an arbitrary choice
16 which they had. They could choose it. We reviewed it, as
17 we understand it, we accepted it.

18 Other plants -- I'm not sure -- may be using the
19 same number.

20 MR. THOMPSON: But we were going to, in essence,
21 try to address these types of details, you know, in the
22 response. We got the letter and met briefly on it yesterday
23 when it was assigned to us and I think if you want to get in
24 specifics on the 20 degrees versus 50, I think we can have
25 someone who can address that in a kind of generic sense.

1 But I think I would prefer, if you want to rely on
2 a response for us, that we are able to provide it.

3 COMMISSIONER ASSELSTINE: Yes, maybe we should give
4 you the chance to look at it, yes.

5 But I think from my standpoint, that's one of the
6 things that I had a particular concern about. When I read it,
7 the sense I got was, this plant is different. It's different
8 because of the degradation to the tubes, and you are taking a
9 complex transient and difficult emergency procedures and making
10 them substantially more so because of the condition of the
11 plant, and that's --

12 MR. THOMPSTON: I certainly think that's the tone of
13 the letter. Certainly, we have looked at the ATOC procedures,
14 the crew training. When I was with the Division of Human
15 Factors Safety, we had a group go down and walk them through
16 the training in Lynchburg on the simulator there to get our
17 level of comfort that in fact in particular on the steam
18 generator tube emergency operation procedure, that that was
19 one which was viable; was one that the operators could follow.

20 We came back with the feeling that, yes, indeed it
21 was. The crews are trained on it, they are licensed on it,
22 and I think Dr. Murley or Rich Starosteky may be addressing
23 part of what they are doing as a follow-up to this.

24 So, it is something that we have not in our audits
25 in oversight been led to believe is a particularly difficult

1 response for the operators to do.

2 COMMISSIONER ASSELSTINE: I mean, this whole area is
3 a tricky transient anyway. It is a pretty difficult one to
4 deal with the path out to the environment.

5 MR. EISENHUT: Well, I'm not sure it's that much --
6 it's certainly one that you have to be trained in.

7 COMMISSIONER ASSELSTINE: Yes.

8 MR. EISENHUT: Other accidents are also tricky when
9 you look into them.

10 MR. THOMPSON: Actually, steam generator tubes was
11 one that people fairly well understand and identify fairely
12 frequently, and drill on it probably more than any others.

13 MR. EISENHUT: Well, that is true. But also, the
14 risk of a steam generator tube rupture, we have all sat around
15 this very table and discussed, is extremely low also.

16 So, you have to keep these things in mind. But, as
17 Hugh said, we just got the letter for action. We will be
18 going through it in some depth, we will be looking at the pros
19 and cons. But the differences themselves are not necessarily
20 bad. So, we will have to take a look at that.

21 CHAIRMAN PALLADINO: Why don't we proceed on another
22 item, proceed according to your agenda?

23 MR. THOMPSON: Okay, Dr. Murley?

24 MR. MURLEY: Whenever we have a plant ready to start
25 up after a long outage in the region, we do some special

1 inspections and readiness evaluations to assure ourselves that
2 the plant and the operators are ready to restart the plant.
3 We have done this on Pilgrim, on Oyster Creek, on Salem. We
4 will do it on Peach Bottom-2 when it comes out of a long
5 outage to replace pipes.

6 We have also done it for TMI-1 and, in fact, we
7 have gone well beyond our normal inspections. We are going to
8 talk about the results of some of those things.

9 The most comprehensive analysis we do is the SALP
10 report. Could I have Chart 6, please?

11 We have just completed a SALP appraisal. The Board
12 met in March. It was chaired by Rich Starostecki who is to
13 my left. It included senior managers from NRR and I&E, as
14 well as the region, and also the senior resident inspector,
15 Rich Conte, who is with me here today also.

16 So, therefore the SALP represents an assessment of
17 the broad range of NRC staff. This latest SALP points out some
18 weaknesses in the operations, but by and large the picture
19 that emerges is one of a good operating team and strong
20 management involvement and control of plant activities.

21 We have to keep in mind, though, that the plant has
22 been in a shutdown mode for several years, and one would expect
23 that the operations staff would be familiar with their jobs
24 and not make mistakes.

25 There is nowhere near the number of challenges to the

1 operators in a plant like this that has been shut down than an
2 operating plant would represent.

3 COMMISSIONER ASSELSTINE: It's sort of tough to get
4 a comparison for how much confidence to put in the large
5 number of Category I items for a plant that has been essentially
6 shut down for several years.

7 MR. MURLEY: Yes.

8 COMMISSIONER ROBERTS: When was the previous SALP done?

9 MR. MURLEY: The previous one was just about a year
10 ago.

11 COMMISSIONER ROBERTS: (Inaudible)

12 MR. MURLEY: On TMI-1? This one was slightly better.
13 We see, for example, fewer procedural errors. But again, they
14 are both for the same shutdown mode.

15 COMMISSIONER ASSELSTINE: In fact, they haven't had
16 one, have they, for operation?

17 MR. MURLEY: No.

18 So, with that caveat, one has to keep in mind what
19 we look for in SALPs like this, are there any fundamental
20 underlying problems and again, as I said, we don't really see
21 any. We see strong management involvement and control of
22 the operators and the plant activities. That's the kind of
23 thing you would look for.

24 Our experience in Region I is that when a plant
25 returns to operation after a long outage, there in fact may be

1 equipment errors and personnel errors. So, that's the kind of
2 thing we will be looking for.

3 One general comment on the SALP is that there are
4 only a few allegations that we have had on this plant. There
5 are none, to my knowledge, that are outstanding now. That is
6 usually a question that the Commission is interested in.

7 Recent information we have gotten on some possible
8 irregularities in a general employment training testing
9 program -- this is not an allegation but is something that we
10 routinely will look into -- I just learned about that today
11 so I don't know anything more about it.

12 That's all I planned to say on SALP. A major effort
13 that we have looked into on TMI-1 is their training program
14 and their operator readiness.

15 COMMISSIONER ASSELSTINE: Before you leave SALP, let
16 me ask you one question. I notice that one of the areas where
17 they got a "2" was licensing activities. As I recall, the
18 staff said this was the worst plant in the country on
19 environmental qualification of electrical equipment, and they
20 got a "2."

21 How do you square that?

22 CHAIRMAN PALLADINO: In terms of --

23 COMMISSIONER ASSELSTINE: In terms of performance
24 and documentation. How do you square that with the "2" rating
25 for licensing activities?

1 MR. MURLEY: The licensing activities, those analyses
2 are done by NRR and I guess I'll --

3 COMMISSIONER ASSELSTINE: How do you square it?

4 MR. MURLEY: Can I turn to Hugh Thompson?

5 COMMISSIONER ASSELSTINE: I notice, there is some
6 brief discussion --

7 MR. THOMPSON: Let me ask John Stolz who was the
8 NRR manager there. I know we focused on the environmental
9 qualification issue and the response to that over the past
10 year. If my memory serves me right, it was a while back that
11 it was a major concern. John?

12 MR. STOLZ: I think you have to recall that the
13 previous assessment reflected very unfavorably on the
14 environmental qualification, and that was in fact reflected in
15 the previous SALP review.

16 COMMISSIONER ASSELSTINE: Did they get a "3"?

17 MR. STOLZ: For that one issue they did. But for
18 overall --

19 COMMISSIONER ASSELSTINE: On licensing activities?

20 MR. STOLZ: But the overall, I think that came also
21 out to "2."

22 COMMISSIONER ASSELSTINE: Okay.

23 MR. STOLZ: Due to the innumerable audits that we
24 held during the course of this period, if you recall, especially
25 on the aux feedwater system, the licensee's performance obviously

1 improved and in fact, we regard the environmental qualification
2 of this licensee to be above average now.

3 But it's due to this so-called remedial action that
4 went on during this period that the licensee turned out okay.
5 So, that's the result of this.

6 COMMISSIONER ASSELSTINE: All right, so the "2"
7 reflects improvement.

8 MR. STOLZ: Yes. Not only that, but the "2" largely
9 is based on the fact that the licensee's performance in
10 so-called "non-critical" areas, those areas that were not
11 immediately needed for restart, we reflected a "2" to account
12 for the fact that the licensee's attention wasn't devoted as
13 much to those areas as it was to the restart issues.

14 COMMISSIONER ASSELSTINE: Yes.

15 MR. EISENHUT: Yes, the point I was going to make,
16 the assessment is all licensing activities.

17 COMMISSIONER ASSELSTINE: Yes.

18 MR. EISENHUT: That is, in this case all licensing
19 requirements, environmental qualification being one of those.

20 COMMISSIONER ASSELSTINE: One of them.

21 MR. EISENHUT: And then it largely fell in the
22 previous rating.

23 COMMISSIONER ASSELSTINE: Okay.

24 CHAIRMAN PALLADINO: Okay, you want to go on?

25 MR. MURLEY: The major effort that we have done in

1 looking for the readiness to restart is to evaluate the
2 operators and their capability.

3 I would like to ask Rich Starostecki to talk about
4 what we have done and what we found.

5 MR. STAROSTECKI: In late 1983, in the fall and
6 winter of '83, there came the question of TMI-1 being shut
7 down so long, and we had a concern as to what is it the
8 operators really knew. And at that point in time, after
9 consultation with NRR, the ATOC procedures were being implemented
10 at several plants, including Three Mile Island.

11 So, we came up with the unique effort to orally
12 examine and conduct plant walk-throughs for as many of the
13 operators as we could. And in February of 1984, we had a
14 team of people made up of the prior senior resident, an
15 examiner and a senior resident from B&W plant in Region V; an
16 instructor from the Chattanooga Training Center; a supervisor
17 from the Region I office in charge of operator licensing, and
18 they interviewed 26, the available 26 people that were on
19 site, with the view of trying to understand what level of
20 knowledge they had and what skills they possessed.

21 The effort did identify that people were able to
22 communicate and demonstrate to us that they could handle
23 casualties, and we came up with a number of deficiencies that
24 we documented. These deficiencies led us to conclude that
25 people got rusty, and it was the routine operations that one

1 would expect the operators to be able to handle that were posing
2 a lot of difficulty, things such as -- and I'll list the two
3 items that dragged on the longest.

4 The two items were understanding the detailed
5 functional controls of what one refers to as the electro-
6 hydraulic control system, which is the system used to control
7 the main turbine. They need a lot of training on that and we
8 said that's a concern. Now, that is not a safety-related
9 system but that is something we expect the operators to be
10 familiar with.

11 The other problem that we noticed was the ability
12 to properly estimate the approach to criticality. And again,
13 in hindsight, we see a flaw in that the training devices used
14 for the operators werenot equipped to do that. Everybody does
15 training after you reach criticality. So, it is the approach
16 to criticality that needed some more training.

17 COMMISSIONER ASSELSTINE: The simulators can't
18 simulate that, the B&W simulators?

19 MR. STAROSTECKI: I don't believe they had B&W
20 training for all the people on that approach to criticality
21 in estimating the critical position.

22 COMMISSIONER ASSELSTINE: I mean, that has to be
23 something --

24 MR. STAROSTECKI: I would turn to GPU and ask them
25 more details. But again, my answer to that is, when you look at

1 how much time these operators spend on the simulator, is that
2 where you put your attention. And I would expect them to put
3 more attention on coping with more severe transients and
4 accidents.

5 COMMISSIONER ASSELSTINE: Yes.

6 MR. STAROSTECKI: So, GPU in fact does have a basic
7 principles trainer right there near the site --

8 COMMISSIONER ASSELSTINE: Yes --

9 MR. STAROSTECKI: -- but it doesn't model this very
10 event.

11 COMMISSIONER ASSELSTINE: That's right.

12 MR. STAROSTECKI: So, therein lies -- it didn't at
13 the time model the event, and that was the problem. It does now.

14 COMMISSIONER ASSELSTINE: Yes. If you had a plant
15 reference simulator, you would presumably put your people right
16 back into that pretty quickly and run them through it, bring
17 them up to speed.

18 MR. STAROSTECKI: Yes, I agree.

19 CHAIRMAN FALLADINO: You said they now have the
20 capability?

21 MR. STAROSTECKI: The basic principle trainer does
22 now afford them the opportunity to do that. But it's still --

23 COMMISSIONER ASSELSTINE: But that's not a simulator.

24 MR. STAROSTECKI: The lesson we have learned in
25 Region I from it is, it's hard to get operators to be familiar

1 with an operating plant unless you have a basic principles or
2 plant-specific simulator, or are operating a plant.

3 COMMISSIONER ASSELSTINE: Yes.

4 MR. STAROSTECKI: The findings are as indicated on
5 the slide. I don't mean to present a bleak picture. In fact, it
6 was fairly encouraging. The people were well motivated, there
7 has been good morale.

8 We have conducted follow-up interviews. NRR, as
9 Hugh Thompson has indicated in, I think it was March of 1984,
10 sent their people to specifically observe the same people we
11 interviewed, how they performed on the Lynchburg simulator.

12 Since then, August of '84 and just this April, we
13 have gone back and examined individuals and looked at records
14 and observed the training to see how they coped with these
15 deficiencies.

16 And furthermore, in my mind, I look at operator
17 readiness, and we have also spent an awful lot of time observing
18 performance during hot functional testing. Hot functional
19 testing has been performed almost every year, and it was
20 August-September of '83 that they had an awful lot of hot
21 functional testing where we had some problems. And the last
22 time we briefed the Commission, that was a point and a subject
23 of escalated enforcement.

24 Pardon me.

25 CHAIRMAN PALLADINO: No, go ahead.

1 MR. STAROSTECKI: We have subsequently seen them do
2 some hot functional testing in 1984 and just recently, this
3 past April, they finished some, including a repeat of the
4 Krypton injection and testing.

5 Yes, some mistakes have been made in the past, but
6 they have learned the lessons and the lessons were not
7 repeated. Procedures were followed and adhered to.

8 CHAIRMAN PALLADINO: Steve, do you have a real
9 concern on their capability to handle approach to criticality?

10 MR. STAROSTECKI: Not at all.

11 CHAIRMAN PALLADINO: Somehow, you generated that
12 feeling in me that they may not be capable.

13 MR. MURLEY: We made them go back in those areas
14 that they were rusty. You ought to mention, Rich, we asked
15 them to go back and increase their training, which they did.

16 MR. STAROSTECKI: I'm sorry, I maybe mischaracterized
17 it. I was trying to give you a flavor of the types of items,
18 and I maybe ought to clarify that most of the deficiencies that
19 we found by and large related to the reactor operators. Very
20 few of the senior reactor operators had identified deficiencies.

21 In the examples I gave you, six reactor operators
22 had a problem with that. So, in the real world am I
23 concerned? No because the senior reactor operators did not
24 have a problem. It's really a commentary, I think, on a
25 fairly comprehensive training program and I don't want to

1 mislead you in saying that's a concern to me.

2 CHAIRMAN PALLADINO: Okay. Well, I'm glad I asked
3 because somehow I had gotten that feeling. But I gather those
4 that had some -- showed some inadequacies, have gone back for
5 the training?

6 MR. STAROSTECKI: All the inadequacies that we
7 identified resulted in retraining for all of the people, and
8 we have gone back and followed up to see how well they were
9 addressed for all the people. We have been satisfied that
10 the training program has thoroughly addressed those.

11 COMMISSIONER ASSELSTINE: Did we give any requal
12 exams to these operators?

13 MR. STAROSTECKI: We have not, to the best of my
14 knowledge, given any of our own requal exams.

15 COMMISSIONER ASSELSTINE: Okay.

16 CHAIRMAN PALLADINO: But sort of like requalification.

17 MR. THOMPSON: We went and originally re-examined
18 all of the TMI operators. So, to that extent we have had a
19 check on all their operators.

20 COMMISSIONER ASSELSTINE: Yes, and then it's been
21 their requal program since that.

22 MR. STAROSTECKI: Everybody has looked at the
23 requal program. The only thing we haven't done in my mind in
24 terms of requal is administered a written exam ourselves.

25 COMMISSIONER ASSELSTINE: Yes.

1 MR. STAROSTECKI: The oral exams and walk-throughs
2 that we did in February of '84 were more comprehensive than we
3 would do for requal today. We only do 20 percent of the
4 licensed operators.

5 COMMISSIONER ASSELSTINE: Yes, that's why I was
6 asking, did they fall in the 20 percent; yes.

7 MR. STAROSTECKI: We did more than 20 percent, we
8 did 26 of some 35 operators, and we did the orals the way we
9 would have done for a regular requal effort.

10 So, we have satisfied ourselves that, yes, we
11 recognize there has been a shutdown condition but the under-
12 lying training, the underlying knowledge and skills seem to be
13 there. But we still need to satisfy ourselves once the plant
14 changes states that they can handle the new demands.

15 That raises the next question of the control room
16 environment.

17 CHAIRMAN PALLADINO: Can I just make a comment?
18 UCS did make some comments on a sampling where they asked
19 questions. You might want to just look at that closely.

20 MR. MURLEY: Well, the short answer there is that
21 they were testing someone's memory. But we are not going to
22 rely on the operator's memory. He is going to have procedures
23 in front of him that will address that very question. So, I
24 don't --

25 CHAIRMAN PALLADINO: Well, look at it.

1 MR. MURLEY: Yes.

2 CHAIRMAN PALLADINO: It's one that you've got to be
3 satisfied that it doesn't give you a clue to some other
4 inadequacies.

5 MR. STAROSTECKI: The control room environment at
6 Three Mile Island, in our view, was well controlled. There is
7 very good discipline. There is a lot of control over access
8 to the control room, and we think that's a very positive
9 attribute.

10 On a number of occasions, Tom Murley and myself, we
11 have been to that plant. I have been to that plant all hours
12 of the day and night and have asked people without any
13 preparation questions regarding their activities, and in all
14 cases the operators have come forward, in response to our
15 questions, with, I think, the correct answers.

16 Although we have not talked to the UCS, based on
17 my reading, I would want to consider more what they are trying
18 to say. I am aware that they administred written exams to
19 those operators without any advance training. My examiners
20 reviewed the records and from what I understand, nobody
21 scored below 82 percent. So, in that regard they seem to be
22 doing quite well on surprise tests.

23 In summary, I would just like to say from an
24 operator readiness standpoint, we have had a number of different
25 people from other regions, from the training center, help us

1 take a look at the quality of these operators and we are
2 satisfied that they are as well prepared, if not better, than
3 some of the other NTOL plants reaching this stage. That
4 the senior reactor operators by and large have had, the shift
5 supervisors have had prior operating experience. There are
6 some expected weaknesses in the RO ranks and the training
7 program has corrected them.

8 COMMISSIONER ASSELSTINE: Do they have at least one
9 experienced SRO on each shift?

10 MR. STAROSTECKI: Yes, sir.

11 COMMISSIONER ASSELSTINE: Are the ROs mostly new?

12 MR. STAROSTECKI: ROs, as far as I am concerned, are
13 all new. None of them have ever seen the plant operate.

14 COMMISSIONER ASSELSTINE: Okay.

15 MR. THOMPSON: There may have been an auxiliary
16 operator or two in that group.

17 MR. STAROSTECKI: Well, there may have been, Hugh,
18 but they did not necessarily operate as a reactor operator.

19 MR. THOMPSON: There were none that were previously
20 licensed..

21 CHAIRMAN PALLADINO: Do you want to go on?

22 MR. MURLEY: With regard to plant hardware, Chart
23 No. 7. I think the points I want to make here, that the plant
24 has been maintained well during its shutdown phase. It
25 should be No. 7, Mr. Chairman.

1 CHAIRMAN PALLADINO: Are they numbered?

2 COMMISSIONER ASSELSTINE: No.

3 MR. MURLEY: It's been maintained well. The
4 equipment has been operated. They have gone through their
5 surveillance tests during this period.

6 It's probably, in comparison with other plants after
7 an extended outage, there are probably fewer open inspection
8 items than in other average plants. We have about -- we keep
9 a list, computerized list, of open inspection items. There
10 are about 70-some for TMI-1. Some of those open items are,
11 for example, things that we need to look at after Cycle 6,
12 some regulatory requirements that we put on that are not due
13 to be done until Cycle 6.

14 And then, the resident inspector keeps this list of
15 items and it tells him that he's got to look at that.

16 A typical operating plant might have 100 such open
17 inspection items. So, it's, as I said, slightly less.

18 I think that's a summary of all I wanted to say
19 about plant hardware. It's in good shape, we think.

20 COMMISSIONER ASSELSTINE: Before you leave that, is
21 the environmental qualification area now closed out for this
22 plant, everything checked, documentation reviewed, the equipment
23 all checked to make sure that what they asserted as qualified
24 is in fact qualified? And do they have a maintenance program
25 to make sure that the equipment stays qualified?

1 MR. MURLEY: Was that a licensing question?

2 MR. CONTE: Excuse me, Tom, maybe I can start off
3 with that.

4 MR. MURLEY: This is Rich Conte, the senior resident.

5 MR. CONTE: Rich Conte, senior resident for TMI-1.

6 Right now, we are doing this week the certification
7 item on small break LOCA EQ. The compliance with 50.49 is
8 being handled like the other plants. There is no special
9 inspection verification of the program right now.

10 Much of the equipment that is going in for the small
11 break LOCA EQ rule is going to satisfy the 50.49. So, we are
12 getting a double benefit there. The inspection this week is
13 oriented towards the hardware installation, program review
14 and adequacy of the program.

15 A little has been done with some of the Licensing
16 Board issues with respect to small break LOCA radiation EQ,
17 what have you. As far as I could see, there are programs in
18 place for maintaining or keeping the equipment under
19 environmental qualification.

20 But as far as I know, we are handling TMI-1 like
21 all the other operating plants with respect to developing a
22 special inspection for program adequacy.

23 COMMISSIONER ASSELSTINE: Okay. So, you get maybe
24 some benefits in those two areas that you mentioned. I
25 guess emergency feedwater was one, also.

1 MR. CONTE: That's correct, sir.

2 COMMISSIONER ASSELSTINE: And the small break LOCA
3 one. But essentially, the EQ area would be handled like any
4 others which is, you will get to it at some point down the
5 road when those get turned over to the regions.

6 MR. CONTE: That's correct, sir.

7 MR. EISENHUT: Yes. As far as the first part of the
8 question, maybe Bob LaGrange can summarize where we are.

9 COMMISSIONER ASSELSTINE: I'm sensitive to this
10 subject because I just read another UCS letter on Calvert
11 Cliffs that's kind of interesting.

12 MR. LAGRANGE: Bob LaGrange, Equipment Qualification
13 Branch.

14 We have performed more review of TMI-1 in the EQ
15 area than at any other plant in the country. We have performed
16 actually three separate reviews. The first was in response
17 to the ECS-2206 on the EFW system.

18 The second was the CLI-8411 radiation certification
19 for the small break LOCA.

20 We have also completed our 50.49 compliance review.
21 The SER is in preparation for being issued to the licensee --
22 I don't think it has been issued yet. But we have completed
23 that review. We have looked at more documentation with the
24 possible exception of the Diablo Canyon plants where there
25 was a hundred-percent inspection of that documentation audit

1 some years ago.

2 This plant has had more documentation reviewed by
3 section members of the EQ Branch or its contractors than any
4 other plant out there. And as far as EQ goes, they are in
5 excellent shape at this time. We know more about their program
6 than any other plant, we reviewed more documentation than at
7 any other plant.

8 Some of the hardware issues that were hanging out
9 as a result of those reviews had to do with replacing or
10 modifying specific equipment of the plant, and those were
11 items that were left for verification, as Rich just mentioned
12 here. They will be looking at them.

13 COMMISSIONER ASSELSTINE: Thank you.

14 MR. MURLEY: If there are no further questions on
15 the plant hardware, I'd like to take a moment and discuss the
16 augmented inspection that we plan if there is indeed a restart.

17 After a long outage, as I said, it is typical that
18 we in the region, and other regions, for that matter, will
19 have augmented inspection coverage. We did it at Pilgrim and
20 Oyster Creek, we had round-the-clock coverage after they came
21 back from an outage.

22 Indian Point we did when they had a strike a couple
23 years ago, and you recall, Region V, Diablo Canyon had round-
24 the-clock coverage for a few weeks when they started up.

25 So, we intend to do the same thing at Three Mile

1 Island. It will be the highest priority plant in the region
2 for us. So, I'll just make the resources available for this
3 kind of coverage.

4 We expect to have inspection help from Regions II
5 and III because they have experienced resident inspectors
6 from B&W plants. I have made arrangements to do that.

7 CHAIRMAN PALLADINO: Can you explain what inspections
8 you are talking about?

9 MR. MURLEY: Yes. We normally have two resident
10 inspectors at Unit 1 now. We will have approximately six
11 inspectors there, so that we can have during times of evolutions
12 like going critical, like raising power to 48 percent and
13 then 75 percent, and so forth, we will have round-the-clock
14 coverage during those periods.

15 Then, they intend -- the plant intends -- to hold
16 for a period of training steam generator -- and so forth,
17 maybe a few weeks. If it is in a stable period, we will cut
18 back to maybe 16-hour coverage. That's what I mean by augmented
19 coverage.

20 We intend to have four hold points for NRC approval.
21 First, prior to taking it critical. Second is after natural
22 circulation testing but prior to going above five percent
23 power. We intend to have a hold point prior to going above
24 48 percent power level, and then there is another period at
25 75 percent where they would plan to hold it for a period and

1 before they went above 75 percent, we expect to have NRC
2 approval.

3 The intention of these inspections -- and we don't
4 expect, as you might know, a perfect error-free start-up. Our
5 experience tells us that there are equipment problems and
6 probably some procedural mistakes after a long outage like this.

7 CHAIFMAN PALLADINO: That is not any different in
8 the other plants.

9 MR. MURLEY: That's right. We will be looking, in
10 light of that experience that we have had, we will be looking
11 at the way they handle these problems as they come up; how
12 the management gets involved and how they correct them.

13 We will be looking at their adherence to procedures
14 and, of course, we will be checking ourselves the performance
15 of the equipment and the plant systems.

16 So this, we believe, will allow us to spot trends
17 earlier than we might otherwise with our normal inspection
18 coverage. And if the inspectors find problems, they will
19 notify the licensee management as well as our own NRC
20 management.

21 So, in summary, that is what we plan to do -- it
22 will probably be a three to four-month period of augmented
23 coverage and if there are problems developed and it extends,
24 then I'll just extend the coverage until it is in some kind of
25 a stable operation.

1 So, that summarizes our views from the region here.

2 COMMISSIONER ASSELSTINE: Tom, in borrowing people
3 from Region II and Region III, are you borrowing residents or
4 regional inspection people, or a combination of the two?

5 MR. MURLEY: I have asked the Regional Administrators
6 in Regions II and III if they can spare resident inspectors
7 who have experience on B&W plants.

8 COMMISSIONER ASSELSTINE: Yes.

9 MR. MURLEY: They said, yes, they can for about --
10 I think I have gotten four to six man-weeks commitment from
11 each one. I don't know the exact residents, but my impression
12 is that it's from a plant that is in the construction phase. It
13 may be Bellefonte or --

14 COMMISSIONER ASSELSTINE: Great, okay. I don't
15 mind so much if you borrow people from Oconee, but I would be
16 more troubled if you borrowed ones from Davis-Besse.

17 MR. MURLEY: Yes. I don't know exactly where they
18 are coming from.

19 MR. STAROSTECKI: I would just want to make a point.
20 We've got three sources of people to help us, Regions II and III
21 where they have in fact spent time as senior resident
22 inspectors, some of them in fact may be region-based people
23 today but were in fact resident inspectors.

24 The other source are two national laboratories where
25 we are getting examiners who have been giving examinations and

1 are certified on B&W plants. So, we are going to use those
2 kinds of individuals who can very quickly in a few weeks of time
3 give us an appreciation of the operational skills that these
4 operators would be demonstrating.

5 COMMISSIONER ASSELSTINE: Okay.

6 MR. STAROSTECKI: So, we are going for that kind of
7 expertise.

8 COMMISSIONER ASSELSTINE: Good.

9 MR. THOMPSON: In view of the time, I would just
10 like to touch lightly on two remaining issues. One is the
11 status of the certification status items. As you know, we had
12 155 items derived from the hearing record, Commission orders
13 that staff is required to certify to the Commission before
14 the restart of the plant.

15 We gave you a status report in SECY-85-64 in
16 February that there were three items that remained open. Of
17 those three, certification item 144, emergency preparedness
18 which dealt with communication deficiencies in the FEMA drills
19 in Lancaster and Dolphin Counties had been completed. We have
20 completed our certification on that in early April.

21 The subcooling monitoring -- margin monitoring
22 instrumentation error is one that we are currently still
23 evaluating the instrument error as well as the system
24 configuration to ensure that it comes within the 20 degrees
25 required by the ALAB 729. And we expect to complete our

1 evaluation of that sometime later this month.

2 With respect to the environmental qualification --

3 COMMISSIONER ASSELSTINE: On that one, on the sub-
4 cooling monitor, you say that the instrument error is less
5 than 20 degrees Fahrenheit. How much less?

6 MR. THOMPSON: As I remember, it kind of depends on
7 precisely where it is. If you want to know precisely, I'll
8 have to ask someone else.

9 COMMISSIONER ASSELSTINE: The concern is, is the
10 point raised in the UCS letter that if they are going to go
11 to a buscooling margin of 25 degrees and it's fairly close
12 to 20, that doesn't leave you much of an error band there.

13 MR. THOMPSON: As I understand, the error band is
14 fairly small, it's more along 17 degrees.

15 But let me see, John, do you have specifics on that?

16 MR. STOLZ: The subcooling margin monitor, of
17 course, operates whenever the reactor coolant pumps are on.

18 COMMISSIONER ASSELSTINE: Right.

19 MR. STOLZ: And it's normally well below 20, that's
20 the error. In addition to that, there is a so-called physical
21 configuration factor which accounts for the difference between
22 where you send the temperatures and the pressures from the
23 top of the candy cane. That allows -- that differs, and
24 that's about 1.3 degrees. So, when you add the two together,
25 you are well below 25.

1 So, we conclude that the subcooling margin monitor
2 is within the ALAB requirements. The other element that we
3 were considering -- and this what took the time -- was the
4 situation that happens when you are not using subcooling
5 margin on it, that is, whenever the reactor coolant pumps are
6 off. And under those circumstances, you are relying on in-
7 core thermocouples, that's the highest five, the average of
8 the highest five thermocouples that is read out from the
9 control room area.

10 Under those circumstances, one does a manual
11 calculation to determine subcooling margin. And we wanted
12 to verify what the margin was using the in-core thermocouple.
13 Today, we received a response from the staff that says, well,
14 the error in that is about twenty -- the physical configuration
15 factor is still 1.3. So, the total is still below 25. I
16 think that is where we are going to be coming to you on.

17 We will be accounting for that slight difference
18 above 20 degrees and in fact, the Appeals Board said approxi-
19 mately 20 degrees. They weren't pulling hair. So, we think
20 we can support the error analysis within a 25-degree sub-
21 cooling margin.

22 COMMISSIONER ASSELSTINE: Yes.

23 COMMISSIONER BERNTHAL: How do these numbers
24 compare to other plants?

25 MR. STOLZ: Other plants use 50 degrees subcooling,

1 and two other B&W plants in the higher ranges have less than
2 50 degrees, I think something like 35. ATA uses 25, and
3 those are the generic guidelines.

4 So that if other plants just submit an error
5 analysis, account specifically for the errors in their
6 instrumentation, we would accomodate them like we are doing
7 with TMI, we would evaluate the error.

8 The principal thing we are concerned with is that
9 we operate the plant without boiling, that we remain in
10 subcooling limits.

11 COMMISSIONER BERNTHAL: But how does the margin
12 compare with other plants? And we are talking about a margin
13 here roughly between 20 --

14 MR. STOLZ: The margin for other plants, in most
15 of the B&W plants, still uses 50 degrees.

16 COMMISSIONER ASSELSTINE: So, the margin is much
17 bigger for other plants.

18 MR. STOLZ: Because they presumably have not
19 evaluated the error in their instrumentation.

20 COMMISSIONER BERNTHAL: You mean the difference
21 between the subcooling factor and the normal error margin is
22 what I am talking about. And in this case we are talking
23 roughly 25 in the first and roughly 20 in the case of the
24 second. Now, what are we talking about --

25 MR. STOLZ: If you recall, in the 50 degree sub-

1 cooling margin there was an assumed error of 45 degrees in
2 the instrumentation --

3 COMMISSIONER BERNTHAL: I see.

4 MR. STOLZ: -- with a five degree subcooling,
5 physical configuration factor. So that that's a gross
6 assumption that is made without going into the details of a
7 specific instrument analysis.

8 When you get down to the details of what the error
9 really is, then you can justify a lower margin.

10 COMMISSIONER ASSELSTINE: Do all of these sub-
11 cooling margin monitors not work when the reactor coolant
12 pumps are off, for all the plants?

13 MR. STOLZ: I believe that's true.

14 COMMISSIONER ASSELSTINE: I hadn't really picked up
15 on that before, but that's sort of interesting. I mean, in
16 terms of thinking about how much improved things are since
17 TMI --

18 (Simultaneous conversation)

19 COMMISSIONER ASSELSTINE: -- that, you know, the
20 pumps are off, they don't work. So, in all the plants they
21 don't work if the pumps aren't running.

22 MR. STOLZ: I am advised that they work, but the
23 accuracy is in question.

24 COMMISSIONER ASSELSTINE: Okay, but they are not
25 reliable. So, you are back to the thermocouples and doing the

1 hand calculations.

2 CHAIRMAN PALLADINO: What do you rely on? I'm sorry,
3 I missed it.

4 MR. STOLZ: I said, the subcooling margin monitor
5 still works, but when the flow isn't going through, that is,
6 when the pumps are off, the accuracy is called into question.
7 So, actually, we rely on the use of the in-core thermocouples
8 and the manual calculations.

9 CHAIRMAN PALLADINO: And why -- I don't have a
10 picture of what this gadget is like, so my question may be
11 stupid. But why don't they work when the flow isn't there?

12 MR. STOLZ: Because they are not measuring -- you
13 know, the reactor coolant pump flow, it's not measuring the
14 temperature and flow conditions as it exits the core. We
15 are interested in the subcooling margin at the core level.

16 COMMISSIONER ASSELSTINE: Yes. Is that where the
17 measurement is taken, as it exits the core?

18 MR. STOLZ: John Thome can probably explain this,
19 or Walter Jensen.

20 MR. JENSEN: My name is Walt Jensen, Reactor
21 Assistance Branch.

22 The instrumentation for the subcooling meter is
23 located about ten degrees below the U-bend up at the top of
24 the candy cane, and that's about 30 feet above the core. If
25 the coolant pumps were not running, there would be some time

1 delay at least between the data the subcooling meter read
2 and the temperature of the core.

3 So, for that reason to obtain a greater accuracy,
4 the operator would use the core exit thermocouples that are
5 located directly on top of the core.

6 COMMISSIONER ASSELSTINE: Okay, so you could have
7 boiling in the core before it was reflected up in the U-bend.

8 MR. JENSEN: Yes, possibly you could.

9 CHAIRMAN PALLADINO: Why did they design things like
10 that? If you want to know subcooling in the core, why not
11 measure the subcooling in the core?

12 MR. JENSEN: Well, that's true. On the other
13 hand --

14 CHAIRMAN PALLADINO: It may be too late to ask that
15 question.

16 MR. JENSEN: They measure the subcooling in the
17 loops very well, and it's also important to keep subcooling in
18 the loops because that ensures you have natural circulation
19 capability.

20 CHAIRMAN PALLADINO: Yes, on the candy cane it's
21 important to have it at both places. Okay, thank you. You
22 helped me understand it better.

23 MR. THOMPSON: The third certification item deals
24 with the electrical qualification for radiation of containment
25 and auxiliary electrical components. The licensee has replaced

1 certain of those components, those that were in question, with
2 qualified components and completed the evaluation. We have
3 completed our review of those and have issued a safety
4 evaluation report, and we are preparing our certification paper
5 to you now.

6 Next slide, please.

7 COMMISSIONER ASSELSTINE: Let me go back to that sub-
8 cooling monitor for just a minute.

9 (Laughter)

10 COMMISSIONER ASSELSTINE: What percentage of
11 accidents where you would want that and need that information
12 are you going to be running the pumps, and what percentage
13 aren't you going to be running them, the pumps?

14 The pumps got shut off at TMI. I mean, I'm wondering
15 if we required a piece of equipment and the way it got
16 designed, it isn't going to be terribly useful in a large
17 number of accident situations.

18 CHAIRMAN PALLADINO: It might be useful, but it
19 will be only useful in part without that particular component.

20 COMMISSIONER ASSELSTINE: Yes.

21 MR. JENSEN: I suspect in a tube rupture accident
22 where a single tube would rupture, as in the design basis,
23 that the reactor coolant pumps would stay in operation because
24 the subcooling margin will be maintained.

25 COMMISSIONER ASSELSTINE: Yes, yes.

1 MR. JENSEN: But for a small break LOCA --

2 COMMISSIONER ASSELSTINE: Station black-out.

3 MR. JENSEN: Well, in a small break LOCA the sub-
4 cooling margin will probably be lost fairly quickly.

5 COMMISSIONER ASSELSTINE: Yes.

6 MR. JENSEN: And then the pumps would be chipped
7 and the core exit thermocouples would have to be dependent
8 upon --

9 COMMISSIONER ASSELSTINE: Okay, yes because I
10 always thought those were kind of neat things so you didn't
11 have to rely on steam tables and doing the hand calculations,
12 and reading the thermocouples, and all the things that caused
13 problems at TMI.

14 MR. JENSEN: They would still be there and be able
15 to be used for a determination of things like how to get core
16 cooling. But as you got super-heat up there, you will know
17 that things were badly wrong.

18 COMMISSIONER ASSELSTINE: Yes, that's true. Yes,
19 okay.

20 MR. CONTE: Excuse me, Commissioner, I think there
21 is another key point here. In the ATOC procedures it is a
22 key parameter that the operators monitor. But there is another
23 Licensing Board condition that also directs the operators to
24 rely on the most conservative instrumentation indicating sub-
25 cooling.

1 There are other means of indicating that. One is
2 the steam tables, plant computer, the subcooling monitors.
3 The operators are directed to use the most conservative. So,
4 it is somewhat of a key parameter in the ATOC procedures for
5 the operators to protect the core to understand that the -- to
6 make sure that there is subcooling in the plant.

7 But there is other instrumentation to back up that
8 monitor.

9 COMMISSIONER ASSELSTINE: Okay.

10 CHAIRMAN PALLADINO: Proceed.

11 MR. THOMPSON: To kind of summarize where we are
12 with respect to the schedule, the steam generators were returned
13 to operable status on April 10 when they completed the
14 plugging.

15 The plant currently or it will be ready for heat-up
16 for criticality as part of their extended start-up program in
17 early May. We still will want to evaluate these licensee
18 submittals of the effects of the plugging on greater than
19 1,500 steam generator tubes which will be completed early in
20 May. We will still need to have the regional readiness report
21 on the unit, those certification items that they anticipate
22 being able to complete in early May.

23 We will have completed our certificatio of the 155
24 items derived from the orders in the hearing record in early
25 May, and we then will need to be prepared to issue the license

1 amendment which is directed from the Commission's decisions,
2 orders, and the Board's.

3 MR. CONTE: Excuse me, Hugh. The chart that is up
4 there, so there is no confusion, that says ready for hot
5 functional testing April 17.

6 MR. THOMPSON: I believe they completed that hot
7 functional testing. We were talking about now is the heat-up
8 for the criticality activity.

9 MR. CONTE: And that's May, we estimate.

10 MR. EISENHUT: And I guess, Tom, they have been
11 going through the leak tightness test on testing the leak
12 tightness of the steam generator tubes at this point in time.

13 MR. THOMPSON: That was done this week.

14 MR. EISENHUT: And I understood the off-gas monitors
15 were -- remember, they run this very sensitive test where, I
16 think it's Krypton --

17 MR. MURLEY: They inject Krypton.

18 MR. EISENHUT: The off-gas monitors didn't really
19 indicate a leak. Then they go in and they take grab samples
20 to check down to the extremely -- very, very low levels, of
21 any leakage. I don't think we have heard the results of those,
22 at least yesterday we didn't. They may well have the results
23 of the detailed check by tomorrow.

24 MR. CONTE: Preliminary indications indicate it's
25 less than a gallon an hour, maybe a gallon an hour. The

1 licensee is going to evaluate the data after all analyses
2 results come in.

3 MR. THOMPSON: That completes my presentation today.
4 Unless there are any specific questions, in view of the time --
5 I think we ran slightly over our allotted hour and-a-half.

6 CHAIRMAN PALLADINO: Are there questions? Commissioner
7 Roberts.

8 COMMISSIONER ROBERTS: If there was a restart and
9 this schedule on your last slide is followed -- and I appreciate
10 you can't predict, but based on your past experience of other
11 plants, what would be the period of time -- leading back to
12 your increased inspection opportunity, three months, where
13 would they likely be after three months?

14 MR. THOMPSON: Dr. Murley might want to address
15 that, I think he has a kind of a --

16 MR. MURLEY: Yes. Assuming things went well, that
17 is to say, after a restart order that they would go into
18 some preliminary tests and then a final heat-up of about four
19 days. Then they would be ready for criticality, at least
20 according to our schedule. And then there would be a period --

21 CHAIRMAN PALLADINO: When would they be, based on
22 your schedule, when would they be at criticality?

23 MR. MURLEY: I'm just talking about the plant
24 readiness now, and not any other conditions that are put on it.
25 The schedule I have shows some feedwater inspections probably

1 need to be done, and then a final heat-up of the plant for a
2 few days. And then some natural circulation testing. And
3 then they would be ready for criticality.

4 There would be a period of probably some low power
5 physics tests and then, after a few days, they would be
6 ready to increase power to 48 percent. The chart that I have
7 that the staff prepared shows about -- it looks like about
8 a week to go from low power up to 48 percent power, at which
9 time they would stay for about 25 days, about three weeks, at
10 that mode.

11 That allows for operator training and familiarization
12 with the plant, and so forth. Then, there would be a period
13 of about eight days where they would increase from 48 percent
14 to 75 percent power. They would hold there for another three
15 weeks or so for plant training, operator training. The plant
16 exhibits different stability characteristics at these power
17 levels, that's why it is important to hold for a few days.

18 Then there would be about another ten-day period
19 where they would move on up to 100 percent power.

20 So, starting, let's say, with the restart decision
21 up to a hundred percent power -- was that your question,
22 Commissioner?

23 COMMISSIONER ROBERTS: Yes.

24 MR. MURLEY: -- it would be about 90 days, in
25 my estimate; about three months.

1 COMMISSIONER ROBERTS: So, the three months
2 increased inspection would be just about to get you to full
3 power.

4 MR. MURLEY: Yes.

5 COMMISSIONER ROBERTS: I'm not criticizing --

6 MR. MURLEY: No, that's why I set the three months,
7 that's our estimate of the time. We would keep augmented
8 inspection for whatever we judge is necessary.

9 COMMISSIONER ASSELSTINE: And that's about the time,
10 then, that they would have to do the eddy current tests, 120
11 days.

12 MR. MURLEY: Yes, I don't know the license condition.

13 (Simultaneous conversation)

14 MR. THOMPSON: A hundred-and-twenty days.

15 CHAIRMAN PALLADINO: Other questions?

16 COMMISSIONER ASSELSTINE: No.

17 CHAIRMAN PALLADINO: Well, we thank you very much
18 for bringing us up to date on those items. I would remind
19 everyone that we do have another meeting tomorrow in which
20 other interested participants would discuss the steam generator
21 problems as they see them.

22 Well, thank you, and we'll stand adjourned.

23 (Whereupon, at 4:12 p.m., the meeting of the
24 Commission was adjourned.)

CERTIFICATE OF OFFICIAL REPORTER

This is to certify that the attached proceedings before the UNITED STATES NUCLEAR REGULATORY COMMISSION in the matter of:

NAME OF PROCEEDING: Briefing on TMI-1 Steam Generator
and Other Plant Matters
Public Meeting

DOCKET NO.:

PLACE: Washington, D.C.

DATE: April 17, 1985

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission.

(sig) M. E. Hansen
(TYPED) M. E. Hansen

Official Reporter

Reporter's Affiliation

Ace-Federal

COMMISSION BRIEFING

APRIL 17, 1985

TMI-1 STATUS

OUTLINE - MATTERS AFFECTING TMI-1 RESTART

- o OVERVIEW OF TMI-1 LICENSING ACTIONS
- o STEAM GENERATOR OPERABILITY (TUBE PLUGGING)
- o REGIONAL INSPECTION STATUS
- o CERTIFICATION ITEMS (3) REMAINING PER SECY-85-64 (2/25/85)
 - CI #144 - EMERGENCY PREPAREDNESS
 - CI #154 - SUBCOOLING MARGIN MONITOR INSTRUMENT ERROR
 - CI #155 - ENVIRONMENTAL QUALIFICATION FOR SBLOCA/RADIATION
PER CLI-84-11
- o RESTART SCHEDULE SUMMARY
- o 2.206 PETITION -- EFW SYSTEM

OVERVIEW - TMI-1 LICENSING ACTIONS

SINCE 1979:

- o 84 MULTIPLANT ACTIONS APPLICABLE TO TMI-1 COMPLETED
19 REMAIN OPEN
- o 93 NUREG-0737 ACTION ITEMS APPLICABLE TO TMI-1 COMPLETED
8 REMAIN OPEN
- o 55 LICENSE AMENDMENTS ISSUED
4 LICENSE AMENDMENT REQUESTS REMAIN OPEN
- o NO OPEN LICENSING ACTIONS PRECLUDE RESTART

TMI-1 STEAM GENERATOR CHRONOLOGY

KINETIC EXPANSION REPAIR

11/81 DISCOVERED MAJOR CORROSION PROBLEM
2/83 COMPLETED KINETIC EXPANSION REPAIR AND PLUGGED TUBES
10/84 ASLB INITIAL DECISION
12/84 ISSUED KINETIC EXPANSION REPAIR AMENDMENT
12/84 TMIA FILED APPEAL AND MOTION TO REOPEN RECORD

LOOSE AND MISSING PLUGS

7/84 LOOSE AND MISSING PLUGS IDENTIFIED (1 UTS; 6LTS)
10/84 LOOSE PLUG REPAIRS COMPLETED
3/85 SER ISSUED ON REPAIRS AND OPERATION WITH 6 MISSING PLUGS

RECENT INDICATIONS AND REPAIRS

11/84 SCHEDULED ECT IDENTIFIED 336 DEFECTIVE TUBES PER
CURRENT CRITERIA
4/15/85 ALL DEFECTIVE TUBES PLUGGED - SGs LEAK TESTED (1.5 GPH) AND
OPERABLE, TOTAL 1542 TUBES PLUGGED

REMAINING ACTIONS

LICENSEE - SUBMIT ANALYSIS ON EFFECTS OF PLUGGING MORE THAN 1500
TUBES ON TRANSIENT AND ACCIDENT RESPONSE
STAFF - ISSUE EVALUATION ON CAUSE OF RECENT INDICATIONS
- ISSUE EVALUATION ON EFFECTS OF PLUGGING MORE THAN
1500 TUBES

REGIONAL INSPECTION STATUS

- o OPERATOR READINESS ASSESSMENT
- o SALP RESULTS
- o STATUS OF HARDWARE
- o AUGMENTED INSPECTION PROGRAM

OPERATOR READINESS ASSESSMENT

- o DETAILED ASSESSMENT DONE
 - PLANT WALK-THROUGH
 - ORAL EXAMINATION
- o FINDINGS
 - KNOWLEDGEABLE
 - WELL TRAINED
 - EFFECTIVE REQUAL PROGRAM
 - SOME OPERATIONAL SKILLS DECLINED
- o FOLLOW-UP PERFORMED BY GPUN AND REGION I
 - WEAK AREAS CORRECTED
- o CONTROL ROOM ENVIRONMENT
 - DISCIPLINE ENFORCED
 - ACCESS CONTROL EXERCISED

SALP RESULTS

- o ASSESSMENT PERIOD: FEBRUARY 84 - JANUARY 85
- o SALP BOARD - MARCH 13, 1985
- o SALP MEETING WITH LICENSEE - APRIL 11, 1985
- o 7 OF 9 AREAS CATEGORY 1; 2 AREAS CATEGORY 2
- o EXTENDED SHUTDOWN PERIOD - NOT NECESSARILY REFLECTIVE OF OPERATIONS - MANAGEMENT AND ATTITUDES FOSTER SELF-ASSESSMENT AND CONSTRUCTIVE FEEDBACK

PLANT HARDWARE STATUS

- o MAINTENANCE AND SURVEILLANCE PERFORMED
- o INSPECTIONS INDICATE PLANT IS READY (SOME REGIONAL INSPECTION ITEMS)
 - CERTIFICATION ITEMS
- o COMPARISON WITH OTHER PLANTS AFTER EXTENDED OUTAGE
 - SIGNIFICANTLY FEWER OPEN INSPECTION ITEMS

AUGMENTED INSPECTION PROGRAM

- o TMI-1 RESTART - HIGHEST PRIORITY IN REGION 1
- o EXTENSIVE INCREASE IN ON-SITE INSPECTORS
 - SUPPORT FROM OTHER REGIONS
 - FAMILIARITY WITH B&W OPERATIONS
- o MANAGEMENT INVOLVEMENT
- o 3 MONTH EFFORT

CERTIFICATION ITEMS STATUS

CI # 144 -EMERGENCY PREPAREDNESS

- o FEMA REPORTS FAVORABLE FINDING ON LANCASTER AND DAUPHIN COUNTY DRILLS
- o NRC COMPLETED CERTIFICATION APRIL 2, 1985 (BN-85-032)

CI # 154 - SUBCOOLING MARGIN MONITOR (SMM) INSTRUMENT ERROR

- o BACKGROUND
 - IN ALAB-729, ALAB REQUIRED SMM INSTRUMENT ERROR TO BE LESS THAN 20°F (PLUS 5°F SYSTEM CONFIGURATION FACTOR)
 - PREVIOUS EVALUATION IN SECY 84-237 (6/14/84⁴) FOR SMM ERROR $\pm 22.1^{\circ}\text{F}$.
 - LICENSEE SUBMITS REVISED ANALYSIS, 8/31/84 (BN-84-164; 9/26/84)
- o THE LICENSEE HAS NOW DEMONSTRATED THAT SMM INSTRUMENT ERROR IS LESS THAN 20°F; SYSTEM CONFIGURATION FACTOR 1.3°F
- o SMM MEETS ALAB-729 REQUIREMENTS - MANUAL SM CALCULATION UNDER REVIEW

- o SER ISSUANCE APRIL 1985

CI # 155 - ENVIRONMENTAL QUALIFICATION FOR RADIATION PER CLI-84-11 (7/26/84)

- o THE LICENSEE HAS REPLACED CERTAIN COMPONENTS WITH QUALIFIED COMPONENTS (15).
- o CERTIFICATION SECY PAPER TO BE ISSUED APRIL , 1985
(NO JIO'S)

RESTART SCHEDULE SUMMARY

- o RETURN OF SG'S TO OPERABLE STATUS (COMPLETE PLUGGING) APRIL 10, 1985
- o PLANT READY FOR HEATUP FOR CRITICALITY MAY 1985
- o STAFFS EVALUATION OF SUBMITTAL ON EFFECTS OF PLUGGING GREATER THAN 1500 SG TUBES. MAY 1985
- o REGIONAL REPORT ON PLANT READINESS MAY 1985
- o STAFF COMPLETES CERTIFICATION OF 155 ITEMS DERIVED FROM COMMISSION ORDERS AND HEARING RECORD MAY 1985
- o ISSUE LICENSE AMENDMENT WITH LICENSEE CONDITIONS APPROVED/ORDERED BY COMMISSION AND BOARDS MAY 1985

UCS 2.206 PETITION - EFW SYSTEM


REMAINING ACTIONS ON THE SUPPLEMENTAL PETITION

- o OI INVESTIGATE WHETHER LICENSEE MADE MATERIAL FALSE STATEMENTS REGARDING ENVIRONMENTAL QUALIFICATION. (PETITION REQUESTED COMPLETION PRIOR TO COMMISSION VOTE ON RESTART).

STATUS: OI INVESTIGATION STILL IN PROGRESS


- o OIA INVESTIGATE WHETHER NRC STAFF PROVIDED FALSE OR MISLEADING INFORMATION, OR HAS BEEN DERELICT IN ITS DUTY REGARDING TMI-1 ENVIRONMENTAL QUALIFICATION.

STATUS: OIA REPORT FINDINGS TO COMMISSION (2/8/85)



1st


100X



2nd

100X

Figure 4. First (0.000") and second (0.005") sections across the crack.



14th


50X

Figure 13. Fourteenth (0.091") section across the crack.



3rd

100X



4th

100X

Figure 5. Third (0.012") and fourth (0.018") sections across the crack.

12/82

TRANSMITTAL TO:



Document Control Desk, 016 Phillips

ADVANCED COPY TO:



The Public Document Room

DATE:

4/22/85

cc: OPS File

FROM:

SECY OPS BRANCH

C&R (Natalie)

Attached are copies of a Commission meeting transcript(s) and related meeting document(s). They are being forwarded for entry on the Daily Accession List and placement in the Public Document Room. No other distribution is requested or required. Existing DCS identification numbers are listed on the individual documents wherever known.

Meeting Title: Briefing on Imi-1 Steam Generator
& other Plant Matters

Meeting Date: 4/17/85 Open ☒ Closed ☐

DCS Copies
 (1 of each checked)

Item Description:

Copies
 Advanced
 To PDR

Original
 Document

May
 be Dup*

Duplicate
 Copy*

1. TRANSCRIPT

1

1

When checked, DCS should send a
 copy of this transcript to the
 LPDR for: _____

w/microwgraphs

2.

3.

4.

(PDR is advanced one copy of each document,
 two of each SECY paper.)

*Verify if in DCS, and
 Change to "PDR Available."