

April 18, 1985

Docket No. 50-304

Mr. Bart D. Withers
Vice President Nuclear
Portland General Electric Company
121 S. W. Salmon Street

Dear Mr. Withers:

DISTRIBUTION:

~~DOCKET FILE~~

NRC PDR
L PDR
ORB#3 Rdg
HThompson
OELD
EJordan
BGrimes

JPartlow
CMTrammell
PMKreutzer
ACRS +10
Gray File

T. Alexion
D. Lasher
D. Beckham

R. Auluck
J. Stevens

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION FOLLOWING PRELIMINARY STAFF
REVIEW OF LICENSEE RESPONSES TO GENERIC LETTER 83-28

Re: Trojan Nuclear Plant

The staff has completed a preliminary review to assess the completeness and adequacy of licensee responses to Generic Letter 83-28 Items 2.1, 2.2, 3.1.3, 3.2.3, 4.4 and 4.5. Your responses were found to be incomplete for Items 2.2.2 and 4.5.3. Brief descriptions of the deficiencies are given as guidelines for corrective action in the enclosed request for additional information. Efforts by Owners Groups, INPO and NSSS Vendors have been or are being made to produce generic responses that may be useful in meeting the requirements of Generic Letter 83-28 Items 2.2.2 and 4.5.3. You may wish to contact your Owners Group or INPO regarding the applicability of such generic responses to Trojan.

In order to preserve our present review schedule, the staff needs to have the supplementary information within 60 days for Item 2.2.2, and within 90 days after NRC completes its review of WCAP-10271 and Supplement 1 for Item 4.5.3. Review completion of the WCAP is expected shortly. We request your cooperation in meeting this schedule.

This request for additional information was approved by the Office of Management and Budget under clearance number 3150-0011 which expires April 30, 1985. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management Room 3208, New Executive Office Building, Washington, D.C. 20503.

Sincerely,

8505010156 850418
PDR ADOCK 05000344
PDR

Original signed by

James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

ORB#3:DL
PKreutzer
4/17/85

CMTrammell:dd
4/17/85

ORB#3:DL
JRMiller
4/17/85

Trojan

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

William T. Dixon
Oregon Department of Energy
Labor and Industries Building
Room 111
Salem, Oregon 97310

Regional Administrator
USNRC, Region V
Office of Executive Director for Operations
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

REQUEST FOR ADDITIONAL INFORMATION

TROJAN:

Item 2.2.2 - Incomplete

The staff found the NUTAC program fails to address the concern about establishing and maintaining an interface between all vendors of safety-related equipment and the utility. Accordingly the licensee will need to supplement his response to address this concern. This additional information should describe how current procedures will be modified and new ones initiated to meet the elements of this concern.

Item 4.5.3 - Incomplete

Licensee needs to submit a description of the specific implementation plan for TROJAN after NRC reviews the WCAP-10271 and supplement 1.