

ORIGINAL

ENCLOSURE 4

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the matter of:

MEETING WITH CYGNA ENERGY SERVICES
ON INDEPENDENT ASSESSMENT PROGRAM
(IAP) FOR COMANCHE PEAK

Docket No.

Location: Bethesda, Maryland

Pages: 1 - 164

Date: Thursday, April 19, 1984

TAYLOR ASSOCIATES

Court Reporters
625 I Street, N.W. Suite 1006
Washington, D.C. 20006
(202) 293-1998

8505060087 850422
PDR ADOCK 05000445
A PDR

WHITLOCK

arl

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

-----X
:
NRC Meeting with CYGNA Energy Services :
on Independent Assessment Program :
(IAP) for Comanche Peak :
:
-----X

Room F-118
7920 Norfolk Avenue
Phillips Building
Bethesda, Maryland

The meeting in the above-captioned matter
convened at 9:15 a.m.

PARTICIPANTS:

- Spottswood Burwell
- B. J. Youngblood
- Richard Bachmann
- David Terao
- Frank Rinaldi
- John Gilray
- Hulbert Li
- Ona Chopra
- Dave Lynch
- Jim Gagliardo

- 1 T. A. Ippolito
- 2 N. M. Shulman
- 3 David Pigott
- 4 N. Williams
- 5 Lee Weingart
- 6 A. E. Moersfelder
- 7 John Peter Russ
- 8 Stephen Bibo
- 9 Gordon Bjorkman
- 10 J. B. George
- 11 D. H. Wade
- 12 W. S. Reynolds
- 13 Annette Vietti
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

lpbl

P R O C E E D I N G S

1 MR. BACHMANN: On the record.

2
3 MR. YOUNGBLOOD: Good morning. We are here
4 basically, to meet with CYGNA Energy Services with regard to
5 the independent assessment program for Comanche Peak. Our
6 meeting today will be transcribed. We want to basically
7 talk about whatever things you might wish to talk about.

8 But basically, the February 6th, and March 22nd,
9 and March the 30th letters, and your responses. I would
10 like to delay discussing the March 22nd letter until after
11 lunch today, because one of our individuals that will be
12 involved in that will not be here until afternoon.

13 The meeting is basically between the Staff and
14 CYGNA. If there are other people who have any questions that
15 they want to ask, we will entertain those at the end of the
16 meeting. If there is some clarification that anybody wants,
17 while possibly that might occur during intermission or
18 something like that.

19 I guess to begin with, CYGNA, do you have something
20 that you want to say?

21 MR. SHULMAN: We would just like to be responsive
22 to the questions.

23 MR. YOUNGBLOOD: Do you have a presentation
24 prepared in regard to the March 30th letter?

25 MS. WILLIAMS: Yes.

lpb2

1 MR. YOUNGBLOOD: Would you prefer us to just
2 start asking questions? Or do you want to do the presentation
3 and see if that takes care of our questions?

4 MS. WILLIAMS: I will do the presentation if you
5 wish. And then we will do question and answers as we go
6 along.

7 MR. YOUNGBLOOD: Tom, do you want to add anything?

8 MR. IPPOLITO: You briefly mentioned it, Joe.
9 This afternoon we will be discussing the matter of independence
10 and some of the questions may involve the people that will
11 be here this afternoon.

12 So when we go over those questions, we will have
13 to defer them until the afternoon.

14 MR. BACHMANN: Off the record.

15 (Discussion off the record.)

16 MR. BACHMANN: Back on the record.

17 MS. WILLIAMS: This has been structured to go
18 through both of the letters, as you can see by the introduction
19 here. I do have slides on the basic scope, methodology,
20 generally how we did the review.

21 So if questions come up along those lines, we
22 can go back and discuss that. This is taken literally from
23 the letter, assuming that everyone is somewhat familiar with
24 what the issues were. You will maybe want to stop me if I'm
25 going too fast.

b3

(Slide.)

1
2 The first question we are now dealing with the
3 March 30th letter, dealing with design change control at
4 Comanche Peak. We have broken that into two questions. The
5 first being to assess the adequacy of the document control
6 system, to assure that the plant was constructed in accordance
7 with all design changes, prior to the introduction of the
8 computerized database tracking system.

9 The second part of that question, we have interpreted
10 to be, to determine the adequacy of the document controls of
11 the piping and pipe support drawings and design changes,
12 since they are part of the manual system. Or what is currently
13 the manual system.

(Slide.)

14
15 Regarding the adequacy of the construction of
16 the plant, prior to implementation of the computerized data
17 tracking system, we did perform an as-built walkdown of the
18 spent fuel pool cooling system. It was the only completed
19 system at the time of our review. And we did check to see
20 that all of the hardware was constructed in the field in
21 accordance with the drawings, and any outstanding design
22 changes in circulation at the time of that walkdown.

23 Secondly, there is a fairly intense effort at
24 the time of our review, currently ongoing at Comanche Peak,
25 where they were doing a validation process of what is referred

lpb4

1 to as the DCTG or design change tracking group database.
2 That database is what is now serving as the core of the DCC
3 index or logging system of design changes, where they were
4 sequentially going through every CMC and DCA to ensure that
5 they had been accounted for in the drawings and in the system.

6 That was not yet completed, though at the time
7 of our review.

8 (Slide.)

9 MR. YOUNGBLOOD: It might be a good idea, Nancy,
10 if you go over sometime, what the scope was, of what the
11 review was supposed to be. Just for the record.

12 MS. WILLIAMS: Maybe I could do that to start
13 off.

14 MR. YOUNGBLOOD: Maybe you ought to do that to
15 start off.

16 MS. WILLIAMS: Just general, what Phases I and II
17 are. Let me get those slides.

18 (Pause.)

19 MS. WILLIAMS: Would you like to start with the
20 purpose, or is this going back too far?

21 MR. YOUNGBLOOD: You might briefly go through
22 that. It is basically -- what I'm after for the record, is
23 the scope of what this review was to cover.

24 MS. WILLIAMS: Very briefly, the purpose of the
25 independent assessment program, or Phases I and II, as they

lpb5

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

are referred to, was to provide supplementary evidence and additional assurance regarding the overall design of Comanche Peak, given that other reviews had been conducted by organizations such as the NRC, and in the SIT and CAT evaluations.

There were several letters which were sent between Texas Utility and the NRC regarding specific issues that they felt should be addressed. And it was around those letters that a determination was made as to what the scope of Phases I and II would be.

(Slide.)

The program objectives were to provide an assessment of the adequacy of the design control program. The design control program was Gibbs & Hill, the engineer. We wanted to provide an assessment of the design adequacy of a selected system, verify a selected as-built configuration, and evaluate the implementation of selected elements of Criterion III of the design control program.

I will go through each one of those now, specifically as to what hardware we did that evaluation for.

(Slide.)

Some criteria that was set forth in discussing I referred to previously for establishing the scope were to include a cross-section of disciplines, include a system which exhibited characteristics which were significant,

lpb6

1 pressure, temperature, significant to safety, which could
2 not be verified by normal means, such as testing.

3 We wanted to include several organizational
4 interfaces when dealing with the design control aspects of
5 the review. We wanted to make that we touched on design
6 changes. And we wanted to make sure that we identified the
7 specific concerns and addressed those that were contained in
8 the letters.

9 As a general guideline for our reviews, we selected
10 a system. And in each case Phase I had one system. Phase
11 II we selected a different system. And we used that system
12 as the basis for selecting the documents that will be
13 reviewed for the design change aspects of the review. And
14 then also to serve as a basis for the design portion of the
15 review.

16 The system selection criteria, as I just stated,
17 was that it had to be safety related. It had to include a
18 material interface with Westinghouse, the NSSS vendor. It
19 had to include an interface with Gibbs & Hill, the architect
20 engineer. It had to meet the design parameters, and we
21 needed to have one that was started -- was turned over to
22 startup, signifying that it was a completed system.

23 Now we could not get all of these things necessarily
24 built into one system. And part of the evolution of the
25 program was that we started out doing a more limited scope

lpb7

1 than what Phase II turned out to be, that the completion of
2 it. And we ended up having to select two systems to complete
3 our review. And I will try to make that distinction now,
4 because it seems to lend to a little bit of confusion.

5 (Slide.)

6 Phase I, we used the spent fuel pool cooling system
7 to serve as the basis for that review. That review consisted
8 of, in the implementation side of evaluating the design
9 change control system. Which means that we used the paperwork
10 associated with the spent fuel pool cooling system to do that
11 review. It included an implementation evaluation of interface
12 control. It included a walkdown of the spent fuel pool
13 cooling system, which is where we get to wanting to select
14 a system which was turned over to startup, so that it was
15 essentially complete.

16 And then in a programmatical sense, which is
17 not tied to the system, we evaluated the design control
18 systems for Gibbs & Hill and for Texas Utilities.

19 (Slide.)

20 I would like to ask and make sure at this point
21 in time that the difference between a programmatical review
22 and an implementation review is clear. That when we are
23 doing a programmatic review, what we are doing is making
24 sure there is a program in place, which complies with all of
25 the requirements of ANSI-N45.2.11.

b8

1 What we do is we check that all of the procedures
2 are there. It is documented in what we call the design
3 control matrix, which is contained in the draft report. It
4 is not a check as to whether they followed the procedures.
5 It is a check as to whether they have a program in place
6 which has all of the essential procedures to carry out the
7 requirements of ANSI-N45.2.11.

8 The implementation reviews, the walkdowns, design
9 change controls, and the interface control are checked to
10 make sure that the procedures are being followed. And that
11 in fact, the work is being implemented in accordance with
12 those procedures.

13 Are there any questions on that one?

14 That was Phase I. We now move into Phase II,
15 where it was determined that we would do a design review.
16 It was felt that the spent fuel pool cooling system perhaps
17 did not exhibit all of the parameters that you might want
18 to check in a design review. And the RHR system Train B
19 was selected.

20 We refer to the design review as another implemen-
21 tation evaluation. Additional implementation evaluation was
22 conducted for Phase II, design analysis control. There were
23 no additional programmatic reviews conducted. And that
24 essentially makes up the scope of Phases I and II.

25 So we ended up with five implementation evaluations

lpb9

1 and two programmatic reviews. I can go through the RHR
2 design review in a little more detail if you want to see what
3 the various components that each of the disciplines looked
4 at. Would that be helpful?

5 MR. YOUNGROOD: I don't know if we really need
6 that. Unless anyone else --

7 MS. WILLIAMS: To summarize this pictorially here
8 is a slide.

9 (Slide.)

10 You can see that these are the programmatic
11 reviews shown on this slide, where Gibbs & Hill design control
12 program, Texas Utilities design control program were
13 evaluated in the five aspects of the implementation evaluation.

14 That makes up the scope unless you want to go
15 into methodology or any greater detail.

16 MR. BURWELL: May I ask for one bit more of
17 information on this particular slide? Over in the five
18 implementation reviews, would you identify which of these
19 related to the RHR, and which related to the spent fuel?

20 MS. WILLIAMS: Good idea. Okay. Going down from
21 the top then. Design analysis control that was performed
22 as it pertains to the RHR system. Design change control
23 was performed as it pertains to the spent fuel pool cooling
24 system, as was interface control for the spent fuel pool
25 cooling system.

lpbl0

1

MR. YOUNGBLOOD: The rationale for that was complete and turned over.

2

3

MS. WILLIAMS: It was really driven by the as-built verification. And then we had selected to do two elements of Criterion III. And they also followed then with using the spent fuel pool cooling system.

4

5

end 1.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 The as-built verification was the spent fuel
2 pool cooling. The top three are RHR and the bottom one is
3 the spent fuel cooling.

4 Going back to March 30th, the design change
5 control, now referring to the spent fuel pool cooling system,
6 we are addressing two questions. One being, does the current
7 installation match with the documents in circulation? And a
8 statement on the controls associated with the piping and
9 pipe support change papers, since it is currently a manual
10 system.

11 (Slide.)

12 Real quickly then with reference to the first
13 item, the as-built walkdown is what we relied on for
14 installation being in conformance with all of the outstanding
15 change papers, and the database process validation that was
16 in progress at the time of our review for the computerized
17 database system.

18 (Slide.)

19 A little history on the computerized system to
20 explain why the piping and pipe support drawings are not
21 currently part of it. The Gibbs & Hill design verification
22 tracking system served as the original basis for the
23 computerized system, which now makes up the DCC tracking
24 system as such. Not all drawings, not all designs were
25 under the responsible of Gibbs & Hill for the design.

2pb2

1 verification. And specifically, the pipe supports were not
2 the design responsibility of Gibbs & Hill.

3 The large bore piping and pipe support drawings
4 will be entered into the database upon completion of those
5 drawings vendor certification and incorporation of all
6 design changes. The process is still ongoing. They are
7 controlled by a manual system right now.

8 The small bore piping as well, only Texas Utilities
9 has elected, not necessarily to incorporate all of the
10 design changes for the small bore piping and pipe supports.
11 But upon vendor certification and as-built drawings being
12 produced, as well as the design changes which are associated
13 with those drawings. They will then be incorporated in
14 the computerized tracking system at DCC.

15 The pipe supports and piping are part of the
16 as-built program. They do have 79-14 as-built verification
17 program in place. We did use those drawings, for example,
18 for our spent fuel pool cooling walkdown.

19 The vendor certification includes a final check
20 of each support as-built configuration and the associated
21 calculations. I think it is important to note here that
22 the discrepancies that we found in our observations for the
23 manual tracking system prior to the implementation of the
24 computerized tracking system were not associated with the
25 piping and pipe support drawings. They were, rather with the

2pb3

1 structural and electrical drawings, which are part of the
2 computerized system, part of the database validation process.
3 Were not necessarily the focus of our concern at the time
4 of writing the observations on DCC.

5 MR. TERAQ: At this point we should have questions
6 on the last item. For the design change controls, you
7 said that was done primarily, or only for the spent fuel
8 pool cooling system. Not for the RHR; correct?

9 MS. WILLIAMS: That is correct.

10 MR. TERAQ: For the design changes that are
11 applicable to the spent fuel pool cooling system, would you
12 say that those changes are typical of the kind of design
13 changes as far as the complexity in those systems?

14 MR. BACHMANN: Off the record.

15 (Discussion off the record.)

16 MR. TERAQ: As far as the design change controls
17 on the spent fuel pool cooling system, would you say that the
18 type of design changes that were made in the spent fuel
19 pool cooling system were typical of the type of changes that
20 were made on other systems, in terms of complexity?

21 MS. WILLIAMS: Are you speaking of the mechanical,
22 the piping, pipe support drawings, or just in general?

23 MR. TERAQ: Piping and pipe support drawings.

24 MS. WILLIAMS: It is a little tough to answer
25 because of the time frame. When we were looking at the

2ph4

1 spent fuel pool cooling, there were less design changes
2 outstanding because they had gone further along in the
3 process of incorporating them. It was closer to completion,
4 or was actually completed.

5 The RHR system, there were perhaps a few more
6 design changes. We did not really evaluate complexity on
7 the spent fuel pool cooling system. However, the supports
8 are more simplistic there than what we are finding in the
9 Phase III review that we are doing right now.

10 MR. TERAQ: So the spent fuel pool system, the
11 supports are simple. Would you say that the system itself
12 is in a congested or a noncongested area?

13 MS. WILLIAMS: Relative to other parts of the
14 plant, it is uncongested.

15 MR. TERAQ: And would you say that the congestion
16 or the noncongestion of the spent fuel pool cooling system
17 is typical of the rest of the plant piping systems? Or
18 not typical?

19 MS. WILLIAMS: I guess I would like to defer
20 answering a question like that until we do the walkdown on
21 Phase III, which we are intending to do. I think that is
22 something we are going to be looking for.

23 Having only done the walkdown on the spent fuel,
24 and we did not do a walkdown on the RHR, it is somewhat
25 conjecture to make a response to that right now, I think.

1 We are going to, as part of, actually on Phase
IV the component cooling water system do a walkdown.

3 MR. TERAQ: You may not have performed the formal
4 walkdown, but you must have walked through the plant and
5 seen the type of congestion or noncongestion that there
6 could have been for the remaining part of the plant.

7 Would you say that most of the plant is typical
8 of the spent fuel pool system in terms of congestion?

9 MS. WILLIAMS: I think I see your question. No,
10 it less congested. The spent fuel pool cooling area is
11 less congested than other parts of the plant.

12 MR. TERAQ: Can you conclude then that the type
13 of design changes that might be outstanding, or the type of
14 design changes that were made on the spent fuel pool cooling
15 systems are not as complex as the other systems, where
16 congestion could be a problem?

17 MS. WILLIAMS: I'm getting confused. When we're
18 talking about design change control and the complexity of
19 the design changes, we are looking at tracking a number of
20 design changes. It was not just with regard to the piping
21 and pipe supports. It was structural and electrical.

22 When you say complexity, then I start looking into
23 the design area, where our engineers would be evaluating
24 how complex they are; whether they were incorporated into
25 the analysis correctly; whether the calculations reflected

2pb6

1 the design as it existed.

2 So are you saying, complexity in a technical sense?

3 MR. TERAQ: I am assuming that the more number of
4 design changes you would have would be indicative of the
5 complexity of the changes to be made to the system.

6 MS. WILLIAMS: It is possible. But I do not know
7 that it necessarily follows. So many of them in the spent
8 fuel pool cooling system had been already incorporated into
9 the drawing that you would really have to go back and go
10 through the history to make a comparison of that. The
11 potential as it exists, the more paper you have, the
12 tougher it is to draft.

13 They went to a computerized system. The fact that
14 they went to the computerized system, I think, is because
15 of the volume. One of the reasons is because the volume is
16 such that it lends itself to that. There are a great number
17 of design changes outstanding. There is no doubt about that.

18 MR. TERAQ: Do you feel that the number of design
19 changes that are outstanding, that are still in the manual
20 system are accurate?

21 MS. WILLIAMS: We did not find any problems with
22 the ones that were -- I want to make one distinction for the
23 manual system.

24 When we went in and did our original review back
25 in July of '83, everything was manual. So when we defined

2pb7

1 manual system, it was everything. And then they were in the
2 process then, through their design change tracking group of
3 bringing the database up to speed so that it could be
4 merged with the manual system in DCC.

5 There were almost two parallel systems there for
6 a while. Although the manual system of DCC governed for all
7 drawings. Our original observations are written against a
8 manual system, but for all drawings. Not for just the
9 piping and pipe supports.

10 And then they went and merged the DCTG computerized
11 system with DCC and then there were certain types of drawings
12 still on the manual system, which are now referred to as
13 manual. And those are the piping and the pipe supports. So
14 the focus narrowed a little bit.

15 The problems we found in the original manual
16 system were not with the piping and pipe support drawings,
17 so much as some of the structural and electrical drawings.

18 MR. TERAQ: With the structural and electrical
19 drawings, were any of the problems related to the accuracy
20 of the design changes?

21 MS. WILLIAMS: For the Phase I and II review? No,
22 because for the walkdowns we did not find -- the only
23 problems that we found with that were with the accuracy,
24 were reflected in the observations as far as matching the
25 drawings as-built configuration matching the drawing. The

2pb8

1 design control portion of the review was how well they track
2 and what problems they are having with their tracking system
3 in the DCC, where you are talking about accuracy of tracking
4 and controlling the paperwork. Not so much accuracy
5 technically of the design changes.

end 2.

6 MR. TERAQ: I'm speaking accuracy in terms of
7 where the packages are complete. Were all of the design
8 changes there? Were all of the latest drawings there?

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

3pbl

1 MS. WILLIAMS: With the exception of the one that
2 we wrote the observations on, we felt that we did those on
3 the ones where they were not complete, where the list did
4 not match. And there were four observations on that.

5 MR. TERAQ: If those are on the manual system,
6 how would those inaccuracies be corrected before they are
7 put onto the computer system?

8 MS. WILLIAMS: This gets into the process they
9 are going through now of checking each CMC in each in DCA,
10 since they are sequentially numbered. And verifying that
11 they are outstanding against the appropriate drawings.

12 If they were incorporated, they are statused as
13 being incorporated. The design verification has been
14 completed. And just taking each one of those pieces of
15 change paper with a discipline engineer who is cognizant of
16 that particular type of drawing and checking that it is
17 correctly logged and tracked within the DCC system.

18 I do not know if that is complete right now. It
19 was ongoing at the time.

20 MR. TERAQ: What would be the consequence if a
21 package were not complete? Can it be corrected?

22 MS. WILLIAMS: In what sense? In the construction
23 sense?

24 MR. TERAQ: If they were to find a package that
25 was not complete, they were missing design changes or latest

3pb2

1 drawings, what steps would be necessary to assure that the
2 package then is corrected and accurate?

3 MS. WILLIAMS: I'm not quite sure I understand
4 the question. They are going through the process of making
5 sure that they are all complete right now. They are not
6 referring to that.

7 MR. TERAQ: You are saying that they are going
8 through the process now. If they were to find one of the
9 packages to be incomplete or inaccurate, missing design
10 changes or drawings, what steps would then have to be made
11 to assure that that package can be put out to the computerized
12 system in a complete and accurate form?

13 MS. WILLIAMS: I would answer that by saying, the
14 steps they are going through, which is checking piece of
15 design change paper and making sure that it is complete to
16 the package. They are making sure that drawing, number
17 S-100 say, has all of the right design changes listed in
18 the tracking system against it. And if they are incorporating
19 the drawing, that they are so noted as incorporated.

20 MR. TERAQ: Maybe my question is a little simple.
21 I'm just asking, how do they correct a package that is
22 inaccurate or incomplete. Is there a way to get a complete
23 package that is accurate?

24 MS. WILLIAMS: Yes.

25 MR. TERAQ: How would they do that?

3pb3

1 MS. WILLIAMS: They would do that at the culmination
2 of going through this purging or validation process. What
3 steps are they going through in that process?

4 MR. TERAQ: Would they have to go back to Gibbs &
5 Hill?

6 MS. WILLIAMS: To obtain a copy of that design
7 change?

8 MR. TERAQ: Yes, to get a complete, accurate
9 package.

10 MS. WILLIAMS: We did not find that it was so
11 much that they physically could not locate the design
12 changes. It is how they were logged in the system that was
13 the problem. They were physically there.

14 Whenever we wanted to request a CMC or a DCA we
15 were able to obtain it.

16 MR. TERAQ: My question is still, do you know if
17 it is possible to get a complete package up-to-date, corrected
18 with all of the latest drawings? Can they do that?

19 MS. WILLIAMS: They can do it now to the extent
20 that that validation process is complete. They have to go
21 through that process in order to make sure that they have
22 accounted for all of the change paper. That is why I
23 qualify the answer. I do not know if it is complete. If
24 that is complete and they have accounted for every one of the
25 CMCs and DCAs and DDAs and all of their old types of change

3pb4

1 papers, then yes you can go into the computerized system and
2 get a listing, and a complete package then, if you want to
3 ask for a hard copy of it from DCC.

4 I'm not answering your question?

5 MR. TERAQ: You keep speaking in terms of
6 validation as meaning that the package is accurate, the
7 package is complete.

8 MS. WILLIAMS: Yes.

9 MR. TERAQ: Let's go back to the question. Suppose
10 they were to find a package that were missing design changes
11 and drawings. How can they assure, what steps would they
12 have to take to bring that package up-to-date? Can it be
13 done?

14 MS. WILLIAMS: I think I see the difference.
15 You're saying, look at a drawing and how do you know where
16 to look for all of the outstanding design changes?

17 MR. TERAQ: No. You know what the -- you might
18 know what the design changes should be, and you could know
19 that you are missing some, or you might know that you are
20 missing a drawing. You may not know that you have the latest
21 drawing.

22 How in the process then, would they get that
23 package up-to-date?

24 MS. WILLIAMS: If you know the design change that
25 you are missing, you would simply go request it. They are

3pb5

1 in the system.

2 MR. TERAQ: You don't see any problems with
3 finding a package inaccurate as far as having the latest
4 drawings or all of the design changes, because you feel that
5 it can be corrected by just going and getting whatever
6 design changes are necessary?

7 MS. WILLIAMS: If you know what design change you
8 need, you won't have so much problem finding it. That was
9 our experience in our audit.

10 To me, the concern was making sure they accounted
11 for all of the design changes for the person who does not
12 know what design changes they should have as part of that
13 package.

14 MR. TERAQ: In your conclusion -- just on DC-0101
15 you said you have confidence that the newly developed
16 computerized document listing is accurate, with respect to
17 design changes outstanding against affected design documents.

18 I guess I still do not understand how you got
19 the confidence that this computerized listing was accurate,
20 if you found inaccuracies in the manual system.

21 MS. WILLIAMS: Our confidence is born out of going
22 through and assessing whether they were conducting a
23 validation process which would pick up all of the
24 discrepancies.

25 MR. TERAQ: I will stop at this point, but we

3pb⁶

1 probably have to discuss it when we get into the DCs --

2 MR. YOUNGBLOOD: Is that something you're going to
3 be discussing further in your presentation?

4 MS. WILLIAMS: No, that would be the end of the
5 design control questions, as it were in the letter, we
6 can talk about any aspect you wish. I just took the letter,
7 each question and summarized it.

8 MR. BACHMANN: Off the record.

9 (Discussion off the record.)

10 MR. BACHMANN: Back on the record.

11 MR. SHULMAN: Can I try one more shot at
12 clarification?

13 MR. YOUNGBLOOD: I think the question, on the
14 last question you said you were going to cover that. I
15 think that is exactly what we want to cover, is if the
16 uninitiated were coming in and checking the system, or
17 someone was coming in to make sure it was up-to-date, what
18 are the things that -- how would they know all of the things
19 that they are supposed to validate? And how would they
20 know that something was missing? And how would they correct
21 that?

22 MS. WILLIAMS: To try to rephrase the question
23 then, if an auditor, an outside auditor, were to come in
24 today and to check the system --

25 MR. YOUNGBLOOD: Either that or someone who is

3pb7

1 just doing the job checking.

2 MR. BURWELL: He wants to inspect something. He's
3 going to go get a package of drawing or whatever he needs
4 to inspect it. The question then, what has he got in his
5 hand. Perhaps he did his inspection and now the system is
6 going in, moving into its validation procedure.

7 Nevertheless, his inspection record --

8 MR. YOUNGBLOOD: Let's back it up one step and
9 say we are transferring this from the manual system to the
10 computer system. What kind of criteria do I have to go by
11 that picks everything that is supposed to be a change? And
12 how is one assured that everything that is supposed to be
13 changed and transferred, is indeed transferred to the
14 computer system?

15 Is that getting it --

16 MR. BURWELL: That is a little bit of a separate
17 question.

18 MR. YOUNGBLOOD: But it is preliminary to the
19 other.

20 MR. BURWELL: Preliminary or following, either
21 way.

22 MS. WILLIAMS: Tell me when I go off on the wrong
23 track here. If I were going in --

24 MR. YOUNGBLOOD: Is there someone back of you
25 that wants to chime in on any of those questions?

3pb8

1 MS. WILLIAMS: I think I'm pretty familiar with
2 the system. I would go in and check this validation process
3 that is going on, that was not completed when we were there.
4 And maybe I can explain what that process is and see if that
5 helps, go through that one more time, because I think I went
6 a little quickly over that.

7 The only way -- because of the number of design
8 changes outstanding, to ensure that they have correctly
9 accounted for each piece of design change paper is to go
10 through them one by one and make sure that they are assigned
11 against the appropriate drawing. The thing that enables them
12 to do that is that they are sequentially numbered. So you
13 can be ensured that you account for each one by going one,
14 two, three, four, or in blocks of 100, or however you want
15 to structure that program.

16 In carrying out this check which, it is our
17 understanding they are doing for the CMCs in the DCAs, they
18 have assigned an engineer in the DCTG group who is cognizant
19 of that discipline. So the electrical drawings would have
20 an electrical engineer who is checking to make sure that
21 it is an electrical design change, that it is applicable to
22 that drawing, and whether or not it is incorporated in a
23 determination as to whether it has been designed verified.

24 And then the paperwork follows where they update
25 the database if that is necessary. So to go back here a

3pb9

1 minute. Knowing that they have sequentially numbered design
2 changes, they parcel them out by discipline. This check is
3 conducted to make sure it is allocated against the appropriate
4 drawing, to make sure there is any cross-references to other
5 drawings that may be affected. And that information is then
6 updated into the database.

7 So I think that what you want to do is make sure
8 that in fact that activity is either completed or being
9 conducted, that there is a good mechanism that is working
10 for getting that entered into the database. And only be
11 going through them sequentially can you tell that they have
12 all been incorporated. You could do it with a technical
13 person if you wanted to, with an auditor.

14 Before I pursue the question any further, does
15 that in any way set the stage for what process is being
16 conducted to assure the completeness of the packages?

17 MR. TERAQ: It basically tells me that there is
18 a processing place, yes.

19 MS. WILLIAMS: So you might want to go back and
20 check that process.

21 MR. YOUNGBLOOD: Is this something that is being
22 checked in one of your other phases that were doing for the
23 hearing?

24 MS. WILLIAMS: I guess there is some discussion
25 on firming up the scope, and maybe today's meeting is part

3pb10

1 of that.

2 MR. TERAQ: Probably a lot more difficult task
3 than just assuring that the process is there is to assure
4 that the process is working. Did CYGNA look into that aspect?

5 MS. WILLIAMS: We really came in when that was
6 just starting to happen. We found discrepancies, and then
7 we wanted to find out what they were doing to resolve these
8 discrepancies. We had a similar question to you, which is
9 we found these omissions from your tracking system, or
10 complex between what a control document holder thinks are
11 the outstanding changes and what your central DCC system
12 thinks are the outstanding changes, so how can you assure
13 us that this will be straightened out in an appropriate
14 manner?

15 So DCTG was not originally part of our audit.
16 This was actually an expansion of our audit that we got into,
17 looking at how that system worked. And we became, to the
18 extent that I have explained it today, familiar with that
19 system because we wanted to assure ourselves that appropriate
20 actions were being taken.

21 But we did not get into, say, auditing that
22 activity as part of our review.

23 MR. TERAQ: So it appears that your conclusion,
24 your confidence that the newly developed computers document
25 listing is accurate with respect to design changes is

3pb11

end 3.

1 based on the fact that the system is in place? Not
2 necessarily that the system is working accurately.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

mgc 4-1

1 MS. WILLIAMS: Yes. And then there is the
2 as-built walkdown, which is our second check, so it is
3 twofold.

4 MR. YOUNGBLOOD: That is on the last complex area
5 that you're doing that?

6 MS. WILLIAMS: Yes.

7 MR. BURWELL: Yes, that is on the spent fuel pool
8 system.

9 MS. WILLIAMS: We are proposing to do one on the
10 component cooling water system for Phase IV.

11 MR. TERAQ: I have no further questions on this
12 particular issue, unless anyone else has any.

13 MR. PIGOTT: Do you have your answers to your
14 questions? Are there any outstanding questions? If there
15 are, we want to stay with it.

16 MR. TERAQ: I understand what Nancy has said.

17 MS. WILLIAMS: Moving on --

18 MR. BURWELL: Before we go away from that, I would
19 like to go back for just a moment to the question that
20 I had earlier on the inspector.

21 You showed the process of -- validation process
22 that they are going through, ultimately leading to the
23 Bulletin 79-14 response.

24 Now in the course of all this, there seems to
25 be a number of ongoing inspections for conformance of the

mgc 4-2

1 piping supports to the design documents.

2 Do you remember any incidents in which you
3 concluded that the spent fuel pool system was not in
4 conformance with the drawings and then went back and later
5 found that there was a document that was found to relate to
6 this, that did bring the system in conformance with the
7 complete package?

8 In a sense, I am asking you, did you find
9 incomplete packages when you did the review of the spent
10 fuel pool cooling system walkdown?

11 MS. WILLIAMS: No. Our observations were more
12 that we had all of the change paper and we had the drawing,
13 but that we needed to go and ensure that the installation,
14 for example, permitted end-for-end reversals of snubbers
15 or it was permissible to have a certain percentage void
16 under a baseplate or things like that, but no violations of
17 the fact that it was not in conformance with the drawing or
18 the change paper, but more that we ended up looking at the
19 specifications to make sure that it was -- anything that
20 we were seeing that we thought was in any way a potential
21 violation -- was covered in specifications. It was just
22 the nature of the things that we found. We did not find
23 dimensional disagreements where there was no change paper
24 that addressed it or anything of that nature.

25 MR. BURWELL: Fine. Thank you.

mgc 4-3

1 MR. YOUNGBLOOD: Any further questions?

2 (No response.)

3 MS. WILLIAMS: This question pertains to the RHR
4 system, which was the system we conducted our design review
5 on. Specifically it was a pipe stress question.

6 We had an Observation PI-00-01. We have been asked
7 to provide an explanation as to whether butt welds on the
8 straight sections of the pipe, precisely three and four-inch
9 Schedule 40, comply with all of the current code
10 requirements.

11 To give a very brief history of that one, I am
12 going to turn to the observation for a second to show
13 how three and four-inch pipe was zeroed in on, and then I
14 will come back to our response on that.

15 (Slide.)

16 This is just a slide of PI-00-01 where we did an
17 observation. Gibbs & Hill did not specify any weld
18 mismatch in determining the stress factors. Our resolution
19 of that is shown on Section 2 of Attachment A to that
20 observation where we discuss a Gibbs & Hill response to
21 certain size pipes where they cite the -- as contained
22 down here, the Moore paper where it says, "A mismatch
23 should be considered for stress indices only for T less
24 than .237 inches." And then we go on to discuss thicknesses
25 greater than .237 inches where Gibbs & Hill did use the

mgc 4-4

1 appropriate stress intensification factor of 1.8 for
2 thicknesses greater than .1875 inches. So we have
3 narrowed down the range there, which turns out to be sizes
4 three and four Schedule 40 piping, which is specifically
5 the question in the letter.

6 (Slide.)

7 Later codes for Equation 8 and 9 use stress
8 indices for the primary stress check. We have what Gibbs &
9 Hill implied with later codes, the later code case. They
10 turned out to be less restrictive on the butt welds, and
11 I am going to show that comparison for Equations 8 and 9
12 right now.

13 (Slide.)

14 The top equation is a code of record. The later
15 code equation is the second one where we substituted the
16 values of B_1 and B_2 for butt welds. By substitution you
17 can compare the two equations, and knowing that $.75i$ must
18 be greater than or equal to one, the equation for the later
19 code case is 1, and also that the allowable for the later
20 code case is $1.5S_H$ as opposed to $2S_H$, we have concluded that
21 for those two Equations 8 and 9, that the later code case
22 is less restrictive than the code case that was employed
23 in the Gibbs & Hill design for Equations 8 and 9.

24 For Equation 10, in the thermal condition, we
25 do not believe that an appropriate stress intensification

mgc -5

1 factor was used, where they used 1 instead of 1.3; however,
2 it is our belief that the moments on those straight runs of
3 pipe are low enough, such that you have sufficient margin
4 that it is not going to be a design concern.

5 MR. TERAQ: How did you conclude that the moments
6 are lower in straight runs?

7 MS. WILLIAMS: Based on our review of the stress
8 analysis for the RHR system where they were low, and then
9 where butt welds typically occur on the straight runs, which
10 is in regions of low moment. That is our experience.

11 MR. TERAQ: You went back and looked at piping
12 stress analyses, determined where the butt welds would be
13 in straight runs, looked at the moments at those points and
14 compared them to the moments in the other parts of the
15 system?

16 MS. WILLIAMS: As you approach the hub of our
17 transition joints or something like that, that SIF is going
18 to govern. We did have the information on the RHR system
19 where the moments were low enough on the straight runs
20 where we believe we will have butt welds which are not
21 governed by SIFs for transition joints, elbows of similar
22 types, and thought they were sufficiently low enough to
23 alleviate any design concern there may be for having used
24 an SIF of 1.

25 That is based on the fact that butt welds

mgc 4-6

1 typically occur on long straight runs, and if they occur
2 near the elbow, then the SIF of the elbow is going to govern.

3 MR. TERAQ: Did you actually compare the moments
4 at the butt welds in the straight piping with the moments
5 at elbows or Ts, reducers?

6 MS. WILLIAMS: I do not have a chart that shows
7 that comparison with me. But yes, that was certainly part
8 of the basis by which you would be able to make an assessment
9 like that, is that we would go in and look at the moments.
10 I did not bring a chart along that shows you what that
11 comparison is on the RHR system.

12 MR. SHULMAN: We can have such a chart, Nancy?

13 MS. WILLIAMS: We can develop that by looking at
14 the stress analysis. We have to get the documentation.

15 MR. TERAQ: Can you tell from the isometric where
16 butt welds would be in straight piping?

17 MS. WILLIAMS: That is based on our experience.
18 You would have to go to the full piece drawings.

19 MR. BURWELL: Would that give it to you? The
20 reason for my question is that typically you have got to
21 fit a pipe up. You weld the one end, and then you have got
22 to openly connect this pipe over to another piece of
23 equipment.

24 Don't they typically make a short spool piece
25 insertion in order to lengthen a straight piece of pipe to

mgc 4-7

1 make this fit-up? Would you not have to go to either a
2 visual inspection or to some as-built records, and I'm not
3 sure that even as-built records would pick that up, would
4 it? Do you know?

5 MS. WILLIAMS: You would have to do what you said.
6 You would have to go in and do that check to make sure that
7 our experience is correct. You cannot do that by looking at
8 the analysis.

9 What we have done is narrowed it down to three
10 and four-inch piping. If you want to go in and verify that
11 and close the loop on this, which is certainly possible,
12 then what you would do is to go in and check the location of
13 the butt welds. You would have to find out what the most
14 accurate piece of documentation is to provide you with that
15 information.

16 MR. TERAQ: My concern is still that the RHR
17 piping is not three or four-inch piping.

18 MS. WILLIAMS: That's right. We did not look at
19 three or four-inch piping as part of the RHR. This
20 observation was based on the RHR system, but it is a much
21 more general observation, which is why it is labeled the
22 00 series. We have narrowed it down to three and four-inch,
23 but our conclusion that we are discussing now is only based
24 on our experience that we don't believe that is where the
25 butt welds are placed.

mgc 4-8

1 What we would have to do is go close the loop by
2 looking at three and four-inch piping and ascertaining
3 whether that is true or not.

4 MR. TERAQ: Are you intending to do that?

5 MS. WILLIAMS: We have been discussing doing that
6 as part of these three, yes.

7 Given the somewhat changing environment in terms
8 of level of detail and making sure that we assess all of the
9 generic issues in an appropriate manner, I think that it would
10 be appropriate to close the loop on this, yes.

11 MR. TERAQ: Going back to the Equation 9, on
12 the primary stresses, you made a statement that the code
13 changes in the winter of '81 addenda allowed a higher
14 allowable stress.

15 Would the minimum wall thickness at the butt
16 welds themselves be covered by the increase in allowable
17 stresses?

18 Maybe I should rephrase that. Did you look at,
19 in addition to the mismatch ratio at butt welds in straight
20 piping, did you also look at the minimum wall thickness
21 allowed for the same butt welds when counterboring of the
22 pipe is required?

23 MS. WILLIAMS: I would have to check that.

24 MR. TERAQ: The question is, when a pipe is
25 counterbored at the same location as straight pipe, when

mgr -9

1 it is counterbored, there is usually a tolerance given for
2 the minimum wall allowed.

3 What is the definition at Comanche Peak for the
4 minimum wall allowed in counterboring the pipe? Would that
5 be the minimum wall per the 12 percent, 12.5 percent
6 criteria, or would it be the minimum wall per NCD 36/40?

7 MS. WILLIAMS: I think the best way to handle that
8 is, I can make a phone call at the break. Unfortunately,
9 John Minichiello could not be here today, and he is the
10 person to ask that question of. I will make a phone call
11 and see if I can get the answer immediately.

12 MR. TERAQ: That would also affect the stress
13 intensification factor.

14 MS. WILLIAMS: Let me ask John that before I try
15 answering something like that.

16 MR. LYNCH: I would like to ask a question to
17 understand your topical approach.

18 While you concede that the stress intensification
19 factor was improperly used for piping of certain thickness,
20 is your basis for finding this acceptable because the stress
21 level was low there?

22 MS. WILLIAMS: For the three and four-inch piping
23 Thermal Equation 10? Our discussion of low stress levels
24 or low moments only pertains to Thermal Equation 10 for
25 three and four-inch piping, Schedule 40.

mgc 4-10

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

MR. LYNCH: What assurance do you have that other piping systems that you did not look at, that the stress level was comparably low so that the use of an inappropriate stress intensification factor would not be acceptable there?

End 4

1 MS. WILLIAMS: To close that loop, we have to go
2 back and look at three and four inch, Schedule 40 piping
3 and check that the location of the butt welds is such that
4 that is not a concern. That the moments are low enough that
5 that is not a concern.

6 MR. LYNCH: I have a problem philosophically.
7 What you're doing is checking design process. Are you saying
8 that though you may find something in error in the design
9 process, you're buying off on it because the stress level
10 is low?

11 MS. WILLIAMS: We are buying off on it on two
12 things. This particular system is they were low, so that
13 is one example of it. But it is our experience that that is
14 not going to be a problem. And that is part of the judgment
15 that we made. We did not believe it was going to be design
16 concern, that it was going to affect the health and safety
17 of the public, or that it was going to truly affect the
18 outcome of the stress analysis.

19 — To close the loop though, just to make sure that
20 our judgment is correct, that would be the path we would
21 take.

22 MR. SHULMAN: In Phases III and IV, we would look
23 at other samples of spot checks, since you have -- if they
24 are that low, we are talking about fairly low stresses.
Well below half of allowable. That is what we have to

Spb2

1 confirm, particularly on III and IV. Specifically for three
2 and four inch pipe.

3 MR. TERAQ: The stresses may be half of the
4 allowable because it is based on a stress intensification
5 factor of one. If you use a stress intensification factor
6 of 1.8 then you are close --

7 MR. SHULMAN: But we have to confirm that it is
8 significantly less than half of allowable, otherwise it
9 would be .9.

10 MS. WILLIAMS: I would like to make one other
11 note. There are cases where we do expand the scope and go
12 outside of the system that we looked at. That happened in
13 several instances in the observations, and even in items on
14 check lists. I don't want this to be construed as indicative
15 that we never go and expand the scope, because we do.

16 In this case we did make the judgment that we
17 did not feel it was a problem. If we judged otherwise, we
18 would have gone in and looked at it. What we're saying here
19 is we closed the loop by looking at it for the three and
20 four inch, Schedule 40 pipe.

21 MR. WEINGART: Comparing the internal stresses,
22 we are talking about the stresses that were typically that
23 low in the system in the RHR that we looked at. Our judgment
24 was based on the high thermal stresses will occur at the
25 nozzles, elbows and fittings. At those points they did use

5pb3

1 the proper SIF.

2 MR. TERAQ: It may be true that the high thermal
3 stresses occur at nozzles and fittings, but the stresses
4 due to seismic may occur in the middle of a simply supported
5 beam.

6 MR. WEINGART: That is correct. However, in that
7 case you would be going to equation 9, in which case you
8 are back to using stress indices as allowed by the later
9 code, which shows by this argument that that is okay.

10 This slide shows that the only point of concern
11 would be for equation 10, which is your secondary stresses,
12 in which case you still have to use the SIF, which is where
13 the problem was.

14 Our logic further followed that, typically for
15 large thermal stresses, which we use in evaluating equation
16 10, those are typically nozzles, elbows, fittings.

17 MR. SHULMAN: That is the judgment that we have
18 to confirm, is the differences between equations 8, 9 and
19 10, and there is a confirmation that the stresses are indeed
20 significantly lower for the -- for all cases on three and
21 four inch piping, where they omitted the appropriate stress
22 intensification factor.

23 MR. TERAQ: And CYGNA is going to confirm that?

24 MR. SHULMAN: Yes. We agree in that one case,
25 in this observation as part of Phase III and IV, we have to

5pb4

1 confirm that that is in fact true.

2 MR. TERAQ: Are we going to get an answer from
3 Mr. Minichiello today?

4 MS. WILLIAMS: I will try to call him today.

5 MR. TERAQ: I have no further questions on this
6 observation.

7 MR. BACHMANN: We will take a five-minute break
8 now, go off the record.

9 (Recess.)

10 MR. BACHMANN: Back on the record.

11 MR. TERAQ: I talked to Mr. Minichiello and
12 clarified our concern regarding the minimum wall thickness
13 of pipe. I basically asked him at girth, butt welds between
14 straight piping, is the minimum wall allowed after counter-
15 boring of the pipe, is it the minimum wall of minus 12-1/2 percent
16 tolerance? Or is it the minimum wall NCND 3640 of the
17 ASME code?

18 The reason for the question is that the factor
19 of one is permitted when the tolerance, minimum wall
20 tolerance is within 12-1/2 percent of the code -- 12-1/2
21 percent of the nominal wall thickness. But stress
22 intensification factor of one is not permitted if the
23 minimum wall is defined as that minimum wall as calculated
24 per NCND 3640 of the code, which could be much less than
25 the nominal wall minus 12-1/2 percent.

1 In other words, if the minimum wall at counterbore
2 is the NCND 3640, then use of a higher stress intensification
3 factor of one is required.

4 MR. YOUNGBLOOD: He is going to follow up on
5 that then?

6 MR. TERAQ: Yes. He understands the question,
7 and he will review the specification, the piping specification.
8 I believe it is MS-200 spec.

9 MR. YOUNGBLOOD: Does that complete everything
10 on question 2 then, at this stage?

11 (No response.)

12 MS. WILLIAMS: Question 3, dealing with pipe
13 stress again on the RHR system, refers to Gibbs & Hill's
14 use of the 20 percent increase in allowables for welded
15 attachments.

16 (Slide.)

17 If you look at the problem in light of later
18 codes and code cases for straight pipe, you arrive at the
19 following conclusions. That in the case of SA106B piping,
20 the Gibbs & Hill allowable is less than the current Code
21 Case allowables.

22 In the case of stainless steel 304 and 316, the
23 Gibbs & Hill allowable is also less than the current Code
24 Case allowables. When you get in the 304 and 316 stainless,
25 for temperatures greater than 400 degrees, then there is some

5ph6

1 difference between the Gibbs & Hill allowable and that of
2 later Code Cases.

3 I'm going to show that on a chart right now.

4 (Slide.)

5 Referring to the 316 and 304 stainless, looking
6 across to the comparison of Gibbs & Hill and the code, you
7 will see for temperatures of 400 degrees, in the case of
8 the 316, that the Gibbs & Hill is slightly greater than that
9 of the current Code Case allowables. Going and looking at
10 the 304 stainless for condition, which on this chart shows
11 us 650 degrees, but actually is 550 if you read off of the
12 charts. There is also a slight increase, or difference,
13 between the current Code Case allowables and that which
14 Gibbs & Hill uses.

15 Now we looked at that, and we looked at the
16 margins where the welded attachments on the RHR system, and
17 the worst ratio of allowables of the actual stress levels
18 to allowable was in the neighborhood of .56. We had almost
19 a 50 percent design margin for the welded attachments on
20 the RHR system dealing with straight piping.

21 So we felt that those margins were certainly
22 outweighing what is less than a 10 percent difference in
23 the Gibbs & Hill allowable versus the current Code Case
24 allowables. On that basis, we made a judgment. We felt
25 there was no design impact.

1 In going on to elbows, which are a much more
2 limited application, at the Comanche Peak plant. If you
3 go through a derivation of comparing the current Code Cases
4 to that which was employed in the plant, you are going to
5 find that there is not this significant margin -- let me
6 rephrase that -- the potential exists that they exceed the
7 current Code Case allowables.

8 And our feeling was that the stress method, the
9 large stress method was sufficiently conservative to outweigh
10 the differences that you would get in looking at the elbow
11 welded attachments. It is really a two-fold reason.

12 One is we felt the method was conservative. And
13 two, that there is a very limited application in welded
14 attachments to elbows at Comanche Peak.

15 MR. TERAQ: Perhaps the welded attachments on
16 the RHR system were found acceptable using this 20 percent
17 increase. Have you considered what the effects of the
18 welded attachments could be on other systems, other than
19 RHR, when the 20 percent increase is allowable?

20 MS. WILLIAMS: You would be able to narrow that
21 with the case of the stainless steel, which is over 400
22 degrees, and we consider that in the sense that we felt that
23 it would not be a problem.

24 To close the loop on that again as with question
25 2, what you want to do is go back and look at a further

Spb8

1 sampling of welded attachments, using that material in
2 systems that exhibit characteristics running at temperatures
3 greater than 400 degrees. This is another case where we
4 made a judgment. It was a judgment based on our experience
5 and our understanding of the type of evaluations that were
6 done there.

7 If you want to go back and demonstrate that that
8 was an accurate judgment, you would have to look at that
9 situation. I would narrow it down to just looking at those
10 specific parameters.

11 MR. TERAQ: My concern is, on the RHR system it
12 is relatively low temperature system. It may not see too
13 many pressure or thermal cycles. Whereas systems such as
14 main steam or feedwater sees many large numbers of pressure
15 and thermal cycles that can impose local stresses at the
16 welded attachments.

17 And these stresses generally are not considered
18 in the analysis. They are Class II and III pipings, so there
19 is a certain amount of uncertainty in the actual stresses
20 for these types of systems.

21 If a 20 percent increase were allowed on those
22 systems, and if pressure cycles, thermal cycles, thermal
23 gradients were neglected, and if there was a small design
24 margin, how could that be accepted?

25 MS. WILLIAMS: Well, first, again I would narrow

5pb9

1 it down to the specific case. And I recognize that the
2 viewgraph does not provide the detail, but we went through
3 a similar comparison as we did in question 2, which is
4 two pages of calculations, which I did not put on a viewgraph,
5 which we can make available to you.

6 To make a comparison, and to narrow it down to
7 the situation where we think that your only concern would
8 be with the stainless steel and the temperature range greater
9 than 400 degrees.

10 MR. TERAQ: That is not my only concern. One
11 concern of course is the stainless steel greater than 400
12 degrees. But even in carbon steel piping, where you can
13 have large numbers of pressure and thermal cycles that are
14 not explicitly accounted for in the design, it is basically
15 covered by NC-3645, which states that localized venting should
16 be minimized.

17 It does not say that you have to do an explicit
18 analysis. Now for those systems where you do see large
19 pressure and thermal cycles that could result in large
20 local stresses in the piping, increased allowable added to
21 the uncertainties in those loadings, may not be acceptable.

22 MR. SHULMAN: I am a little confused here. Are
23 you questioning the 20 percent increase in allowable? Or
24 are you questioning later code versions? I think part of
25 Nancy's problem is, were Gibbs & Hill to use later versions

5pb10

1 of the code, the only case where those allowables that
2 Gibbs & Hill use would exceed the allowables of later versions
3 of the code would be in the case of 304 and 316 stainless
4 steel. And only when the temperatures were above 400 degrees.
5 Above 400 --

6 MS. WILLIAMS: Above 400.

7 MR. SHULMAN: I am confused as to whether you
8 agree with that premise, or are you disagreeing with that?

9 MR. TERAQ: The Code Case itself that you are
10 referring to is N-318. Now that Code Case goes into varying
11 detailed analysis of the different loadings at a local welded
12 attachment. It covers not only the external loading, but
13 the internal thermal loadings.

14 Not only the primary, but the secondary and peak
15 loadings. If that has been done, then there would be no
16 concern. The question is whether or not a general increase
17 of 20 percent, not knowing for certain what loadings were
18 considered, may not give you the same safety margin as
19 using the Code Case.

20 MR. WEINGART: Our comparison was not necessarily
21 even related to the Code Case. This comparison was to the
22 later code itself, where we compared the allowables that
23 Gibbs & Hill had used, versus a later code, and then added
24 in the large stresses that were calculated by Gibbs & Hill.

end 5.

25

1 MR. TERAQ: I don't think that would be
2 appropriate. You are referring to the NCND-36 equations?
3 Those only calculate pressure membrane and general ending
4 stresses.

5 MR. WEINGART: Which is part of what the Code
6 Case specifically refers to, 318. And in 318 you will see
7 the analogous equations, where they add in the 318. They add
8 the membrane bending stresses to the stresses that you find
9 in the equation from the code 8, 9, 10, the same allowables.

10 Now your question, I'm not quite sure I follow how
11 your question relates. You are saying there is additional
12 loadings which should be applied.

13 MR. SHULMAN: To use 318, the stress analysis
14 has to be treated differently. I think that's what you're
15 saying. You have to consider other stress distributions.

16 MR. TERAQ: Thermal gradients. I think the general
17 concern is why was the increase in the ASME code allowables
18 used? Why was it permitted?

19 MS. WILLIAMS: That was our question to Gibbs &
20 Hill, as well. It is my understanding that it was a decision
21 that was made that they felt was adequate or appropriate at
22 the time. And then what we set out to do was to assess whether
23 we were comfortable with that decision, that they were using
24 in their design.

25 We felt that it would not be a problem, and accepted

61b2

1 it on that basis. I guess what you are saying is that you still
2 have a concern as to whether that was appropriate.

3 MR. SHULMAN: The real question is the manner in
4 which stresses were calculated. Is it conservative relative
5 to what Code Case 318 requires?

6 MR. TERAQ: I guess what I am saying is when the
7 ASME code recognized that higher stresses are needed for --
8 to account for local welded attachments, a good deal of
9 engineering and analysis and a rational basis was developed
10 in order to come up with the Code Case and 318, whereas the
11 approach apparently Gibbs & Hill used, is they just felt that
12 20 percent increase was acceptable.

13 Now it is proved that 20 percent increase is not
14 acceptable for all piping, all materials. Knowing what we
15 know today, with the Code Case, how can we accept the 20
16 percent increase that really had no justifiable basis?

17 MS. WILLIAMS: We went through a similar line
18 of questioning when we wrote up the observation. I guess
19 what we are getting down to now is do we agree that it is
20 acceptable, in light of current day practices, and you have
21 some specific concerns on that, that this does not address --
22 that our response does not address, or that you disagree, even
23 with our comparison.

24 So far, on this response, I want to make sure that
25 we are talking the same concerns here, so we can focus in on

1 it. We thought it was a concern, too. We did not think there
2 was a basis for it. There was some room for interpretation
3 of the codes, as they existed back then. We had a conference
4 call, telephone call, with Gibbs & Hill, where they explained
5 their logic behind that.

6 We thought about it some more, to discern whether
7 we thought it was really a problem, given that we had a
8 50 percent margin in the system and given that we felt that
9 there was only specific concerns, such as in the case of the
10 stainless steel. We felt that there was no ultimate design
11 impact on using that.

12 And now we are discussing that basis, whether that
13 is an adequate basis for saying that is acceptable.

14 MR. TERAQ: The main concern is reaching the
15 pressure boundary of the pipe. There are many ways that an
16 engineer can meet the intent of NC-36.45, in order to
17 minimize the excessive localized bending in the pipe. One
18 can use pads, saddles. One can avoid welded attachments that
19 can induce localized bendings, such as shear lugs would intend
20 to induce shear on the pipe rather than stantions, which can
21 induce the localized bending into the pipe.

22 And I guess the philosophy is if shear lugs break,
23 it would fail and shear, and it would not necessarily breach
24 the pressure boundary of the pipe, whereas welded stantions
25 to the pipe -- if that fails, it would induce a localized

1 bending into the wall of the pipe.

2 So the intent of NC-36.45 can be met by using --
3 shall I say -- good engineering practices and recognizing
4 what you are trying to avoid. Do you find that these kinds
5 of engineering practices were used by Gibbs & Hill?

6 MS. WILLIAMS: They used the SYLNOZ, S-Y-L-N-O-Z,
7 program, where it was deemed necessary that they use pads.
8 It probably does not address the concern of trying to avoid
9 the use altogether, the use of welded attachments altogether,
10 which I think I hear you saying.

11 MR. TERAQ: I wonder if there was a reasonable
12 basis for either using or not using pads on piping, where
13 local stresses can be significant? Was there any screening
14 done by Gibbs & Hill, for example, limitations on temperatures
15 of the pipe, pressures of the pipe, where a certain type of
16 attachment was or was not allowed? Is there any kind of
17 guidance of that given in any other procedures or specs?

18 Let me see if Lee can answer that.

19 MR. WEINGART: What we found was that it was
20 totally based on the results of adding the ^CSYLNOZ stresses to
21 the Code equations, it would increase the allowables. And
22 if they pass, that there was no further requirements imposed.

23 Now if I understand your concern correctly, you're
24 saying that just adding those stresses to the equations 8, 9,
25 and 10, and showing that those stresses met the allowables,

6LB5

1 would not be sufficient.

2 MR. TERAQ: What I am saying is perhaps in the
3 RHR that may be appropriate. The thermal gradients and the
4 number of cycles are relatively small. The use of that
5 procedure, for example ^CSYLNOZ, only calculates external loadings
6 and not internal loadings. The use of that program may not
7 be appropriate, for example, in evaluating the main steam or
8 feedwater pipe or the thermal gradients can be quite large.

9 MR. WEINGART: You do not consider for Class 2 and 3
10 piping.

11 MR. TERAQ: The reason for not considering, for
12 not having to have an explicit analysis, is because most
13 Class 2 and 3 pipings don't see the type of pressure and
14 temperature cycles that Class 1 piping sees. The main steam
15 and feedwater sees considerable and significant numbers
16 of cycles throughout the life of the plant.

17 One should use a little engineering rationale
18 there, in order to determine whether those stresses should
19 be calculated. Just because the codes -- the Code does not
20 say don't calculate, the code only says that one should
21 avoid excessive localized bending and thermal gradients in
22 the pipe.

23 MR. SHULMAN: We do not know, at this point, what
24 they did on the main steam and feedwater.

25 MS. WILLIAMS: The main steam is a subject for

1 our Phase III review. Correct me if I am wrong, but I think
2 that they minimize the use of welded attachments on the main
3 steam system. That's not true? Okay.

4 MR. WEINGART: If I understand what you are saying,
5 you are not limiting your argument to just welded attachments.
6 It is piping analysis in general for high temperature lines,
7 or lines that will see significant temperature transients
8 or pressure transients.

9 MR. TERAQ: The overall concern is have welded
10 attachments been properly considered? And is this 20
11 percent increase appropriate? My position, at this point, is
12 it may be appropriate for some piping systems, but other
13 piping systems it may not be appropriate. Now you have
14 looked at -- CYGNA has looked at the effect of the 20 percent
15 increase on RHR and concluded that it does not impact RHR.

16 Our question is how did it impact the other piping
17 systems?

18 MS. WILLIAMS: We might be able to pick up on that
19 specific concern on Phase III, since we are looking at the
20 mainsteam. It might be an appropriate place to evaluate that.

21 (Pause.)

22 MR. YOUNGBLOOD: We were just discussing what your
23 responses will be, with regard to these question. Obviously,
24 some of them will require some response from Phase III or
25 Phase IV. Phase III or Phase IV, I believe, are being done

1 basically in response to the hearing board, and so forth.

2 Do you plan to give us these responses separately
3 for the IAP, and not as part of your package that you are
4 doing for the total Phase III and Phase IV?

5 MR. PIGOTT: Are you referring to the specific
6 questions being asked today?

7 MR. YOUNGBLOOD: Yes.

8 MR. PIGOTT: We can answer your specific questions
9 in the context of Phases I and II without requiring that
10 they be rolled into whatever.

11 MR. YOUNGBLOOD: You may roll them into that
12 report, but we would like a separate response.

13 MR. PIGOTT: The timing may be another question.
14 I don't know if we are in a position yet to give you those
15 answers.

16 MS. WILLIAMS: Not quite yet. We are still
17 evaluating Phase III.

18 MR. SHULMAN: What would the time frame be, given
19 that they are part of the Phase III and IV evaluation?

20 MR. YOUNGBLOOD: We cannot finish our report until
21 you give us these responses. The timing is sort of --

22 MR. BACHMANN: There were certain specific responses
23 that were requested and that were referred to Phase III,
24 possibly Phase IV. Those very specific answers, if they can
25 be pulled out and forwarded, as Mr. Youngblood said, are

1 necessary for us to complete the Staff's evaluation, the
2 Staff's review of the IAP. And if at all possible, we would
3 like to get those -- obviously -- as soon as possible. We
4 would appreciate being made aware of any of these responses,
5 and of course we will all have the transcript so we can see
6 exactly what they were that will be delayed, or that could
7 not readily become available within a reasonable period of time
8 as soon as you are aware of them, and let us know. And see
9 if there is a possibility, if they can be worked around or
10 something.

11 We definitely would like to wrap up this review.
12 Some of these, as far as I know, are completely indispensable
13 to completing the review.

14 MR. PIGOTT: We will have to look at the
15 questions and determine how fast we get the answers. As
16 we get to the answers outside of Phase III and IV certainly.

17 MR. YOUNGBLOOD: The reason I said that is I would
18 expect that to take a little longer than maybe pulling the
19 separate ones out. It is -- we are certainly interested in
20 Phase III and Phase IV.

21 So far as the IAP is concerned, we do not have to
22 have all of that.

23 MR. PIGOTT: You do need these for this particular
24 phase of your review?

25 MR. YOUNGBLOOD: Yes.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

(Slide.)

MR. BACHMANN: Off the record.

(Discussion off the record.)

(Recess.)

end t6

1 MR. BACHMANN: Back on the record.

2 MS. WILLIAMS: Cable trays, item four.

3 (Slide.)

4 This is an apparent omission on one of our tables
5 contained in the design criteria. It was an appropriate
6 question. It was omitted. It was not because we did not
7 perform the review using that criteria. It just was not
8 filled in so we have provided, and this will show up in a
9 revision to the design criteria, what the safe shutdown
10 column should read using the 1.6 bump factor in allowables.

11 MR. BACHMANN: Will you provide this as an official
12 amendment to your report?

13 MS. WILLIAMS: When we issue official Rev. 0, yes.
14 It is in one of the errata sheets that will be provided.

15 MR. RINDALDI: In your testimony, you address
16 this number, Walsh No. 5, question. I was given some papers
17 on your testimony, on cable trays. You addressed the Walsh
18 No. 5.

19 My question is mainly when you compute --

20 MR. WILLIAMS: Which part of Walsh 5?

21 MR. RINALDI: The attachment that you have, page
22 one of one, for example, here. Let me ask a general question.
23 I don't think you need to look at numbers, Nancy.

24 Basically the factor of safety that you use in
25 the computation for the bolts, it is related to the same load

1 factor that you have, the 1.6 that we are talking about right
2 now. You alternate between factors of 3, 4 and 5 and it is
3 not clear why you keep on changing and 7902 recommends 4 and
4 then for OBE you use 4, other cases you use up to 5. I don't
5 think that this point is clear, what was done or what you
6 have accepted.

7 MS. WILLIAMS: We will start with the anchor bolt
8 safety factors, which is the only thing that that would refer
9 to.

10 MR. RINALDI: The 1.6.

11 MS. WILLIAMS: That does not apply to anchor bolts.
12 That is the key and really part of Mr. Walsh's question is
13 whether 1.6 is a bump factor allowable for the SSE condition
14 in using the structural design.

15 You look at the chart and when you get down, the
16 bump factors on anchor bolts, you will find that there really
17 are none. You have built in safety factors that the
18 manufacturer requires if you follow his installation
19 procedures, which give you permissible capacities for the
20 bolt. That is when we start discussing safety factors of
21 4 and 5.

22 Now, Hilti, when you look at their table for
23 capacity, built into that number is a safety factor of 4.
24 Gibbs & Hill originally started doing their design using
25 safety factors of 5 in some cases, but that is not required.

1 7902 addresses various types of anchor bolts where
2 the sleeve pipe inserts require safety factors of 5. Hilti's
3 requires safety factors of 4, which is in accordance with
4 the manufacturer's manual and they only use Hilti's in the
5 case of the cable trays. So you can forget about the safety
6 factor of 5 being required for anything because it did not
7 use a sleeve type redhead insert.

8 The fact that Gibbs & Hill used a factor of 5 for
9 some parts of this calculation, that is fine but it is not
10 required.

11 So a safety factor of four refers to Hilti type
12 anchor bolts, expansion -- concrete expansion type anchor
13 bolts.

14 This calculation here on Attachment W-2 is an
15 assessment of what safety factor they really have in their
16 bolts, using the type of design approach that they do on the
17 cable trays.

18 Now that is another subject.

19 MR. RINDALDI: I would like to refer you to a
20 specific part. You have page one of six, Attachment W-5-3.
21 You have CYGNA's approach at the bottom of the page. Maybe
22 if you explain that sentence.

23 MS. WILLIAMS: I have to put it in context,
24 unfortunately. I will try to do that in an overview type
25 manner.

1 There is the OBE and the SSE condition that you
2 designed the cable trays for prior to -- and this is shown
3 on Attachment W-5-2. It is just a one-sheet attachment.

4 They went through and basically normalized those
5 equations so that they only had -- they picked the worst case
6 between OBE and SSE and they did their design to that case.

7 What this sheet on W-5-2 is, a reflection of how
8 they went through and assessed what that worst case was.

9 So now they have chosen what the governing loading
10 condition is and they use that throughout their design but
11 now inherent in doing this is the fact that you are allowing
12 a bump factor of 1.6 in your numbers.

13 Now you have taken and compared the OBE and the
14 SSE. The fact that you are comparing the SSE, you are
15 acknowledging that you are allowing the 1.6 bump factor in
16 your allowables for that condition, but anchor bolts are not
17 allowed at 1.6 bump factor.

18 That is where we get into the next attachment,
19 which is, "well, how important is this to the design?" Was
20 that an omission? Was it really a concern? When we were up
21 there doing the review, we stumbled on this as well, just
22 as Mr. Walsh has in this question.

23 Then we went back and we found out that in fact
24 Gibbs & Hill had addressed it back in 1979 as well. There
25 were internal memorandums on it. We did our own calculations

1 here to make sure that we agreed with what they did. This
2 attachment, W-5-3, is a summarization of our calculations
3 where we went back and checked whether we think the anchor
4 bolts are okay given using that design approach of normalized
5 or governing loading conditions.

6 MR. RINALDI: I understand the general statement.
7 Can you addresss specifically the three with the four, how
8 that comes in? I just looked at this during the meeting.

9 MS. WILLIAMS: In the middle of the page there?

10 MR. RINALDI: Through all of the computations on
11 the following page.

12 MS. WILLIAMS: We are checking to make sure that
13 the anchor bolts, whether or not the anchor bolts meet the
14 required safety factor of four given that approach. The
15 safety factor of three is what we agree would be acceptable
16 for the SSE condition and we went through and did some checks
17 and discussed it with the manufacturers and evaluated those
18 conditions. So 3 and 4 refer to the anchor bolts, 4 being
19 what is normally required, 3 being a minimum that we would
20 think was allowable and we wanted to set out to see if they
21 met the 3.

22 MR. RINALDI: What is the basis for accepting the
23 3? Why do you determine that it was an acceptable number?
24 A minimum acceptable number?

25 Is that document anywhere?

1 MS. WILLIAMS: MS-129-4, I don't believe we
2 included that here. No, we did not include this as part of
3 the response. I do not think I sent it out.

4 MR. RINALDI: I have not looked at great depth.
5 I just looked at it this morning. This is one of the questions
6 if possible I would like to be clarified on, MS-129-4 that
7 you indicate.

8 The other thing is you also attached some report,
9 which is Attachment W-5-4. It refers to seismic testing of
10 electric cable support systems. I believe this was some
11 research work done to qualify various cable trays. The second
12 page to your attachment, figure 1, shows some configuration
13 of typical cable trays.

14 Are these pretty much the same as what we are
15 talking about, the Comanche Peak site?

16 MS. WILLIAMS: We are relying on this paper to be
17 clear. This is the dampin values. John, do you want to
18 comment on that?

19 MR. RUSS: I have to check -- if you give me some
20 time. They did use different types.

21 MS. WILLIAMS: There are several papers we did not
22 include here. We put this in as a sample. It is our belief,
23 based on the various test reports available in the industry,
24 that using the damping values, the cable tray damping values,
25 can be very high.

1 MR. RINALDI: I understand your point.

2 All I am trying -- since this is an attachment
3 to your testimony. I wanted to make sure that there was a
4 real solid tie between the field use of the cable trays and
5 the one we referred to in the document. That is what I was
6 trying to do by my question.

7 MS. WILLIAMS: I understand your question, but I
8 would point out that there is more of a generic discussion
9 on our part. We will check on that.

10 MR. RINALDI: Going back on the cable trays,
11 relating to the damping value, I guess the big question is
12 the damping factor related to welded structure versus bolted.

13 It is a fact, I understand, that these trays are
14 clamped down to the brackets and the welding is only for the
15 trays themselves, only the weld applies to the trays and not
16 to the connection in the trays and the supports, right?

17 MS. WILLIAMS: Basically that is true. They have
18 various clamping configurations that I think when you were
19 at the review we had the catalogue out. The welding is
20 basically within the members of the support structures
21 themselves.

22 MR. RINALDI: Out of the trays are clamped and
23 bracket support?

24 MS. WILLIAMS: Yes, we look at it as a system
25 because of that.

1 MR. RINALDI: Any welding used in the brackets is
2 minimum? You indicated there is some welding of bracket
3 supports that does exist at the site.

4 MS. WILLIAMS: It is the bracket to the tray -- the
5 bracket to the support, not the bracket to the tray. They
6 have those fiction type bracket connections with the tray
7 and they also have bolted connections between the tray and
8 the support. Those are the two types of configurations I
9 believe we found in our review.

10 MR. RINALDI: Is it possible to obtain a sketch
11 showing what the welding exactly -- what it looks like, what
12 we're talking about?

13 I want to be very clear, if possible.

14 MS. WILLIAMS: It is on one of the drawings. I
15 just have to get the drawing number for you. I think you
16 have a set.

17 MR. RINALDI: I have a set.

18 MS. WILLIAMS: It is in the bottom lefthand corner
19 of a drawing if I remember properly.

20 MR. RINALDI: I do not have any more questions on
21 this item, on the March 30th letter.

22 (Slide.)

23 MS. WILLIAMS: Item 5, cable trays. Did we verify
24 that the construction drawings matched with the design
25 drawings or the design?

1 Our review, we looked at the design drawings which
2 are the S-900 series drawings, and we checked to make sure
3 that they in fact matched with the design analysis. The
4 reason it is important in the cable trays is because they
5 used a generic design approach where they have certain
6 standard details, standard design calculations and they apply
7 that as an envelope to certain specific designs which they
8 have produced, the structural design drawings 4.

9 Now we did go and make sure that each one's
10 standard details that we looked at was a correct match with
11 the analysis which qualified that support.

12 I want to make the distinction between that and
13 a construction drawing where we were not really going into
14 the field and checking the construction drawings that may be
15 developed from the S-900 series of drawings to make sure that
16 the design matched with the qualifying calculations.

17 MR. RINALDI: What is the tie to assure that the
18 S-900 drawings are indeed pursued in the field for field
19 drawings?

20 MS. WILLIAMS: There are two ways. You can go in
21 and make -- to look and make sure that the installed condition
22 matches the S-900 series drawing or you can compare the
23 construction drawings with the S-900 drawings.

24 Quite often some sites, because we did not look
25 at construction in the case of Comanche I can only say this

1 in general, they can use their structural drawings as con-
2 struction and they take off details from there for the
3 connections in items such as that, which is what I presume
4 they do at Comanche, but it was not part of the scope of our
5 review.

6 MR. RINALDI: Do you know if it was part of the
7 scope of any other work at the site, of any other group?

8 MS. WILLIAMS: I cannot speak for other groups.
9 I can only say that we are going to do walkdown of the cable
10 trays for Phase IV, where you would make that link.

11 MR. RINALDI: When would that take place?

12 MS. WILLIAMS: I would say that is about six
13 weeks. I don't have my schedules here with me but to give
14 you a rough time frame.

15 MR. RINALDI: The S-900 drawings do indeed show
16 compliance with the design, the 15 Standard Design, of the
17 cable tray supports.

18 MS. WILLIAMS: Yes.

19 MR. RINALDI: Thank you.

20 MS. WILLIAMS: Item 6 is electrical --

21 MR. BACHMANN: This might be a good time to break
22 for lunch. We will break for lunch and reconvene at 1:15.

23 (Whereupon, at 11:42 a.m., the meeting
24 was recessed, to reconvene at 1:15 p.m., this
25 same day.)

mgc 8-1

AFTERNOON SESSION

(1:20 p.m.)

1 MR. BACHMANN: On the record.

2
3 MR. YOUNGBLOOD: Let's continue where we were
4 this morning. We are at Question 6 now on the March 30,
5 1984 letter to CYGNA and Comanche Peak.
6

7 MR. PIGOTT: If I may interrupt, before we go off
8 into looking at Walsh questions with respect to cable trays,
9 in the middle of the response to 4 and 5, at the risk of
10 being repetitive, I was going to ask Nancy to succinctly
11 state our answers to 4 and 5 again, so that we have them at
12 one place in the record.

13 MR. YOUNGBLOOD: Would it be worth pursuing, for
14 those of us here and those of us that may be reading this
15 transcript, how you see the overall work that CYGNA is
16 doing, what relates to the IAP and what may relate to the
17 rest of it that relates to what the hearing is going to be.
18 They both interweave each other.

19 Would that take some thinking before you would
20 attempt to do that?

21 MR. PIGOTT: May I answer that?

22 MS. WILLIAMS: Yes.

23 MR. PIGOTT: I had contemplated at the end of
24 our presentation -- I don't know if the Staff would want to
25 caucus, but I thought that we would caucus and go through

mgc 8-2

1 and pick out the questions that you have asked, and then try
2 and make an assessment as to whether or not they are within
3 the IAP or if they are within 3 and 4, and give you some kind
4 of a timeframe also as to how long it may take to answer
5 those questions and perhaps address your concerns in that
6 way.

7 MR. YOUNGBLOOD: All right. I will cite that what
8 is in the IAP is in the IAP. If you are going to pick up
9 some of that in what you are doing in Phase III and IV, then
10 that is a serendipity part of it you will feed into the IAP.

11 MR. PIGOTT: Right.

12 MR. YOUNGBLOOD: Do you think maybe you can do
13 that after we get through it?

14 MR. PIGOTT: If you give us fifteen minutes at the
15 end of the meeting, I think that we can probably, at least,
16 give you an initial shot at it.

17 MS. WILLIAMS: Of the things that we are discussing
18 here, not going through the Walsh-Doyle questions and saying
19 which ones are in scope and out of scope.

20 MR. YOUNGBLOOD: No.

21 MS. WILLIAMS: Okay.

22 Frank, to answer some of your questions, I have
23 the drawing numbers that you were asking for on the
24 connection details. Those are 2323-S-090 through 0903.
25 The first one is 0901. It is 01 through 03. Those show

mac 8-3

1 connection details in various portions of those drawings
2 where they are always bolted to the tray support in those
3 connections, but you can find them on those drawings.

4 MR. RINALDI: We are also talking about the welding
5 of supports, right?

6 MS. WILLIAMS: Yes. And then the clarification
7 on that one is that the welds and supports are found on the
8 support members but not the tray to the support or the
9 anchorage of the tray to the support.

10 MR. RINALDI: You were going to indicate -- the
11 question this morning was also related to at what location
12 the welding did occur and to identify these locations.

13 MS. WILLIAMS: I understood your question to be
14 the connections of the trays to the tray supports.

15 MR. RINALDI: That is one part. We are talking
16 about the clamping devices, the trays and the supports. We
17 are trying to determine whether the clamping was the only way
18 that the trays were attached to the supports, the cable tray
19 supports.

20 Also, I think you indicated that welding occurs
21 along the support at certain locations. I was asking if you
22 could clarify the locations by reference to drawings.

23 MS. WILLIAMS: Those, you would look at the standard
24 details for the cable tray supports themselves where you
25 would see which portions of them are welded, which had the

mgc 8-4

1 .0900 series.

2 MR. RUSS: Those are the drawings in question.
3 Those will show the details you require.

4 MS. WILLIAMS: In general, what you will find is
5 that the members for the supports, member-to-member, are
6 welded. Sometimes the members are welded to the clip angle
7 or the angle which forms the baseplate.

8 MR. RINALDI: I'm not very clear right now from
9 your explanation of exactly what is going on, other than
10 reviewing the drawing in detail for the field conditions.
11 I understand you have given me an answer. I do not think
12 it is very clear at this point exactly what is going on,
13 where the connections are with the clamps.

14 MS. WILLIAMS: You will find that in those details.

15 The other reference was to the report which was
16 attached to Walsh-5. I think that when you go through the
17 report, there will be a reference in there to an ANCO Test
18 Laboratory report performed for Bechtel LA where they did
19 over 2000 tests on all kinds of trays. One of the
20 conclusions that comes out of that report is that the tray
21 dynamic characteristics are not so much a function of tray
22 type.

23 So that should lead you through it, when you read
24 through it.

25 As far as the table goes for Question 4, I guess it

mgc 8-5

1 was, -- is that one answered? I just wanted to make sure
2 that I'm not getting lost in Walsh-5 versus answering your
3 questions here in the March letter.

4 MR. RINALDI: In the March letter was the very
5 simple phrase that something was missing.

6 MS. WILLIAMS: Item 5, you want to look at the
7 drawings some more?

8 MR. RINALDI: Not just the drawings. The field
9 conditions and construction drawings. Being there are all
10 of the questions about the systems, I think the only way to
11 satisfy anybody's concern is to tie the whole chain.

12 MS. WILLIAMS: That is out of the scope of our
13 review.

14 MR. YOUNGBLOOD: That would be looked at in Phase IV
15 at the walkdown.

16 MR. BURWELL: When you did your walkdown on the
17 spent fuel pool cooling system, I think you did look at some
18 cable trays and the supports, the cable tray supports.

19 MS. WILLIAMS: Only to the extent that the spacing
20 was there and they provided adequate support to the power
21 train to the pump, but the structure was actually the
22 foundations in that review.

23 MR. BURWELL: But in doing that review, did you
24 review the supports against the field drawings or the
25 generic?

enc 3-6

1 MS. WILLIAMS: We reviewed them against the
2 applicable drawings and found them to be in general
3 conformance, but not to the level of detail in comparing
4 the analysis -- making sure the analysis matches the cable
5 tray supports in the construction drawings. It was not a
6 detailed review of what I think would be required to answer
7 what Frank is saying. I would not rely on looking at that
8 to answer Frank's question.

9 MR. BURWELL: Okay. But I was only trying to get
10 at, what did you use on the walkdown? I was not trying to
11 get all across the bridge there.

12 MS. WILLIAMS: We used the 900 structural design
13 drawings and the spec.

14 MR. PIGOTT: No. 5 is recognized as not within the
15 scope of this report. It is not being asked that we pursue
16 it further at this time.

17 MR. YOUNGBLOOD: That is incorrect. Our question
18 is, CYGNA should describe how it verified that
19 construction drawings have been correctly prepared from the
20 15 Standard Design drawings.

21 If you cannot do that within what you did before,
22 then you can do that within what you are proposing to do.
23 We would like that answer.

24 MR. PIGOTT: That's what I want to know.

25 MR. YOUNGBLOOD: If you cannot do that in what you

mac 8-7

1 are proposing to do, we want to propose that you go do that.

2 MR. PIGOTT: And in proposing that we do it, that
3 it be done in a manner that can be used for your writeoff
4 of the IAP?

5 MR. YOUNGBLOOD: Yes.

6 MS. WILLIAMS: Item 6 on the March letter, the
7 question why we did not include Reg Guide 1.106 and Branch
8 Technical Position ICSB-18 as part of our review criteria
9 for the RHR system.

10 (Slide.)

11 Both of these guidelines are concerned with power
12 supplied to the MOVs. To quickly reiterate the scope
13 of the electrical control review for the RHR system, we
14 checked the power supply to the pump, and we evaluated the
15 control circuitry associated with a motor-operated valve,
16 the isolation valve in the isolation tank. We did not
17 look at a control circuit and power circuit associated with
18 a given component. My understanding of the history was that
19 we were going to do that with the pump, and then it was
20 decided that perhaps we should look at a motor-operated valve
21 instead.

22 This got a little split there. We were not
23 looking at both power and controls to one component. Our
24 review scope included the valve control circuits only. We
25 defined the valve control circuit as beginning with the

mgc 3-8

1 control circuit transformer through the rest of the control
2 circuit for the valve. The overload protection was correctly
3 not included in the design. In other words, it was checked.
4 If it had been a necessary part of the design, then we would
5 have referenced those in our design criteria. But for the
6 particular design of this particular valve, it was not
7 part of the design, not required to be part of the design.

8 There are two valves in series, though. The valve
9 in question that we looked at is 3701B, and we did look at
10 3702B, which is the next valve in series, to be sure that
11 they had separate power supplies, so the single failure
12 criteria was met.

13 MR. CHOPRA: Can you go back to the original
14 question? Did you say that the control circuitry of the
15 valve was not included in your scope?

16 MS. WILLIAMS: The control circuit of the valve
17 was included. We take that from the control transformer
18 for the balance of the control circuit.

19 MR. SHOPRA: It would not include the overload
20 devices?

21 MS. WILLIAMS: It was not applicable to this
22 particular valve.

23 MR. MOERSFELDER: The overload contacts were
24 correctly not included in the starting coil circuit.

25 MR. LI: But the justification was not included.

mgc 8-9

1 I think we imposed that Branch Technical Position for
2 overload, the MOVs. The concern is, it may damage the
3 valve, and during a critical moment, it cannot perform the
4 safety function.

5 MR. MOERSFELDER: I believe you are speaking of
6 Reg Guide 1.106 that talks about the terminal overloads.

7 MR. LI: Right.

8 MR. MOERSFELDER: It said the thermal overload
9 protection devices will not needlessly prevent the motor
10 from performing its safety function. Agreed?

11 MR. LI: Okay.

12 MR. MOERSFELDER: Therefore they are willing to
13 sacrifice the motor to make every possible attempt to move
14 that valve.

15 MR. CHOPRA: In normal conditions, they are
16 bypassed. The overload conditions --

17 MR. MOERSFELDER: The overloads are not in the
18 circuit at all.

19 MR. CHOPRA: They are not in the circuit. Okay.
20 In other words, your scope did include to review this portion
21 of the design, 1.106.

22 MR. MOERSFELDER: The review of the control
23 circuit, yes, did verify, in fact, that the thermal overloads
24 would not prevent the performance of the turbine function.

25 MR. LI: Do you intend to amend your report to

mgc 3-10

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

include the statement you just made?

MR. MOERSFELDER: Yes.

MR. LI: I think this is part of the control circuit. It is not excluded. It should be in the scope, in our judgment, but the justification is acceptable. You have to amend it in the report.

MR. MOERSFELDER: All right.

End 3

9pbl

1 MS. WILLIAMS: I will jump to the February letter
2 now.

3 MR. YOUNGBLOOD: What about item 7?

4 MS. WILLIAMS: There was a request to do both
5 electrical items together.

6 MR. CHOPRA: Can you put that viewgraph back
7 again? I'm not clear -- on your response.

8 (Slide.)

9 MR. LI: We're talking about the 8811B. You
10 mentioned the single failure and refer to the 8701B, 8702B.
11 I think the single failure we are referring to involves
12 8811B. That is on a single valve.

13 MS. WILLIAMS: The review scope was 8701B. That
14 was the I.D. number for the oscillation valve that was
15 originally chosen as part of the scope. Isn't that right?

16 Now we came into contact with checking the logic
17 between that valve and the other valves you are talking
18 about. We did evaluate the logic between the valves. But
19 as far as doing a routine evaluation, the base of that was
20 8701B.

21 MR. LI: I think the scope is 8811B. That's where
22 the problem came from.

23 MR. MOERSFELDER: Maybe that is the source of
24 the confusion. We have to go back and check. What we
25 reviewed was the 8702B, 8701B.

9ob2

1 MR. BURWELL: My understanding was that the 8811 --
2 that is why this particular thing confuses us -- that is the
3 gist of the misunderstanding, the gist of why you asked the
4 question.

5 MR. LI: 2.2 of this diagram. Here we referred
6 to this one.

7 MR. MOERSFELDER: On the right side is the 8701
8 and -02 combination.

9 MR. LI: Interfaced with this valve. We are
10 talking about this valve, not those valves.

11 MR. BURWELL: We're talking about the one in the
12 little doghouse, which is 8811.

13 MS. WILLIAMS: That's how it was written up.

14 MR. LI: Texas Utilities' response primarily they
15 addressed our concerns. They asked you to amend, to clarify
16 the interlock.

17 MS. WILLIAMS: I have not seen that letter yet,
18 that is response to the February letter. You're right in
19 saying the intended scope was the isolation valve. If you
20 want to go through -- since you did do, since you were part
21 of the review -- if that would be at all helpful and take
22 it from there --

23 MR. MOERSFELDER: The response that we had prepared
24 for you for the technical, Branch Technical Position,
25 related to the 8701, 8702, where with the two valves

9pb3

1 directly in series like the figure shows, I don't think
2 there would have been a question of single failure criteria.

3 In the case of the 8811A, there are not two
4 valves in series. I think that is the crux of your question.
5 I too have not seen the April 2nd letter before, so we
6 will have to review that.

7 MS. WILLIAMS: The original scope, I think, is
8 what you're going to have to explain. Can you go through
9 what that was?

10 MR. MOERSFELDER: I think now in light of this,
11 we have to go back and review exactly -- we have to know
12 with our review that we actually performed, we have to go
13 back and see, or reconfirm for ourselves what we did review,
14 to what extent.

15 MS. WILLIAMS: I think what I am hearing -- I
16 want to make sure I am clear on this -- is that the program
17 plan where this figure was contained is not --

18 MR. MOERSFELDER: I want to check that. I want
19 to verify that.

20 MS. WILLIAMS: We will provide an answer to the
21 February letter, which I think will still require some
22 further checking, knowing that is how Al has explained the
23 review scope. You have to take his answer in that light,
24 and this clarification in that light.

25 If we all agree there is something else that needs

9pb4

1 to be checked, then so be it. In any case, this was a
2 summary of that question -- of our response.

3 The question was, we have a checklist. EE-02
4 where we reference a pressure and there is some question as
5 to whether we were reviewing for compliance with Section
6 7.6.5 of the FSAR. We will show you that checklist very
7 briefly.

8 (Slide.)

9 The source of confusion is Item 1, subitem V where
10 we are checking for compliance with Section 7 of the FSAR.
11 We are not so specific as to say Section 7.6. There is a
12 note over in the comments column discussing the 425 psi gauge
13 pressure.

14 It is my understanding that the correct number
15 for that pressure, correct valve is again, the 8701.

16 (Slide.)

17 MR. MOERSFELDER: Let me ask one other question.
18 In the review that we did, we concentrated on the controls
19 part of the control valve. We did not concentrate on the
20 electrical power supply to the valve. What you are really
21 asking about here does involve the power supply to the valve.

22 MR. LI: No, it is interlocked. The interlock is
23 part of the control. The other concerns relate to interlock.

24 MR. MOERSFELDER: That part of the response is
25 not prepared. We will have to review that further.

9pbs

1 MR. YOUNGBLOOD: Do you understand what your
2 question is?

3 MR. MOERSFELDER: I think so now, yes.

4 MR. LI: When you review Texas Utilities' response,
5 the April 2nd letter, I would like to bring your attention
6 to clarify two items. In the middle of the paragraph, it
7 says operator action, the third line from the bottom of the
8 second paragraph. It says operator action is required to
9 close the refueling water storage tank, the RHR pump, suction
10 isolation valve, the 8812A/B immediately following the
11 opening of the containment sump isolation valve.

12 I think this statement does not quite agree
13 with the FSAR Section 7.6.5. The FSAR requires some kind of
14 automatic interlock, and this says needs operator action. So
15 I want you to check which one is correct.

16 The second item, the last paragraph on the first
17 page. It says, the reactor coolant system pressure must be
18 below approximately 425 psig before the RHR isolation valve
19 will open. I talked to our system people, our reactor systems
20 people, and this statement is questionable. It must be below
21 -- I want to verify that because during the small LOCA
22 situation the pressure may be above 425 psig, but you still
23 have to open this valve.

24 I want you to verify this, these two items.

25 MR. MOERSFELDER: The last sentence in the last

9pb6

1 paragraph.

2 MS. WILLIAMS: Second to the last.

3 MR. YOUNGBLOOD: First sentence, the bottom
4 paragraph of page 1.

5 MR. LI: Texas Utilities recommends in the last
6 paragraph of this section, the CYGNA comments regarding
7 direct interlock between containment sump isolation valve
8 and the reactor coolant system pressure is not clear, and
9 it should be clarified or reworded. You may have to revise
10 your report to make it a correct assessment.

11 MR. BACHMANN: Let me ask a question here. The
12 statement that was just read by Mr. Li and the Texas
13 Utilities' letter, where they suggest that the CYGNA comment
14 is not clear and should be clarified or reworded, did you
15 have this letter prior to arriving here?

16 MR. MOERSFELDER: No, I did not.

17 MS. WILLIAMS: Part of our confusion is on the
18 scope issue. It is an apples and orange question to some
19 extent.

20 MR. BACHMANN: The reason I brought that up is,
21 had you had it perhaps you might have been preparing
22 clarification. But since you did not have it before this
23 meeting, no questions.

24 MR. BURWELL: The same type of question -- there
25 is an April 6th letter from Mr. Smith to Mr. Youngblood

9pb7

1 dealing with Texas Utilities' comments on CYGNA's work. I
2 assume you have that.

3 MS. WILLIAMS: Yes, we're going through that
4 right now.

5 MR. BACHMANN: It appears we have no further
6 questions from the Staff at this time concerning the
7 electrical instrumentation and control.

8 The next area that we want to move into, in a
9 sense, back to, is the document control area.

10 MS. WILLIAMS: Do you want question number 7?

11 MR. BACHMANN: I guess so.

12 MR. YOUNGBLOOD: It gets into that area, too.

13 MR. BACHMANN: Mr. Spraul, who was not here this
14 morning is here now and that was his particular question.
15 We can move into 7 then.

16 MS. WILLIAMS: The question was with regard to
17 observation WD-02-02. That observation deals with end-for-end
18 reversal of snubbers that we found during the spent fuel
19 pool cooling walkdown. We were asked to identify that
20 procedure on the checklist.

21 (Slide.)

22 The procedure in question is a Brown & Root
23 installation procedure, CP-CPM 9.17. The reason we
24 encountered that procedure was in an attempt to resolve this
25 observation on the end-for-end reversals, it is not on the

9pb8

1 checklist because what we were doing was as-built
2 confirmation of the drawings to the installed hardware, as
3 opposed to an evaluation of the installation procedures.

4 In this particular case we found that there was
5 a discrepancy between the drawings and the installed
6 condition and the place where that was permitted happened to
7 be an installation procedure. So that was really part of
8 the resolution and that is where it is documented, as opposed
9 to something we were checking on the original review.

10 MR. SPRAUL: What is CYGNA's position regarding
11 support drawings, as related to as-built drawings? Do the
12 support drawings constitute part of the as-built package?

13 MS. WILLIAMS: They use the support drawings to
14 stamp them as-built once they have done their walkdowns.
15 It is a somewhat dynamic process, in the sense that it is
16 going on on a continuous basis. We use the drawings that
17 were as-built at the time, the spent fuel pool cooling, if
18 there were any outstanding design changes then we would have
19 incorporated them as well.

20 They were stamped as-built in the spent fuel
21 pool cooling system. When you say package, that is a
22 QC. We did not go into QC and ask for the as-built package.
23 We went to DCC and asked for the drawing.

24 MR. SPRAUL: The as-built stamped drawing did not
25 reflect this reversal allowance.

9pb9

1 MS. WILLIAMS: That's right.

2 MR. SPRAUL: Does it now?

3 MS. WILLIAMS: No, because this procedure permits
4 that deviation from the drawing.

5 MR. SPRAUL: So at 30 years from now when
6 someone wants to look at this, it takes the drawing, more
7 than the drawing to reflect the as-built, right? It takes
8 the drawing plus the procedure? Does the drawing reference
9 the procedure?

10 MS. WILLIAMS: No, it does not reference the
11 procedure. I cannot say that they did not go back and
12 as-built those drawings. But at this point in time, no,
13 there is no reference to the procedure. You find it because
14 it is called a snubber installation procedure, so it is
15 a natural place to look when you are trying to find out
16 what the discrepancy -- what the reason for the discrepancy
17 is.

18 There is no reference then at this point in time,
19 it is not in the drawing.

20 MR. SPRAUL: And you still use the term discrepancy?

21 MS. WILLIAMS: It is an observation in this case.

22 MR. BURWELL: If one is not completely familiar
23 with all of the procedures, there is no way they can
24 guarantee that the as-built and the as-built drawings
25 really are in sync? How many other places may there be

9pb10

1 something that is completely different and people say, well,
2 the procedures must allow this?

3 MS. WILLIAMS: I cannot tell you how many other
4 places, obviously.

5 MR. YOUNGBLOOD: Obviously you cannot. But are
6 there other places where there might be real confusion about
7 the as-built drawing does not represent the as-built?

8 MS. WILLIAMS: I see. Let me think back on the
9 observations that we had for the walkdowns. Let me just
10 scan this.

11 MR. SHULMAN: Should not the as-built drawing
12 represent the as-built?

13 MS. WILLIAMS: Yes, it should represent the
14 as-built. I do not think it is inappropriate that they
15 allow for something like that in a procedure though.

16 MR. SHULMAN: The other question is should the
17 as-built reference the procedure then?

18 MS. WILLIAMS: Their as-built program should
19 reference the procedure, but not necessarily the drawing.

20 MR. YOUNGBLOOD: Then how do you know by looking
21 at the drawing that it is all right for that to be different?

22 MS. WILLIAMS: You would have to go out and find
23 out why it's different.

24 MR. YOUNGBLOOD: Anything on that drawing that
25 may differ, you have got to go back and hunt?

9pb11

1

MS. WILLIAMS: Yes.

2

3

4

5

MR. YOUNGBLOOD: Does that not lead one to say, gee, that is probably okay in the procedures somewhere. I will skip it then. It does not make any difference if it matches what the as-built is or not.

6

7

8

I am playing devil's advocate here. I think there should be a tie-in. If you can tell me that there should not be a tie-in, great.

9

10

11

12

MS. WILLIAMS: I think the tie-in should be that somewhere in the as-built program there is some link which you know which procedures are associated with the installation, so that you can check what they permit.

13

14

15

16

17

18

19

20

21

22

23

24

25

If you want to go out there and check an as-built knowing that something like this exists, you probably want to know what all of those procedures are. And that would make the correct package. I think that the as-built program, the 79-14 program, should reference those. And they do have a 79-14 walkdown procedure.

I would check there to see if that is where the link is.

end 9.

mgc 10-1

1 MR. YOUNGBLOOD: I think you ought to think on it,
2 and whatever your response is, the Applicant will want to
3 think on it, too, and see what their response should be on
4 that.

5 MR. BACHMANN: I would like to add something to
6 that as long as we are on this sort of general subject of
7 the as-built versus the -- as-built item versus the
8 quote, unquote as-built drawing.

9 There were a couple of other observations. I only
10 bring this up because we seem to be in the general area.
11 Perhaps you can give us a feeling for them -- WD-07-01
12 and WD-07-02, both of which similar problems -- similar,
13 not identical.

14 Could you comment? The first one was the difference
15 in the grounding on the spent fuel pool cooling pump, and
16 the other one was the fact that the temperature indicator
17 was not installed. These were CYGNA observations.

18 MS. WILLIAMS: WD-07-01 deals with a requirement
19 for safety-related motors per Gibbs & Hill drawing E1-170-301,
20 that they be double-grounded. That is for 1E or safety-
21 related motors. This was at the top of Attachment A for
22 that observation review record. We had noted that this
23 observation was invalid or not valid because a further
24 review revealed that the detail on the grounding details we
25 were using to check this pump against were not stamped 1E.

mgc 10-2

1 That is for personnel safety only, so it was not a requirement
2 from a safety standpoint.

3 MR. SPRAUL: That was confusing to me. When I
4 read the observation, I thought all of the pump motors were
5 to be double-grounded, not just the safety-related pump
6 motors.

7 MS. WILLIAMS: But the requirement is for
8 personnel safety.

9 MR. SPRAUL: But they are all to be double-grounded
10 whether or not they are safety-related. As I read that
11 observation, I got the impression that they were all supposed
12 to be double-grounded. The particular one that you looked
13 at did not happen to be safety-related.

14 MS. WILLIAMS: The requirement is not safety-related.
15 The pump was safety-related. It is not a safety requirement.
16 And we were doing this review looking for -- to make sure
17 that there was no safety impact on any of the discrepancies
18 or observations that we had.

19 MR. SPRAUL: But this observation being not
20 safety-related, there was no follow-up. It was just dropped
21 per se. Is that right?

22 MS. WILLIAMS: We do not view something for
23 personnel safety as part of our charter, no.

24 MR. SPRAUL: So you have your scope limited to
25 safety-related components, if you will, safety-related

enc 10-3

1 activities and hardware and so forth. But if you find
2 something wrong outside that scope, there is no follow-up
3 to see that it is corrected or anything like that?

4 MS. WILLIAMS: It does not fall within the same
5 QA type requirements, when you come right down to it. Our
6 overall objective is to -- is public safety and whether there
7 is any design impact, so it really does not fit into those
8 objectives. Again, it really does not fall into the same
9 control requirements from a QA standpoint.

10 MR. SPRAUL: I assume the answer to my question is
11 no.

12 MS. WILLIAMS: That's right, and I'm trying to say
13 why, because I think it is important.

14 MR. IPPOLITO: Let me interject here. What I hear
15 you saying is that a Class 1E or safety requirement for
16 these motors is -- in order to meet Class 1E requires only
17 a single ground that will assure that that motor functions
18 correctly, but that there is an added requirement, added
19 by whomever, that says double-grounded, and the second
20 ground is required only to provide further assurance of
21 personnel safety, OSHA requirements. Maybe no OSHA
22 requirements, but to provide additional safety to the plant
23 personnel. It is not related to the operational safety of
24 the plant.

25 MS. WILLIAMS: Yes.

mgc 10-4

1 MR. IPPOLITO: So therefore when you apparently
2 found an installation with only one, you said to yourself,
3 "The safety has been satisfied, although the personnel
4 protection was not satisfied."

5 Am I reading you right?

6 MS. WILLIAMS: Yes.

7 MR. BACHMANN: I have been informed by Mr. Spraul
8 that that finishes off the questions that the Staff has at
9 this time on the items, up to Item 7.

10 At this time, Staff would like to go back to the
11 document control area, now that Mr. Spraul is here, and
12 perhaps recap a bit of what you said, for his benefit, that
13 was said this morning, and then we can have questions on
14 that.

15 MR. YOUNGBLOOD: Off the record.

16 (Discussion off the record.)

17 MR. BACHMANN: Back on the record.

18 MR. YOUNGBLOOD: At this point, we are gaining
19 on where it is we are at this point. Why don't we attempt
20 to get into the March 22nd letter that we sent with regard
21 to advanced notice of documentation?

22 Our basic question at this point, one of our
23 basic questions, in view of the April 12th submittal by the
24 Applicant, as compared to your April 10th response to our
25 question, does that change anything with regard to your

mnc 10-5

1 response?

2 MR. PIGOTT: With respect to April 12th? You
3 are speaking to the motion?

4 MR. YOUNGBLOOD: Yes.

5 MR. PIGOTT: I guess I could probably respond to
6 that one. I have reviewed the testimony supplied with that
7 motion. I guess the most careful way to cover it would be
8 to specifically mention the various pieces of testimony.

9 The testimony provided by Mr. Hutchinson, I see
10 nothing in that testimony that is inconsistent with the
11 letter that we wrote on April 10, 1984.

12 MR. IPPOLITO: Off the record for a moment.

13 (Discussion off the record.)

14 MR. IPPOLITO: Back on the record.

15 Let me ask some questions. It is a fact, on the
16 date in question you did provide to the Applicants a list
17 of drawings that you wanted the next morning?

18 MR. PIGOTT: No. On the date in question, we filed
19 a list where we asked for computer printouts to be returned.
20 We did not ask for drawings.

21 MR. IPPOLITO: Fine. You asked for a printout?

22 MR. PIGOTT: Yes.

23 MR. IPPOLITO: And you provided that the afternoon
24 before? You got the printout?

25 MR. PIGOTT: Yes.

mgc 10-6

1 MR. IPPOLITO: Let me ask you a question. The
2 purpose you wanted this printout -- was for what purpose?

3 MR. PIGOTT: There were a couple of reasons. They
4 are reflected in the letter of April 10 on Page 2 -- to
5 determine in effect whether or not the base information had
6 been put into this document control computer. That was one
7 thing. And then secondly to determine whether the documents
8 were being distributed under proper control.

9 MR. IPPOLITO: Let me assume for the moment that
10 you walked into a document control center or whatever it
11 is called and said, "Give me this printout right now," and
12 that printout was lacking a number of items on it.

13 How would this have affected what you were trying
14 to verify?

15 MR. PIGOTT: I'm going to turn to the person who
16 did it on that one.

17 MS. WILLIAMS: That is not what we were verifying.
18 We were not verifying accuracy of the printout, the listing
19 out outstanding CMCs and DCAs. That was part of the DCTG
20 discussion, which is further on in this letter, that we make
21 the distinction that that was a separate and distinct
22 evaluation.

23 The purpose of this follow-up was that we had
24 an observation where they were -- there were discrepancies
25 between what the control document holders felt were the

mgc 10-7

1 List of outstanding CMCs and DCAs and what the central DCC
2 system was saying were the correct listing of outstanding
3 CMCs and DCAs against a given drawing. That was the
4 accuracy between two sets of lists.

5 Now the fact that they have implemented this
6 computerized data base system where the satellites have
7 remote access to the same data base, you somewhat alleviate
8 that potential discrepancy between two manual logs being
9 maintained.

10 The other part of it was the tightening up of
11 the distribution controls, which is also part of our check
12 of the satellite system, to see whether, in fact, that was
13 a good solution for the file custodian system which they
14 were previously operating under.

15 MR. IPPOLITO: I am afraid you have lost me.

16 You wanted a printout, and the printout was to
17 verify what?

18 MS. WILLIAMS: Was to verify -- we wanted the
19 printout, which was who are the controlled holders of this
20 Document X. And they would say, "Okay, Satellites 304, 301,
21 and what have you are the control holders of that document."
22 That is the distribution list we are talking about. And
23 we also wanted a listing, computerized listing or a manual
24 in the case of the piping drawings, of what the outstanding
25 CMCs and DCAs were for each of the drawings on the list.

mgc 10-8

1 Those were the two documents that we requested, one for
2 distribution, one for a list of outstanding change documents.

3 MR. IPPOLITO: And the purpose for this was what?

4 MS. WILLIAMS: For the distribution. We wanted
5 to go to what were the satellites which superseded the file
6 custodian system and see that the control document holder,
7 in fact, was cognizant of that drawing and that the
8 distribution system was being tightened up.

9 MR. IPPOLITO: Let me stop you there. What if
10 the printout did not contain all of the things that you have
11 listed here?

12 MS. WILLIAMS: All of the drawings? All of the
13 changes? That was not the purpose of the check, though.
14 We did not care, really. We were trying to check the
15 distribution system, who was the control distribution holder.
16 But the accuracy of that listing is a whole-other issue
17 altogether, and that is when you get into the DCTG
18 verification process again. That was an equally large
19 problem with a different solution.

20 MR. IPPOLITO: I guess I still do not see --
21 you have a listing. I am not sure how you have generated
22 this listing.

23 MS. WILLIAMS: Random sample.

24 MR. IPPOLITO: Fine. If this listing does not
25 show up on your printout, there is no way that you can check

mgc 10-9

1 whether or not that change is where it should be.

2 MS. WILLIAMS: This is not a list of changes.

3 This is a list of drawings.

4 MR. IPPOLITO: How do you know whether the missing
5 drawing -- what happened to it? Does the man have it out
6 there in the field? Isn't that what you were checking?

7 MS. WILLIAMS: No, not quite. This is a list of
8 drawings. We wanted to know what the outstanding design
9 changes were for these drawings, each one of these drawings.
10 We got a separate computer listing or a copy of a manual
11 log, 32 drawings, whatever is here. We got 32 printouts or
12 32 total manual and computer printouts.

13 Now on those printouts are who are the satellites
14 who are responsible for controlling that drawing, and
15 secondly, what are the outstanding design changes for each
16 of these drawings. Those are the two documents that we walk
17 away with.

18 MR. YOUNGBLOOD: Two types of documents.

19 MS. WILLIAMS: Right. Nowhere in that process
20 are we asking them, is this list of design changes accurate
21 for this drawing? You take Drawing VRHL, the first one on
22 the list, we were not asking whether the list of design
23 changes was accurate. That was a separate effort, separate
24 observation, separate solution.

25 MR. SPRAUL: You wanted to see which satellites

mgc 10-10

1 were responsible for that particular drawing?

2 MS. WILLIAMS: Yes, and to see if they were
3 following the procedures.

4 MR. SPRAUL: The next day you went out to the
5 satellite, and how did you determine whether they recognized
6 their responsibility?

7 MS. WILLIAMS: We went out to the satellites.
8 This is the second follow-up review, and we had done a
9 previous follow-up review where we felt that some of the
10 procedures were not quite adequate to implement the system
11 that they were attempting to implement, the satellite system,
12 and also that the clerks were not very familiar with their
13 jobs -- somewhat understandable, because it was a new
14 system, and they were still in the process of implementing
15 it and all of the start-up problems that would be associated
16 with a new system.

End 10

17
18
19
20
21
22
23
24
25

1 We went to assure that the clerks knew what their
2 job was, that the satellites had the drawings they were
3 supposed to have, and that they were controlling them in the
4 manner they were supposed to be controlling them. We observed
5 the process of the satellites during the day, we checked some
6 1000 pieces of change paper during the day.

7 MR. SPRAUL: This list is what you took out to the
8 satellites and said show me? Satellite 301, that you do have
9 control of this particular drawing? Or something like that?
10 Is that the way it works.

11 MS. WILLIAMS: Yes, and watched how their regular
12 operations were handled, in general, observed their access
13 to the computerized data base system, checked that their
14 books contained all of the CMCs and DCAs that were required to
15 be there, as a controlled holder of that document. And we
16 would go to several satellites, if that was appropriate for
17 each one of these drawings, checking that process.

18 MR. BURWELL: Just so I understand, let's just
19 take an example. Let's take number three, RH-1-00-3-011-S42R.
20 I think you said that you went out to the responsible satellite
21 station. You asked for this hanger package. You then checked
22 the hanger package to establish that all of the outstanding
23 change paper listed in your printout was, in fact, in that
24 package? Is that what you did?

25 MS. WILLIAMS: That was one of the things we did,

1 yes.

2 MR. IPPOLITO: Going back to my question. If
3 in doing this, following Mr. Burwell's example, you found
4 X number of pieces of paper missing from that document, what
5 would you do then?

6 MS. WILLIAMS: We would write another observation
7 or revise the existing observation, as a system not
8 functioning properly.

9 MR. PIGOTT: You had an earlier question, as
10 perhaps now all of the documents coming up on your request.

11 MR. IPPOLITO: That's right.

12 MR. PIGOTT: I'm not sure that was answered. I
13 believe that would have reflected that they did not have
14 their data base in place, that they were implementing this
15 program, and one of the things was to see whether or not they
16 had put everything in there.

17 MR. IPPOLITO: That is fine. I'm sorry. I thought
18 her response to me was so what? You had looked at it
19 before. Let me repeat it. If you still found that this
20 data base did not contain some of these drawings, what would
21 you do then?

22 MS. WILLIAMS: We probably would have gone in
23 and tried to find out if that was a function of the fact
24 that they were still turning the data base over and merging
25 it with DCC.

111b3

1 MR. IPPOLITO: You would pursue it and try to
2 find out why?

3 MS. WILLIAMS: Yes. But finding drawings in the
4 system has not been so much the problem, as the listings
5 of changes associated with the drawings and discrepancies
6 between the numerous number of lists that existed onsite,
7 which is where the computerized data base is a good attempt
8 to clean it up, because you're only working with one source
9 for the list.

10 MR. IPPOLITO: So effectively, my hypothesizing
11 that some of the changes were not in the package, or if some
12 of the drawings were not in the data base, could have altered
13 your evaluation in both of those areas?

14 MS. WILLIAMS: Yes.

15 MR. IPPOLITO: Could you identify any other
16 instances in which you provided a listing or requested
17 information in advance of your needing it and whether it is
18 for verification or for the original basic review?

19 MS. WILLIAMS: This was the only example.

20 MR. IPPOLITO: This is the only example?

21 MS. WILLIAMS: Normally, in the technical reviews,
22 our reviewers go down, they make the request, they take the
23 drawings. In many cases, it was myself. I was there just
24 physically, took the drawings. The turnaround time was within
25 hours, in receiving the drawings. This was a second follow up

1 for the satellites and we were really checking to see that
2 they were moving along the right lines and implementing
3 the new program and felt that the emphasis was not entirely
4 on the accuracy of the listings.

5 And for those reasons, thought also that the time
6 frame was relatively short, that it was not totally inapropriat
7 in such a setting. But in general, that is not how we
8 conduct the audits.

9 MR. IPPOLITO: I liked your statement, except
10 for the statement general.

11 MS. WILLIAMS: Let me take it out then.

12 (Laughter.)

13 MR. IPPOLITO: It is a very important point and
14 I'm sure you share that with me. Obviously, I do not want
15 to place words or characterize your audits. I think it is
16 important that you -- what your response is regarding -- is
17 this the exception to the rule? I guess that is the question
18 I want to ask and I want your answer.

19 MS. WILLIAMS: Yes. The answer is this is the
20 exception to the rule.

21 MR. IPPOLITO: The one and only exception to the
22 rule?

23 MS. WILLIAMS: Yes.

24 MR. SPRAUL: Roughly, for this list of drawings
25 here, can you give me some idea of how many change notices or

111b5

1 engineering change order are reflected for the average
2 drawing? Or something like that? Are we talking about one
3 or two per drawing? 23, 50, 100, you know, what order of
4 magnitude are you talking about?

5 MS. WILLIAMS: It varies. The total for the
6 list was roughly 1000.

7 MR. SPRAUL: 1000 changed notices.

8 MS. WILLIAMS: Of change paper associated with
9 these 32 drawings.

10 MR. SPRAUL: Would you like to comment on the
11 feasibility of somebody taking this from the time that you
12 gave it and putting those 1000 change notices properly into
13 the data base, if they were not there?

14 MS. WILLIAMS: It would not be into the data base.
15 It would be physically in the satellites, recognizing that
16 they have to be in more than one satellite. In other words,
17 more than one satellite can have control over one of these
18 drawings. And you are dealing with so many. We did not think
19 it was very feasible.

20 MR. IPPOLITO: Did you find the next morning, when
21 you went to get these documents, did you find everything in
22 order?

23 MS. WILLIAMS: We did not have any discrepancies.

24 VOICE: We may have been missing a few on the
25 list when the paperwork was brought over. I think there were

1 a few missing.

2 MS. WILLIAMS: A log itself -- as far as when you
3 went into the satellites. Were there any CMCs or DCAs missing?

4 VOICE: No.

5 MR. IPPOLITO: Were you surprised by this?

6 MS. WILLIAMS: No, it was already our second
7 follow up. We had been pursuing this system since July and
8 it was now October. They had been putting a fairly intensive
9 effort, on a documented plan for developing this system.
10 I don't think it is unreasonable to expect that they would
11 have been slowly getting it cleaned up.

12 MR. IPPOLITO: What if your experience would have
13 been different? Let's start with 10 percent of the changes
14 were missing. How would that have affected your evaluation?

15 MS. WILLIAMS: It would have very negatively
16 affected our evaluation. That is a large percentage.

17 MR. IPPOLITO: Let's drop it then, five percent.
18 Is that still a large number?

19 MS. WILLIAMS: Even then, it would still be written
20 up.

21 MR. IPPOLITO: Obviously, nothing is perfect. Would
22 it be half a percent? You would expect? You obviously must
23 have some criteria that says this verification -- I guess that
24 is what you call it -- that you were doing. You know, I
25 conclude that, based on half a percent, they are doing the

1 right job.

2 MS. WILLIAMS: We use MIL Standard 105D for the
3 sampling, in developing the standard size for an acceptable
4 limit. And I believe for this sample size, one error was
5 permissible.

6 MR. IPPOLITO: One error means one change missing
7 from one drawing.

8 MS. WILLIAMS: In this sample, 32 drawings.

9 MR. IPPOLITO: One change in one drawing is
10 acceptable, two changes --

11 MS. WILLIAMS: Is not acceptable.

12 MR. IPPOLITO: Whether it is in the same drawing?
13 I want to make sure. One change missing from any one of
14 32 drawings or is it one change missing from all 32 drawings.

15 MS. WILLIAMS: It is one change missing from
16 one drawing, because that drawing would not be adequate. Your
17 acceptability limits are based on 32, so one out of 32 was
18 not correct.

19 MR. IPPOLITO: That is acceptable, but two is not
20 acceptable?

21 MS. WILLIAMS: That's right. Then what we would
22 do is expand our sample size to continue along the sampling
23 process until we got a good handle on how good or bad the
24 situation was.

25 MR. IPPOLITO: Basically, if you found greater than

111b8

1 one, it would have caused you to continue your verification
2 program until such time as you felt that you could identify
3 the problem and identify the problem in a very decided manner?

4 MS. WILLIAMS: Right, depending on how many
5 errors there were, as to whether we would stop and say you
6 have a lot more work to do on this system. We're not even
7 going to go audit it anymore until it gets cleaned up, or
8 continue the sample size because we think that might be
9 isolated.

10 MR. IPPOLITO: Basically what you did, the next
11 morning, when you got down there, you apparently found everything
12 okay and your review stopped at that point, or your verification
13 stopped at that point?

14 MS. WILLIAMS: Yes.

15 MR. SPRAUL: I missed most of this morning, is
16 their effort going to pick up the piping and pipe support
17 drawings under the same system? Was that discussed this
18 morning?

19 MS. WILLIAMS: There are piping and pipe support
20 drawings on this list. I will go through it again, if you
21 wish.

22 MR. SPRAUL: Does it take long?

23 MS. WILLIAMS: I will try not to.

24 MR. BACHMANN: I think what Mr. Spraul is indicating,
25 you're talking about the computerized system? We're talking

1 about the computerized versus the what we now call manual.

2 MS. WILLIAMS: I should make that distinction.

3 There is an old definition of manual and a new
4 definition of manual. When we first started our review, back
5 in the June-July time frame, of 1983, everything in DCC was
6 still on a manual system. This is old manual. Everything is
7 manual.

8 And then parallel, at this point in time, they were
9 developing the computerized data base using a data base that
10 Gibbs & Hill had in existence to track design verifications.
11 Since it was the data base Gibbs & Hill used for design
12 verification, not every type of drawing was at that time
13 entered in, because not all drawings were under Gibbs & Hill's
14 responsibility.

15 Pipe supports were not in Gibbs & Hill's responsibi-
16 lity. And then sometime in -- I believe it was August, late
17 July or August, some time around there -- there was a merger
18 of the DCC and what we call the DCTG data base. This data
19 base is the one I just referred to, that they were taking from
20 Gibbs & Hill and adapting for their purposes onsite.

21 Then DCC began to run off of this computerized data
22 base. However, certain types of drawings still were maintained
23 on a manual system, and those are the piping and pipe support
24 drawings. And that is the new manual ^Alo~~o~~s. They are still
25 manual.

1 It is their intention, I understand, to put that
2 into the computerized data base when they have completed all
3 of the vendor certifications and everything is as built.
4 And in the case of large bore, they have incorporated all of
5 the design changes. They are not going to carry design changes
6 against large bore piping and pipe supports.

7 MR. SPRAUL: Of the sample of 32, how many were
8 computerized, and how many were manual? Do you have any idea?

and 11

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MS. WILLIAMS: There are seven piping and pipe
2 support drawings -- eight. You are right. There are eight
3 manuals.

4 MR. SPRAUL: And these eight had roughly their
5 fair percentage of design changes relative to the rest of
6 them? There is no big difference as far as design change
7 documents for these eight as opposed to the other 24?

8 MS. WILLIAMS: The piping and pipe support drawings
9 do not carry as many design changes as the electricals and
10 structurals which are on the computerized database. The
11 electricals and structurals have the most significant number
12 of design changes being carried against them. The piping
13 and pipe supports are a manageable number.

14 MR. SPRAUL: If there were a problem still existing
15 in the new manual system, as opposed to the old thermal
16 system, with a sample size of eight with relatively few
17 changes involved as opposed to the rest of the drawings,
18 the feasibility of double-checking to make sure that these
19 things were right when you got to them the next morning is
20 more feasible?

21 MS. WILLIAMS: Yes. We never did have a problem
22 with the piping and pipe support drawings in our original
23 audit.

24 Looking at the observations, DC 101 through 104,
25 they are fired against the electrical and structural drawings.

1 MR. SPRAUL: That is because of the large number
2 as opposed to the relatively small number on the piping and
3 pipe supports?

4 MS. WILLIAMS: That could be a reason. That is
5 supposition.

6 MR. IPPOLITO: Would it not be improper, since the
7 database, whether it is the manual or the computerized one,
8 these are living databases -- changes are made, let's say
9 daily.

10 How did you factor that into what you were doing
11 about verification?

12 MS. WILLIAMS: We were always operating with the
13 list as it existed for a given point in time. I am not quite
14 sure I understand your question beyond that.

15 MR. IPPOLITO: What I am trying to say is it just
16 may have happened that on the day that you asked -- received
17 the information or the changes attributed to these drawings,
18 a change just came about.

19 How would you know that that change just came about
20 and that it is a valid change?

21 MS. WILLIAMS: The first point would be that there
22 is a time lag between a change being issued against a
23 drawing and it being entered into the system sent to all of
24 the distribution points and the logistics associated with
25 any system that operates like that.

1 I understand that the turnaround time had been
2 long, i.e., a week or something, which was now down to fairly
3 rapid 24-48 hour turnaround.

4 MR. IPPOLITO: Was this both for the new manual
5 and the computer database?

6 MS. WILLIAMS: That is my understanding. Our
7 focus was on trying to understand the computerized database
8 and how it was functioning, how it was intended to function.

9 And as I answer that question, I am mainly aiming
10 at that. The way in which we would see that process happening
11 would be, for example, if we looked at the centralized log
12 and then went out to the satellites and the paperwork had not
13 yet arrived to match the log, The real time-data being a
14 more rapid process of entering something into the database,
15 it is then locked up against the drawing but yet the paper has
16 not reached the satellite yet. We did not happen to run into
17 that but that is certainly a feasible occurrence.

18 MR. IPPOLITO: Therefore, had there been a
19 discrepancy, like more than one missing document, I think
20 what you are telling me -- or are you telling me that one of
21 the first steps you would take is to make sure it is not a
22 document in process?

23 MS. WILLIAMS: Yes.

24 MR. BACHMANN: I have an overall question. This
25 is sort of a content question.

1 Earlier on you had used the word or words that this
2 was sort of a second followup.

3 Have you done this type of shall we say testing
4 of the satellites prior to the one in question?

5 MS. WILLIAMS: Yes.

6 MR. BACHMANN: In other words, had you gone down
7 with a list of drawings and checked the satellites to see that
8 they had it?

9 MS. WILLIAMS: Yes, and it was a longer duration
10 audit with our people there. They went in and pulled the
11 documents and we have some internal memoranda indicating that
12 there were still problems and discrepancies with the system.

13 MR. BACHMANN: In that time, had they been given
14 the list ahead of time or had that just been a real time --
15 come in, Nancy, let's look at the situation?

16 MS. WILLIAMS: To the best of my knowledge --

17 MR. BIBO: We went to document control and said
18 these are the printouts. It did take some time to get them.
19 We were onsite at the time.

20 We went in and said this is what we want, the
21 information was given. It did take some time during the
22 day to get the information.

23 MR. BACHMANN: Was it about the same size sample?

24 MS. WILLIAMS: I think it was.

25 It might have been larger for that matter. It was

1 at least 32.

2 MR. BIBO: I do not remember the exact -- maybe
3 32, maybe a little bit less.

4 MS. WILLIAMS: I believe it was 32.

5 MR. BIBO: We requested the same information
6 relative to the distribution of all of the loads and a list
7 of all changes.

8 MR. BACHMANN: Did this turn up discrepancies?

9 MS. WILLIAMS: Yes.

10 MR. BACHMANN: Can you give us an idea of the
11 magnitude or the number of discrepancies versus the sample?

12 MS. WILLIAMS: We had five -- I am guessing now,
13 I would say it is around there. It was enough that we did not
14 even expand the sample. We said there is still a problem and
15 we are going to come back when the system has been checked
16 and corrected.

17 MR. SHULMAN: Five out of about 1000 ?

18 MS. WILLIAMS: Out of 32. We're missing a design
19 change.

20 I think it was basically missing a design change.
21 I do not know if it was a distribution problem or just missing
22 it and I would have to go back in our minutes and check.

23 MR. BACHMANN: So this particular situation was
24 to verify that they had fixed it for the first time. Am
25 I characterizing that correctly?

1 MS. WILLIAMS: Yes, to see if they had corrected
2 the problems we saw on the first followup.

3 MR. BACHMANN: Yes. And the second time through
4 you corrected the problems?

5 MS. WILLIAMS: They had revised procedures. The
6 clerks knew better what their what their job was and there
7 was the checking and the distribution, the functioning, and
8 then whether they contained all of the documents -- the
9 satellites contained all of the documents they were supposed
10 to.

11 MR. BACHMANN: Going back to the DC checklist as a
12 whole, this particular inspection, which I guess was October,
13 either 24th or 25th, this is dated the 24th, I assume the
14 inspection itself was the 25th?

15 MS. WILLIAMS: Yes.

16 MR. BACHMANN: How significant was this particular
17 action that you took compared to the entire DC section of the
18 IAP? Based on all of the checklists, how much did it weight
19 in your final conclusions in the DC area?

20 MS. WILLIAMS: I think we felt they were heading
21 along the right directions toward implementing a system that
22 was going to correct their problems.

23 It weighted in that it closed out the numbers, i.e.,
24 going in and checking.

25 MR. SHULMAN: Was it one-third? One-fourth?

1 MS. WILLIAMS: That is hard to quantify. We would
2 not have closed it out if it were not a successful audit.

3 MR. IPPOLITO: Let me ask that another way.

4 This was the second time you went. Let's say it
5 would have failed -- it failed your test and then you said
6 I think in answer to a previous question that you had not
7 closed this out, but I think you said that you would go and
8 probably go and get another sample?

9 MS. WILLIAMS: If it was so bad, like in our
10 first followup, we would just wait until it was corrected.

11 MR. BACHMANN: The entire DC set of checklists,
12 the DC area, the ones that you used the DC checklists on,
13 had this not gone through and come up with, within the one
14 mistake out of 32, that entire section would still be open?

15 MS. WILLIAMS: Not so much the checklist as the
16 observations. The checklists are the reviewer's tools.

17 MR. BACHMANN: I did not mean closing out the
18 checklist. I meant closing out the areas represented by the
19 DC checklists.

20 MS. WILLIAMS: An observation is borne out of
21 one item on a checklist, so that does not have any effect
22 on the balance of that checklist. That is why I like to
23 focus on observations.

24 MR. BACHMANN: The overall DC area would have
25 stayed open until this particular audit had come out right?

1 MS. WILLIAMS: No. That particular aspect of that
2 area would have remained open.

3 MR. BACHMANN: Of the DC area?

4 MS. WILLIAMS: Of the DCC system, it is a particular
5 area in their design change control system that we felt was
6 weak. We wrote an observation.

7 MR. BACHMANN: I will go back again to my question
8 and say how big is this compared to the overall design control
9 system, this particular part?

10 MS. WILLIAMS: I think the proper functioning of
11 the system is an important part to control the paper.

12 MR. BACHMANN: Necessary?

13 MS. WILLIAMS: To control the paper, yes,

14 MR. IPPOLITO: As a following question, how many
15 times -- I will use the word "pulse" the system before you
16 say, "Man, you've got serious problems here"?

17 You did it once and it failed. Assuming you failed
18 the second time, how many times would you try to pulse it
19 before you say you have got to fix something?

20 MS. WILLIAMS: That is a question on degree of
21 seriousness and here we felt they were moving along the
22 appropriate corrective action path.

23 MR. IPPOLITO: Would you go back two more times
24 before you threw up your hands and said that the system is
25 now working? One more time? Five more times?

1 MS. WILLIAMS: No one likes to spend their time
2 futilely and if we really felt it was bad, we would not
3 keep going down. We felt that they were moving in the right
4 direction. It is tough to answer hypothetical questions to
5 some extent.

6 MR. IPPOLITO: I do not think it is a hypothetical
7 question.

8 If you were in the verification process -- and I
9 am saying what is your criteria? How many times to you fail?
10 If one assumes with every attempt at verification you have
11 failed, an assumption, would you keep going back two times,
12 three times, four times? At what point would you say "enough"?

13 I think it is a legitimate question to ask.

14 MS. WILLIAMS: I think if the system had not been
15 corrected when we went back this time, it would have (a)
16 remained open.

17 The next question is, would we have raised it to
18 a PFR, which is our way of saying this is really a problem,
19 Potential Finding Report, where we did that in the cable
20 trays. That is probably the course of action we would have
21 taken.

22 MR. IPPOLITO: If this one verification had proved
23 negative?

24 MS. WILLIAMS: I should say the potential exists
25 there.

1 MR. SHULMAN: Would it matter if you had found
2 two problems or six problems as to whether you would have
3 made that decision?

4 MS. WILLIAMS: I think it is also a function of
5 whether we think they had corrected their procedures, whether
6 the people know their jobs, whether this evidence shows
7 that it is functioning properly.

8 It is more than just as aspect of finding one or
9 two errors of whether we overall think it is a valuable
10 system.

11 MR. IPPOLITO: Isn't the end result, is it working?
12 One can design a system that makes every bit of logic there
13 is but isn't the end result, you know, is it -- when you
14 pulse the system and it keeps coming up, you know, not up
15 to speed, don't you have to suspect one of these other
16 parameters?

17 MS. WILLIAMS: Yes, you have to suspect it and
18 if we really believe, suspect that they have a breakdown,
19 then it becomes a Potential Finding Report, it gets raised
20 to a higher level of visibility and we discuss with our
21 senior review team and in-house what we think. It is either
22 necessary for them to correct it or discuss what the root
23 cause problems might be further and just sit back and totally
24 re-evaluate and re-assess where they are going with it.

13pbl

1 MR. IPPOLITO: Could this reach a level, you may
2 have to revise your system?

3 MS. WILLIAMS: It could.

4 MR. BACHMANN: I would like to refer to the first
5 paragraph, page 3 of the April 10th response. This is
6 going to be similar to a question that I asked before. You
7 state that the documents requested were not -- on October
8 24, were not for the purpose of detecting problems not
9 solely relied upon, whether TUGCO had resolved its problems
10 with respect to accurate listings of CMCs and DCAs.

11 The next sentence states that that verification
12 required an assessment of the design change tracking group
13 activities. The documents requested, not solely relied upon,
14 would you have given equal weight to the verification of
15 the DCTG to this particular verification? More weight?
16 Less weight?

17 There is an indication that both are relied upon.
18 This verification and the verification at the design -- of
19 the design change tracking group. I'm trying to get a
20 feeling for which is the more important or the equally
21 important. Is one much more important than the other?

22 Can you comment on that?

23 MS. WILLIAMS: I think they are equally important,
24 but they are also separate problems. The satellite system
25 in this list is a control and distribution problem. The

13pb2

1 DCTG is an accuracy problem with their listings and their
2 database.

3 This paragraph is trying to make a distinction
4 that the DCTG and the verification process for the computerized
5 database is separate from what our purpose was with that
6 list to check the distribution problems, and the implementation
7 of the satellite system.

8 MR. BACHMANN: My question was sort of to the
9 extent that -- I think you have answered. You said they are
10 of equal weight within the scope of your entire investigation
11 of the design control program.

12 MS. WILLIAMS: Yes.

13 MR. BACHMANN: That is really the answer I was
14 looking for.

15 MR. IPPOLITO: On page 3, the first paragraph
16 in quotes, this is page 3 of your April 10th letter. The
17 last sentence says, "CYGNA did not rely solely on the review
18 of documents to ascertain whether either problem had been
19 resolved."

20 Could you tell me what other things you relied
21 on?

22 MS. WILLIAMS: This is the procedures, did they
23 revise the procedures. Our assessment of whether we think
24 that they are viable procedures, our assessment as to whether
25 the clerks understand their jobs, whether they are carrying

13pb3

1 them out. And then of course, you want to go and check
2 the documents themselves. So there are a couple of aspects
3 to it.

4 MR. IPPOLITO: But the proof of the pudding is
5 in the eating thereof.

6 MS. WILLIAMS: It has got to work.

7 MR. IPPOLITO: Right. Wouldn't you say that that
8 is the ruling criteria? Everything that you have just
9 stated, you know, the procedures are there, the people are
10 there and all of that. You can test them and they all could
11 prove satisfactory.

12 But the end result, not bore out, you know, all
13 of this. All of these good ingredients that went into
14 making the pudding.

15 MS. WILLIAMS: I agree. I think they carry some
16 weight. If you do find errors you have to look at them
17 in light of the fact, are they even going down the right
18 path. This is even a system that we think is going to work
19 and comply with the regulations.

20 It has got to work, and it is approved. The
21 other one pretty much puts it in perspective. It puts
22 any errors in perspective, more likely.

23 MR. BACHMANN: I have a very basic question. In
24 answer to one question on how the 32 documents were chosen,
25 you stated they were by random. Could you just expand a

13pb4

1 little bit on that? Did -- this is, if I recall correctly
2 the spent fuel pool cooling system documents.

3 MS. WILLIAMS: Yes.

4 MR. BACHMANN: Did you take a gigantic list of
5 all the documents that were in the -- throw darts at it? You
6 picked them at random from what sort of a pool?

7 MS. WILLIAMS: These are from the RHR system.
8 You are right, though. The original review of the spent
9 fuel pool cooling system, but because we did a random
10 sample and a first followup using the spent fuel pool cooling
11 we decided to use the RHR. That is not relevant.

12 I just wanted to make it accurate.

13 MR. BACHMANN: The first followup, when you found
14 problems was with the spent fuel pool. And the second one
15 to see if they had corrected the problem. On the second
16 followup you chose the RHR system.

17 MS. WILLIAMS: Yes, we have a list of all of the
18 drawings that -- in the case of the RHR, the technical
19 reviewers are using cross-discipline for doing the technical
20 evaluation. Given that list, then they just randomly picked
21 one off of 25 pages of drawings, or whatever the total number
22 is.

23 MR. BACHMANN: Do you have a vague idea of
24 approximately how many drawings the 32 -- 32 out of, are
25 we talking 1,000?

13pb5

1 MS. WILLIAMS: I did remember that number. I
2 would have to go back and check.

3 MR. BACHMANN: Do you have a general number?

4 MS. WILLIAMS: I'm going to guess, 200.

5 MR. IPPOLITO: But the sample size was based on
6 MIL Standard 105?

7 MS. WILLIAMS: You can see a range and a quality
8 level and 32 would be the given sample, yes.

9 MR. IPPOLITO: Are you at all surprised -- let
10 me make the assumption again, the second verification, it
11 showed a number of failures. It exceeded your acceptance
12 criteria.

13 Since the fact that the Applicant knew that the
14 two systems you were reviewing -- how much weight would it
15 be if you were to find continual mistakes in those two
16 systems, when you post it with the verification? Doesn't
17 that add a degree of wonderment that maybe it is a bigger
18 problem. Let's face it, you know. The way we have identified
19 the systems and all that, you know, it is prenotice if you
20 will. And here we have two prenotice systems, or portions
21 of systems.

22 And if on the reverification -- on the first time
23 around you found some problems. And then if you were to
24 accept my premise that the second time around you would find
25 problems. Isn't that a significant finding?

13pb6

1 MS. WILLIAMS: We thought it was, too. And that's
2 why we wrote an observation. We would have expanded into
3 other systems also if we found it was a continuing problem.
4 We would not have stuck with those two systems with the
5 "knowledge" that that is what CYGNA was in their review.

6 MR. IPPOLITO: I think it expands on a question
7 I previously answered. You saw the audit that we made --
8 that portion which made it open, and what you are saying,
9 that audit would remain open.

10 Again, on my premise that the second time, the
11 second go-around proved negative. What you are indicating
12 to me is that, hey, if that were the case, I would then
13 go look at other systems.

14 MS. WILLIAMS: Just as we did not stick with the
15 spent fuel for the second followup, we would not stick with
16 the RHR or the spent fuel for anything beyond that.

17 MR. YOUNGBLOOD: In Phase III and Phase IV, do
18 you plan to do any of this in Phase III and Phase IV?

19 MS. WILLIAMS: It seems like it would be a good
20 idea.

21 MR. YOUNGBLOOD: Without prenotification?

22 MS. WILLIAMS: Without prenotification.

23 MR. PIGOTT: In this letter and what has been
24 stated today, I think, in justification of what we thought
25 was a reasonable procedure of -- at the time for making this

13pb7

1 following review. I hope it is not construed that we're
2 saying that it would have been impossible for someone to
3 have affected our review, as a result of having it for this
4 period of time.

5 We reasonably did not expect it for the number
6 of reasons stated. But we are not going so far as to say
7 that it was impossible for guaranteeing that something could
8 not have happened to affect these results. We are only
9 saying that it was reasonable, given the circumstances, and
10 what we were attempting to do at that particular time.

11 MR. IPPOLITO: I understand your statement.

12 MR. BACHMANN: I happened to think of another
13 question. It was stated earlier that of the 1,000 changes
14 approximately associated with the 32 drawings, that it would
15 not be reasonably considered feasible for changes to be
16 made. In perspective, I would like to kind to, sort of
17 question -- not question, but get a little better understanding
18 of how this would work.

19 If someone, this hypothetical person has -- knows
20 which of these 32 drawings from each of the satellites --
21 what is the worst they could do, in your estimation to bring
22 things up to speed? What would they actually have to do
23 if they had this list and you had the guy out there who
24 wants to make sure that it is perfect for you. What do you
25 understand they could possibly do if they wanted to?

13pb8

1 MS. WILLIAMS: They could go and make sure that
2 for each satellite that is responsible for a given drawing,
3 that all of the DCAs and CMCs applicable to that drawing
4 are physically located within that satellite.

5 MR. BACHMANN: How would they physically do that,
6 if you can explain briefly as far as the computerized system
7 and the manual system?

8 MS. WILLIAMS: They still keep hard copies of the
9 CMCs and DCAs in the satellites. They could take the listing
10 of the outstanding CMCs and DCAs from the central system,
11 just as we are getting it, find out that satellite, for
12 example 304 is responsible for holding that drawing. Go to
13 that satellite and make sure that all of the CMCs and DCAs
14 applicable to that drawing are physically there.

15 MR. BACHMANN: On a given typical drawing, and
16 let's take the -- let's forget the piping ones which are
17 smaller. But on a given typical drawing, how long did it
18 take your people to verify that all of the changes were with
19 that drawing on a given drawing? Can you give any
20 guesstimate, when your people went out and looked at the
21 drawing?

22 MR. BIBO: It varied. You could find that a
23 particular drawing was a satellite and there were 35 design
24 changes, and the computerized listing which showed them
25 numerically. You go to the hard copy of the satellite,

13pb9

1 where they were filed numerically in the books, and you
2 just verified that each one of them was, in fact, in the
3 book.

4 MR. BACHMANN: The drawing of 35 changes?

5 MR. BIBO: That is a guess.

6 MR. BACHMANN: Let's assume 35. I am talking
7 about a CYGNA auditor. Now how long would it take to go
8 through those and verify 35 changes in a given drawing?

9 MR. BIBO: It depends -- there may have been
10 15 changes right in a row, numerically, which would be in
11 one book. You could go through 15 in one book in a matter
12 of seconds. You would not have to go to various books.

13 It could take anywhere from five minutes to a
14 half hour.

15 MR. BACHMANN: That's the answer.

16 MR. BIBO: Here again, it depends on the number
17 of changes. In one of the satellites the changes were
18 physically in a package with the drawings. In that case,
19 it was really quick. You could pull out the package, 35
20 design changes were right there. You could verify them
21 against the computer list.

22 It also varied from satellite to satellite and
23 how they were filed. It is a little bit difficult to answer.
24 I just wanted you to understand.

end 13.24

25

1 MR. IPPOLITO: Is it safe to say a half hour per
2 drawing?

3 MR. BIBO: No, I would say it would be less than
4 that.

5 MS. WILLIAMS: It was ten hours for the audit?

6 MR. BIBO: I was there two days.

7 MR. BACHMANN: It took two days to verify the 32
8 drawings?

9 MR. BIBO: Verify that the drawing for that particu-
10 lar satellite --

11 MR. IPPOLITO: One person, two days?

12 MR. BIBO: Yes.

13 MR. BACHMANN: How many people were involved in
14 the audit of the 32 drawings?

15 MR. BIBO: The last review of the 32 drawings?
16 Just myself.

17 MR. BACHMANN: You hit each of the 32, on all of
18 the satellites?

19 MR. BIBO: Right. Some of the satellites may only
20 have had one drawing. Like I said, it varied.

21 MR. YOUNGBLOOD: You went from satellite to
22 satellite on this? The last satellite you went to was a day
23 and a half after you gave them the list? That is a question
24 I am asking, not a statement I am making, although it
25 sounded that way.

141b2

1 MR. BIBO: I think there were seven satellites,
2 300 to 307. Satellites 307 to 304 were physically in one
3 place. Yes, it may have been a day before I got to the last
4 satellite.

5 MR. PIGOTT: To be clear on the timing, Ms. Williams
6 came in on the first day and provided the list. Mr. Bibo
7 came in on the second day and then worked two days.

8 MS. WILLIAMS: It was three days total and they
9 did not know the sequence of satellites.

10 MR. BACHMANN: We would like to take a ten minute
11 break now, if it is all right with everyone.

12 (Recess.)

13 MR. BACHMANN: Back on the record.

14 Mr. Youngblood had a couple of follow up,
15 additional questions, to what we were talking about just before
16 the break.

17 MR. YOUNGBLOOD: One of the questions I had would
18 be if you were to do the check again on the satellites,
19 without prenotification, would it be -- since it takes a
20 day or a day and a half, two days to do this -- would it be
21 less apt to be biased by someone doing something with the
22 packages if you were to have someone at all sever satellites
23 at the same time, or what do you think the probability of your
24 evaluation being biased is? Would be, not only with the
25 12 hour notice, but also an extra day and a half notice, that

141b3

1 some satellite could change up, modify, get the packages
2 together, be sure all of the notices are in there? Since
3 you do not find an error.

4 MS. WILLIAMS: Is that possible?

5 MR. YOUNGBLOOD: I'm asking you that question and
6 I don't think -- maybe you can give me an extemporaneous
7 answer. That is a question I want to lay out to CYGNA.

8 MS. WILLIAMS: Let me make sure I understand it.
9 Not CYGNA people at seven satellites?

10 MR. YOUNGBLOOD: Yes.

11 MS. WILLIAMS: If you were to go back and redo it
12 and put a CYGNA person at each one, would that reduce the
13 possibility of any interference?

14 MR. YOUNGBLOOD: Yes.

15 MR. FIGOTT: What's the answer?

16 MS. WILLIAMS: Certainly.

17 (Laughter.)

18 MR. YOUNGBLOOD: What was the other question?

19 MR. BURWELL: May I proceed along the same path,
20 shall we say rather than requesting a list for a request one,
21 two, three, go do your thing; and then request three, four,
22 you know, as you go. Would that improve your chances of
23 maintaining control over the -- over what you are reviewing?

24 MR. YOUNGBLOOD: It would certainly increase their
25 work effort if they had to go to one drawing, and then go to

1 three satellites, and then go back and get another drawing
2 and go to the same three satellites.

3 MS. WILLIAMS: There is a possibility, since the
4 remote access to the data base is available at the satellites,
5 of us having internally a sample selected and knowing because
6 the satellites are divided by discipline, the electrical
7 satellites say with our list that only we know what we want,
8 and then ask them to dial up on the screen, right then and
9 there, and see what they should see. And then go, right then
10 and there, and check them. With the advent of the CRTs in the
11 satellites, I would think that is a viable way to go.

12 MR. BACHMANN: Were these CRTs in these satellites
13 in October of '83, at the time of your audit?

14 MS. WILLIAMS: I think they had just recently
15 put them in and were getting them ready, and the bugs out.

16 MR. BACHMANN: Would they have had the capability
17 to do that on October 25th, 1983?

18 MS. WILLIAMS: They were operational in October,
19 yes, but we did not know that they were operational until we
20 got down there. To some extent, it went into us asking for
21 the outstanding listings. If we had gone and done that right
22 at the satellite, it would have been the same information.
23 We just did not know that portion of it was going to be
24 operational.

25 MR. SPRAUL: You are saying that there are ways

1 that you could provide more assurance of unbiased audit
2 results?

3 MS. WILLIAMS: Absolutely.

4 MR. YOUNGBLOOD: Our corporate memory has lost
5 us now. Noone here remembers what the other question was,
6 so will forget it for now.

7 (Laughter.)

8 You were going to give us a little bit on the
9 overall scope of what CYGNA is doing and what portion of it,
10 at this point, as you know, would apply to our IAP.

11 MR. PIGOTT: Do you want that now? There is one
12 item which is a burning interest to us before we leave today,
13 and that is to talk about how we implement the protocol from
14 this time forward.

15 MR. YOUNGBLOOD: We can go with that first, if you
16 want to. There is a little wrap up we want to do. We want
17 to ask a few questions, for the record, that we picked up
18 during some site visits that we made, or audits that we made.
19 And we want to ask the questions so that we can get the
20 answers formally on the record, rather than just having it
21 been something that somebody picked up verbally.

22 MS. WILLIAMS: We went through each of the items
23 on the March letter and identified what we think the open
24 items are and what our follow up would be, and where that
25 might be in time. So I wanted to take just a moment and go

1 through that.

2 In Item 1, which is dealing with document
3 control questions, it is our understanding that there was a
4 question on the validation of the data base and whether it
5 would be appropriate to go in and assess how well that
6 activity had been performed or was being performed. We
7 think that is an appropriate thing to do and would propose
8 that that could be accomplished by the end of May.

9 In the second, in the document control center,
10 would be a reaudit of the satellite system. We, just briefly,
11 discussed that now as the possibilities of how that may
12 be conducted and we think it is possible to conduct that
13 sometime by mid-May.

14 And Item 2, there was a discussion of three inch
15 and four inch Schedule 40 piping. We think it would be
16 appropriate to make a sampling of three and four inch lines
17 and make a check to ensure that the proper SIFs at the butt
18 weld locations does not result in any stresses above the
19 allowables.

20 For Item 3, we will evaluate the concerns with
21 respect to the increased allowable that we have discussed
22 today. We are going to have to get back to you on what we
23 think our course of action would be on that in the next
24 couple of days.

25 MR. BACHMANN: On Item 2, you talked about the

141b7

1 stressing justification factors of the butt welds. Did you
2 mean to give us any time frame on that?

3 MS. WILLIAMS: That one, by the end of May, would
4 be appropriate.

5 MR. SHULMAN: On the one that Nancy just mentioned,
6 we cannot give a time frame yet. We're not totally sure of
7 our approach.

8 MR. YOUNGBLOOD: Let me interject here, also.
9 These are things that we winnowed out of our discussion after
10 we read the transcript, obviously. We always want the string
11 to be able to add or modify.

12 MS. WILLIAMS: Okay.

13 MR. YOUNGBLOOD: I assume on question two there
14 was a special question? Dave got on the phone and talked
15 to someone. Was that being wrapped up in that question
16 also? Or were you speaking to it?

17 MR. SHULMAN: We wrapped it up in the question,
18 but we can give an answer now on the specific question that
19 Dave asked.

20 MR. WEINGART: In regard to the counterbore
21 Dave Terao asked about earlier, checking into the fabrication
22 specification, it states that field counterboring shall not
23 reduce the wall thickness of the pipe to be less than
24 minimum wall thickness. And that minimum wall thickness
25 is defined as being within the 12 1/2 percent of the nominal

1 wall thickness. I believe that was your question.

2 MR. YOUNGBLOOD: I interrupted you. Do you
3 want to continue?

4 MR. IPPOLITO: I think when you started to
5 proceed down this question list, that you have before you,
6 you referred to the March 22nd letter? I think you really
7 meant the March 30th letter.

8 MS. WILLIAMS: If it is the one with the seven
9 items, yes.

10 MR. IPPOLITO: For the record, it is the March
11 30th record.

12 MS. WILLIAMS: On Item 4, I have nothing.

13 MR. YOUNGBLOOD: You're going to correct that in
14 a revision?

15 MS. WILLIAMS: Yes. On Item 5, we will be
16 checking the construction drawings and the installation for
17 cable tray supports as part of Phase IV.

18 MR. FIGOTT: Am I correct that you want that
19 pulled out so that you can have it available to finish off --

20 MR. YOUNGBLOOD: Anything you were doing in Phase
21 III and Phase IV, that can be used for the IAP, I think the
22 Applicant will want you to respond to us on the IAP, rather
23 than waiting until you finish all of Phase III and Phase IV.

24 MR. SHULMAN: That is an issue in terms of
25 timing.

1 MR. PIGOTT: We have not really looked at the
2 timing on that one, because obviously you want that one first.

3 MR. YOUNGBLOOD: I am not anxious for you to
4 freeze the timing on it now, if you're just giving something
5 that you think, that's all right.

6 MS. WILLIAMS: Item 6, I want to clarify something
7 that threw me off balance during the course of today's
8 discussions. That is, that 8811B is the basis for our
9 review scope on the electrical controls.

10 Now personally, I was left with the feeling that
11 maybe something had disconnected internally, on what the
12 basis for our review scope was. I think it was a communications
13 problem, on what question we had answered with respect to
14 which valves.

15 My first point, 8811B was the basis for a review.
16 However, there are three other valves which are interlocked
17 in some manner of speaking with that valve. As such, they
18 make up part of the review of the complete systems or
19 control logic review for that valve.

20 The thing that is missing is that we need to
21 address the question in the March letter with regard to
22 8811B, rather than 8701B. That was our miscommunication with
23 regard to answering the letter.

24 MR. BURWELL: I think you meant the February 6th
25 letter, not the March letter.

1 MS. WILLIAMS: I think the clarification was
2 appropriate, that the 425 psig guage does apply to the
3 correction that we stated. We stuck with that valve in
4 answering the March letter and that is what we did not
5 intend to do.

6 MR. MOERSFELDER: Mr. Li was questioning me about
7 Branch Technical Position 18 and I could not answer that on
8 the basis of 8811.

9 MS. WILLIAMS: Were you one off on the 425 psi
10 and kept on that valve. It was not the basis for that
11 review.

12 MR. SHULMAN: The review was the appropriate scope.
13 We got tongue-tied when we were talking a couple of hours
14 ago. We were not sure whether that was clear or not.

15 MS. WILLIAMS: It was not clear in my mind.
16
17
18
19
20
21
22
23
24
25

end14

mgc 15-1

1 MR. YOUNGBLOOD: If when we get your answer, it is
2 still not clear, we will ask you again.

3 MS. WILLIAMS: I thought that was necessary to
4 clarify.

5 Item 7, I'm not sure we finished that discussion.
6 The way it was left so far was whether the as-built procedure
7 would in any way link you to the snubber installation
8 procedure or somehow close the loop on completing what the
9 as-built should look like.

10 MR. YOUNGBLOOD: That's right.

11 MS. WILLIAMS: That's all I have.

12 MR. YOUNGBLOOD: We want to discuss protocol some.
13 I'm sure everyone in the room is interested.

14 MR. PIGOTT: Do you want me to start?

15 MR. YOUNGBLOOD: Yeah, why not? You can start
16 with the last sentence in your letter to us, if you want to.

17 MR. BACHMANN: Are you talking about the letter
18 of April 10th?

19 MR. YOUNGBLOOD: No. That is not the one that
20 I saw -- maybe it is -- yes, it is the last sentence on
21 Page 3.

22 MR. PIGOTT: That is a good place to start. I
23 think it accurately reflects the way we have interpreted
24 and applied the protocol. The face-to-face exchanges to
25 resolve technical issues do not fall within Paragraph 3 of

mgc 15-2

1 the protocol, which would define it as a meeting and require
2 the appropriate notice to the NRC.

3 Also, as we indicated earlier, it is apparent that
4 there has been more than one interpretation applied to the
5 protocol. We have since at least this date and probably a
6 little bit before adopted what we reflect in here, the very
7 conservative position that face-to-face exchanges of any
8 type have to be noticed. But frankly, that is really not
9 a workable way for us to proceed.

10 MR. IPPOLITO: Why did you propose it, then?

11 MR. PICOTT: Because of the exposure that we
12 currently have in the hearing arena, because of the -- what
13 we perceived to be a very strict interpretation of that
14 document coming at least from the Board, and for that matter,
15 from Mr. Eisenhower's letter as perhaps reflecting Staff's
16 interpretation of that letter at this time, and we felt until
17 something more workable is put together, that we did not have
18 the unilateral capability of implementing some alternate
19 interpretation of that protocol. So on the grounds of being
20 better safe than sorry, we took the most conservative view
21 until such time as we can work out something more practical,
22 which is what we are hoping we can do today.

23 MR. IPPOLITO: Let me ask you, I think I am allowed
24 to because I am a new kid on the block to ask the question,
25 had you had any discussions with the Staff as to the

nc 15-3

1 understanding of this protocol before you got started?

2 MR. PIGOTT: I'm going to leave that to Nancy.
3 Perhaps you can best discuss that.

4 MS. WILLIAMS: No.

5 MR. IPPOLITO: At what time did you determine that
6 this protocol was ambiguous or however you want to
7 characterize it?

8 MR. PIGOTT: I would have to say coming out of
9 the hearings in February, the on -- the 19th and 20th,
10 the issue arose. It appeared -- it appears from that
11 transcript that the Chairman perceived, if not an ambiguity,
12 what he considered to be some difference between the way
13 it was being applied and the way he would read it. I would
14 have to say, to my knowledge, that would be the first
15 indication of varying interpretations.

16 Nancy, do you have an earlier time?

17 MS. WILLIAMS: No. I would say it is the
18 February hearings and subsequent discussions.

19 MR. IPPOLITO: Let me ask a question, then, and
20 this could be a criticism of the Staff as well.

21 In February, it looked as if we were not in synch
22 as to what the protocol meant. Why didn't you come forward
23 and say, "Let's clear this up now," in February?

24 MS. WILLIAMS: I'm not sure it was at least clear
25 in my mind that the discrepancy existed with the Staff, so

mgc 15-4

1 much as with other parties involved in the hearings, and we
2 had made what we thought was a logical interpretation of
3 the intent.

4 When you start interpreting it more literally and
5 you start to listen to what some of the various
6 interpretations may be, it is about that time that we
7 started considering that we should be talking it over with
8 the Staff.

9 MR. IPPOLITO: Let me ask you, how do you
10 understand -- what are the elements that would cause you to
11 call a meeting -- in other words, meeting Item 3? Why
12 would you call a meeting? To discuss what?

13 MR. PIGOTT: As it is now? At least I would guess
14 in the current atmosphere, resolution of corrective actions,
15 we would, I guess, look at it practically, not think that
16 technical exchanges, either face-to-face or on the telephone,
17 should reach the level of a meeting, if we were to discuss
18 whether or not certain factual -- certain facts rise to the
19 level of an observation, I would think that would be the
20 first point at which -- well, I guess the key is, you are
21 probably talking about discretionary rather than purely
22 technical interpretations, and I would guess that when you
23 are getting into judgments, you probably have to think about
24 meetings.

25 MR. IPPOLITO: What do you mean by technical

mgc 15-5

1 discussions? I'm not trying to trip you up or anything.
2 I'm looking at the protocol.

3 In my quick looking at it right now again, I
4 cannot find the word "technical" in the protocol.

5 MG. WILLIAMS: "Technical staff to resolve open
6 items." It is essentially the entire content of what we
7 do.

8 MR. SHULMAN: The biggest problem we have is that
9 Item 2 says "telecons." That does not define other types
10 of interactions of a very similar nature. You could have
11 no more implication than a telecon in terms of resolving
12 technical issues. If it is a meeting in AL's offices in
13 New York to talk about cable trays, between Nancy and some
14 of our cable tray experts and people from Gibbs & Hill,
15 how do we handle that right now? It seems to fall into a
16 hole between 2 and 3 right now. That is where we are having
17 our problem. We do not think that is any different than a
18 telecon, but if we look at our interpretation of this right
19 now, almost being overly defensive and cautious about it,
20 it does not enable us to clearly put it in Item 2. And
21 that is the kind of thing more than anything, I think, we
22 want to get clarification on.

23 MR. IPPOLITO: What I want to do is understand
24 how you have behaved, what has to be done about these? What
25 I would like to know is, what has been happening?

mgc 15-6

1 I have started off with No. 3 saying, you know,
2 why would you call a meeting? What are the bases for you
3 calling a meeting right now? Have you had any meetings with
4 the -- with TUGCO?

5 MR. PIGOTT: Have we had any meetings, or have
6 we noticed any meetings? We have not noticed any meetings.

7 MR. IPPOLITO: Under Item 3.

8 MR. PIGOTT: We have not noticed any meetings.

9 MR. IPPOLITO: You have not had meetings following
10 the Protocol 3?

11 MR. PIGOTT: Not to the best of my knowledge.

12 MR. YOUNGBLOOD: In going over the draft report,
13 a meeting was called for that, to get together and discuss
14 that. We have done that.

15 Are you talking about outside?

16 MR. BURWELL: That is our meeting?

17 MS. WILLIAMS: Yes, with your reviewers. Mostly
18 all of our work is asking questions to either find out if
19 there is a document that we have not encountered that would
20 address our concerns or ask them for an answer on a
21 technical question with that information in hand. Then we
22 go away internally and evaluate whether we still think it
23 is a problem, whether they have to initiate corrective
24 actions, or what our opinion on the situation is. But we
25 do not go and discuss that with the Applicant.

mgc 15-7

1 The first time they see our assessment of the
2 problem is in the draft report.

3 MR. IPPOLITO: Getting to Protocol No. 2, it
4 says -- what it says here, you can talk to them on the
5 telephone to resolve open findings.

6 As you are doing -- I want to underline "open
7 findings" -- what are open findings as it relates to what
8 you people do?

9 MS. WILLIAMS: It could be an unsatisfactory item
10 on a checklist. It could be an observation. It could be a
11 potential finding report.

12 MR. IPPOLITO: In other words, this is something
13 that you have in an evaluation you have completed, and you
14 have a piece of paper in front of you; is that correct?

15 MS. WILLIAMS: Yes, and we write that "in telecon,"
16 whether it is face-to-face or over the phone, --to ask them
17 what their position on it is, and that is the extent of the
18 conversation.

19 MR. SHULMAN: Let's clarify that. That is what
20 we had done in the past. As it is now, it is only over the
21 phone. That's what we're trying to resolve.

22 MS. WILLIAMS: Or in writing.

23 MR. IPPOLITO: But what you have said is, you have
24 also had telecons to obtain clarification of procedures,
25 to obtain procedures, pick up the phone, "Please send me

mgc 15-8

1 send me Procedure No. XYZ." Is that what you do by telephone?

2 MS. WILLIAMS: Yes.

3 MR. IPPOLITO: And you can also go over and ask for
4 it. You do both?

5 MS. WILLIAMS: Yes.

6 MR. IPPOLITO: I don't have any more questions.
7 Do you have any?

8 MR. YOUNGBLOOD: I would make a statement. The
9 protocol was not intended to keep you from doing your job of
10 gathering and collecting information. As long as you are
11 doing that, that is what you have been hired to do. Once
12 you start trying to get into the resolution of some of these
13 things, it starts getting to be a gray area in here, when
14 you do a telephone call trying to get a resolution to some
15 of the corrective actions and so forth. And in those cases,
16 you probably should get the project manager on the line
17 with you whenever you have any discussions, or if you want
18 to have a general discussion about philosophy or something
19 like that, you probably should get the PM on the phone with
20 you, so that it is a three-way party.

21 MR. SHULMAN: I have a question independent of
22 the content of the conversation. We understand the criterion
23 for the content.

24 Do you view a technical telephone call between
25 two people any differently than a meeting between two

mgc 15-9

1 technical people? That is the issue. If we walk out of
2 here with that resolved, we would feel like we had
3 accomplished a major part of what we need to go to work.

4 MR. YOUNGBLOOD: You mean technical issues to
5 get clarification or to collect further information with
6 regard to your evaluation? In that case, I would not.
7 I personally would not view them differently.

8 MR. BURWELL: May I supplement that a little bit?
9 I guess I am speaking on my own judgments.

End 15

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 Although you have not used my words, I read
2 somewhat in what you have said the same idea. To me, face
3 to face conversations for the purpose of collecting informa-
4 tion in dealing in factual understanding, dealing in facts,
5 would fall under Item 2. If you began to deal in judgmental
6 questions, then I might look on it slightly as being --

7 MR. SHULMAN: You would say the same thing about
8 a telephone call, wouldn't you?

9 MR. BURWELL: Yes. Whether or not it is a
10 telephone call or it is a face to face meeting, to me it
11 should hang on a movement into a discussion of judgmental
12 elements.

13 MR. SHULMAN: Rightly or wrongly, that has been
14 our hangup basically. We understand the concerns about the
15 content of those discussions. We just do -- we want to make
16 sure that there is no difference between whether there is a
17 telephone conversation or two people or even three people
18 meeting to discuss the same things that they would be allowed
19 to discuss under Item 2 in a phone call.

20 MR. IPPOLITO: You have just heard two personal
21 views.

22 MR. PIGOTT: Underline personal.

23 MR. IPPOLITO: Again, being the new kid on the
24 block, I thought the purpose of the protocol, at least one
25 of the significant purposes, was an attempt at putting on

1 paper certain rules for performing an independent design
2 review that would provide the greatest assurance of under-
3 line independent -- to maintain the independence during the
4 review. While not trying to handcuff you to do a review, I
5 think that was the purpose.

6
7 But what we have here is I think no previous
8 discussion as to the understanding of the protocol, both on
9 your part and our part. I think at this point we have
10 progressed quite deeply into this independent design review.
11 We could always have a clarification at this point on how
12 to proceed, you know, from here until you conclude.

13 Let me say that the review that the Staff wanted
14 I am not talking about the additional review that the Board
15 may want -- I think what has to be done here is to understand
16 what you did and to assess whether or not it has affected
17 independence.

18 That is why my question was to understand just
19 what did you do -- and obviously I focused on the -- on two
20 and three and I think you will agree with me that these are
21 the troublesome areas.

22 I think what I want, I would like to know
23 specifically what you did or how you treated two and I think
24 your answer on three is we have never had a meeting, a pre-
25 noticed meeting with the Applicants.

I think I need to understand what you did for

1 Item 2 and your understanding that certain things could be
2 discussed face to face as being equivalent to Item 2.

3 Now if you think you can tell me no, that's fine.
4 If you feel you need to take some time to think about it,
5 that is okay too.

6 Am I making myself clear?

7 MR. PIGOTT: Yes, and I think we can probably
8 answer it now.

9 MR. IPPOLITO: Fine.

10 MS. WILLIAMS: I will describe the activities under
11 Item 2, then.

12 MR. IPPOLITO: I don't want to limit you to Item 2.

13 MS. WILLIAMS: That is pretty much everything we
14 do.

15 I will discuss our communications in general. Maybe
16 that would be a better way to put it.

17 There are two major things: we collect data and
18 we kind of go away and do our reviews and then we come back
19 with questions.

20 The questions could be, is there a document that
21 will answer this or where is this missing piece of information.

22 That is kind of the first layer of questions,
23 where we have gone through the review and we find out
24 something is incomplete or something does not quite fit or
25 make sense.

1 Then we get that new set of information and we
2 assess now what the picture looks like and we have internal
3 meetings and reviews to assess what the open items are,
4 the discrepancies, the observations, or anything that we feel
5 is not apparently adequate at that time and then we would
6 ask the question -- to take, for example, the 20 percent
7 allowable on the welded attachment, please provide justifi-
8 cation for use of a 20 percent allowable.

9 We could do that over the phone or we could do
10 that face to face. We will get the answer to that and in
11 most cases what we will do is take that internally and assess
12 that and determine whether we feel that that is an adequate
13 answer or not.

14 MR. IPPOLITO: You said in most cases.

15 MS. WILLIAMS: I should stop using that then. That
16 is what we do.

17 Sometimes we might go back with another question
18 based on their answer and that is the extent of the
19 communications.

20 It could be done with more than one party involved
21 in talking. It could be two of our reviewers and two of
22 their reviewers or something of that nature. That is the
23 type of questions which we ask.

24 Our assessment on those answers -- of those
25 answers -- is a totally internal matter and that gets

1 documented on the observation review record and then that
2 gets issued.

3 Texas Utilities does not see those documents
4 before the report goes out and we do not discuss whether they
5 should take corrective action until that point in time and
6 provide them with any direction that they should be taking.

7 In the case of document control system, they were
8 taking corrective action at the time, so we would have a
9 conversation which was along the lines of "When is it going
10 to be ready? We will come down and re-audit it and perform
11 the re-audit."

12 We take the results in hand and go back internally
13 and assess that.

14 What we consider to be technical exchanges of
15 information, all interpretations and evaluations of that
16 are internal to CYGNA.

17 MR. YOUNGBLOOD: You just reminded me of my other
18 question.

19 You did an audit. You found a lot of problems
20 with it. And you said we will come back and audit this
21 again later. Why weren't those observations, instead of
22 going back and doing it later?

23 MS. WILLIAMS: This is Rev 1 of the observation.
24 There was a Rev 0 of the observation, which is on our file
25 at CYGNA which is the results of the first audit. In that, I

1 heard your answer.

2 MR. IPPOLITO: Any other questions on the protocol?

3 (Pause.)

4 MR. BACHMANN: After referring to Mr. Ippolito,
5 the Staff's conclusion at this point and subject to definite
6 further discussions, would be to leave the actions taken by
7 CYGNA vis-a-vis the protocol, as you have stated in your
8 letter, for the time being, for the present.

9 As Mr. Ippolito stated before, you have heard some
10 personal observations. The Staff will be discussing what
11 we have talked about today, probably tomorrow or very, very
12 shortly, believe me.

13 We will be getting back to you on a better, or
14 at least a more complete interpretation of what we have
15 discussed.

16 It will be the Staff's suggestion that the steps
17 described by CYGNA's, let's say, new interpretation or current
18 interpretation of the protocol, especially as described on
19 page four of the April 10 letter, last paragraph, beginning
20 with "During the interim . . ." with CYGNA adopting the
21 most conservative interpretation, be left in place until the
22 Staff has had a chance to discuss amongst themselves what
23 we have discussed today.

24 We are not going to hang you up very long. We
25 simply have got to have a chance to discuss this a little

1 bit further and make a definitive statement to you, which
2 should be done in very short order.

3 MR. IPPOLITO: Let me add to that, I do not like
4 leaving you in the position that you are being left. Had I
5 had the background and understanding of why these three steps
6 in the protocol were written the way they were written, if
7 I had that understanding, you would have gotten an answer
8 right now.

9 I don't have an understanding and until I get that
10 understanding I just will not give you an answer right now.

11 Let me say this to you: whatever comes out, we
12 will meet and we will have a thorough discussion of whatever
13 protocol, whether it is these or any other protocol that
14 might be devised for carrying us from this point forward.

15 I know you prefer to walk away with an answer
16 today but I cannot do it.

17 MR. PIGOTT: I understand that, and obviously
18 you recognize this conservative approach virtually stops our
19 activity.

20 MR. IPPOLITO: I will not agree with that. I
21 cannot agree with that because you can still go fact-finding.

22 MR. PIGOTT: By telephone.

23 MR. IPPOLITO: You are on site, so instead of
24 walking to trailer number three or whatever it is, you pick
25 up the phone and call trailer number three.



Item 6 Response
(Electrical/I&C)

- Both regulatory guidelines are concerned with power supplies to MOV's.
 - The review scope included valve control circuits only.
 - Although the approved scope only included one valve, there are two valves in series which are powered from separate sources.
-



RHR Isolation Valve

Response to NRC letter of February 6, 1984 from
Mr. B.J. Youngblood to Mr. R.J. Gary

Question

(The interlock described in Cygna checklist EE-02 is not in conformance with FSAR Section 7.6.5 requirements. Conversely, the Cygna report is silent on the control and interlock requirements described in FSAR Section 7.6.5. Cygna should explain this inconsistency and confirm that the design is consistent with the FSAR.



Independent Design Review Checklist

ELECTRICAL (INSTRUMENTS & CONTROL)

Reviewer A. Moersfelder/J. Dady *[Signature]*

Checklist No. EE-02

Date 9/27/83

Item	Satisfactory		Comments
	Yes	No	
1. Does the design of the control circuits comply with the following regulations, industry standards and project-specific licensing requirements:			
a. Gibbs & Hill Instrumentation and Control Diagram 2323-M1-2263-06, Rev. 5?	X		Although the drawing is not marked Nuclear Safety Related, it is classified as Class 1.
b. CPSES/FSAR, Section 7?	X		Defines requirement that valve 1-88118 be interlocked to prevent opening until pressure decays to 425 psig.
c. Gibbs & Hill Instrumentation and Control Diagram 2323-M1-2260-05, Rev. 4?		X	1. Drawing is not marked Nuclear Safety Related, but is noted as Class 1. 2. Logic diagram for Loop Inlet Isolation Valve has no reference to Note 4 which describes Alternate Power Supply connections. 3. Loop A inlet/outlet isolation valve logic does not agree with Loop B after Alternate Shutdown capability change. FSAR section 7.6 indicates that inlet/outlet valve logic is identical for both loops. This discrepancy is due to modifications required to meet fire protection regulations.



RHR Isolation Valve

NRC letter of February 6, 1984 from
Mr. B.J. Youngblood to Mr. R.J. Gary

Response

- Cygna's review found that valve 1-8701B, not 1-8811B, is interlocked to prevent opening until the RCS pressure decays to 425 psig.
 - The Cygna review did corroborate that valve 1-8811B meets the interlocking requirements described in FSAR paragraph 7.6.5.
-



Item 7
(Walkdowns)

Cygna should identify the Texas Utilities procedure which served as the basis for closing Observation WD-02-02 on the checklist.



Item 7 Response (Walkdowns)

- Brown & Root installation procedure CP-CPM 9.17 allows end-for-end reversal of snubbers.
 - The checklist does not reference the procedure since it is an installation procedure. The walkdowns were intended to verify whether or not the installed hardware matched the as-built drawings.
-

1 MR. PIGOTT: We recognize that.

2 MR. IPPOLITO: It may hinder you in some respects
3 but I will not agree that this is going to bring it to a
4 full stop, especially if we are talking about a short period
5 of time.

6 MR. PIGOTT: It perhaps does not stop collection
7 of data purely and simply by telephone. It does bring to a
8 stop interpretations of data or finding out what people mean
9 by particular documents, that part of it -- other than the
10 gathering. That is about where we are at in the process but
11 I understand your position. You have got to understand all
12 the corners of it before you are ready to respond.

13 Let me say, myself and Nancy, we will be in town
14 tomorrow and available if there is anything we can do further
15 on this subject.

16 MR. IPPOLITO: Would you give Mr. Burwell a place
17 of contact. I am not going to promise it will be tomorrow.

18 MR. PIGOTT: We are anxious and we will be back
19 in hearing on Tuesday. It makes Monday very difficult for
20 meeting.

21 Obviously it is an important matter to us and to
22 the Applicant, I suspect.

23 MR. IPPOLITO: I hear you.

24 MR. BACHMANN: Does that take care of comments
25 on the protocol situation?

1 MR. REYNOLDS: We filed a letter yesterday with
2 Mr. Eisenhut dated April 18th, from Mr. Schmidt. We would
3 appreciate it if Mr. Ippolito would review that letter before
4 he makes his decision on the protocol question.

5 MR. IPPOLITO: I am in receipt of that letter . I
6 will use whatever facts I need to make a decision, all
7 available facts.

8 MR. BACHMANN: Dave Terao has some followup
9 questions.

10 MR. TERAO: I will try to make it short. I would
11 like to talk about pipe supports for a moment here, pipe
12 supports and standard industry practice.

13 In your April 10th letter, you refer to the
14 Board memorandum, on March 15th, 1984, where it states,
15 "We are concerned that whenever CYGNA relies on industry
16 practice it be able to specify the scope of that practice.
17 It also should be able to obtain and review the engineering
18 analysis that supports the alleged practice. Then and only
19 then will the Board know whether this practice comports with
20 the applicable regulations and code sections."

21 I think one thing that I would like to reach an
22 understanding with CYGNA on, recognizing that CYGNA has
23 performed other independent design verifications on Fermi 2
24 and Grand Gulf. I am sure it has had many experiences going
25 through other plants -- I also recognize that in the

1 February hearing, there was some discussion about -- I think
2 Mr. Ward testified that CYGNA was not to comment on good
3 versus poor engineering practice.

4 I do not want to talk about good versus poor
5 engineering practice. What I want to talk about is standard
6 engineering practice versus non-standard engineering practice.

7 From CYGNA's experience, I would like to understand
8 if CYGNA considers the pipe supports at Comanche Peak to
9 conform to standard engineering practice, or -- in other
10 words, in your opinion, do you think the pipe supports,
11 typical pipe supports at Comanche Peak are in conformance
12 with standard engineering practice or not?

End 16.

13
14
15
16
17
18
19
20
21
22
23
24
25

mgc 17-1

1 MR. PIGOTT: For the systems we looked at?

2 MR. TERAQ: For the walkdown you performed on the
3 spent fuel pool cooling system. It is not typical. The
4 supports on the spent fuel pool cooling system are simple
5 from what you have visually seen in the rest of the plant
6 informally. Recognizing that it is not like the spent fuel
7 pool cooling system supports, would you say those supports
8 are typical of standard industry practice?

9 MS. WILLIAMS: I think as time goes on, we are
10 learning more and more about what is common at Comanche Peak.
11 We started with the spent fuel, which was a relatively simple
12 system. We went to the RHR; it was still relatively simple.
13 Now we are doing the component cooling water and the main
14 steam. We are finding that there are a lot of ^{unit} designs.
15 I am not commenting on whether that is good or bad by saying
16 that. I am just saying we are becoming more knowledgeable
17 on the gamut of designs that are in place at Comanche Peak,
18 and we are discussing that amongst ourselves right now.

19 MR. TERAQ: The reason I feel this is a very
20 important point is, if according to the Board memorandum,
21 if you are to justify engineering practice or industry
22 practice, let's say, I think a more important question is,
23 does Comanche Peak's support design, if they are not industry
24 practice, is it valid to use standard engineering procedures,
25 practices, for the support designs applicable to Comanche

mgc 17-2

1 Peak?

2 MS. WILLIAMS: I think that is a fair question, but
3 I am not sure we are ready to answer it today.

4 MR. IPPOLITO: I cannot leave it like that. The
5 obvious next question is, when can you answer it?

6 MS. WILLIAMS: We have got some questions
7 outstanding on the pipe supports that we are reviewing in
8 Phase III. It is within the scope of Phase III with what
9 we looked at in Phase II and Phase I that we are getting
10 this understanding of what the general practices at
11 Comanche Peak are, and we are at the point now where we
12 have to have some in-house meetings and project reviews to
13 discuss that. We are going to be doing that over the course
14 of the next month.

15 MR. SHULMAN: Part of the reason -- I'm not sure
16 there is one answer to it. There may be several answers
17 to different aspects that may come out of Phase III and
18 Phase IV.

19 MS. WILLIAMS: Nonstandard practice does not mean
20 they do not meet the codes. It may mean they are unit
21 designs. We want to assure ourselves that all proper
22 considerations have been given to them.

23 MR. TERAQ: But again, I want to point out that
24 nonstandard practice in support design can invalidate
25 standard engineering assumptions or practices, ignoring

mgc 17-3

1 some of the things the rest of the industry may do --

2 MS. WILLIAMS: That's right.

3 MR. SHULMAN: We agree with that.

4 MS. WILLIAMS: Yes.

5 MR. BACHMANN: Any more on this particular item?

6 MR. YOUNGBLOOD: We should discuss a little bit --
7 ordinarily we would think of, if you have gotten everything
8 wrapped up, then you would send in a final report. This
9 may take another iteration before you send in a final report.
10 I don't know. This is something you may want to meet with
11 us and the Applicant to discuss or something.

12 MR. BACHMANN: I think that might stand a little
13 bit of clarification, since the November 1983 submittal
14 was entitled "Draft Final." There were indications on -- in
15 the testimony on the transcript during the February hearings
16 that certain of the observations and resolutions of those
17 observations would be updated in time for the final filing.

18 Can someone put that in perspective on what are
19 the steps in producing a final report sometime? Is that
20 dependent upon certain other things occurring? Could you
21 please clarify that for us?

22 MS. WILLIAMS: All those that we know need
23 updating or revision at this time, they are sitting in my
24 office. They are revised. We recently received the
25 Applicant's comments on the report, and now we need to go

mgc 17-4

1 through and see if there are any additional comments that
2 need to be incorporated. And then there are two vehicles
3 we can use for issuing it. We can either do an errata and
4 a new cover sheet which says this is Rev 0, no longer draft,
5 or we can just reissue the entire report.

6 MR. BACHMANN: I understood the reason for
7 entitling it the Draft Final Report was so that you could
8 take the former course without reissue.

9 MS. WILLIAMS: Yes.

10 MR. BACHMANN: Do you have a timeframe for when
11 you feel this might be done, and if there are any hangups or
12 impediments to that, can you let us know?

13 MR. PIGOTT: We did have -- frankly, as a result
14 of this meeting, we will probably have to determine whether
15 or not the items discussed today should properly be
16 considered and included in whatever comes out as the final
17 report. So although we felt at one time we were fairly
18 close to a final, I would have to think that we have to
19 reassess just exactly where we are before we can put out
20 that final-final.

21 MR. BACHMANN: I don't know if we mentioned it
22 earlier, but other than the Staff and CYGNA, I guess we
23 only have representatives of the Applicant here.

24 Did anyone from the Applicant's side want to make
25 any statements or comments on the record?

mgc 17-5

1 MR. REYNOLDS: No.

2 MR. BACHMANN: They indicate no.

3 Does CYGNA wish to make any more statements about
4 what we discussed today just for the record, anything you
5 happen to think about before we wrap this up?

6 (No response.)

7 MR. BACHMANN: Staff, any other comments?

8 (No response.)

9 MR. BACHMANN: The meeting is closed.

10 (Whereupon, at 4:52 p.m., the meeting was
11 adjourned.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CERTIFICATE OF PROCEEDING

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

This is to certify that the attached proceedings before the
NRC COMMISSION

In the Matter of: Meeting with Cygna Energy Service (for
Comanche Peak)

Date of Proceeding: 19 April 1984

Place of Proceeding: Bethesda, Md.

were held as herein appears, and that this is the original
transcript for the file of the commission.

Barbara Whitlock

Official Reporter - Typed

Barbara Whitlock

Official Reporter - Signature



TEXAS UTILITIES SERVICES, INC.
INDEPENDENT ASSESSMENT PROGRAM
COMANCHE PEAK STEAM ELECTRIC STATION

APRIL 19, 1984

CYGNA RESPONSE TO
NRC QUESTIONS
OF FEBRUARY 6 AND
MARCH 30, 1984



Item I
(Design Change Control)

Cygna should provide an assessment of:

- (1) The adequacy of the document control system to assure the plant was constructed in accordance with all design changes prior to the introduction of the computerized document listing system.
 - (2) The adequacy of the document controls on piping and pipe supports which were not included in the computerized document listing at the time of the reinspection.
-



Item I Response
(Design Change Control)

- (1)
- As-built walkdown of a completed system
 - Data base validation activities which were on-going at the time of the Cygna review.
-



Independent Assessment Program

Purpose

- Provide supplementary evidence and additional assurance regarding the overall design quality of the Comanche Peak Steam Electric Station (CPSES)
 - Address the concerns and comments expressed by the NRC in letters to Texas Utilities dated May 4 and July 15, 1983, including supplement.
 - Satisfy the commitments made at the August 18, 1983 NRC meeting regarding content of the program plan, which was subsequently approved by the NRC.
-



Program Objectives

- Provide an assessment of the adequacy of the design control program
 - Provide an assessment of the design adequacy of a selected system
 - Verify a selected as-built configuration
 - Evaluate the extent of implementation of selected design control program elements
-



Review Scope Selection Criteria

- **Include a cross-section of disciplines**
 - **Include characteristics which cannot be verified by normal means, such as performance testing**
 - **Include several organizational interfaces**
 - **Include design changes**
 - **Include other specific concerns identified by the NRC**
-




System Selection Criteria

- **Safety-related**
 - reactor operation
 - reactor protection
 - **Design and materials interface with Westinghouse**
 - **Design and materials interface with Gibbs & Hill**
 - **Demanding design parameters**
 - **Turned-over to the start-up group**
-




Spent Fuel Pool Cooling Element






RHR Train "B" Element





Review Scope





Item 1 Response (continued)
(Design Change Control)

- (2)
- Not originally part of the design verification data base which serves as the basis for the DCC data base.
 - Large bore piping and pipe supports will be entered into the data base upon final vendor certification and incorporation of all design changes.
 - Small bore piping and pipe supports will be entered into the data base upon final vendor certification.
 - Pipe supports are part of the as-built verification program.
 - Vendor certification includes a final check of each support as-built configuration and associated analyses.
 - Piping is field checked to a 79-14 as-built verification walkdown procedure.
-



Item 2 (Pipe Stress)

Regarding Observation PI-00-01, Cygna should provide an adequate explanation of whether girth butt welds between straight sections of piping (sizes 3 and 4 inch, schedule 40) conform to the ASME Code requirements for welded joints.



Observation Record

Checklist No.	General	Revision No.	0
Observation No.	PI-00-01	Sheet	1 of 1
Originated By	M.K. Mani	Date	10/6/83
Reviewed By	J.C. Minichiello	Date	10/18/83

1.0 Description

Gibbs and Hill does not specify any weld mismatch (δ) when determining stress intensification factors for butt welds.

2.0 Requirement

2.1 Brown and Root Inspection Procedure CP-CPM 6.90, Rev. 5, Section 3.10.1.3 allows 1/32" radial mismatch.

2.2 ASME Boiler and Pressure Vessel Code, 1974 edition, Section III, Figure NC 3673.2(b)-1 states that

$$I = 1.8 \text{ for } t < 3/16" \text{ or } \frac{\delta}{t} > .1$$

for as-welded butt welds.

3.0 Document Reference

Computer output for the as-built analyses of stress problems AB-1-69, Rev. 0, and AB-1-70, Rev. 0.

4.0 Potential Design Impact

Use of an SIF of 1.8 rather than the value which was used (1.0) may result in stresses greater than allowables.

Attachments

A. Observation Record Review

Extent

Isolated

Extensive X

Other (Specify)

Texas Utilities Services, Inc.
Independent Assessment Program; 83090



Observation Record Review Attachment A

Checklist No. <u>General</u>	Revision No. <u>0</u>
Observation No. <u>p[-00-01]</u>	Sheet <u>1</u> of <u>2</u>

	Yes	No
Valid Observation	X	
Closed	X	

Comments

1.0 Probable Cause

Inadequate procedures.

2.0 Resolution

Cynga is concerned primarily with welds at elbow to pipe joints for the following reasons:

- a. Welds at reducers will be taken care of by the reducer, SIF = 2.0.
- b. Welds at tapered transition joints (TTJ) will be taken care of by the TTJ, SIF = 1.9.
- c. Welds in long straight runs (between spool pieces) will typically have much lower load and stress levels than near elbows.

In response to Cynga's comment, Gibbs and Hill referenced NUREG/CR-0371 "Stress Indices for Girth Fillet Welded Joints Including Radial Weld Shrinkage, Mismatch and Tapered Wall Transitions" by E.C. Rodabaugh and S.E. Moore (1978). In it, Rodabaugh and Moore state that mismatch should be considered for stress indices only for $t < 0.237"$. This was adopted by the ASME Code in the Summer 1981 addenda for transition joints (para. NB-3683.5(a)) and welds (para. NB-3683.4). While it has not yet been changed in subsection NC, paragraph NC-3673.2(b) does allow the SIF (1) to be calculated based on the stress indices (C_2 and K_2) using

$$1 = C_2 K_2 / 2.$$

Approvals

Originator <u>M. K. Jain</u>	Date <u>11/4/83</u>
Project Engineer <u>John Strohbecker</u>	Date <u>11/5/83</u>
Project Manager <u>M. D. Williams</u>	Date <u>11/5/83</u>
Senior Review Team <u>...</u>	Date <u>11/5/83</u>

Texas Utilities Services, Inc.
Independent Assessment Program; 83090



Observation
Record Review
Attachment A

Checklist No. General	Revision No. 0
Observation No. P1-00-01	Sheet 2 of 2

	Yes	No
Valid Observation	X	
Closed	X	

Comments

Therefore, for butt welds with $t > 0.237"$

$$C_2 = 1 \quad K_2 = 1.8$$

$$I = 0.9 < 1 \text{ therefore } I = 1.0$$

For welds with $t < .1875$, Gibbs and Hill has used an SIF of 1.8, so it is only those welds on piping where $.1875 < t < .237$ which may have unconservative SIF's. From the piping specification, this situation involves only 3" sch 40 and 4" sch 40 piping. For these, the SIF for an elbow (1.8 and 2.0, respectively) are equal to or greater than the SIF for the butt weld. Thus, the Gibbs and Hill analyses are acceptable and Cygna considers this observation closed.

By Approval

Originator	<i>M. K. Mann</i>	Date	11/1/93
Project Engineer	<i>John C. Marshall</i>	Date	11/1/93
Project Manager	<i>W. J. Williams</i>	Date	11/5/93
Senior Review Team	<i>David J. ...</i>	Date	11/5/93

Texas Utilities Services, Inc.
Independent Assessment Program; 83090



Item 2 Response (Pipe Stress)

- Later Codes use stress indices for the primary stress checks instead of SIF's.
 - A comparison of the Code of record with later codes shows the later code is less restrictive for primary stress checks on butt welds.
-



Item 2 Response (continued)
(Pipe Stress)

Code of Record

$$\frac{PD_o}{4t} + .75i \frac{M_a}{Z} < S_h$$

Later Code

$$B_1 \frac{PD_o}{4t} + B_2 \frac{M_a}{Z} \leq 1.5 S_h$$

For butt welds

$$\begin{aligned} B_1 &= .5 \\ B_2 &= 1.0 \end{aligned}$$

Substituting

$$\frac{PD_o}{4t} + \frac{M_a}{Z} \leq 1.5 S_h$$

In conclusion:

$$.75 i \geq 1$$

and

$$S_h < 1.5 S_h$$



Item 3 (Pipe Stress)

Cygna should provide an explanation on whether the use of a 20% increase in upset and emergency allowables, when considering welded attachment stresses in combination with general piping stresses, consistently results in calculated design stresses which meet more recent Code Cases for all welded attachment designs and materials.



Item 3 Response (Pipe Stress)

- The Gibbs and Hill allowable is less than the Code Case allowables for all conditions for SA106 B piping.
 - The Gibbs and Hill allowable is less than the Code Case allowable for all conditions, except emergency, for 304 and 316 stainless steel piping.
 - For 304 and 316 stainless steel piping, the Gibbs and Hill emergency allowable is less than the Code Case emergency allowable if the temperature is less than approximately 400° F.
-



TABLE 1

COMPARISON OF GIBBS & HILL TO
CODE LIMITS FOR WELDED ATTACHMENTS

Material	Temp. (°F)	S_H (ksi)	S_Y (ksi)	$1.5 S_H$ (G&H)	$1.5 S_Y$ (Code)	$2.16 S_H$ (G&H)	$1.8 S_Y$ (Code)
A106B	200	15	31.9	22.5	47.9	32.4	57.4
	650	15	25.4	22.5	38.1	32.4	45.7
312, 316 358	100	18.8	30.0	28.2	45.0	40.6	54.0
	400	18.1	21.4	27.2	32.1	39.1	38.5
	650	16.7	18.5	28.1	27.8	36.1	33.3
312, 304 358	100	18.8	30.0	28.2	45.0	40.6	54.0
	400	16.2	20.7	24.3	31.1	35.0	37.3
	650	15.9	17.9	23.9	36.9	34.3	32.2



Item 4
(Cable Tray Supports)

Cygna should revise Exhibit 4.3-1, Allowable Stresses, of Design Criteria DC-3 to include the Safe Shutdown allowables.



Item 4 Response (Cable Tray Supports)

**EXHIBIT 4.3.-1
ALLOWABLE STRESSES**


Stress	Load Case			
	Operating		Safe Shutdown*	
	Value	KSI	Value	ksi
Tension	$0.6 F_y$	21.6	$0.96F_y$	34.56
Shear	$0.4 F_y$	14.4	$0.64F_y$	23.04
Web Crippling	$0.75 F_y$	27.0	$1.2 F_y$	43.2
Compression	F_a per AISC Section 1.5.1.3		$1.6 F_a$ per AISC Section 1.5.1.3	
Bending	F_b per AISC Section 1.5.1.4		$1.6 F_b$ per AISC Section 1.5.1.4	
Bearing	$0.9 F_y$	32.4	$1.44F_y$	51.84
Bolts 307:				
Tension and Shear	Per AISC Appendix Section 1.5.2 and 1.6.3		1.6 x Allowables per AISC Appendix Section 1.5.2 and 1.6.3	
Anchor Bolt	See Exhibit 4.4-1		See Exhibit 4.4-1	
Welds (Fillet, Full or Partial Penetration):				
Shear	$0.3 F$ (Weld ^y Metal)	21.0	$0.48F$ (Weld ^y Metal)	33.6
Tension	$0.6 F$ (Base ^y Metal)	21.6	$0.96F$ (Base ^y Metal)	34.56
Combined Stress	As per AISC Section 1.6.1		As per AISC Section 1.6.1	

*1.6 x Operating Allowable



Item 5
(Cable Tray Supports)

How did Cygna verify that construction drawings were correctly prepared from the 15 standard design drawings?





Item 5 Response (Cable Tray Supports)

- Cygna's review did not include verification of field-prepared construction drawings.
 - Structural design as shown on the 2323-S-900 series drawings were checked for consistency with design calculations.
-



Item 6
(Electrical/I&C)

Why weren't R.G. 1.106 and BTP ICSB18 (PSB) included in Cygna Design Criteria DC-5 for the electrical design review?



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FEB 6 1984

Docket No. 50-445

Mr. R. J. Gary
Executive Vice President
Texas Utilities Generating Company
Skyway Tower
400 North Olive Street
L. B. 81
Dallas, Texas 75201

Dear Mr. Gary:

Subject: Independent Assessment Program (IAP) Performed by Cygna

In the course of the NRC staff's review of the Cygna Report we have found an inconsistency which requires explanation. In Appendix E, Document No. DC-5 Cygna describes the electrical system review criteria to include the control circuit (the manual and automatic logic) that operates valve 1-8811B. This review is detailed in Appendix H, Checklist EE-02. FSAR Section 7.6.5 (FSAR Pages 7.6-17 through 7.6-19) describes the control and interlock requirements for the recirculation sump isolation valves (8811A and 8811B). These valves open automatically when two of four refueling water storage tank level signals are less than the Lo-Lo-1 level setpoint in conjunction with the initiation of the engineered safety feature actuation signal ("S" signal). The design provides for the retention of the "S" signal to allow automatic switchover from injection mode to recirculation mode of the ECCS. The recirculation sump isolation valves are also interlocked such that they must be closed before the following valves can be opened:


1. RWST/RHR pump suction isolation valves, 8812A and 8812B.
2. RHR inner or outer isolation valves 8701A, 8701B, 8702A, and 8702B.

In the Cygna Report, Appendix H, Checklist No. EE-02, it only mentions that valve 1-8811B should be interlocked to prevent opening until the pressure decays to 425 psig. The interlock described by Checklist EE-02 is not in conformance with FSAR Section 7.6.5 requirements. Conversely, the Cygna Report is silent on the control and interlock requirements described in FSAR Section 7.6.5.

Cygnia should be instructed to explain this inconsistency and to confirm that the control and interlocks circuitry for valve 1-6811B is designed consistent with the description given in FSAR Section 7.6.5. Texas Utilities should comment on the design adequacy of the control and interlock circuitry for the recirculation pump isolation valves.


Texas Utilities should give us your overview on the Cygnia report including any statements, comments, or corrections you deem appropriate at this time. Your response should specifically comment on and describe your actions concerning the Cygnia suggestion that a set of standard instructions be prepared for the design, revision and review of cable tray supports (p. 4-12); and the Cygnia suggestion that the anchor bolt embedment lengths be deleted from the support drawings (p. 4-10).

Sincerely,



B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

*MR
Comanche Peak*

MAR 22 1984

Socket No. 50-445

Mr. L. L. Kammerzell
Vice President
CYGNA Energy Services
101 California Street
Suite 1000
San Francisco, CA 94111

Mr. R. J. Gary
Executive Vice President
Texas Utilities Generating Company
400 North Olive Street
L.B. 81
Dallas, Texas 75201

Dear Sirs:

Subject: Independent Assessment Program on Comanche Peak Steam Electric
Station Performed by CYGNA

This letter concerns the Independent Assessment Program on the Comanche Peak Steam Electric Station performed by CYGNA for the Texas Utilities (TUGCO). Recently certain information has been developed during the Comanche Peak operating license hearings before the Atomic Safety and Licensing Board which raises questions concerning the adequacy of independence maintained between the CYGNA staff and the TUGCO staff during the course of CYGNA's review.


1. We understand that CYGNA gave the TUGCO advance notice of the documentation needed to conduct CYGNA's review. These documents were then used to ascertain the accuracy of documentation control paperwork as well as the adequacy of control of document distribution (Tr. 9368-9372).
2. Based on the transcript (Tr. 9377-9382), it appears that CYGNA did not follow the protocol attached to my letter to Mr. Gary dated September 23, 1983 with respect to notice of all meetings between TUGCO and CYGNA.

We would like CYGNA's comments on these matters and CYGNA's assessment of whether these matters affect the adequacy of the independence maintained by CYGNA during its review. We would also like the separate comments of TUGCO on these matters, and TUGCO's assessment of whether these matters affect the adequacy of the

independence of CYGNA's review. In addition, we require CYGNA's assessment of whether its review was fully independent, with a detailed basis for CYGNA's conclusion. In any areas in which CYGNA's review was, in their view, not fully independent, we wish their assessment of how such matters may affect any conclusion drawn by CYGNA.

Full responses will be important in NRC assessment of the degree to which we feel we can rely upon the CYGNA evaluation and report to provide the NRC staff with additional assurance that the Comanche Peak plant has been designed and constructed in accordance with the application and NRC Regulations.

Sincerely,


Darrell G. Esenhut, Director
Division of Licensing

cc: See next page



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 30 1984

Docket No. 50-445

Mr. M. D. Spence
President
Texas Utilities Generating Company
400 N. Olive St., L.B. 81
Dallas, Texas 75201

MR
Mr. L. L. Kammerzell
Vice President
CYGNA Energy Services
101 California Street
Suite 1000
San Francisco, CA 94111


Dear Mr. Kammerzell:

Subject: Independent Assessment Program (IAP) Performed by CYGNA

As a result of our review of the November 5, 1983 draft CYGNA report of its Independent Assessment Program (IAP) for the Comanche Peak Steam Electric Station, Unit 1, the NRC staff has a number of questions which we would like to discuss with the CYGNA reviewers. The specific matters are described in the enclosed request for additional information.

We believe that a meeting in approximately two weeks would be appropriate. Mr. Burwell, the NRC Project Manager will contact your staff and the CYGNA project manager in the next few days to schedule such a meeting. All explanations, assessment or other additional information provided at the meeting should be subsequently documented in the final CYGNA report or by a supplement to the report.

Sincerely,


Darrell G. Eisenhut, Director
Division of Licensing

Enclosure:
As stated

cc: See next page

Contact: S. Burwell
(301) 492-7563

8404120318 5pp.

COMANCHE PEAK

APR 10 1984

Mr. M. D. Spence
President
Texas Utilities Generating Company
400 N. Olive St., L.B. 81
Dallas, Texas 75201

cc: Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N. W.
Washington, D. C. 20036

Robert A. Wooldridge, Esq.
Monsham, Forsythe, Sampels &
Wooldridge
2001 Bryan Tower, Suite 2500
Dallas, Texas 75201

Mr. Homer C. Schmidt
Manager - Nuclear Services
Texas Utilities Generating Company
2001 Bryan Tower
Dallas, Texas 75201

Mr. H. R. Rock
Gibbs and Hill, Inc.
393 Seventh Avenue
New York, New York 10001

Mr. A. T. Parker
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

David J. Preister
Assistant Attorney General
Environmental Protection Division
P. O. Box 1254P, Capitol Station
Austin, Texas 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound
Energy
1426 South Polk
Dallas, Texas 75224

Mr. James E. Cummins
Resident Inspector/Comanche Peak
Nuclear Power Station
c/o U. S. Nuclear Regulatory
Commission
P. O. Box 38
Glen Rose, Texas 76043

Mr. John T. Collins
U. S. NRC, Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

Mr. Lanny Alan Sinkin
114 W. 7th, Suite 220
Austin, Texas 78701

B. R. Clements
Vice President Nuclear
Texas Utilities Generating Company
Skyway Tower
400 North Olive Street
L. B. 81
Dallas, Texas 75201

William Burchette, Esq.
Law Office of Northcutt Ely
Watergate 600 Building
Washington, D. C. 20037

Ms. Bille Garde
Government Accountability Project
1901 Q Street, N. W.
Washington, D. C. 20009

Ms. Nancy H. Williams
CYGNA
101 California Street
San Francisco, California 94111-5894

MAR 30 1984

REQUEST FOR ADDITIONAL INFORMATION
FROM CYGNA RELATING TO THE
CYGNA INDEPENDENT ASSESSMENT OF THE
COMANCHE PEAK STEAM ELECTRIC STATION, UNIT 1

1. In two related observations (DC-01-01 and DC-01-02), CYGNA found that design changes generated against drawings and specifications were not adequately recoverable by the document control system. In the observation record review for these two observations, CYGNA described its reinspection of the document control system after the applicant had made improvements. CYGNA closed these observations based on their confidence that the newly developed computerized document listing is accurate with respect to design changes outstanding against affected design documents and that adequate programs have been put in place to assure that the plant is constructed in accordance with the design and associated design changes. However, the CYGNA Report did not provide a discussion on the adequacy of the document control system to assure the plant was constructed in accordance with all design changes prior to the introduction of the computerized document listing system. Secondly, the CYGNA Report did not provide information (data) on the adequacy of the document controls on piping and pipe supports which were not included in the computerized document listing at the time of the CYGNA reinspection.

CYGNA should provide an adequate explanation or assessment on how the document controls assure that design changes and inspections made prior to the availability of the computerized document listing are resolved in a manner which assures that the plant is constructed in accordance with the design and associated design changes. The NRC staff is considering requiring an additional assessment by CYGNA of whether the implementation of the applicant's present document control system does identify and make available all outstanding design change documentation as may be needed in the inspection of systems and components, especially the outstanding design changes associated with the piping and pipe supports.

2. In observation PI-00-01, the applicant's piping designer (Gibbs & Hill) did not specify any weld mismatch (δ) when determining the stress intensification factor for as-built girth butt welds. Consequently, a stress intensification factor of 1.0 was used in the piping analyses. CYGNA was concerned that the use of a stress intensification factor of 1.8, which is specified in the ASME Code in Figure NC--3673.2(b)-1 for a wall thickness (t) less than 3/16 inch or a mismatch ratio (δ/t) greater than 0.1, could result in exceeding the allowable stress limit. For welds with a wall thickness less than 3/16 inch, the applicant used a stress intensification

factor (SIF) of 1.8 as required. For welds in piping with wall thicknesses greater than 0.237 inch the stress intensification factor was also shown to be acceptable. However, the NRC staff does not find that an adequate justification was provided to allow the use of an SIF equal to 1 for girth butt welds between straight piping with wall thicknesses between 0.1875 and 0.237 inch. CYGNA should provide an adequate explanation of whether girth butt welds between straight sections of piping (sizes 3 and 4 inch, schedule 40) conform to the ASME Code requirements for welded joints.

3. In observation PI-00-02 CYGNA noted that the applicant's piping designer uses a 20 percent increase in the upset and emergency condition allowable stresses when considering localized stresses in welded attachments in combination with general membrane and bending stresses. CYGNA concluded that the observation was closed based upon a finding that later codes allow the use of stress indices which result in an increase in the allowable stresses for upset and emergency conditions. CYGNA should provide an adequate explanation on whether the use of the 20 percent increase in allowable stresses consistently results in calculated design stresses which are within the stresses allowable under more recent Code Cases for all welded attachment designs and materials.
4. With regard to the design review of cable tray supports, the allowable stresses table (Exhibit 4.3-1) is arranged to provide allowable stress values for operating and safe shutdown conditions. However, no values are provided for many safe shutdown conditions. The NRC staff believes CYGNA should revise the report to provide the missing values.
5. In the design of the 40 cable tray supports within the CYGNA scope of review, construction drawings for each support were prepared in the field from the 15 standard designs prepared and analyzed by the architect-engineer. CYGNA should describe how it verified that construction drawings have been correctly prepared from the 15 standard design drawings.
6. With regard to design review of electrical, instrumentation, and control systems, the NRC staff reviewed the CYGNA criteria and checklists for the electrical design review (CYGNA Report, Appendix E, Document No. DC-5, Sections 2.0, 3.0, 4.0 and 5.0) to determine the adequacy of the criteria for assuring compliance with NRC regulatory requirements. The NRC staff notes that the review criteria did not include NRC Regulatory Guide 1.106 relative to bypassing of motor overload protection circuits and NRC Standard Review Plan Section 8.3, Appendix 8A, Branch Technical Position ICSB 18 (PSB) relative to the single failure of safety related valves. The NRC staff could not determine whether these two regulatory guidelines were included in the electrical design review of the valve control circuitry. CYGNA should supplement the design review criteria and checklist for this valve and assess the design of the valve control circuitry against these two regulatory guidelines, or otherwise justify their omission.

7. One observation (I/D-02-02) addressed a concern that some snubbers were installed 180° from the configuration shown on the piping support drawings. CYGNA closed this observation based on a procedure which indicates this installation is acceptable since the snubbers will still perform their intended function. This procedure should be identified in the checklist.

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER 400 NORTH OLIVE STREET, L.B. #1 DALLAS, TEXAS 75201

Log # TXX-4134
File # 10010

April 2, 1984

Mr. B. J. Youngblood
Chief, Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
INDEPENDENT ASSESSMENT PROGRAM PERFORMED
BY CYGNA

Dear Mr. Youngblood:

Texas Utilities has reviewed your concern regarding the containment sump isolation valves and the two recommendations made in the CYGNA IAP Report regarding: (1) that a standard instruction be prepared for the design, revision and review of cable tray supports and, (2) that the anchor bolt embedment lengths be deleted from the support drawing. In addition, Texas Utilities is presently reviewing the CYGNA IAP Report and any formal comments will be submitted to the NRC Staff and to CYGNA in the near future.

Containment Sump Isolation Valves

The NRC Staff requested that Texas Utilities review the control and interlock mechanisms of the containment sump isolation valves (1-8811A/B). In the CYGNA IAP Report Appendix H, Checklist Number EE-02 reviews the control circuitry of the containment sump isolation valves for compliance to FSAR Chapter 7. Although the valve 1-8811B is not directly interlocked to a RCS pressure setpoint of 425 psig, CYGNA indicates that such an interlock exists.

During the injection mode, the RWST/RHR pump suction isolation valves are open and allow flow to the RCS. These valves can only be opened if the containment sump isolation valves are closed. The containment sump isolation valves open automatically when two of four refueling water storage tank level signals are less than the lo-lo-1 level setpoint, coincident with an engineered safety feature actuation signal (S signal). Furthermore, the design allows for automatic switchover from the ECCS injection mode to the recirculation mode during an accident. Operator action is required to close RWST/RHR pump suction isolation valves 8812A/B immediately following the opening of the containment sump isolation valves (cold leg recirculation mode)..

In addition, the containment sump isolation valves must be closed before the RHR system can be aligned to the RCS hot leg during a normal cooldown. The RCS pressure must be below approximately 425 psig before the RHR isolation valves will open. Thus, the containment sump isolation valves are interlocked so that they must be closed before the following valves can be opened:

1. RWST/RHR pump suction isolation valves (8812A/B);
2. RHR inner or outer isolation valves 8701A, 8701B, 8702A and 8702B. (below 364 psig RCS pressure setpoint)

FSAR Section 7.6.2.1 describes the control logic of the inner and outer RHR isolation valves (8702A/B and 8701A/B). These valves are normally closed and can only be opened after the RCS pressure is reduced below approximately 425 psig and the containment sump isolation valves are closed. Additionally, the RHR system is only used for conditions below approximately 425 psig and 350°F. Thus, the design of the RHR system precludes the exposure to high pressure.

The CYGNA comment regarding a direct interlock between the containment sump isolation valve and RC pressure is not clear and should be clarified or reworded. The design of the control and interlock circuitry for the recirculation sump isolation valves, RHR isolation valves and RWST/RHR pump suction isolation valves is correct and there is not a 425 psig RCS pressure permissive required to open the recirculation sump isolation valves.

Standard Instructions - Cable Tray Supports

A standard set of instructions for the design, revisions and review of cable tray supports as suggested by CYGNA is being prepared and will be provided to CYGNA prior to May 1.

Anchor Bolt Embedment Lengths

CYGNA suggested that anchor bolt embedment lengths should be removed from pipe support drawings. This suggestion was made to ensure that there would be no confusion between the embedment length shown on the drawing and the embedment length used for design calculations.

Installation procedure CEI-20 (Rev. 9, 12/16/83), "Installation of 'Hilti' Drilled-in Bolts" requires that anchor bolts be embedded to a minimum depth below the surface of the 4000 psi (28-day strength) structural concrete prior to setting (torquing). A table in the procedure provides the anchor bolt diameter and the minimum embedment length for Hilti-Kwik and Super Kwik-Bolts. (The minimum embedment length is approximately $4\frac{1}{2}$ times the diameter of the bolt for Kwik-Bolts and $6\frac{1}{2}$ times the diameter of the bolt for Super Kwik-Bolts).

The instruction has been revised to state that the minimum embedment length shall be that specified in the anchor bolt installation procedure and that specified on the drawing. Quality control procedures ensure compliance to these instructions.

Original design calculations to ensure adequate qualification of the anchor bolt design assumes the minimum anchor bolt embedment lengths required based on the CEI-20 procedure. If, for an initial calculation, a greater embedment depth is necessary than required by the CEI-20 procedure, the required depth is indicated on the design drawing.

Furthermore, if for any reason (re-analysis, "as-built" verification, etc.) loads are high and a deeper embedment length is necessary than provided by the initial calculation using the minimum embedment lengths in the CEI-20 procedure or on the design drawing, then a calculation can be made to determine the minimum installed embedment length based on the actual bolt length. This calculation is done by knowing the actual length of the bolt and subtracting the thickness of the concrete topping (if any), steel plates, washers, and assuming the nut is fully torqued at the bottom of the threaded run of the bolt. This provides a conservative estimate of the installed embedment depth. This depth can then be used in load calculations to determine the adequacy of the pipe support design. The engineer can also have a field verification made to determine the actual embedment depth, if necessary.


Although the design support drawings and Installation Procedure CEI-20 provides a minimum embedment length required, the design calculations can be based on a conservative estimate of the actual embedment length. Therefore, there may be differences between the drawing minimum embedment length and the embedment length used in the calculations, but, as CYGNA rightly states, the differences has no design impact. We feel that no further changes are required.

Summary

Texas Utilities will provide formal comments regarding the CYGNA IAP Report. In addition, a standard set of instructions for cable tray support design, review and revision will be provided to CYGNA prior to May 1.

If there are any questions regarding the remaining concerns or those discussed above, please contact us.

Very truly yours,



H. C. Schmidt
Manager, Nuclear Services

HCS/grr