

## NOTES FOR TABLE 3.3.6.4-1

- (a) If either the primary or secondary indication is inoperable, the torus temperature will be monitored at least once per shift to observe any unexplained temperature increases which might be indicative of an open SRV. With both the primary and secondary monitoring channels of an SRV inoperable, either verify that the S/RV is closed through monitoring the backup low low set logic position indicators (2B21-N302 A-H and K-M) at least once per shift or restore sufficient inoperable channels such that no more than one SRV has both primary and secondary channels inoperable within 7 days or be in at least hot shutdown within the next 12 hours.
- (b) With the number of operable channels less than required by the minimum channels operable requirements, initiate the preplanned alternate method of monitoring the appropriate parameters within 72 hours and:
- (1) either restore the inoperable channel(s) to operable status within 7 days of the event, or
  - (2) prepare and submit a Special Report to the NRC pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability, and the plans and schedule for restoring the system to operable status.
- (c) A channel contains two detectors: one for mid-range noble gas and one for high range noble gas. Both detectors must be operable to consider the channel operable.