

ORIGINAL

UNITED STATES
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF:

PERRY NUCLEAR POWER PLANT, UNITS 1 & 2

THE CLEVELAND ELECTRIC ILLUMINATING CO., ET AL

DOCKET NO:

50-440/50-441

LOCATION: PERRY, OHIO

PAGES: 3433 to 3644

DATE: THURSDAY, MAY 2, 1985

*TR. 0101
Return to E. Pleasant 1121-H*

ACE-FEDERAL REPORTERS, INC.

8505070068 850502
PDR ADOCK 05000440
T PDR

Official Reporters
444 North Capitol Street
Washington, D.C. 20001
(202) 347-3700

NATIONWIDE COVERAGE

SueT

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 BEFORE THE ATOMIC SAFETY AND LICENSING BOARD
4

-----X
5 In the matter of: :
6 PERRY NUCLEAR POWER PLANT, : Docket Numbers
Units 1 and 2 : 50-440
7 : 50-441
8 THE CLEVELAND ELECTRIC ILLUMI- :
NATING COMPANY, et al :
-----X

12 Perry Town Hall
13 Center Road & Main Street
Perry, Ohio 44081

14 Thursday, May 2, 1985

16 The hearing in the above-entitled matter was
17 convened at 9:00 a.m., JAMES P. GLEASON, presiding.

18 BEFORE:

19 JAMES P. GLEASON, Chairman
20 Nuclear Regulatory Commission
Atomic Safety and Licensing Board

21 JERRY R. KLINE, Member
22 Nuclear Regulatory Commission
Atomic Safety and Licensing Board

23 GLENN O. BRIGHT, Member
24 Nuclear Regulatory Commission
Atomic Safety and Licensing Board

SueT

APPEARANCES:

On Behalf of the Applicant, Cleveland Electric
Illuminating Company, et al:

JAY E. SILBERG, Esquire

and

HARRY H. GLASSPIEGEL, Esquire

SHAW, PITTMAN, POTTS & TROWBRIDGE

Attorneys at Law

1800 M Street, N. W.

Washington, D. C. 20036

On Behalf of the Intervenor, Ohio Citizens for
Responsible Energy:

SUSAN L. HIATT

8275 Munson Road

Mentor, Ohio 44060

On Behalf of the NRC:

COLLEEN WOODHEAD, Esquire

Office of Executive Legal Director

Nuclear Regulatory Commission

Washington, D. C. 20555

C O N T E N T S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

SueT

WitnessesDirect Cross Redirect Recross

Eileen M. Buzzelli
Richard D. Richardson
Kevin W. Holtzclaw
Roger W. Alley
Bernard Lewis
Bela Karlovitz
G. Martin Fuls
-Resumed-

3437
(Continuing)

E X H I B I T SIdentifiedReceived

OCRE Exhibit Number 15

3465

3467

OCRE " " 16

3508

3508

P R O C E E D I N G S

(9:00 a.m.)

JUDGE GLEASON: All right.

Whereupon,

EILEEN M. BUZZELLI,

RICHARD D. RICHARDSON,

KEVIN W. HOLTZCLAW,

ROGER W. ALLEY,

BERNARD LEWIS,

BELA KARLOVITZ,

- and -

G. MARTIN FULS,

resumed the stand as witnesses called by and on behalf of the Applicants and, having previously been duly sworn by Judge Gleason, were further examined and testified as follows:

JUDGE GLEASON: I believe you had a preliminary matter, Mr. Glasspiegel?

MR. GLASSPIEGEL: Thank you, Mr. Chairman.

Yesterday during the hearing a matter came up concerning the PNPP drywell electrical penetrations at transcript 3418 to 3419, and I believe, Ms. Buzzelli, you have some clarifying testimony to give relating to some answers you gave yesterday.

WITNESS BUZZELLI: Yes. Yesterday I talked about I believe electrical penetrations in the drywell

1 in containment were similar, but to clarify that and also
2 clarify my response to the question whether the Perry drywell
3 electrical penetration was similar to the description provided
4 in the document which is identified as the BWR Systems Training
5 Manual, at page 4.1-4.

6 That description of the drywell electrical
7 penetration is similar to the Perry electrical drywell
8 penetrations, except that Perry does not have just a single
9 fitting for sealant on the outside of the drywell wall.

10 There is an air and water tight header box that
11 is filled with a ceramic blanket and a sealant material
12 that is qualified to the drywell environment.

13 In addition, there is a welded multi-cable transit
14 cable spreader on the outside face for positioning the
15 cables.

16 MR. GLASSPIEGEL: We appreciate the opportunity
17 to make that clarification. Thank you.

18 JUDGE GLEASON: Ms. Hiatt?

XXX

CROSS EXAMINATION

19 BY MS. HIATT: (Continuing)

20 Q I believe yesterday we were talking about station
21 blackout accidents, and you indicated that hydrogen would
22 accumulate in containment without being burned off in such
23 a situation, did you not?
24

25 A I indicated yesterday that for the unlikely station

1 blackout that had progressed for a considerable period of
2 time, past the point in time -- let's clarify -- past the
3 point in time in which the reactor core insulation cooling
4 system would have provided makeup to the vessel.

5 Sustained station blackout would allow hydrogen
6 to accumulate if the igniter system is not powered during
7 that extended severe accident type of an event.

8 Q Now, if we assumed that a 75 percent metal water
9 reaction has occurred, wouldn't the concentration of hydrogen
10 in the containment, assuming it is completely mixed, be around
11 28 percent, by volume?

A Approximately that concentration.

12 Q Isn't that a denotable mixture?

13 A I will have to let Dr. Lewis explain that.

14 A (Witness Lewis) That depends. It depends on
15 how much steam. It depends on the source of ignition, and
16 some of the other features in the ignition process.

17 Q Assume there is not much steam in the atmosphere.
18 It is in the detonable range?

19 JUDGE GLEASON: That is a question, Dr. Lewis.

20 WITNESS LEWIS: That depends on how much air,
21 is present and how much hydrogen is present.

22 BY MS. HIATT: (Continuing)

23 Q Well, in this they are talking about a concentration
24 of 28 percent hydrogen in air.
25

1 A (Witness Lewis) Oh, in air.

2 Q In air, yes.

3 A It is a detonable mixture under the right
4 circumstances.

5 Q Now, if the AC power is restored at that point,
6 and the distributed igniter system is actuated, have you not
7 introduced an ignition source into a detonable atmosphere?

8 A No.

9 Q You have not?

10 A No.

11 Q Are you saying that the igniters are not an
12 ignition source in a detonable atmosphere?

13 A That is right. Well, they are an ignition source,
14 but not an ignition to detonation. You can't get detonation
15 from a thermal ignition source.

16 Q You could not ignite the detonation?

17 A You could not initiate a detonation.

18 Q Even at detonable concentrations?

19 A That is right.

20 Q What is the basis for your statement, sir?

21 A Fifty years of experience.

22 Q Can you cite any experiments which prove that?

23 A Yes.

24 Q Would you please do so?

25 A Beg your pardon?

1 Q Would you please cite some specific experiments
2 to show this.

3 A I can't immediately recall the exact publication,
4 but I can say this. If you have say, a glow plug, and you
5 ignite a mixture which is flammable, it might be a mixture
6 which is able to sustain a detonation.

7 But the frame that is formed around the ignition
8 source is a frame without convolutions, and no opportunity
9 to accelerate.

10 If you can't accelerate a deflagration, then you
11 can't get a detonation. I know in the minutes of a meeting
12 between Sandia representatives and Professor Lee of Montrael.
13 Professor Lee admits, as you know, that you cannot -- it is
14 most unlikely to get a detonation with a glow plug source
15 in an open space.

16 Q It would get very high over-pressures even from
17 a deflagration at those concentrations though, would you not?

18 A Oh, yes. That is another matter.

19 Q Do you know what pressures you might get?

20 A What concentration are you talking about, 28
21 percent?

22 Q 28, yes.

23 A Those pressures could be starting with atmospheric
24 pressure, could be about 100 pounds; 100 to 110 pounds.
25 The loss could be as low as 50 pounds.

1 Q You are talking about heat loss?

2 A Heat loss, yes.

3 Q Right. Okay. Now, if we had such a situation,
4 station blackout situation, upon recovery of AC power, would
5 the operators in any way rely upon measurements of hydrogen
6 concentration in the containment atmosphere in deciding to
7 actuate the distributor igniter system?

8 A (Witness Buzzelli) Yes, they would. There would
9 be guidance provided to the operator to have him determine
10 the concentration prior to initiating the igniter system.

11 Q Would you base the measurements of hydrogen
12 concentration, containment atmosphere, on results from
13 the hydrogen analyzer?

14 A No, that would not be the mechanism for the
15 operators determination of hydrogen concentrations in a
16 postulated station blackout event.

17 Q What system would be used?

18 A Post-accident sampling system.

19 Q Is that dependent upon AC power?

20 A No, it is not.

21 Q What methods does it use to measure hydrogen
22 concentration?

23 A The grab sample technique. I don't have the
24 details on the exact procedures the operator would use.

25 Q Is containment venting or purging to be used if

1 the use of the distributor igniter system is impossible or
2 inadvisable?

3 A The concept of venting is factored into the
4 generic guideline discussions for situations, including
5 hydrogen and other situations in which containment over-
6 pressure is a concern.

7 End 1.
8 MS fols.
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Sim 2-1

1 Q So it might be used?

2 A It is the subject of discussion in the development
3 of this specific emergency procedure guidelines for hydrogen
4 control as well as the overall containment overpressure
5 concern from other accident sequences.

6 Q Now when you vent the containment, you have
7 essentially created a leak, haven't you?

8 A The concept of venting is to control the
9 overpressure.

10 A (Witness Richardson) It is more than a controlled
11 release. There is guidance provided in the emergency procedure
12 guidelines by the BWR Owners Group to vent under certain
13 circumstances. We first evaluate the potential radiological
14 release that may result.

15 Q Now for the Perry design just where would you
16 vent containment atmosphere to?

17 A (Witness Buzzelli) The exact vent path has not
18 been established. It is under review and evaluation at this
19 time for the Perry plant.

20 JUDGE GLEASON: By whom?

21 WITNESS BUZZELLI: By our engineering staff and
22 that of Gilbert and General Electric. Discussions are under-
23 way to establish what that vent path might be for the
24 overpressure concerns of the containment.

25 BY MS. HIATT:

Sim 2-1

1 Q Do you know what the flow rate would be of this
2 venting system?

3 A No, I do not.

4 A (Witness Richardson) It would depend on the vent
5 path that is finally selected.

6 Q Now in your analyses of containment response,
7 do you not assume that containment sprays are available and
8 will be actuated during or prior to hydrogen ignition?

9 A (Witness Buzzelli) Yes.

10 A (Witness Richardson) Yes. In the preliminary
11 evaluation the containment sprays were assumed to be actuated
12 after the first hydrogen burn when the operator would see
13 an increase in temperature and pressure.

14 Q Now the containment spray system is a sub-system
15 of the residual heat removal system, correct?

16 A Correct.

17 Q And another function of the heat removal system
18 is low-pressure coolant injection?

19 A That is correct.

20 Q And low-pressure coolant injection is also an
21 ECCS sub-system?

22 A Correct.

23 Q And to get into a degraded core accident with
24 hydrogen production you must have the ECCS unavailable or
25 degraded in some manner, correct?

Sim 2-3

1 A To postulate the degraded event that we have
2 analyzed, then you must assume a delayed injection by some
3 means. That specific means a non-mechanistic scenario, and
4 that specific means has not been established. It is just
5 assumed that it occurs somehow.

6 Q Now both containment spray and low-pressure
7 coolant injection are dependent upon the same RHR pumps?

8 A Yes.

9 Q And they might also share some common valves
10 or piping?

11 A They share some common piping.

12 Q And they also share AC power controls and wiring?

13 A They share some common electrical power supplies.

14 Q So it really isn't conservative to assume that
15 containment sprays are available in a degraded core accident,
16 is it?

17 A We feel that it is acceptable to make that
18 assumption in that since the scenario is non-mechanistic it
19 is not identified what the exact failures are. It is just
20 assumed that there are failures which would result in a
21 delayed injection into the core. It is reasonable to assume
22 that one of those failures may be a failure of the injection
23 valve for one of the A or B LPCI injection systems which
24 would still allow the containment spray.

25 Q Isn't it true that containment spray operation

Sim 2-4

1 is a permissive for operating the drywell purge compressors?

2 A To my knowledge, it is not at the Perry plant.
3 I know it is not at the Grand Gulf Nuclear Station and, to
4 my knowledge, it is not at the Perry Nuclear Power Plant.

5 Q Ms. Buzzelli, do you agree with that?

6 A (Witness Buzzelli) I am not aware of such an
7 interlock at the Perry plant.

8 Q I am handing you a part of the final safety
9 analysis report for the Perry plant. Do you recognize
10 this?

11 A I do.

12 Q Specifically Figure 73-5, RHR system function
13 control design. On sheet 5 of 5 on this diagram does it
14 not state here that there is a permissive to start hydrogen
15 mixing system?

16 A (Witness Richardson) This figure is out of the
17 final safety analysis report, which is a copy of a General
18 Electric elementary diagram for the -- I assume this is the
19 RHR system. It shows a permissive coming out of the logic
20 to go to some other instrumentation and controls. As it shows
21 here, it says "Permissive to start hydrogen mixing system
22 by others." This is not the important document for identifying
23 whether that permissive has been picked up in the plant
24 design.

25 There are several permissives which are

Sim 2-5

1 provided by General Electric in the logic that they place
2 in the plans, and those permissives are auxiliary relays
3 which can then be used, if necessary, in other logic circuits
4 such as the combustible gas control system. The document
5 that would be important for establishing that would be the
6 actual logics and control circuits for the combustible gas
7 control system.

8 Q So are you saying that your final safety
9 analysis report does not completely describe the design of
10 the Perry plant?

11 A The final safety analysis report, that relay,
12 to my knowledge, would probably be in the circuits. Whether
13 that contact is picked up in the other circuits is not shown
14 and it is not necessary that it be shown in that diagram.

15 Q But you don't believe that feature has been
16 incorporated at Perry?

17 A To my knowledge, no.

18 Q If we assume ---

19 A I would like to add that I know in the case
20 of Grand Gulf, which I am a little bit more familiar with
21 in terms of in particular the instrumentation and control,
22 since I have looked at many of the diagrams and circuits,
23 that same permissive is provided in the GE instrumentation
24 and control from the RHR system, and the relay was not picked
25 up by the architect/engineer because it was not necessary.

Sim 2-6

1 Q If we assume that sprays are available in a
2 degraded core accident, will they automatically actuate
3 a containment pressure of 9 psig?

4 A Excuse me, did you say -- what was the first
5 assumption? I missed that.

6 Q If we assume the sprays are available in a
7 degraded core accident, they will automatically actuate at
8 a containment pressure of 9 psig; is that true?

9 A They will actuate at approximately 9 psig. I
10 don't know what the exact setpoint is. It is nominally
11 approximately 9 pounds.

12 Q Isn't it true that containment spray takes
13 precedence over other RHR functions with the exception of
14 low-pressure coolant injection for the first 10 minutes
15 of an accident?

16 A That is true.

17 Q Will both trains of containment spray continue
18 to operate as long as containment pressure exceeds 9 psig?

19 A If the pressure is above 9 psig and stays there
20 and the operator does not take manual control of the system
21 then the system would continue to operate in the spray mode.

22
23
24
25
end Sim
Sue fols

#3-1-SueT 1 Q And if the containment pressure were to fall
2 below 9 psig, operator action would be necessary to realign
3 the A or B loop of RHR to another function such as pool cool-
4 ing, correct?

5 A (Witness Richardson) I think that's true. It
6 depends on whether that contact is a seal end or not. I
7 think that that is a seal end contact which would require
8 the operator to realign the system.

9 Q Isn't it true that the operator cannot manually
10 override containment spray as long as the containment pressure
11 exceeds 9 psig?

12 A I would have to check the schematics to verify
13 that. I do not think that that is the case, but I would
14 have to check the schematics.

15 Q Ms. Buzzelli, do you know?

16 A (Witness Buzzelli) I don't know without checking
17 the schematics on that.

18 Q Do any of your draft emergency procedure guidelines
19 instruct operators to activate containment spray upon high
20 containment temperature regardless of core cooling?

21 A (Witness Richardson) I'm sorry. Would you re-
22 state the question?

23 Q Do any of your draft emergency procedure guide-
24 lines instruct operators to activate containment spray upon
25 high containment temperature regardless of core cooling?

#3-2-SueT 1 A (Witness Buzzelli) The emergency procedure guide-
2 lines on containment temperature control, I believe is the
3 specific guideline, direct the operator to focus all of his
4 efforts on restoring core cooling. In the event the contain-
5 ment temperature is increasing, he is able to cycle the
6 system. That is, put the water to containment sprays to bring
7 that pressure down and then restore it back to core cooling.

8 It is not an either/or situation. It's direction
9 to the operator to protect the containment, bring that pres-
10 sure down and once again restore core cooling.

11 Q Mr. Richardson, did you make a presentation to the
12 Nuclear Regulatory Commission on behalf of the Hydrogen Con-
13 trol Owners' Group on June 29th, 1983?

14 A (Witness Richardson) If you have a document that
15 shows that, I guess I did. I would like to see it. I made
16 a number of presentations to the NRC, and I can't remember
17 the dates.

18 (Ms. Hiatt is showing the witness the document.)

19 Q Yes.

20 A Yes, I was there, and I did make certain portions
21 of the presentation. There were other people also making
22 presentations.

23 Q This is a handout of materials that you gave the
24 NRC and others in attendance?

25 A It appears to be. I don't remember all of the

#3-3-SueT

1 handouts that were given, but it does appear to be information
2 that was provided.

3 I know some of this information was provided. I
4 can't attest that all of it was. I don't remember.

5 Q Doesn't this page concern the emergency procedure
6 guideline for hydrogen control?

7 A That -- this document, this handout was a descrip-
8 tion of some draft information that the Hydrogen Control
9 Owners' Group had submitted to the BWR Owners' Group in an
10 attempt to initiate discussions and provide some basic guide-
11 lines that we felt should be considered for incorporation into
12 the emergency procedure guideline.

13 And this was some very preliminary information that
14 has been used to prepare those documents.

15 Q I call your attention to the part under Operator
16 Actions. Could you read this last part into the record here?

17 A Yes. It says, "Initiate containment spray on high
18 high containment temperature regardless if adequate core cool-
19 ing is assured."

20 Again, I restate that this is some initial thinking
21 that was provided to the BWR Owners' Group who has the primary
22 responsibility for developing these guidelines. And whether
23 or not that statement will be in the final guidelines, I am
24 not sure.

25 Q Could you identify what high high containment

#3-4-SueT

1 temperature would be?

2 A At that time, we had no value for that. It was a
3 concept which was to take certain actions based on some high
4 temperature which was to be established, and then a -- later
5 establish a high high temperature at which point you would
6 take further actions if you could not reduce the temperature
7 down. It's more of a concept than a specific value.

8 Q Now, these high containment temperatures, are these
9 the ones resulting from hydrogen combustion?

10 A There already are in the guidelines are some steps
11 for actuating containment sprays based on temperature if
12 adequate core cooling is assured. And that presently is 185
13 degrees.

14 I'm sorry, what was your --

15 Q The high temperatures in containment you are talk-
16 ing about, these would be resulting from hydrogen combustion,
17 correct?

18 A As I was getting ready to say, there already are
19 some steps in there for actuating containment sprays on high
20 temperatures, 185 degrees. And these tests are intended to
21 provide some additional guidance if necessary to the operator
22 for actuating the sprays on high temperature.

23 The -- my latest understanding of the guideline
24 is that there would be no additional steps to actuate sprays
25 above the existing temperature of 185 degrees. That is again

#3-5-SueT 1 the guideline currently, to cover other events.

2 Q Now, when the residual heat removal system is used
3 in the containment spray mode, isn't it true the suppression
4 pool cooling is greatly diminished as compared to that avail-
5 able when you have an RHR loop devoted to pool cooling?

6 A First of all, there are two systems that can provide
7 either containment spray or suppression pool cooling. The
8 RHR-A and the RHR-B.

9 So, if the other RHR system is available, it can
10 be aligned in the suppression pool cooling mode. In addition,
11 if the spray system is on line spraying, the water from the
12 suppression pool is directed through the heat exchange even
13 before it's sprayed. So, there is some pool cooling by the
14 water eventually getting back down to the suppression pool.

15 Q But if we assume that there are no RHR loops
16 devoted to pool cooling, and we have containment spray, there
17 isn't as much heat removal from the pool in the spray mode,
18 is there?

19 A That's true.

20 Q So, as decay heat is added to the pool its tempera-
21 ture will rise?

22 A That's a true statement.

23 Q So, even if the pressures resulting from hydrogen
24 burning do not directly fail the containment, if the contain-
25 ment spray is kept operating the pool cooling is effectively

#3-6-SueT 1 disabled, isn't it?

2 A I would not agree that it is effectively disabled,
3 no; in that, as I said, you are removing the water from the
4 suppression pool through the heat exchange and spraying it.
5 And the problem, even though the cooling in the heat removal
6 may be diminished, you know, the problem with the elevated
7 suppression pool temperature may be to increase the pressure
8 in the containment.

9 However, the spray would be adequate to handle any
10 pressure which may increase.

END #3 11

Walsh flws 12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Q Now, isn't it true that when you do not have an
2 RHR loop devoted to pool cooling, you do not have the mixing
3 in the pool which you would ordinarily have?

4 A (Witness Richardson) You have RHR loops in the
5 pool cooling mode?

6 Q Correct.

7 A You would not have the circulation of water and
8 the mixing that would normally occur when the loop is in the
9 pool cooling mode.

10 Q Isn't it true that most of the containment spray
11 will not reach the pool, but it will be impeded by the operating
12 floor of other structures, and floors within the plant?

13 A Well, all of the water that is sprayed in the
14 top of the containment will eventually get down to the pool.
15 Other than some small amount which may be dropped in some
16 lines or something, but that is minimal.

17 It might not arrive there in a very small drop or
18 spray or mist, but it is going to eventually get bzck down to
the pool.

20 Q Isn't it true that the reactor core isolation
21 cooling system has a maximum water temperature it can pump
22 of 140 degrees F?

23 A The 140 degrees F is a guideline provided by the
24 vendor on not allowing AC operation above that temperature,
25 because the lube oil cooler which obtains its cooling from the

1 flow of water through the system.

2 I know in a lot of plants, such as Grand Gulf,
3 I am not quite sure if the same evaluation has been done with
4 Perry, but evaluations have been done to show that that
5 operation of the RCIC system can be extended much beyond that.

6 A (Witness Holtzclaw) In addition, there has been
7 some work done recently to define what the actual capability
8 of RCIC turbines and pump systems to operate well beyond 140
9 degrees, and it has been established that those pumps can
10 operate without impairing the lube oil cooling to temperatures
11 of well in excess of 140 degree value.

12 Q Exactly what are those temperatures?

13 A I don't recall the exact numbers, but there has
14 been an estimate by some of the turbine manufacturers that
15 lube oil cooling would not be impaired for operation in excess
16 of 180 degrees F.

17 Q The high pressure core spray likewise has the
18 maximum temperature of 212 degrees F?

19 A (Witness Richardson) To my knowledge the limit
20 that you are referring to is a design limit, and it is based
21 on a very conservative nps, net positive suction head
22 calculations.

23 The system typically has much more capability
24 than that. Particularly in this event where both calculations
25 are done assuming a very hot pool with no pressurization in the

1 containment, and in this condition, if you did have some
2 pressurization, that would add to the pressure and suction
3 on the pump.

4 Q And when the water in the condenser storage
5 tank is exhausted, HPSI and RCIC take suction from the pool,
6 correct?

7 A Correct.

8 Q Does the BWR Owners Group generic emergency
9 procedure guideline establish any curves for pool water
10 temperature and operability of these various pumps?

11 A Generic guidelines have several actions taken
12 on pool temperature. I can't recollect that there is one
13 on there for operation of those systems.

14 A (Witness Holtzclaw) There is some work that
15 has been ongoing by the BWR Owners Group, looking at suppression
16 pool temperature limits, primarily to reduce the conservatisms
17 that are currently identified in things like final safety
18 analysis report, that place fairly conservative limit on
19 suppression pool temperature.

20 There is an activity that has been ongoing for
21 the last year in the BWR Owners Group. They recently submitted
22 a report to the NRC to relax some of the suppression pool
23 temperature limits.

24 I believe that there is an activity that will be
25 ongoing to best define what the actual limiting condition is

1 based on things like pump performance, and it is expected that
2 there will be a significant relaxation in suppression pool
3 temperature limit requirements.

4 As of right now, the NRC Staff is reviewing the
5 most recent Owners Group documentation to relax some of the
6 suppression pool temperature limits.

7 Q Is this work based upon calculations, or are there
8 actual tests of equipment involved there?

9 A I believe that a good deal of the work is based
10 on analysis of what the actual suppression pool temperature
11 would be in a number of scenarios.

12 I am not aware of the test support for that
13 document.

14 Q Mr. Richardson, I am handing you a document
15 dated December 22, 1982, from BWR Owners Group to Nuclear
16 Regulatory Commission, concerning a draft of the generic
17 emergency procedure guidelines.

18 Are you familiar with this document?

(Witness peruses document.)

19 A (Witness Richardson) Not familiar with this
20 actual letter that submitted these guidelines. I am generally
21 familiar with the guidelines.

22 Q Now in the caution section, are there not codes
23 concerning the net positive suction head requirements for
24 pumps taking suction from the suppression pool?
25

1 A (Pause.) The caution in the front of this
2 document provides the operator a caution on hearing NPSH
3 requirements for pumps taking suction from the suppression
4 pool.

5 This caution is in the front, and you can actually
6 see -- to actually see how it was implemented, you would have
7 to go back through the document here and see where that
8 caution is picked up.

9 Q Well, looking at these graphs, can it not mean
10 that for the residual people who are in the system, when the
11 containment pressure is 10 psig, if you get above a 248 degrees
12 F, the pumps will gravitate?

13 A According to this curve, and again, this -- I do
14 not know the basis for this curve and what plant this was
15 calculated on, the calculation has to be plant specific.

16 And these guidelines, they generally take a plant,
17 which may be a BWR-3 or 4, and they evaluate the piping of
18 that particular plant, and provide a curve which is some
19 general guidance, and that curve has to be -- if the guidance
20 provided to the specific plant from the Owners Group, that
21 has to be taken; and the actual net positive suction head
22 occurs with that plant, and for the actual installation in
23 that plant has to be developed.

24 So, this is a general curve, and this curve does
25 show that for the RHR pump, it shows a curve based on flow to

1 the pump for a given suppression pool temperature.

2 And it has the -- for the 10 psig curve, it
3 is on the order of -- it appears to be 248 or so at low flows.

4 Q So, if you are trying to take hotter water than
5 that, the pump will gravitate? Is that the basic idea of
6 these theories?

7 A Again, it depends on the -- that is the basic
8 idea of these curves. It depends, -- if you say hotter water,
9 you would have to evaluate the pressure, because the calculations
10 must also include in the pressure that exists in both the
11 pool and --

12 Q And for the curves for the low pressure core spray
13 pump, that would indicate about 245 degrees F at 10 psig would
14 be the limit?

15 A This curve that is in this document shows, as you
16 have stated, approximately 245 pre-cool temperature at 10 psig.

17 Q Do you know if this is generally applicable to
18 the BWR-6?

19 A The concept is applicable. The exact curves, I
20 would have to evaluate the actual mpsh calculations of a given
21 plant, because it depends on the routing of the pipe and the
22 head of water that exists above the suctional pump in the
23 suppression pool.

24 Q Ms. Buzzelli, are you familiar with any Perry-
25 specific curves like that?

1 A (Witness Buzzelli) I am not aware that our plant
2 specific curves have been developed as yet.

3 A (Witness Richardson) It may not have been clear
4 before when I was talking about it, but as I was saying to the
5 Board, there are limits that are placed in the guidelines for
6 suppression pool temperature where there are steps actually
7 in the guidelines to tell the operator actions to take.

8 That is different from the cautions that you are
9 asking here. This is a caution for the operator to be
10 concerned about potential for cavitation due to net positive
11 suction head requirements, and there is a distinction there.
12 To my knowledge there are not specific steps taken. There
13 are only cautions that may be in here.

14 Q Isn't it true that at Perry the reactor core
15 isolation cooling system, by-pressure core spray system,
16 low pressure core spray system, and residual heat removal
17 system take suction from areas of the pool within the safety
18 relief valve discharge quencher zone?

19 A Can you define what you mean by, 'safety relief
20 valve quencher zone?'

21 Q Well, maybe I will do this. I hand you a document,
22 a letter dated May 29, 1984, from Murray R. Edleman to Mr.
23 B. J. Youngblood, of the NRC, correct?

24 A Yes.

25 Q And it concerns a piping design review of the Perry

1 Plant?

2 A (Witness Buzzelli) It does. The subject of that
3 letter does concern a piping design review.

4 Q Now, did you employ CYGNA Energy Services to conduct
5 this piping design review?

6 A CYGNA Energy Services was the consultant utilized
7 in the piping design.

8 Q And attached to the letter is an observation record
9 which they made as a result of their review of the pipes?

10 A It was a SYGNA observation record. It describes
11 their observation, specific review item, as part of that
12 program.

13 Q Doesn't this observation state that the location
14 of HPCS, LPCI, RCIC and RHR suction strainers are within
15 the SRV discharge quencher zones?

16 A The description of the specific finding was on
17 the HPCS suppression pool suction strainer is not located
18 outside the safety relief valve discharge zone is the
19 description of one of the three findings in this observation
20 document.

21 The resolution comments indicate that the
22 observation has no impact on designer safety, and for that
23 particular item that General Electric had approved the location
24 of the suction strainers for the HPCS, high pressure core
25 spray, low pressure fuel injection, reactor core isolation

1 cooling, residual heat removal, suction strainers, and that
2 approval was based on the pump manufacturer's certification
3 on the acceptability of that configuration for the pump
4 operation.

5 Q Wasn't the approval based on the quantity of
6 ingested air that is acceptable for pump operation?

7 A The vendor certified -- the approval was based
8 on the pump vendor's certification that the quantity of
9 ingested air (40 percent maximum in 1.5 seconds) is
10 acceptable for the pump operation.

11 Q And you don't know if temperature was evaluated
12 in the disposition of this item?

13 A I cannot tell if temperature was included based
14 on this observation.

15 Q Couldn't this possibly be a misprint? Should
16 that be LPCS by any chance?

(Witness peruses document.)

17 JUDGE GLEASON: Let's identify where you are
18 referring to, if you please.

19 MS. HIATT: It is the last page of this document.
20 Observation Record Review. The paragraph small letter 'a.'
21 The sentence: General Electric approved the location of the
22 HPCS, LPCI, RCIC, and RHR.
23

24 Do you know that that should be LPCS and not
25 LPCI?

1 A That may be a typo in this document. As I
2 stated before, the original finding was focused on the high
3 pressure core spray system, and the discussion herein focuses
4 on the high pressure core spray.

5 I think the comment here is extended beyond the
6 scope of the original finding. I don't know without looking
7 further if the supporting documents are identified therein.

8 Q Well, the low pressure injection does not have
9 a separate suction strainer from RHR?

10 A (Witness Richardson) Each of the RHR systems,
11 A, B, and C, do only have one suction from the suppression
12 pool.

13 However, it is hard to tell what the author
14 intended there. He could have been referring to the C System,
15 which is only a LPCI mode, and is often referred to only as
16 LPCI as opposed to RHR.

17 Q Do you know if the low pressure core spray is
18 also -- has a suction strainer located within the SRV quencher
19 discharge zone?

20 A (Witness Buzzelli) I don't know.

21 MS. HIATT: I would like this document to be
22 marked for identification as OCRE Exhibit --

23 JUDGE GLEASON: The document will be marked as
24 OCRA Exhibit No. 14.

25 MS. HIATT: I believe that would be 15.

1 JUDGE GLEASON: 15? I am sorry, you are right.
2 It will be Exhibit No. 15.

XXX INDEX

3 (Above mentioned document
4 is marked OCRE Exhibit No. 15,
5 for identification.)

6 JUDGE GLEASON: Is there objections to its
7 admission?

8 MR. GLASSPIEGEL: I need a moment to try to check
9 to see if this appears to be the complete document. Just
10 one moment, please.

11 JUDGE GLEASON: Do you have a copy, Ms. Woodhead?

12 MS. WOODHEAD: Yes, I do. I object on the grounds
13 of relevance. I don't understand where this line of questioning
14 is going.

15 MR. GLASSPIEGEL: Mr. Chairman, first I would
16 agree with Ms. Woodhead's objection, and further, I understand
17 that this was a transmittal letter, transmitting a report that
18 was in excess of an inch thick.

(VOICE) This is the document., Harry.

20 (Document passed to Mr. Glasspiegel.)

21 MR. GLASSPIEGEL: I am holding the backup document,
22 and you can see it is rather thick.

23 So, I think there is some additional potential at
24 least for prejudice here. I am not recommending that we put
25 two inches of documentation in the record. I think the

1 better approach is that Ms. Hiatt has asked the questions she
2 wants to ask.

3 I think the record is relatively clear on which
4 portions of the letter she has asked about any my preference
5 would be not to have the document in the record.

End 4.
MS fols.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Sim 5-1

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

(Pause.)

JUDGE GLEASON: Well, whether the document is in any way inadequate as a summary, or the letter is inadequate as a summary as to what is in that document, I will let you handle on rehabilitation, and its relevancy I don't really want to argue at this point. So the objections are denied and the letter will be admitted into the record.

MR. GLASSPIEGEL: I am sorry, which exhibit number was that?

JUDGE GLEASON: 15.

MR. GLASSPIEGEL: Thank you.

(OCRE Exhibit No. 15,
previously marked for
identification, was
admitted into the record.)

(OCRE Exhibit No. 15 follows:)



P.O. BOX 5000 * CLEVELAND, OHIO 44101 * TELEPHONE (216) 622-9800 * ILLUMINATING BLDG. - 35 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

May 29, 1984
PY-CEI/NRR-0117 L

82

Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Perry Nuclear Power Plant, Units 1 & 2
Docket Nos. 50-440; 50-441
Piping Design Review

Dear Mr. Youngblood:

This letter is to provide you with a copy of the final report on the Piping Design Review program. This program was discussed with the NRC staff on March 12, 1984 and in our April 5, 1984 letter (PY-CEI/NRR-0103 L).

The piping design review program was undertaken as one element of the overall Design Verification effort. This final report consists of two parts. Part I describes the overall program, CEI's review of the consultant's (Cygnus Energy Services) observations and our evaluation of generic implications. Part II is the final report of the consultant's detailed review of selected piping systems. (Volumes 1 and 2).

Based on this combined review effort, and the resulting programs that are underway and being tracked to resolve the observations and generic concerns, CEI believes that the mechanical design adequacy at the Perry Nuclear Power Plant is assured.

We hope that this information is helpful in the development of any initiatives you may plan. If you have any questions please contact us.

Very truly yours,

M. R. Edelman for M. Edelman

Murray R. Edelman
Vice President
Nuclear Group

MRE:njc

Attachments

cc: Jay Silberg, Esq.
John Stefano
Max Gildner

8406060189 840529
PDR ADOCK 05000440
A PDR

Limited Dist

3001
1/1



Observation Record

Observation No. ME-02-03	Revision No. 0
Checklist No. ME-02 HPCS Item No. 2	Sheet 1 of 2
Originated By <i>R. W. Hux</i>	Date 12/1/83
Reviewed By <i>R. W. Hux</i>	Date 12/9/83

1.0 Description

The location and arrangement of some equipment and piping is inconsistent with General Electric and NRC Criteria. Specifically:

- The HPCS suppression pool suction strainer is not located outside the safety relief valve discharge zone.
- Valve F023 is located approximately 14 ft. from the containment penetration. It should be located as close as practical to the penetration. Normally a distance of 5 ft. or less is achievable.
- The length of straight pipe after a valve and prior to flow orifice N007 does not meet the 43 ft. requirement.

2.0 Requirement

- General Electric Specification 22A3131, Section 4.2.4.6, states that the HPCS suction strainer shall be located away from safety relief valve discharge zones.
- Both General Electric Specification 22A3131, Section 4.2.3.13 and 10CFR50 Appendix A Criterion 56 require that outside containment isolation valves, such as F023, be located as close to the containment penetration as practical.
- Per General Electric Specification 21A9505BV, Rev. 1, Section 4.3.1.1 there should be 43 ft. of straight pipe between the outlet of a valve and the inlet of the flow measuring orifice.

3.0 Reference Documents

- 3.1 Design Specification HPCS, 22A3131, Rev. 5
- 3.2 General Design Criteria, 10CFR50 Appendix A
- 3.3 Flow Orifice Assembly HPCS, 21A9505BV



Observation Record

Observation No.	ME-02-03	Revision No.	0
Checklist No.	ME-02 HPCS, Item No. 2	Sheet	2 of 2
Originated By	<i>R. W. Burr</i>	Date	12/1/83
Reviewed By	<i>L. W. Hingst</i>	Date	12/9/83

3.4 Drawings

- | | |
|---|-------------------|
| 3.4.1 HPCS Plans and Sections | D-304-701 |
| 3.4.2 HPCS Sections | D-304-702 |
| 3.4.3 HPCS Reactor Building El. 620'-6"
and 574'-10" | D-304-703 |
| 3.4.4 MSSR Piping Inside Reactor Building
El. 574'-10" and 599'-9" | D-304-026 |
| 3.4.5 Discharge Quencher | 767E676 I.C.D |
| 3.4.6 Quencher Arrangement Design Envelope | B-301-734, Rev. J |

4.0 Potential Design Impact

- The location of the HPCS suction strainer within the quencher discharge zone could cause air or steam entrainment in the HPCS pump suction line.
- The location of F023 away from the containment penetration provides a greater length of nonisolatable piping which could lead to a breach of containment if it failed.
- The accuracy of flow orifice N007 could be affected by its proximity to the valve located upstream.

5.0 Probable Cause

Design oversight and lack of documentation of design variances.

Attachments

- Observation Record Review



Observation Record Review Attachment A

Observation No. ME-02-03

Checklist No. ME-02

Revision No. 0

FR No.

Sheet 1 of 1

Yes No

Closed

X

Extent 1 of 3 Systems with nonconformance to GE Equipment arrangement requirements

Comments

Based on the following GAI and GE data and documentation, this Observation does not have any impact on design or safety.

- a. General Electric approved the location of the HPCS, LPCI, RCIC and RHR suction strainers within the SRV discharge quencher zones in Field Deviation Disposition Request No. KL1-301 approved on 6/6/83. This approval was based on the pump vendor certification that the quantity of ingested air (40% maximum in 1.5 seconds) is acceptable for pump operation.

GAI has stated, based upon their review of the piping arrangement, that due to the proximity of other piping and the valve operator size, F023 cannot be located any closer to the containment penetration.

- c. GAI has stated that the current piping arrangement will provide the 1% accuracy specified for flow element E22-FE-N007. GE concurrence with the existing piping arrangement was requested by GAI in letter PY-GAI/GEN-2931, dated 12/30/83.

Approvals

Originator R. W. Huns

Date 1/13/84

Project Engineer J. W. Wainwright

Date 1/13/84

Project Manager J. T. Witting

Date 1/16/84

CEI Representative J. G. M. M. M.

Date 1/20/84

Cleveland Electric Illuminating; 83102
Perry Nuclear Power Plant Piping Design Review

2 Q Isn't it true that with diminished pool mixing,
3 that the water drawn by these systems from the zone of the
4 safety relief valve discharge quenchers would be hotter
5 than the bulk pool temperature?

6 MR. GLASSPIEGEL: I will object on the basis
7 that I don't believe Ms. Hiatt has laid a foundation for
8 the premise.

9 JUDGE GLEASON: Let's find out where she is
10 going with it.

11 Answer the question if you can, please.

12 WITNESS BUZZELLI: It is not likely based
13 on the configuration of the safety relief discharge lines,
14 and locations of the suction strainers and the overall volume
15 of the pool.

16 BY MS. HIATT:

17 Q You do admit that there would be diminished
18 pool mixing if you did not have an RHR loop in pool cooling?

19 A (Witness Richardson) Diminished is certainly
20 relative. If you have an RHR system in pool cooling, you
21 sustain a significant amount of additional mixing with the
22 pool. However, during these events with safety relief
23 valves lifting and discharging there is a considerable
24 amount of mixing and agitation of the pool water. So
25 diminished is certainly relative.

Sim 5-3

1 Q Wouldn't the water in the vicinity of the
2 safety relief valve quencher be hotter because of the steam
3 heat addition?

4 A Typically as you discharge the water into
5 the pool the area right immediately outside the quencher
6 would be hotter than other areas of the pool.

7 To just follow up on that, if I am not mistaken,
8 the suctions of the ECCS systems are lower than the actual
9 discharge heighter of the quencher, which means they would
10 be drawing water from an area which is typically cooler.

11 Q How much lower are they?

12 A How much lower?

13 Q Yes.

14 A I don't remember the exact figure.

15 Q Have you evaluated suppression pool response
16 with both A and B RHR loops used in the containment spray
17 mode?

18 A (Witness Buzzelli) Can you repeat the question?
19 My immediate answer is no, not as part of the preliminary
20 evaluation of the hydrogen control system. If you ask me
21 is that evaluation part of our preliminary analysis of the
22 hydrogen control system, the answer is no.

23 Q Well, has General Electric performed an evalua-
24 tion generally for the Mark III of the suppression pool
25 temperature response with A and B RHR loops used in

Sim 5-4

1 containment spray?

2 A (Witness Holtzclaw) As part of the consideration
3 of the operation of the hydrogen control system, I don't
4 believe such an evaluation has been done. Typically I
5 think for design basis accident evaluations there is an
6 evaluation of suppression pool temperature.

7 Q And did that evaluation consider that one of
8 the RHR loops was used in the pool cooling?

9 A I have to admit that I am just not familiar
10 with those evaluations and I can't say for sure.

11 Q Isn't it true that at least one RHR loop must
12 be devoted to pool cooling to prevent containment over-
13 pressure from lack of steam condensation and pool surface
14 evaporation?

15 MR. GLASSPIEGEL: I am sorry. For my benefit
16 I would appreciate it if the reporter would read the question
17 back.

18 (The pending question was read by the reporter.)

19 JUDGE GLEASON: Go ahead.

20 WITNESS RICHARDSON: I am not aware of the
21 specific analysis that you are talking about, but it sounds
22 like you may be referring to considerations for design
23 basis events to assure that certain limits are maintained
24 in accordance with the design basis analysis. Such calcula-
25 tions have not been done for the degraded core event for

Sim 5-5

1 the hydrogen event where the containment pressure may get
2 to higher levels as demonstrated by the ultimate capacity
3 of the containment.

4 BY MS. HIATT:

5 Q Are you familiar with the RSMAP study of the
6 Grand Gulf plant?

7 A (Witness Richardson) I am familiar with it.

8 Q And isn't that a study of the beyond basis
9 accidents?

10 A RSMAP stands for Reactor Safety Study Management
11 Applications Program, and it was a study to extrapolate the
12 results of the reactor safety study to a more modern plant
13 such as Grand Gulf, and it is a study of events which lead
14 to severely melted cores.

15 Q Do you consider this a valid study?

16 A There are some inconsistencies and there are
17 some errors in some of the descriptions in there relative
18 to the plant design and there are some features that are
19 not accounted for because it was a simplified study. Beyond
20 that, it is a valid study.

21 Q I am handing you a document numbered NUREG
22 CR-1659, Volume IV entitled "Reactor Safety Study Methodology
23 Applications Program, Grand Gulf No. 1 BWR Power Plant" by
24 the Sandia National Laboratory.

25 I would call your attention to Page A1-11.

Sim 5-6

1 MS. WOODHEAD: Mr. Chairman -- oh, I am sorry.

2 MS. HIATT: Would you please read the first
3 sentence of this paragraph into the record.

4 MS. WOODHEAD: Mr. Chairman, I think the
5 witness has identified this document as being related only
6 to a full core melt, and I think the purpose of our hearing
7 is to discuss the hydrogen control system in the event of
8 a degraded core at the Perry plant.

9 If this document is, as Ms. Hiatt and the witness
10 have identified it, being related only to full core melt, it
11 is totally irrelevant to the purpose of this hearing, and I
12 see no point in going forward with discussions of design
13 basis accident.

14 JUDGE GLEASON: What is your response to that?

15 MS. HIATT: Well, I think there is a fine line
16 between the degraded core accident and the severe core
17 meltdown. If you do not have certain systems available such
18 as decay heat removal, you might accelerate the degraded
19 core accident into a severe core accident meltdown.

20 The specific part of this document we are
21 referring to, we are not really talking about severe core
22 accidents. We are talking about the ability of systems
23 within the BWR-6 Mark III and their performance in beyond
24 design basis accident situations. So I think it is
25 applicable.

Sim 5-7

1 JUDGE KLINE: Ms. Hiatt, the Board is concerned
2 that you appear to be beyond the requirements of the rule
3 as to hydrogen. I mean we are not clear as to where we
4 are going on the question of hydrogen control, and I guess
5 we need a little more explanation as to why this is
6 relevant.

7 MS. HIATT: The object of my questioning is
8 to determine whether or not the necessity to remove the
9 heat of hydrogen combustion from the containment atmosphere
10 will degrade the decay heat removal processes which would
11 normally be operating in the plant and thus might aggravate
12 the course of a degraded core accident.

13 JUDGE KLINE: I mean even if one granted that
14 scenario to be true, and I am not saying that it is, but
15 even so, of what relevance is it to hydrogen control?

16 The question that we have before us is the
17 ability to control hydrogen to 75 percent of the metal water
18 reaction. So even granted that the accident might progress
19 beyond that, why is it relevant to the question?

20 MS. HIATT: I think we might have to go back
21 to the rule and look at that. I think there was a statement
22 therein that the hydrogen control systems should not in
23 themselves aggravate the course of an accident. I can
24 find it, if you want.

25 JUDGE KLINE: Yes, why don't you try.

Sim 5-8

(Pause.)

MS. HIATT: In the Federal Register notice, page 3500 under the heading "Hydrogen Control Systems," it is near the bottom of the page.

"The system that is proposed and approved must safety accommodate large amounts of hydrogen and operation of the system either intentionally or inadvertently must not further aggravate the course of an accident or endanger the plant during normal operations."

That is basically what I am getting at here is whether or not the measures necessary to control the large amounts of hydrogen will perhaps inadvertently also degrade decay heat removal.

MR. GLASSPIEGEL: I would like to respond to that if I could.

JUDGE GLEASON: Wait just a minute, please.

MR. GLASSPIEGEL: Okay.

(Pause.)

(Board conferring.)

JUDGE GLEASON: Mr. Glasspiegel, we are ready for your argument.

MR. GLASSPIEGEL: Well, I have some reservations about the statutory interpretation that Ms. Hiatt is proposing without conceding any arguments about the context of the statement she is referring to. I think we should

1 just let the question in and move on.

2 JUDGE GLEASON: I do, too.

3 WITNESS RICHARDSON: Would you restate the
4 question, please?

5 BY MS. HIATT:

6 Q All right. We were on page A1-11 of the RSMAP
7 study. Would you please read this first sentence into the
8 record.

9 A (Witness Richardson) I would like to first
10 say that I am reading from a section of the document,
11 Section 2.2.5 which is entitled "Event I - Residual Heat
12 Removal." That event for these sequences that are considered
13 in this document is not included in one of the dominant
14 accident sequences that results in a failure of the contain-
15 ment or hydrogen combustion as identified in Table Figure
16 6-1 of the report.

17 And the basis for that is that they are
18 discussing long-term loss or degradation of suppression
19 pool cooling and loss of decay heat removal which is a
20 consideration in severely melted cores and severe accident
21 considerations and in risk studies where they are considering
22 other modes of failure of the containment beyond hydrogen
23 burning such as long-term decay heat removal, and that
24 is what this section describes, that particular event.

25 The specific paragraph that you have asked

Sim 5-10

1 me to read starts out "In addition to this, successful RHR
2 depends on either RHRS loop A or B operating in the
3 suppression pool cooling mode. This means that one flow
4 path from the suppression pool through a heat exchanger
5 and back to the suppression pool must be established. The
6 steam condensing mode of the RHRS was not considered for
7 LOCAs. This is due to the fact that successful operation
8 of the steam condensing mode requires RCIC system operation
9 and the RCICS will not be available long-term due to low
10 steam pressures."

11 MS. HIATT: That is enough I think.

12 BY MS. HIATT:

13 Q Do you agree with the first two sentences
14 there?

15 MR. GLASSPIEGEL: I will object to any further
16 questions. I think the witness has clearly stated that
17 this isn't relevant to the issue.

18 end Sim
19 Sue fols

19

20

21

22

23

24

25

#6-1-SueT

1 JUDGE GLEASON: She has already laid a foundation
2 for getting this question answered. Your objection is denied.

3 Answer the question.

4 WITNESS RICHARDSON: I agree with that statement
5 only in the context that it was made for this event which was
6 evaluated for an event which did not result in hydrogen burn-
7 ing in containment failure.

8 BY MS. HIATT: (Continuing)

9 Q But doesn't this section specifically talk about
10 various systems and not specific accident scenarios?

11 Isn't that what this section of the document is
12 about?

13 MR. GLASSPIEGEL: Objection.

14 JUDGE GLEASON: Objection denied.

15 WITNESS RICHARDSON: This section discusses events
16 and potential failure modes for given events. And it makes
17 some simplifying -- the study made some simplifying assumptions
18 for given events in order to simplify the risk study.

19 It did not evaluate the actual capability of the
20 system and what is really required before you get a potential
21 loss of suppression pool cooling. You have to -- you can only
22 take this section in context with the events that are being
23 considered.

24 BY MS. HIATT: (Continuing)

25 Q Mr. Richardson, what do you believe is the accident

#6-2-SueT

scenario that that specific paragraph was talking about?

A That particular paragraph is -- and I'm not looking at the document now, but Event I had to do with loss of RHR, which is an event and not a scenario. It's an event that is considered for risk studies, and it's one of several events.

And, so to answer your question, it's not a scenario.

Q And this particular event could be postulated in a number of accident scenarios; isn't that true?

A The event can be postulated in a number of scenarios, and it's important in what the event is relative to the scenario.

In that particular case, it's more concerned with long term decay heat removal, as I've stated, and containment failures from other means besides hydrogen and generation and combustion.

Q Well, don't you in any event need long term decay heat removal to maintain the core in a safe condition?

A You do need long term decay heat removal to maintain the core in a safe condition, that's true in design basis considerations as well as degraded cooling.

Q Do you know John M. Humphrey? Have you ever heard of him?

A I have heard of him and met the man.

Q He is a former General Electric engineer, correct?

A That's correct.

#6-3-SueT

1 Q And his speciality at GE was containment design,
2 correct?

3 A He was a containment -- I mean, at the time he left,
4 he was the Lead System Engineer for the containment systems.
5 I'm not sure if that qualifies him as a specialty. He may
6 have worked in other areas that I'm not aware of.

7 Q And he specifically worked on the MARK III contain-
8 ment design, didn't he?

9 A To my knowledge, yes.

10 Q Are you aware that Mr. Humphrey prepared a Discus-
11 sion Report on MARK III Containment Interface Issues?

12 A I have heard of such a report.

13 Q Have you ever seen it?

14 A No, I have not.

15 Q Has anyone here seen it?

16 A (Witness Buzzelli) I may have seen the report,
17 but I'm not familiar with details of its contents.

18 Q Do you think Mr. Humphrey is a reputable engineer?

19 A (Witness Richardson) It depends on what you mean
20 by reputable. I mean, I --

21 JUDGE GLEASON: Let's not quibble over little things.
22 You know what reputable means.

23 WITNESS RICHARDSON: He appears to be a reputable
24 engineer.

25 BY MS. HIATT: (Continuing)

#6-4-SueT

1 Q Do you think that is work is valid?

2 A (Witness Richardson) Yes.

3 Q I am handing you Page 3.3-25 of his Discussion
4 Report. Could you please read this paragraph into the re-
5 cord?

6 JUDGE GLEASON: Now, this is a Discussion Report
7 on what?

8 MS. HIATT: On MARK III Containment Interface
9 Issues.

10 JUDGE GLEASON: And is there a date on it?

11 MS. HIATT: June 30th, 1983, prepared for the U. S.
12 Nuclear Regulatory Commission, Final Report.

13 JUDGE GLEASON: All right.

14 MR. GLASSPIEGEL: Mr. Chairman, this came up in
15 the last two days, and I just have a problem if I understand
16 the Chair's rulings up until now.

17 The answers given were that the witnesses -- I
18 think Ms. Buzzelli said she was generally familiar with the
19 document but didn't know its contents. There were questions
20 about whether Mr. Humphrey was reputable, whether his -- Mr.
21 Richardson had reason to question whether his work was valid.

22 Those questions aren't really helpful to the re-
23 cord. It's well known that Mr. Humphrey has raised some
24 issues which the witnesses may agree or disagree with.

25 Now, to start reading paragraphs into the record I

#6-5-SueT

1 think is a little dangerous. If Ms. Hiatt wants to read a
2 paragraph into the record and ask the witnesses if they agree
3 or disagree with the finding, I think that's one thing. We
4 handled it that way in the past.

5 JUDGE GLEASON: Go ahead, Ms. Hiatt. You read it
6 and see if he agrees with it. I think it's much easier if
7 they read it themselves, because then they can concentrate on
8 it.

9 But if you can listen better than you can read,
10 then let her read it. Go ahead.

11 MS. HIATT: All right.

12 JUDGE GLEASON: How would you prefer to go?

13 MR. GLASSPIEGEL: I would rather go this way.

14 JUDGE GLEASON: No, I'm asking your witnesses.

15 WITNESS RICHARDSON: If I'm going to have to re-
16 spond to questions, then I am going to need the document in
17 front of me, now or later.

18 BY MS. HIATT: (Continuing)

19 Q Do you want to read this, then?

20 A (Witness Richardson) This document, which is a
21 Discussion Report on MARK III Containment Interface Issues,
22 Page 3.3-25, states: "Containment spray operation has two
23 potential effects on the suppression pool temperature re-
24 sponse. The additional head required to pump the RHR flow
25 through the spray headers at the top of the containment results

#6-6-SueT

1 in a reduced RHR flow rate and roughly a fifteen percent re-
2 duction in the RHR "K" value for suppression pool cooling.
3 Spray operation also terminates the direct RHR discharge flow
4 into the suppression pool which is designed to provide pool
5 mixing. Some of the spray will land in the suppression pool
6 and provide localized vertical pool mixing. However, most of
7 the spray will land in the upper pool or on containment floors.
8 This flow will likely find its way back to the pool via the
9 upper pool dump lines or the containment sumps and should also
10 provide some localized vertical mixing. However the net ef-
11 fect of containment spray operation is likely to be a
12 significant reduction in suppression pool mixing effective-
13 ness which will potentially result in increased suppression
14 pool stratification."

15 Q Okay. Are those true statements?

16 A I would have to take -- taking it from the begin-
17 ning, it says that "The additional head required to pump the
18 RHR flow through the spray headers at the top of the contain-
19 ment results in a reduced RHR flow rate and roughly a fifteen
20 percent reduction in the RHR "K" value for suppression pool
21 cooling." Taking that in pieces, it is true that because you
22 are pumping through a higher part of the containment, there
23 is a higher head of water and therefore this can be a lower
24 flow. Whether or not there is a fifteen percent reduction
25 in the RHR "K" value, I would have to evaluate that myself.

#6-7-SueT

1 The next part says, "Spray operation also terminates
2 the direct RHR discharge flow into the suppression pool..."
3 that portion is certainly true.

4 "...which is designed to provide pool mixing."
5 The design does facilitate pool mixing, but as I stated be-
6 fore there is considerable agitation in the pool such that
7 the reduction due to, you know, the suppression pool discharge
8 not being available, is not too significant.

9 The next sentence says, "Some of the spray will
10 land in the suppression pool and provide localized vertical
11 pool mixing." That is certainly true. "However, most of the
12 spray will land in the upper pool or on containment floors."
13 There is nothing wrong with that statement.

14 "This flow will likely find its way back to the
15 pool via the upper pool dump lines or the containment sumps
16 and should also provide some localized vertical mixing." As
17 I had said before, except for some very small amounts of water
18 which are trapped in some pockets or something, almost all
19 the water will go down because a significant amount of water --
20 you are talking on the order of 5600 gallons per minute, that's
21 a significant amount of water dropping on to the suppression
22 pool whether it's being dropped from the spray or from the
23 droplets after it has landed on some other larger equipment.

24 He mentions localized vertical mixing. That's
25 going to be occurring all the way around, and I would not

#6-8-SueT 1 necessarily agree that it's localized.

2 "However the net effect of containment spray..."
3 Moving on further, "However, the net effect of containment
4 spray operation is likely to be a significant reduction in
5 suppression pool mixing effectiveness which will potentially
6 result in increased suppression pool stratification." I
7 would take exception to the term "significant reduction."
8 As I've stated, there may be a reduction in pool mixing
9 effectiveness. I do not think it will be that significant,
10 and I also do not feel that it is pertinent to the hydrogen
11 control evaluation.

12 Q Have you personally evaluated these effects in
13 that report?

14 A I personally have not evaluated these effects it
15 discusses here. When I was at Mississippi Power and Light
16 we evaluated some of the Humphrey issues. I personally did
17 not; some of the people from my organization as well as our
18 architect engineer and General Electric worked, under my
19 direction, to evaluate some of these issues.

20 At the time we evaluated them and felt that these
21 were not significant issues.

22 Q How do you define significant?

23 A That they were second or third order effects
24 relative to the results of the analysis.

25 Q But they are real effects?

#6-9-SueT

1 A There are some effects.

2 JUDGE GLEASON: This might be a good time for us
3 to take a break.4 (Whereupon, the hearing is recessed at 10:25 a.m.,
5 to reconvene at 10:42 a.m., this same day.)6 JUDGE GLEASON: All right. I think we can go back
7 on the record, please.

8 CROSS EXAMINATION

9 BY MS. HIATT: (Continuing)

10 Q Mr. Richardson, in October of 1982, did you and Mr.
11 Sam Hobbs of Mississippi Power and Light present a paper
12 entitled "A Utility Perspective on Hydrogen Control" at the
13 Second International Conference on the Impact of Hydrogen on
14 Water Reactor Safety?

15 A May I see the paper, please?

16 Q I'm handing you a book entitled "Proceedings of the
17 Second International Conference on the Impact of Hydrogen
18 on Water Reactor Safety" designated NUREG CP-0038.

19 And the paper in question is on Page 283.

20 (The witness is looking at the document.)

21 A This paper was -- that you gave me says "A
22 Utility Perspective on Hydrogen Control" by John D. Richardson
23 and Sam H. Hobbs. Yes, it was co-authored, but Mr. Hobbs
24 presented it.

25 Q But you were responsible in some degree for it?

#6-10-SueT

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A That's true.

Q Would you please read this paragraph on Page 291 into the record?

A Reading from a paragraph on Page 291, "One of the most interesting cases studied involves the drywell break case and the resulting differential pressures between the containment and the drywell. In this case, which occurs after the core has been recovered, the drywell is inerted with a mixture of hydrogen and steam, and air is being added to the drywell atmosphere from the containment atmosphere by the purge compressors. Eventually the concentration of oxygen is sufficient to support a large burn in the drywell. Due to this burn, the pressure increases dramatically and a substantial amount of the hydrogen rich drywell atmosphere is forced into the containment through the suppression pool. There is a burn in the wetwell, but the large volume of hydrogen being forced through the suppression pool causes a substantial volume of hydrogen to be swept into the main containment atmosphere where there is a global burn. This burn causes a relatively high pressure in the containment which forces the suppression pool to depress rapidly. Simultaneously, the hot water vapor in the drywell is being condensed by the flow of water from the break location which causes a low pressure to occur in the drywell at the same time that the high pressure is occurring in the containment. The combined negative

#6-11-SueT 1 "differential pressure transient causes the violent over-
2 flow of the suppression pool into the drywell. This overflow
3 further condenses water in the drywell..."

4 MR. SILBERG: I'm sorry. Water vapor.

5 WITNESS RICHARDSON: "...water vapor in the dry-
6 well..." Let me restate that sentence.

7 "This overflow further condenses water vapor in
8 the drywell atmosphere which increases the net effect to
9 some extent. This analysis is still being finalized. Based
10 on the results, the effects of the violent pool overflow will
11 be evaluated to determine what adverse effects there are on
12 essential equipment which is needed for long term accident
13 recovery."

14 BY MS. HIATT: (Continuing)

15 Q Now, were these analyses a result of CLASIX 3
16 sensitivity studies?

17 A These analyses were a result of CLASIX 3 studies.
18 If you are referring to a specific set of studies, I would
19 have to know which ones you are talking to, in that there
20 were a number of sensitivity studies conducted.

21 These particular cases were evaluated with some
22 very conservative assumptions beyond those which were expected
23 to occur in our use in the base case CLASIX 3 analysis.

24 Q What have you done to evaluate the effects on
25 drywell equipment, components and structures from violent

#6-12-SueT 1 overflow of suppression pool?

2 A Again, this -- are you referring to Grand Gulf or
3 are you referring to Perry?

4 Q Well, either one. Have you done any evaluations
5 of the effects?

6 A Yes. As you see, this said that this analysis is
7 still being finalized. And as I stated this was a very con-
8 servative analysis beyond the base case, those conditions
9 which existed -- which are considered to exist or will exist
10 in a postulated case.

11 And MP&L did evaluate the potential consequences
12 and found that there were no adverse consequences for this
13 reference here.

14 And, as you can see in the Perry case, the dif-
15 ferential pressures that are shown in the preliminary evalua-
16 tion in Appendix A -- if you like, I will give you a figure --

17 Q Well, why don't I stop --

18 A -- a significant figure, less than the design
19 basis case.

20 Q -- you right here. The studies referred to in
21 your paper are not -- you are not using the same conditions
22 as were postulated in the Appendix A preliminary evaluation,
23 correct?

24 A That's correct.

25 Q All right.

#6-13-SueT 1

A These studies here were done -- some studies were done by Mississippi Power and Light to evaluate more conservative assumptions.

MR. GLASSPIEGEL: Ms. Hiatt, your question wasn't limited to Grand Gulf, and I would like to let the witness if he wants to finish the statement that he was interrupted.

JUDGE GLEASON: It's up to Ms. Hiatt.

MR. GLASSPIEGEL: Well, she cut him off.

JUDGE GLEASON: She is entitled to cut him off. If she wants to stop him, he has to ask if he can amplify the statement.

WITNESS RICHARDSON: May I amplify the statement that I was making?

MS. HIATT: I think you can cover it on redirect, Mr. Glasspiegel.

BY MS. HIATT: (Continuing)

Q Wouldn't you be worried about recirculation pumps piping, any control rod drive piping, perhaps the reactor pressure vessel being impacted by water or suffering thermal shock perhaps leading to breakage resulting from this violent overflow of the suppression pool?

A No.

Q You wouldn't?

A Is that a question?

Q Yes. You wouldn't be?

#6-14-SueT

1 A No, I would not.

2 Q You have specifically evaluated those effects?

3 A We have evaluated the differential pressures in
4 the preliminary evaluation, and they have been shown to be
5 less than the differential pressures in the design basis case.

6 And the design basis case evaluates the potential
7 consequences of any reverse or falling pool flow.

8 Q Okay. This preliminary evaluation you are talking
9 about, is that the preliminary analysis that has been designat-
10 ed Applicants' Exhibit 8-1?

11 Is that what you are talking about?

12 A I don't remember the exact exhibit number.

13 Q But that's what you are talking about?

14 A Yes, that's what I'm talking about.

15 Q Mr. Richardson, does the Hydrogen Control Owners'
16 Group have a program plan for solving the hydrogen control
17 issue?

18 A Yes, it does.

19 Q And isn't it true that Task 10 of that plan is
20 entitled "Evaluation of Drywell Response to Degraded Core
21 Accidents?"

22 A I have to look at the plan that you are referenc-
23 ing to see if that's the exact task.

24 There is a task for evaluating drywell response.
25 I don't remember if that's the exact task, though.

#6-15-SueT 1

2 MS. WOODHEAD: Mr. Chairman, could I ask if we
3 are getting into the final analysis required of the Owners'
4 Group which is not the subject of this hearing?

5 JUDGE GLEASON: I think you have already asked
6 that, Ms. Woodhead.

7 MS. WOODHEAD: Pardon?

8 JUDGE GLEASON: I think you have asked it.

9 (Laughter.)

10 MS. WOODHEAD: May I have an answer?

11 JUDGE GLEASON: Ms. Hiatt?

12 MS. HIATT: Well, I think it is an undetermined
13 question of law as to what constitutes an appropriate pre-
14 liminary analysis and what can be left to a final analysis.
15 I don't think that has been determined.

16 JUDGE GLEASON: So the answer is maybe yes and
17 maybe no.

18 MS. WOODHEAD: I believe Ms. Hiatt is objecting
19 to the scope of this hearing. It's well defined by the
20 Applicant as to what its definition of preliminary analysis
21 is, because --

22 JUDGE GLEASON: Well, he has one definition.

23 MS. WOODHEAD: Well, we have it before us.

24 JUDGE GLEASON: And the Staff has a definition.

25 MS. WOODHEAD: That's correct. We also have --

JUDGE GLEASON: I gather that the Intervenor may

#6-16-SueT

1 not agree with that. She is entitled to pursue it. I made
2 comment on this earlier, a day or so ago, as to where we
3 stand -- where this procedure stands with respect to that
4 ruling.

5 And so she is entitled to pursue as to what should
6 be contained in the preliminary analysis. And that is what
7 she is doing, if I understand it correctly.

8 MR. GLASSPIEGEL: Mr. Chairman, I don't want my
9 silence to be misinterpreted.

10 JUDGE GLEASON: You are never misinterpreted.

11 (Laughter.)

12 MR. GLASSPIEGEL: I'm not arguing with the Chair.
13 I want to be on record as saying that if we -- if Ms. Hiatt
14 attempts to get into a detailed cross-examination on matters
15 that are covered by the final analysis, matters that are not
16 completed, then I would agree with Ms. Woodhead that that
17 is outside the scope of the hearing. The rule does specifi-
18 cally say that the final analysis --

19 JUDGE GLEASON: I don't think that that is what
20 Ms. Woodhead said. I think she said -- her question was in
21 the area of final analysis. And Ms. Hiatt doesn't necessarily
22 agree with that.

23 So, proceed, Ms. Hiatt.

24 MS. HIATT: Thank you.

25 JUDGE GLEASON: All right.

1 BY MS. HIATT: (Continuing)

2 Q I am handing you a document that I believe pertains
3 to the Perry plant.

4 (Witness peruses document.)

5 A (Witness Richardson) This does appear to plan

6 --

7 JUDGE GLEASON: Mr. Richardson, we have a hard
8 time hearing you at times. I know the reporters are having
9 a hard time. You will have to speak up just a little louder,
10 please.

11 WITNESS RICHARDSON: This does appear to be the
12 program as updated.

13 BY MS. HIATT: (Continuing)

14 Q And does does include the Task 10 series of
15 drywall type of introductions.

16 A (Witness Richardson) Task 10 is an evaluation
17 of drywall response to degraded core accidents. It is a
18 further evaluation for the long term programming. The drywall
19 response had already been evaluated in a preliminary evaluation.

20 This is to evaluate additional questions and some
21 long term issues.

22 Q Section 10.21 is entitled Evaluate Potential for
23 Pool Swell Loading From Hydrogen Combustion.

24 A That is correct. I would like to state that this
25 document is very comprehensive in an integrated program which

1 includes a task for generic long term hydrogen control program
2 as well as task that may have been completed for even specific
3 utilities, and it is placed it there to account for any possible
4 task which may be necessary for all the owners.

5 This task is, as I stated, mainly potential for
6 pool swell loading -- potential for pool swell loading from
7 hydrogen combustion, which is a consideration that has been
8 evaluated in the case of preliminary evaluation for Perry
9 Nuclear Power Plant.

10 Q Would you read this section into the record,
11 starting right there?

12 (Pointing)

13 A I am reading from page 4-119 of the Task 10-21,
14 and the section I have been asked to read starts out: An
15 immediate and large deflagration in the wetwell could produce
16 a large containment to drywell differential pressure. This
17 pressure may result in forcing a jet of water from the area
18 between the drywell wall and weir wall upward into the drywell.
19 With sufficient velocity, this jet of water may produce loads
20 on structures or affect safety related equipment above the
21 weir area. The possibility for occurrence of this negative
22 pool swell will be investigated.

23 Q Isn't the present status of this part that it
24 hasn't even been started yet?

25 A You have to understand the basis for this document.

1 In referring to this statement in this document, that is
2 dependent on -- it is stated that way because it is a generic
3 task. It is made that way to encompass all of the owner groups,
4 since it is a generic program.

5 The standpoint of Perry Nuclear Power Plant, the
6 preliminary evaluation, we have evaluated the differential
7 pressures that result from the case we studied, and those
8 differential pressures were less than the design basis case.

9 In the long term program, if there are any other
10 issues that because of further analysis which arise and could
11 impact that consideration, we would evaluate that further. That
12 is why that task is stated that way.

13 Q Now, the cases studied in the preliminary analysis
14 are not the same cases that -- case we do to this concern,
15 correct?

16 A I would not agree with that statement. The drywell
17 brake case studied in the preliminary evaluation is the case
18 that is of concern.

19 Q But don't you assume some different parameters to
20 -- in the paper that you presented at the International
21 Conference on Impact of Hydrogen, didn't you say this is
22 considered different considerations from the cases studied in
23 the preliminary evaluation?

24 A I stated that the assumptions that were made in
25 the analysis that were referenced on my paper and the proceedings

1 on the second national conference were different than the
2 base case. They were conservative assumptions made beyond
3 the assumptions that are made in the base case, and the
4 assumptions made in the base case were those which are assumed
5 to exist, and are conservative.

6 Q And the Perry Preliminary Evaluation evaluated
7 the base case, correct?

8 A The Perry -- events analyzed in the Perry
9 Preliminary Evaluation are the base case assumptions which
10 are conservative for the events being analyzed.

11 Q Now, your analyses assumed that hydrogen is
12 released to the wetwell through the suppression pool, correct?

13 A That is correct.

14 Q And for a small break LOCA in the drywell, the
15 hydrogen would first be released to the drywell, correct?

16 Q Initially it would be released directly to the
17 drywell.

18 JUDGE GLEASON: You are talking about Perry now?

19 MS. HIATT: Yes.

20 JUDGE GLEASON: All right.

21 BY MS. HIATT: (Continuing)

22 A (Continuing) After a certain period of time,
23 however, half will be going to the drywell, as far as the
24 analysis is concerned. Half would be going through the
25 drywell and half would be going through the suppression pool

1 via the safety release valves.

2 Q And you are also assuming that steam and hydrogen
3 pressurization along with the operation of the drywell purged
4 compressors will pressurize the drywell such that the first
5 row of LOCA events is uncovered, and the hydrogen within the
6 drywell would then bubble out through the pool?

7 A That is true.

8 Q Now, there are two trains of drywell
9 compressors with a capacity of 546 standard cubic feet per
10 minute?

11 A There are two trains graded at approximately
12 500 cubic feet per minute.

13 Q Now, according to Table 5.4-2 of your preliminary
analysis, isn't the maximum allowable drywell leakage 5,843
standard cubic feet per minute, at 2.5 psig?

14 A Is that table 5.4-2?

15 Q Yes.

16 A Would you restate the value you gave?

17 Q 5,843 standard cubic feet per minute, at 2.5 psig.

18 A This table gives -- commonly called the capability
19 of the design value for allowable leak rate that was used in
20 design basis analysis.

21 That is the maximum allowable for design basis
22 analysis, and it is not necessarily what will occur or what
23 it is tested for.
24
25

1 Q So, does that correspond to the drywell leakage
2 pool area of 1.68 square feet?

3 A It does not state here what the basis for that
4 number is. A over root K for Perry is 1.68, to my knowledge.

5 Q You don't know if that leak rate in cubic feet
6 per minute corresponds to that specific area?

7 A I would have to review the FSAR discussion to
8 see if that value is derived from that, A over root K.

9 Q Would you happen to know that, Ms. Buzzelli?

10 A (Witness Buzzelli) I don't know if that is the
11 exact number for that 1.68 design allowable test.

12 Q Well, let me ask this: Would this number
13 correspond to the 1.68 rather than the .168?

14 A That would be correct.

15 Q Now, isn't the figure in this table over five
16 times capacity of both drywell purged compressors?

17 A (Witness Richardson) This figure here is over five
18 times capacity.

19 Q So, it is possible the hydrogen may leak out to the
20 drywell wall rather than flowing through the pool?

21 A Given -- as I said, the value here is for design
22 purposes, and it is not anticipated that that will be the
23 actual leakage, and if you have leakage through the drywell
24 wall then hydrogen could go through the drywell wall.

25 Q Now, the tech spec allowable, wouldn't that be about

1 one-tenth of the figure given here?

2 A Tech spec allowable is typically ten percent.

3 Q So, you wouldn't have to do anything about the
4 leakage until it approached that number, correct? Under the
5 technical specifications?

6 MR. GLASSPIEGEL: Are we still talking about
7 5,843?

8 MS. HIATT: Well, we would be talking about ten
9 percent of that for the tech spec allowable, I believe. He
10 can confirm my conclusions.

11 WITNESS RICHARDSON: The technical specifications
12 requires that you periodically test drywell for leakage, and
13 that value is typically, as I stated, ten percent of the
14 capability, and you are not required for tech specs to take
15 any action if the leakage is less than the tech spec allowable.

16 BY MS. HIATT: (Continuing)

17 Q At what pressures do you periodically test the
18 drywell for leakage?

19 A (Witness Richardson) I would have to look at the
20 technical specifications to see the exact pressure in that.
21 Some of those values may vary from plant-to-plant, and I don't
22 remember what the exact value is in the case of Perry.

23 It is on the order of approximately three pounds.

24 Q Now, if hydrogen were to leak out through the
25 drywell wall, wouldn't that change the transport and combustion

1 characteristics in containment?

2 A No.

3 Q It would not?

4 A No. It would not change the combustion that is
5 analyzed in the preliminary evaluation.

6 Q Wouldn't it change the concentrations of hydrogen
7 in certain compartments as a function of time?

8 A There may be some changes in the concentrations.
9 However, the overall effect would -- it would not change the
10 conclusions.

11 Q Have you evaluated the effect?

12 A No.

13 Q Do you plan to include any drywell leakings in
14 any experimental studies, such as the quarter scale facility?

15 A No.

16 A (Witness Buzzelli) I would like to add that the
17 drywell bypass leakage concern is being dealt with in the long
18 term program as part of the hydrogen control owners group
19 program plan, so it is not specifically just an experimental
20 test.

21 JUDGE KLINE: Could we clarify right here as to
22 whether these assumptions -- of whether this discussion is
23 under the assumption that the hydrogen control system is
24 functioning or not functioning?

25 MS. HIATT: My assumptions were that the system

1 is functioning, and the concern about the bypass leakage is
2 -- hasn't been analyzed versus their analysis, which it seems
3 it is all released through the pool into the bottom of the
4 wetwell.

5 JUDGE KLINE: But it matters whether -- I mean it
6 matters as to the amount of hydrogen being transported whether
7 the system is functioning or not, doesn't it?

8 MS. HIATT: I am not an expert witness.

9 JUDGE KLINE: All I want to know is what the
10 assumption is. Is the igniter system working or not working
11 as we trace the pathways of hydrogen through the system?

12 MS. HIATT: My assumption was that things are
13 functioning. The igniter system is functioning.

14 JUDGE KLINE: That is all we need to know.

15 BY MS. HIATT: (Continuing)

16 Q Ms. Buzzelli, at page 6 of the preliminary analysis,
17 it is stated that the spray shields are provided for igniters
18 assemblies in areas where they may be exposed to containment
19 sprays, is that correct?

20 A (Witness Buzzelli) That is correct.

21 Q Does that mean that some igniter assemblies do
22 not have spray shields?

23 A This statement is intended to convey that spray
24 shields are provided to protect the igniters against contain-
25 ment sprays.

1 Most all of our locations are such that the spray
2 shield is installed on the igniters. I can't think of a
3 specific example where the spray shield is not included.

4 Q Case 8 of the preliminary analysis there is a
5 discussion of igniter locations in the drywell taking full
6 advantage of existing steel as protection against jet impinge-
7 ment.

8 Could you describe just how such assemblies are
9 placed so that they are protected by existing steel?

10 A The locations are selected to take advantage,
11 as the statement indicates, of existing steel. We postulate
12 a pipe break, the jet impingement load is the direct steam
13 jet from that pipe break. If the igniter is located with
14 an intervening structural steel member it is protected from
15 that jet impingement load.

16 You look at the code of that jet from your jet
17 impingement studies, and locate the igniters accordingly.

18 Q So you would be postulating specific pipe breaks
19 in drywell for your jet impingement studies, is that it?

20 A (Witness Richardson) For the design basis
21 accidents, there are certain type break locations postulated,
22 and the jet code is analyzed for safety-related equipment.

23 Q Isn't it true that many of the igniter assemblies
24 are located close to ceilings or under other obstructions?

25 A There are some igniters located on the ceilings.

1 You said near obstructions?

2 Q Under.

3 A Under obstructions.

4 Q Aren't more of them under such conditions?

5 A I haven't taken a count. I would have to evaluate
6 whether there was more.

7 Q Less?

8 A There are many igniters in open areas.

9 I don't know what the split is. I would have to count them.

10 A (Witness Buzzelli) The igniters are located
11 in areas where hydrogen may potentially accumulate, and in
12 an enclosed or ceiling area, you would have -- such as a steam
13 tunnel -- you would have igniters under there, so that as the
14 hydrogen mixed into that region, we would have ignition at
15 low concentrations.

16 Q I am handing you a document entitled Perry Nuclear
17 Plant, Units-1 and 2, Interim Report on the Hydrogen Control
18 System, a draft document.

19 Specifically pertaining to Table 2.2-1 on Igniter
20 locations. Have you seen this before?

21 A Yes. This is a portion of an early draft report
22 on the hydrogen control system, which identified preliminary
23 igniter locations throughout the containment and drywell.
24 Noted specific igniter number, its elevation, relative location
25 in containment, and a description of the location.

1 This document, entitled Interim Report -- it is
2 actually superseded by the preliminary evaluation which has
3 been marked Applicants Exhibit 8-1.

4 Q Are most of the igniter locations in this table
5 similar or identical to those in the preliminary analysis?

6 A As I stated, the preliminary analysis supersedes
7 this listing on this early draft report.

8 JUDGE GLEASON: That is not her question. That
9 is not her question. She is saying are they identical?
10 Are they both the same?

11 WITNESS BUZZELLI: The answer is, no. The
12 actual locations are superseded --

13 JUDGE GLEASON: I know they are superseded, but
14 are they different? Are they different?

15 WITNESS BUZZELLI: They are different. I don't
16 know that they are all different. Many are different.
17 Preliminary spotting locations for the igniters, the finalized
18 as-built construction is requested in the preliminary evaluation.

19 BY MS. HIATT: (Continuing)

20 Q So, your preliminary evaluation does not include
21 the location description that is given herein, does it?

22 A (Witness Buzzelli) No, it is -- a description
23 is provided through the drawings included in preliminary
24 evaluations, which located the igniters more representatively
25 than to say inside face of drywell. A more accurate

1 representation is provided by the drawings in the preliminary
2 evaluation.

3 Q Isn't it a little hard to tell from those
4 drawings whether you are on the underside of a support ring
5 for a crane, for example?

6 A Preliminary evaluation has both drawings and a
7 listing with the elevation and azimuth of the igniters. The
8 reproductions may be difficult to read, but the drawings
9 themselves give you a more accurate representation of the
10 relative location of the igniter adjacent equipment and
11 major supporting structures.

12 End 7.
13 MS fols.
14
15
16
17
18
19
20
21
22
23
24
25

Sim 8-1

1 Q Wouldn't it be true to say that the locations
2 and location descriptions given in this document are not
3 significantly different for the most part from the locations
4 in the preliminary analysis?

5 A (Witness Buzzelli) I would have to say that in
6 some cases, and perhaps in many cases they are significantly
7 different than the preliminary -- the very early draft listing
8 you are referring to.

9 JUDGE GLEASON: She has already testified
10 that they are substantially different.

11 BY MS. HIATT:

12 Q Now you can tell from the specific location
13 dimensions given whether or not these are similar to or
14 identical to those within the preliminary analysis, correct?

15 A (Witness Buzzelli) Can you repeat that question?
16 I am not sure I understood what you were asking.

17 Q You could tell, couldn't you, from the specific
18 location dimensions given for elevation, dimensions of
19 containment asmuth, whether or not these locations for these
20 igniter numbers are the same or different from those given
21 in the preliminary analysis?

22 A One could do a comparison of that listing to
23 the listing and drawings in the preliminary evaluation and
24 ascertain exactly which igniters have changed.

25 Q I would ask that this document be marked for

Sim 8-2

1 identification as OCRE Exhibit 16.

2 JUDGE GLEASON: This will be designated as OCRE
3 Exhibit 16, and is there objection for its admission?

4 MR. GLASSPIEGEL: Yes, absolutely. The witnesses
5 have testified that this is not a current description of
6 locations. Ms. Buzzelli has testified that there are
7 substantial differences. She has testified there are two
8 ways in the preliminary evaluation to determine more precisely
9 whether igniters are adjacent to structures, and I would
10 object to putting that document in the record for those
11 reasons.

12 JUDGE GLEASON: Ms. Woodhead, do you have any
13 objection?

14 MS. WOODHEAD: I object for the same reason.
15 It doesn't reflect the as-built plan.

16 JUDGE GLEASON: Ms. Hiatt, what is the purpose
17 of putting it in?

18 MS. HIATT: I think it gives a better idea of
19 just how these igniter assemblies are located in the plant,
20 than does the preliminary analysis, and for reasons that will
21 be apparent later, the location of the igniters is important.

22 I agree that they may not all be identical ---

23 JUDGE GLEASON: You don't have to say anything
24 more than that.

25 The objection is denied and the exhibit will

Sim 8-3

1 be admitted into the record.

2 (The document referred to
3 was marked OCRE Exhibit
4 No. 16 for identification
5 and admitted into the record.)

INDEX

6 JUDGE GLEASON: Could we have a date? Is there
7 a date for this interim report?

8 MR. GLASSPIEGEL: Did I get a copy, Ms. Hiatt?

9 Excuse me. I don't have a copy, Mr. Chairman.

10 (Pause.)

11 JUDGE GLEASON: Do you have a date of this?

12 MS. HIATT: I am not sure I ever saw a date
13 appearing on it. They might know better than I do.

14 JUDGE GLEASON: Does anybody have a date?

15 WITNESS BUZZELLI: I don't have a date for this
16 document. It was a draft document.

17 MR. GLASSPIEGEL: I don't have a copy, Mr. Chairman.

18 (A copy was provided by Judge Gleason to
19 Counsel Glasspiegel.)

20 JUDGE GLEASON: All right, let's proceed, please.

21 MR. GLASSPIEGEL: Mr. Chairman, may I inquire
22 of the Chair. Is Ms. Hiatt to be permitted to ask questions
23 for the record about the location of the matters using the
24 document that has just been admitted?

25 JUDGE GLEASON: Yes, sir.

(OCRE Exhibit No. 16 follows:)

INDEX

OCRE #16 w/19

NUCLEAR REGULATORY COMMISSION

Docket No. 50-440 Official Enb. No. 50-1-6 4410

In the matter of _____

Staff _____ IDENTIFIED _____

Applicant _____ RECEIVED _____

Intervenor _____ REJECTED _____

Going Date _____

Contractor _____ DATE 5 2 8 5

Witness _____

Reporter _____

PERRY NUCLEAR POWER PLANT
UNITS 1 & 2

51 91

INTERIM REPORT ON THE
HYDROGEN CONTROL SYSTEM

DRAFT

DOCKET NUMBERS
50-440, 50-441

1 = change from Robin

Table 2.2-1
Igniter Locations

	IGNITER #	ELEVATION	AZIMUTH	DIMENSION TO OF CONTAINMENT	SUPPORTING MEMBER	REFERENCE DRAWING #	LOCATION DESCRIPTION	
✓	312	01	592'-0"	1°	33'-0"	Concrete	E-002-002	Inside face of weir wall
	311	02	592'-0"	52°	33'-0"	Concrete	E-002-002	Inside face of weir wall
✓	311	03	591'-9"	104°	33'-0"	Concrete	E-002-002	Inside face of weir wall
	311	04	591'-9"	148°-30'	33'-0"	Concrete	E-002-002	Inside face of weir wall
	312	05	592'-0"	208°	33'-0"	Concrete	E-002-002	Inside face of weir wall
	312	06	592'-0"	260°	33'-0"	Concrete	E-002-002	Inside face of weir wall
✓	312	07	591'-6"	310°-15'	33'-0"	Concrete	E-002-002	Inside face of weir wall
✓	331	08	629'-6"	7°	36'-6"	Concrete	D-411-137	Inside face of drywell wall
✓	331	09	632'-6"	41°-30'	41'-6"	Concrete	D-411-137	Inside face of drywell wall
	331	10	632'-6"	87°-30'	36'-6"	Concrete	D-411-137	Inside face of drywell wall
	331	11	630'-7"	137°	36'-6"	Concrete	D-411-137	Inside face of drywell wall
	332	12	630'-7"	182°	36'-6"	Concrete	D-411-137	Inside face of drywell wall
	332	13	630'-7"	221°	36'-6"	Concrete	D-411-137	Inside face of drywell wall
	332	14	630'-7"	273°	36'-6"	Concrete	D-411-137	Inside face of drywell wall
	332	15	630'-7"	320°	36'-6"	Concrete	D-411-137	Inside face of drywell wall
	352	16	660'-7"	0°	30'-0"	Concrete	D-411-137	Inside face drywell top slab
✓	351	17	659'-9"	57°	35'-0"	Concrete	D-411-137	Inside face drywell top slab
	351	18	660'-7"	114°	30'-0"	Concrete	D-411-137	Inside face drywell top slab

	IGNITER #	ELEVATION	AZIMUTH	DIMENSION TO OF CONTAINMENT	SUPPORTING MEMBER	REFERENCE DRAWING #	LOCATION DESCRIPTION
351	19	660'-7"	171°	30'-0"	concrete	D-411-137	Inside face drywell top slab
352	20	660'-7"	228°	30'-0"	concrete	D-411-137	Inside face drywell top slab
352	21	660'-7"	280°	30'-0"	concrete	D-411-137	Inside face drywell top slab
352	22	660'-7"	320°	30'-0"	concrete	D-411-137	Inside face drywell top slab
321	23	624'-6"	54°	57'-0"	Beam "A"	D-511-023	Inside face drywell top slab
321	24	624'-6"	89°	57'-6"	Beam "A"	D-511-023	HCU floor
321	25	624'-6"	121°-30'	57'-6"	Beam "A"	D-511-023	HCU floor
321	26	624'-6"	161°-30'	50'-6"	Beam "A"	D-511-023	HCU floor
322	27	624'-6"	194°	57'-0"	Beam "A"	D-511-022	HCU floor
322	28	624'-6"	234°	57'-0"	Beam "A"	D-511-022	HCU floor
322	29	624'-6"	271°	57'-0"	Beam "A"	D-511-022	HCU floor
322	30	624'-6"	324°	57'-0"	Beam "A"	D-511-022	HCU floor
332	31	637'-0"	0°	41'-6"	Concrete	D-411-141	Outside surface of drywell wall steam tunnel room
331	32	641'-0"	151°	43'-6"	Concrete	D-411-214	Underside of floor slab for refueling pool
332	33	641'-0"	185°	43'-6"	Concrete	D-411-214	Underside of floor slab for refueling pool
332	34	640'-0"	324°	50'-6"	W16x100	D-511-861	I beam below grating at 640'-0"
331	35	642'-0"	60°	51'-0"	W16x100	D-511-062	I beam below grating at 642'-0"
331	36	642'-0"	117°	52'-6"	W16x50	D-511-062	I beam below grating at 642'-0"

	IGNITER #	ELEVATION	AZIMUTH	DIMENSION TO OF CONTAINMENT	SUPPORTING MEMBER	REFERENCE DRAWING #	LOCATION DESCRIPTION
/ 332	37	640'-0"	227°-15'	50'-6"	W16x100	D-511-061	I beam below grating at 642'-0"
332	38	642'-0"	261°	55'-0"	W30x211	D-511-026	I beam below grating at 642'-0"
/ 342	39	650'-9"	286°-30'	41'-6"	Concrete	D-411-141	Outside surface drywell wall
342	40	648'-2"	0°	51'-0"	Concrete	D-411-141	Ceiling of steam tunnel
341	41	652'-2"	42°	50'-6"	W16x100	D-511-026	I beam below grating at 652'2"
/ 341	42	651'-3"	89°	50'-5"	Concrete	D-411-214	Room ceiling
/ 341	43	651'-8"	103°	49'-0"	Concrete	D-411-214	Room ceiling
/ 351	44	660'-3"	82°	48'-6"	Concrete	D-411-217	Room ceiling
/ 351	45	660'-3"	100°	48'-6"	Concrete	D-411-217	Room ceiling
/ 351	46	662'-4"	54°	54'-0"	W14x257	D-511-028	I beam below grating at 664'-7"
/ 351	47	665'-0"	112°	56'-0"	Concrete	D-411-221	Outside wall of room
351	48	664'-7"	147°	53'-0"	W12x30	D-511-028	I beam below grating at 664'-7"
352	49	664'-7"	218°	51'-6"	W21x111	D-511-027	I beam below grating at 664'-7"
/ 352	50	664'-7"	251°	50'-2"	W14x193	D-511-027	I beam below grating at 664'-7"
/ 352	51	661'-10"	289°	49'-6"	W21x111	D-511-027	I beam below grating at 664'-7"
/ 352	52	661'-10"	324°	50'-6"	W21x111	D-511-027	I beam below grating at 664'-7"
/ 362	53	669'-6"	0°	55'-0"	Concrete	D-411-214	Room wall
/ 362	54	684'-9"	355°	52'-6"	Concrete	D-511-315 D-411-214	Room ceiling
361	55	686'-0"	75°	48'-0"	Concrete	D-411-221	Room ceiling

	IGNITER #	ELEVATION	AZIMUTH	DIMENSION TO OF CONTAINMENT	SUPPORTING MEMBER	REFERENCE DRAWING #	LOCATION DESCRIPTION
361	56	686'-0"	85°	47'-0"	Concrete	D-411-221	Room ceiling
361	57	686'-0"	95°	47'-0"	Concrete	D-411-221	Room ceiling
361	58	686'-0"	105°	48'-0"	Concrete	D-411-221	Room ceiling
361	59	686'-0"	75°	35'-0"	Concrete	D-411-221	Room ceiling
361	60	686'-0"	105°	35'-0"	Concrete	D-411-221	Room ceiling
361	61	689'-6"	45°	48'-0"	W30x132	D-511-025	I beam below grating at 689'-6"
361	62	689'-6"	133°-15'	41'-0"	W8x24	D-511-025	I beam below grating at 689'-6"
362	63	685'-3"	229°	48'-0"	W36x150	D-511-024	I beam below grating at 689'-6"
362	64	689'-10"	252°	43'-6"	W21x62	D-511-024	I beam below grating at 689'-6"
362	65	689'-10"	289°	43'-0"	W21x62	D-511-024	I beam below grating at 689'-6"
362	66	689'-5"	311°	48'-6"	W36x150	D-511-024	I beam below grating at 689'-6"
666	67	715'-6"	358°-51'	58'-9"	Steel	E-002-002	Underside of support ring for crane
666	68	715'-6"	27°-8'	58'-9"	Steel	E-002-002	Underside of support ring for crane
666	69	715'-6"	61°-47'	58'-9"	Steel	E-002-002	Underside of support ring for crane
666	70	715'-6"	87°-32'	58'-9"	Steel	E-002-002	Underside of support ring for crane
666	71	715'-6"	119°-27'	58'-9"	Steel	E-002-002	Underside of support ring for crane
666	72	715'-6"	150°-33'	58'-9"	Steel	E-002-002	Underside of support ring for crane

	IGNITER #	ELEVATION	AZIMUTH	DIMENSION TO OF CONTAINMENT	SUPPORTING MEMBER	REFERENCE DRAWING #	LOCATION DESCRIPTION
/ 666	73	715'-6"	178°-46'	58'-9"	Steel	E-002-002	Underside of support ring for crane
/ 666	74	715'-6"	209°-27'	58'-9"	Steel	E-002-002	Underside of support ring for crane
/ 666	75	715'-6"	240°-35'	58'-9"	Steel	E-002-002	Underside of support ring for crane
/ 666	76	715'-6"	267°-3'	58'-9"	Steel	E-002-002	Underside of support ring for crane
/ 666	77	715'-6"	300°-26'	58'-9"	Steel	E-002-002	Underside of support ring for crane
/ 666	78	715'-6"	331°-38'	58'-9"	Steel	E-002-002	Underside of support ring for crane
666	79	745'-6"	0°	48'-0"	Steel	E-002-002	Containment vessel
/ 666	80	745'-6"	34°	48'-0"	Steel	E-002-002	Containment vessel
666	81	745'-6"	72°	48'-0"	Steel	E-002-002	Containment vessel
/ 666	82	745'-6"	102°	48'-0"	Steel	E-002-002	Containment vessel
/ 666	83	745'-6"	143°	48'-0"	Steel	E-002-002	Containment vessel
666	84	745'-6"	180°	48'-0"	Steel	E-002-002	Containment vessel
666	85	745'-6"	216°	48'-0"	Steel	E-002-002	Containment vessel
666	86	745'-6"	252°	48'-0"	Steel	E-002-002	Containment vessel
/ 666	87	745'-6"	287°	48'-0"	Steel	E-002-002	Containment vessel
666	88	745'-6"	324°	48'-0"	Steel	E-002-002	Containment vessel
666	89	757'-0"	0°	1'-0"	Steel	E-002-002	Containment vessel
666	90	757'-0"	180°	1'-0"	Steel	E-002-002	Containment vessel
670	91	647'-0"	166°	59'-0"	Concrete	D-411-211	Room ceiling

	IGNITER #	ELEVATION	AZIMUTH	DIMENSION TO OF CONTAINMENT	SUPPORTING MEMBER	REFERENCE DRAWING #	LOCATION DESCRIPTION
670	92	645'-0"	172°	58'-0"	Concrete	D-411-211	Room wall
321	93	613'-4"	6°	44'-0"	Concrete	D-411-140	Room ceiling
321	94	613'-4"	13°	43'-6"	Concrete	D-411-140	Room ceiling
322	95	613'-4"	347°	43'-6"	Concrete	D-411-140	Room ceiling
322	96	613'-4"	354°	44'-0"	Concrete	D-411-140	Room ceiling
322	97	642'-0"	289°	50'-6"	W30x211	D-511-026	I beam below grating at 642'-0"
362	98	685'-6"	342°	53'-0"	Concrete	D-511-315	Room ceiling inside jet shield
361	99	685'-6"	17°	53'-0"	Concrete	D-511-315	Room ceiling inside jet shield
	100	686'-0"	75°	25'-0"	Concrete	D-411-221	Room ceiling
	101	686'-0"	105°	25'-0"	Concrete	D-411-221	Room ceiling
	102	670'-0"	351°	12'-6"	} ALEW	1	
	103	670'-0"	3°	12'-6"			

Sim 8-4

1 MR. GLASSPIEGEL: Is there going to be any
2 request to have her -- how is the record going to ---

3 JUDGE GLEASON: She has indicated she is going
4 to make it relevant.

5 MR. GLASSPIEGEL: Well, I didn't quite hear her
6 say that. What I heard her say was that locations are
7 important and the applicants don't dispute that. And she
8 has also stated that from Ms. Hiatt's standpoint, and I might
9 add that she is not the expert testifying here, she believes
10 it is easier to determine locations from this document than
11 from using the currently applicable locations. But I don't
12 frankly see how that is going to happen.

13 JUDGE GLEASON: Well, I don't think that is the
14 sole purpose. I presume it is not the sole purpose. I presume
15 the purpose is that the issue of location or the issue of
16 the changing of the locations is relevant to this proceeding
17 as to the effectiveness of the system. Is that ---

18 MS. HIATT: Yes, basically. I had not intended
19 to ask any further questions on it. I think the document,
20 along with the preliminary analysis, relatively speaks
21 for itself.

22 The point I was making is that the igniter
23 location is important, and I think that exhibit identifies
24 that a little more clearly than do the drawings and tables
25 in the preliminary analysis.

1 JUDGE GLEASON: Well, on that basis I just can't
2 admit it into the record. I thought there was going to be
3 some follow-up to demonstrate the importance of the location
4 of these in the system.

5 MR. GLASSPIEGEL: Mr. Chairman, also Mr. Silberg
6 just pointed out looking at the document that there are a
7 number of notations and marks and I don't know whether they
8 are ---

9 MS. HIATT: Those were my marks and they can
10 be excluded.

11 MR. GLASSPIEGEL: Well, the record -- is Ms.
12 Hiatt plans to use this document in her proposed findings,
13 she is perfectly entitled to do that. However, the record
14 needs to be clear on which hand markings are her's. I am
15 just looking at this document for the first time and I assume
16 that on page 1 where there are hand markings they are
17 Ms. Hiatt's. On page 2 where there are hand notations ---

18 JUDGE GLEASON: You have my document. So I
19 don't know what you are talking about.

20 (Laughter.)

21 MR. GLASSPIEGEL: Anyway, there are hand markings
22 on each of the pages and I think -- Susan, are you saying
23 that all of the hand markings on this document are your
24 markings?

25 MS. HIATT: That is correct, and I am not

Sim 8-6

1 offering those for evidence. I also think that if they are
2 really objectionable you could find an unmarked copy for the
3 record.

4 MR. GLASSPIEGEL: That is not my point at all.
5 I am just saying that if this document is to be used for
6 findings, the record needs to understand which are your
7 markings and which are somebody else's markings. That is
8 my only point.

9 MS. HIATT: Well, all of the markings therein
10 that were not obviously typewritten in are my markings and
11 are excluded for the purposes of the record.

12 (Board conferring.)

13 JUDGE GLEASON: The Board has decided that this
14 exhibit will be admitted into the record, and if you have
15 some follow-up questions with respect to it, please proceed,
16 Mr. Glasspiegel.

17 MR. GLASSPIEGEL: Excuse me one minute.

18 JUDGE GLEASON: All right.

19 (Pause.)

20 JUDGE GLEASON: I frankly have to state that
21 I really have a real question in my mind as to why you would
22 want to keep this material out of the record.

23 MR. GLASSPIEGEL: Well, I don't know why she
24 is using it. Let me make a couple of ---

25 JUDGE GLEASON: Well, would you agree as a

Sim 8-7

1 general proposition that the location of these plugs is a
2 relevant matter for this proceeding?

3 MR. GLASSPIEGEL: Yes, sir, but I would like
4 to explain what my concerns are.

5 JUDGE GLEASON: All right. Go ahead.

6 MR. GLASSPIEGEL: I haven't had a chance to
7 study the document and I don't know all of the background.
8 My understanding is from just conferring with people in the
9 audience that just because a particular igniter may be
10 located at the same azimuth in the same elevation, doesn't
11 necessarily mean that it is in the same location.

12 Therefore, one of my concerns is that Ms. Hiatt
13 hypothetically might in her findings say that the document
14 that she has just introduced speaking about one igniter
15 has the same azimuth in the same elevation as the azimuths
16 and elevations given in the preliminary analysis and there-
17 fore the characterization that is in the exhibit that was
18 just submitted is an accurate characterization.

19 My understanding is that is not necessarily
20 going to be the case.

21 Now, secondly, I understood her to answer
22 your question that she was not concerned about changes of the
23 location from the preliminary document to the final, but
24 she was worried about location. And as I have just answered
25 a moment ago, certainly the issue of location is relevant

Sim 8-8

1 to the proceeding, but my ultimate point is that if the
2 issue of location is relevant to the proceeding, then the
3 parties ought to be using the current and applicable descrip-
4 tions of locations, and I am concerned that that will not
5 be done in the findings.

6 JUDGE GLEASON: It is so obvious to me that I
7 really must be overlooking something that you are going to
8 have to point out to me. If location is important, certainly
9 changes in location are important.

10 MR. GLASSPIEGEL: Well, Ms. Hiatt didn't say
11 she was going to say it for that purpose.

12 JUDGE GLEASON: Well, I don't know what she
13 is going to use it for.

14 MR. GLASSPIEGEL: Well, could she please tell
15 us at this point how she is going to use it?

16 JUDGE GLEASON: She doesn't have to.

17 MR. GLASSPIEGEL: Well, I didn't say she
18 had to. I am asking her to.

19 MS. HIATT: You will find out in my findings.

20 MR. GLASSPIEGEL: Okay.

21 JUDGE GLEASON: Let's move on. The exhibit
22 will be admitted into the record.

23 BY MS. HIATT:

24 Q Isn't it true that the spray shield and the
25 placement of igniter assemblies underneath ceilings would

1 inhibit upward flame propagation?

2 A (Witness Buzzelli) I would like to have
3 Dr. Lewis address that.

4 A (Witness Lewis) No.

5 Q Now if an igniter is placed right under a
6 ceiling, where is the flame going to travel? It doesn't
7 have far to go upward, does it?

8 A The flame will propagate from the igniting
9 source, which is the glow plug. If the concentration is
10 in the right ball park, the flame will move downward, sideways
11 and upward, and no closeness to a wall, ceiling or shield
12 is going to change that phenomenon. The flame is going
13 to propagate everywhere.

14 Q And the criterion for downward propagation is
15 what, sir?

16 A That it should be of the order of eight and a
17 half percent or a little higher, eight to eight and a half
18 to ten.

19 Q Dr. Lewis, do you know Barry Shot?

20 A I don't know him personally.

21 Q Do you know of him?

22 A I know his name.

23 Q Do you know that he is with the Los Alamos
24 Scientific Laboratory?

25 A I didn't know, but I understand he is.

Sim 8-10

1 Q Do you consider him to be a combustion expert?

2 A I don't know him.

3 Q Mr. Karlovitz, do you know?

4 A (Witness Karlovitz) I don't know about him,
5 only one reference or one statement.

6 Q Are you aware of the experiments conducted at
7 the Nevada test site?

8 MR. GLASSPIEGEL: Which experiments, Ms. Hiatt?

9 MS. HIATT: They were large-scale hydrogen
10 combustion experiments conducted in a spherical vessel I
11 believe.

12 WITNESS LEWIS: A large spherical vessel, yes.
13 Well, I have not seen the report, but I have been told of
14 the contents.

15 BY MS. HIATT:

16 Q Do you know if those tests used the igniter
17 assembly with spray shield that is used in the Perry plant?

18 A (Witness Lewis) I don't know.

19 Q Do you know how the igniters were placed in
20 that experiment?

21 A I don't know.

22 A (Witness Richardson) The igniter placement
23 in that assembly had nothing to do with trying to replicate
24 anything in the Perry plant. As a matter of fact, that test
25 was more oriented to large dry containments for PWR's.

Sim 8-11

1 Q Now the volume of that vessel was 75,000 cubic
2 feet?

3 A (Witness Lewis) Well, if you will give me the
4 diameter, I can agree or not.

5 (Laughter.)

6 MS. HIATT: I am not sure I have it.

7 (Pause.)

8 JUDGE GLEASON: If the others of you know the
9 answer, it would help us get along with they would just
10 volunteer the answer.

11 WITNESS LEWIS: You would have to calculate it.
12 It is very easy.

13 JUDGE GLEASON: I understand. Do you know,
14 Mr. Richardson?

15 WITNESS RICHARDSON: I don't remember the exact
16 volume.

17 (Discussion off the record.)

18 MS. HIATT: I am afraid I don't really have
19 dimensions.

20 JUDGE GLEASON: Well, I think we can proceed.

21 BY MS. HIATT:

22 Q Didn't the Nevada test site results show that for
23 concentrations of hydrogen greater than about 7.7 percent
24 combustion is virtually complete?

25 A (Witness Lewis) I believe that was the case.

Sim 8-12

1 Q And didn't the Nevada test site results show
2 that when combustion is complete the maximum pressures and
3 temperatures are only about 10 to 15 percent below the
4 adiobatic theoretical values?

5 A I am not sure of that. I haven't read the
6 report.

7 Q I am handing you a page marked "Preliminary
8 Results For Premixed Combustion Tests." Does this look
9 familiar in any way as the Nevada test site results?

10 A I have never seen that.

11 Q Has Dr. Karlovitz seen that?

12 A (Witness Karlovitz) No, I have never seen that.

13 Q Isn't it true that for many of the lean premixed
14 combustion tests at the Nevada test site combustion could
15 not be induced except by using fans, sprays or different
16 igniters?

17 A I didn't hear the part of your sentence dealing
18 with the operations of the fans.

19 Q I will re-read it.

20 Isn't it true that for many of the lean premixed
21 combustion tests at the Nevada test site combustion could
22 not be induced except by using fans, sprays or different
23 igniters?

24 A How lean?

25 Q It was my understanding that it was maybe in the

1 six percent range?

2 MR. GLASSPIEGEL: Could I have just a clarifica-
3 tion. Ms. Hiatt said she had a document in front of you.
4 There is a reference to different igniters. Does the context
5 say different than what?

6 MS. HIATT: I believe it may have been a
7 location or additional igniters. The document from which
8 I obtained that is a draft Sandia document designated
9 NUREG CR-4138, "Data Analysis For Premixed Combustion Tests
10 Performed At The Nevada Test Site," if you would like to
11 look at it.

12 MR. GLASSPIEGEL: No. I just had a very specific
13 question. You were at a sentence and it was hard to tell
14 out of context what the reference to different igniters meant.
15 There was a reference to different igniters and I am just
16 asking different than what?

17 MS. HIATT: I will read the statement from the
18 document and see if that will help.

19 It states that "Note for some of the initially
20 lean hydrogen combustion tests local conditions around the
21 ignition sources were not immediately conducive for combustion.
22 In these instances different igniters might be triggered
23 or spray systems and/or fans might be again operated to
24 facilitate combustion."

25 That is all the information I have.

Sim 8-14

1 WITNESS LEWIS: May I answer the question?

2 MS. HIATT: Yes.

3 WITNESS LEWIS: It is perfectly obvious that
4 you don't get combustion from a comparable ignition source
5 if you don't have a premixed mixture. It is outside of
6 the flammable range or otherwise the igniter would ignite
7 it, I mean would propagate it.

8 BY MS. HIATT:

9 Q Well, the tests were intended to be premixed;
10 isn't that true?

11 A (Witness Lewis) They were what?

12 Q They were intended to be premixed combustion
13 tests?

14 A They were intended to be premixed, but what I
15 am saying is they didn't ignite the mixture around the
16 igniters. It was not an ignitable mixture. Therefore, in
17 certain places in that large sphere there were mixtures that
18 were not within the flammable range. It is not surprising
19 at all.

20 Q Dr. Lewis, do you believe that a flame speed
21 of six feet per second is conservative for use in the
22 CLASIXS analysis?

23 A Yes, I do.

24 Q And is one of the experimental bases for that
25 conclusion the Lawrence Livermore igniter tests?

Sim 8-15

1 A No.

2 Q You were not relying on that whatsoever?

3 A No. We have an independent way of determining
4 the flame speed.

5 Q And what was that method?

6 A Well, we know what the laminar speed is of
7 propagation, and by laminar I mean an unperturbed flame
8 propagation, unperturbed by turbulence, and that was of the
9 order of a little more than one foot per second. The
10 introduction of turbulence would increase that to about
11 three and a half to four, and under certain circumstances
12 maybe even to five. It depends on tube diameters and so
13 on, and that is conservative against six assumed in the
14 CLASIXS.end Sim
Sue fols

15

16

17

18

19

20

21

22

23

24

25

#9-1-SueT

1 Q This is based on experimental data that you have
2 performed, sir?

3 A Well, it's in the literature open to the world.

4 Q What was the size of the vessels in which these
5 experiments were conducted?

6 A Various sizes.

7 MR. GLASSPIEGEL: Excuse me, which experiments
8 are we talking about, Susan?

9 MS. HIATT: The experiments that Dr. Lewis has
10 referenced.

11 MR. GLASSPIEGEL: He talked about information being
12 available in the general literature. I didn't hear him talk
13 about specific experiments.

14 BY MS. HIATT: (Continuing)

15 Q Are you aware that the Sandia National Laboratory
16 has conducted an extensive program on hydrogen combustion?

17 A I believe that's true.

18 Q Are you aware that one of the vessels which was
19 used is known as the variable geometry experimental system,
20 an upright cylindrical tank with a volume of about 176 cubic
21 feet?

22 A I am not aware of that vessel.

23 Q Do you know Dr. John H. S. Lee?

24 A Yes, I do.

25 Q And he works at McGill?

#9-2-SueT

1 A McGill in Montreal, Canada.

2 Q And isn't he true that he has conducted research
3 on flame acceleration?

4 A Yes.

5 Q And hasn't his research found that at concentra-
6 tions of eight volume percent of hydrogen, speeds of twenty
7 meters per second have occurred due to acceleration of flames
8 by obstacles?

9 A Under those conditions, yes.

10 Q Now, Dr. Lewis, on Page 31 of your prefiled testi-
11 mony, you refer to a detonable range of hydrogen/air mixtures.

12 Would you define what that range is, sir?

13 A Well, the term detonable range appears in the
14 last sentence on Page 31.

15 Q Yes. And what is that detonable range, is what
16 I'm asking, sir? What concentrations of hydrogen are you
17 talking about?

18 A Well, the upper range. The upper range is on the
19 order of 60 percent, 59/60 percent. And the lower range can
20 vary between about 14 and 18 percent. I believe that the
21 value of 18 is not quite low enough. It's based on all
22 determinations.

23 And the value of 14 percent would be a competent
24 lower limit for detonation. That would be a mixture that
25 can support and continue to propagate the detonation range.

#9-3-SueT

1 If it is under 14 percent or thereabouts, the way -- if you
2 overdrive by high explosives, you will get an apparent
3 detonation which will then die out to a deflagration flame.

4 Q Are you aware that Dr. Lee's research has pro-
5 duced a detonation, a mixture of thirteen point eight percent
6 hydrogen and air?

7 A Yes. I am aware of that. And that has all been
8 done with high explosive charges. We don't have high explosive
9 charges in the containment.

10 JUDGE KLINE: Do you mean the high explosive
11 initiates the --

12 WITNESS LEWIS: Petrol. Petrol or TNT are that
13 strength of explosives. As a matter of fact, the thirteen
14 point eight is postulated to require 50,000 grams or over a
15 hundred pounds of TNT to continue the detonation into a --
16 from a tube that is twenty-eight feet in diameter out into
17 an open space containing the same mixture composition.

18 This is manifestly -- first of all, it is interest-
19 ing for Dr. Lee to find this, because he is seeking to
20 determine basic principles for the relation between detona-
21 tion cells and critical diameter for propagation into a
22 larger space. It has no application whatsoever to the condi-
23 tions that are under consideration in this case.

24 BY MS. HIATT: (Continuing)

25 Q Are you aware that Dr. Lee and his colleagues

#9-4-SueT

presented a paper on Direct Initiation of the Spherical Detonation by a Hot Turbulent Gas Jet at the Seventeenth International Symposium on Combustion?

A There is such a paper. Yes.

Q Is this a copy of the paper, sir?

A Yes, it is.

Q I would direct your attention to the comment at the end of the paper by E. T. McHale. Do you know Mr. McHale?

A Oh, yes. Yes.

Q Would you please read that comment into the record?

A May I read it first?

Q Oh, go ahead.

A It is small print.

(Laughter.)

Yes. May I comment on this?

JUDGE GLEASON: Why don't you read it into the record?

MS. HIATT: Sure.

JUDGE GLEASON: Let her read it --

WITNESS LEWIS: May I comment on this?

JUDGE GLEASON: Let her read it in the record and then you comment on it.

WITNESS LEWIS: Oh, all right.

MS. HIATT: Comments by E. T. McHale, Atlantic

Research Corporation, U.S.A. "It is of interest to add a historical comment in connection with this work. Dr. Gene von Elbe predicted approximately five years ago that detonation of unconfined fuel/air mixtures could be initiated by injection of certain reactive chemicals. Approximately two and one half years ago, we obtained such detonations for the first time in unconfined two-phase mixtures of hydrocarbon droplets in air and several reactive coordinated agents have been found to be suitable initiators."

BY MS. HIATT: (Continuing)

Q Are you familiar with that, sir?

A Yes. Dr. von Elbe was a colleague of mine for fifty years.

Q What would be the mechanism by which reactive chemicals would initiate a detonation?

A Yes. Now, these would be reactive chemicals containing very important atoms and radicals. Radicals are a combination of two or three atoms in a single molecule. They have a deficiency of one or more atom so that they are highly reactive. We call them reactive species and chain reactions.

Well, what they injected was a material that would make a profuse concentration of these reactive species. They are not inert, because they react with the fuel and the air

- #9-6-SueT 1 mixture and cause a highly sensitive mixture to be formed by
2 virtue of their presence. And you can go over into deflagra-
3 tion and detonation.

4 It has nothing to do with inert in terms of ordinary
5 inert gases like nitrogen, carbon dioxide, et cetera. These
6 are very special chemicals which has nothing to do with any
7 situation here.

8 Q Wouldn't ionizing radiation have the same effect?

9 A Well, the mere fact that a molecule has had an
10 electron removed from it and, therefore, becomes a positive
11 ion doesn't imply that it is a reactive radical.

12 For example, if you had hydrogen molecules with an
13 electron removed, it would be a hydrogen H2 positive charge.
14 That is not reactive.

15 Q Well, doesn't ionizing radiation create radicals?
16 I mean, can it do that?

17 A Yes, it can. It depends on the concentration that
18 it makes in its reaction -- in its effect on molecules that
19 it ionizes.

20 Q Are you aware that at the Fifth Symposium on
21 Combustion a paper was presented on the Effect of Atomic
22 Radiation on the Combustion of Hydrocarbon/Air Mixtures?

23 A Yes.

24 (Ms. Hiatt is showing the witness a document.)

25 Yes, I'm aware of this paper.

#9-7-SueT

1 Q Doesn't the paper conclude that the presence of
2 ionizing radiation will promote accelerated combustion effective-
3 ness and increase the reaction rates?

4 A Yes. But because the piece of paper was published
5 in 1928 at the Wisconsin University Combustion Meeting, at
6 that time not very much was known, and a lot was guessed at,
7 with respect to ionizing radiation having an effect on initiat-
8 ing flames and initiating detonations.

9 Q And --

10 MR. SILBERG: Wait, wait.

11 WITNESS LEWIS: I would continue a moment.

12 BY MS. HIATT: (Continuing)

13 Q All right. I'm sorry.

14 A I've made a note on this paper. Beta radiation.
15 And beta radiation is nothing but a high speed electron. And
16 he also used, not hydrogen but, propane and air as a form of
17 a mixture.

18 And the result of this radiation, the flame speed
19 was not altered. The blowoff of the flame, which is a special
20 phenomena as to whether a flame can remain stabilized on, say,
21 a burner, that blowoff was not effected.

22 So, therefore, he concluded there is no significant
23 change due to radiation of low source energy. When you work
24 with higher sources energy in a constant area combustor, he
25 measured in this tube, in this flow tube, an increase in the

- #9-8-SueT 1 pressure drop. This merely meant that in his tube he was
2 having problems develop and consequently the flame speed in-
3 creased and he got a pressure drop of some dimension. And
4 that's it.

5 It's common to get a pressure drop if you increase
6 the speed.

7 MR. GLASSPIEGEL: May we have a five minute break,
8 Mr. Chairman?

9 JUDGE GLEASON: Yes. In fact, it's seven to 12.
10 Why don't we -- is it all right to go to lunch? Or, is this
11 an appropriate place?

12 MS. HIATT: Yes.

13 JUDGE GLEASON: All right. Let's be back at 1:15.

14 (Whereupon, the hearing is recessed at 11:53 a.m.,
15 to reconvene at 1:15 p.m., this same day.)
16
17
18
19
20
21
22
23
24
25

SueT

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

-----X
In the matter of: :
: :
PERRY NUCLEAR POWER PLANT, : Docket Numbers
Units 1 and 2 : 50-440
: 50-441
THE CLEVELAND ELECTRIC :
ILLUMINATING COMPANY, et al. :
-----X

Perry Town Hall
Center Road & Main Street
Perry, Ohio 44081

Thursday, May 2, 1985

The hearing in the above-entitled matter was
resumed at 1:15 p.m., JAMES P. GLEASON, presiding.

BEFORE:

JAMES P. GLEASON, Chairman
Nuclear Regulatory Commission
Atomic Safety and Licensing Board

JERRY R. KLINE, Member
Nuclear Regulatory Commission
Atomic Safety and Licensing Board

GLENN O. BRIGHT, Member
Nuclear Regulatory Commission
Atomic Safety and Licensing Board

1 APPEARANCES:

2 On Behalf of the Applicant, Cleveland Electric
3 Illuminating Company:

4 JAY E. SILBERG, Esquire

5 and

6 HARRY H. GLASSPIEGEL, Esquire

7 SHAW, PITTMAN, POTTS & TROWBRIDGE

8 Attorneys at Law

9 1800 M Street, N. W.

10 Washington, D. C. 20036

11 On Behalf of the Intervenor, Ohio Citizens for
12 Responsible Energy:

13 SUSAN L. HIATT

14 8275 Munson Road

15 Mentor, Ohio 44060

16 On Behalf of the NRC:

17 COLLEEN WOODHEAD, Esquire

18 Office of Executive Legal Director

19 Nuclear Regulatory Commission

20 Washington, D. C. 20555

Sim - 1 1

C O N T E N T S

2

AFTERNOON SESSION

3

WITNESSESDIRECTCROSSREDIRECTRECROSSBOARD

4

EILEEN BUZZELLI)

RICHARD RICHARDSON)

3581

3632

5

KEVIN HOLTZCLAW)

ROGER ALLEY)

6

BERNARD LEWIS)

BELA KARLOVITZ)

7

G. MARTIN FULS)

8

9

10

11

LAYIN DOCUMENTS

12

(None)

13

14

15

16

E X H I B I T S

17

EXHIBIT NO.IDENTIFIEDRECEIVED

18

19

OCRE No. 17

3562

3562

20

21

22

23

24

25

- #9-9-SueT

A F T E R N O O N P R O C E E D I N G S

(1:15 p.m.)

JUDGE GLEASON: All right. If we could proceed,
please.

Ms. Hiatt.

Whereupon,

EILEEN M. BUZZELLI,

RICHARD D. RICHARDSON,

KEVIN W. HOLTZCLAW,

ROGER W. ALLEY,

BERNARD LEWIS,

BELA KARLOVITZ,

- and -

G. MARTIN FULS

resumed the stand as witnesses called by and on behalf of
the Applicant and, having previously been duly sworn by Judge
Gleason, were further examined and testified as follows:

CROSS EXAMINATION

BY MS. HIATT:

Q If we consider the conditions in the drywell for
a small break loss of coolant in drywell degraded core ac-
cident, initially the drywell air will be driven out of the
drywell by steam; is that correct?

A (Witness Fuls) Yes.

(Witness Richardson) Yes.

- #9-10-SueT

1 Q As the metal-water reaction proceeds, the drywell
2 atmosphere will consist of steam and hydrogen, correct?

3 A (Witness Fuls) Yes.

4 (Witness Richardson) Yes.

5 Q And the drywell purge compressors will admit air
6 from the containment which contains oxygen to the drywell,
7 right?

8 A (Witness Fuls) That's correct.

9 Q Now, let's consider specifically your conditions
10 portrayed in Appendix A to the preliminary analysis for the
11 drywell break case.

12 In Figure 22 at a time of fifty-five hundred
13 seconds, the drywell temperature is 230 degrees Fahrenheit;
14 is that correct?

15 A What figure was that, please?

16 Q Figure 22, Appendix A.

17 A What was the question?

18 Q At time equals fifty-five hundred seconds the
19 drywell temperature is about 230 degrees Fahrenheit; is that
20 correct?

21 A That's about correct, yes.

22 Q And from Figure 25, is the drywell pressure about
23 26 psia at T equals fifty-five hundred seconds?

24 A That's correct.

25 Q And from Figure 29, is the drywell oxygen concentration

- #9-11-SueT 1 about two percent at T equals fifty-five hundred seconds?

2 A That's correct.

3 Q And from Figure 32, is the drywell nitrogen con-
4 centration about eight percent at T equals fifty-five hundred
5 seconds?

6 A That's correct.

7 Q And from Figure 35, is the drywell hydrogen con-
8 centration about thirteen percent at T equals fifty-five
9 hundred seconds?

10 A That's correct.

11 Q And from Figure 38, is the drywell steam concentra-
12 tion about seventy-five percent at T equals fifty-five hundred
13 seconds?

14 A Well, it might be a little bit higher than that.
15 But I will grant you that close.

16 Q Okay. Now, that is not a flammable mixture, is
17 it?

18 A No, it's not.

19 Q Now, let's suppose that at T equals fifty-five
20 hundred seconds we get vessel reflood such that cold water
21 will flow out in the break into the drywell; now, would
22 that situation result in any rapid condensation of steam in
23 the drywell?

24 A Well, it depends upon how you characterize rapid.
25 It will be a tendency to condensate and be a function of the

1 heat transfer characteristics between the spray and the at-
2 mosphere.

3 Q This is a copy of the Perry Final Safety Analysis
4 Report, correct, Ms. Buzzelli?

5 A (Witness Buzzelli) It is.

6 Q I'm asking you.

7 A It is. Yes.

8 Q Would you please read this statement, Page 6.2-22,
9 starting at that sentence?

10 (The witness is looking at the document.)

11 Q Would you please read that into the record?

12 A From FSAR, Page 6.2-22, under, called Evaluation of
13 Drywell Negative Differential Pressure, "Following the blow-
14 down phase of a LOCA air initially contained in the drywell
15 has been purged to the containment and the drywell is full of
16 steam. During this period the ECCS is injecting cooling water
17 from the suppression pool into the reactor pressure vessel.
18 When the reactor pressure vessel is flooded to the level of
19 the break water begins spilling into the drywell condensing
20 the steam and causing rapid depressurization of the drywell.
21 A bounding calculation of the peak drywell negative differen-
22 tial pressure is based upon the following conservative as-
23 sumptions..."

24 Q That's enough. You don't have to --

25 A (Witness Fuls) I disagree. There is --

#9-13-SueT 1

JUDGE GLEASON: Nobody has asked her a question to agree or disagree with. All she was asked to do was to read that statement.

4

BY MS. HIATT: (Continuing)

5

Q And that's a true statement of your Final Safety Analysis Report?

6

7

A (Witness Buzzelli) That is a true, first two and a half sentences of the part you asked me to read. There is more information contained in the balance of that same paragraph if you would like me to read it into the record.

10

11

Q No. I just wanted that sentence. That's all.

12

MR. GLASSPIEGEL: Mr. Chairman, I understand we had this discussion before, but the witness was asked to read something and was stopped in the middle of a sentence.

14

15

I can come back on redirect and we can finish the sentence or finish the sentence now. It would be much more helpful for the record if we just finished sentences.

17

18

JUDGE GLEASON: Do you intend to -- I don't know what the question is. As I recall, she was just asked to read something in the record.

20

21

MR. GLASSPIEGEL: The witness tried to finish the sentence and was cut off.

22

23

JUDGE GLEASON: Well, she could go on and read the rest of the material, but there is no question that relates to it. What is your question? Was there a question?

24

25

#9-14-SueT 1 MS. HIATT: I asked her if those were true state-
2 ments, and I believe she agreed.

3 MR. GLASSPIEGEL: And my point, Your Honor, you
4 don't have the benefit of the sentence in front of you but
5 she was asked whether a part of a sentence is a true statement.
6 That creates a misleading record.

7 JUDGE GLEASON: How do you want to proceed, Ms.
8 Hiatt? Do you want her to pick up reading the rest of it,
9 following it up on reidrect, or should she do it now?

10 MS. HIATT: Well, they have the option of redirect
11 on their witnesses.

12 JUDGE GLEASON: All right. Just wait. It doesn't
13 have much value the way it is now.

14 BY MS. HIATT: (Continuing)

15 Q All right. Now, from the conditions which we
16 took from the preliminary analysis, Appendix A, we can
17 calculate the vital concentrations of nitrogen, oxygen and
18 hydrogen if we assume that all the steam is condensed and
19 neglecting further air addition from vacuum breaker operation
20 during depressurization; is that correct?

21 A (Witness Fuls) It's probably valid that you
22 could do that.

23 Q Would you care to perform that calculation?

24 A Now?

25 Q Yeah.

#9-15-SueT

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. GLASSPIEGEL: Well, I object. There is no

basis to ask a witness to perform a calculation in the middle of a hearing.

JUDGE GLEASON: Is it a complicated calculation?

WITNESS FULS: All I can give you is an estimate of what the answer would be. It is involved. There is heat transfer, there is rate to heat transfer. There is temperature changes.

JUDGE GLEASON: You would have to accept an estimate.

MS. HIATT: Well, I was -- maybe we can simplify it a little further than that, if we could just consider the ideal gas while we are assuming all the steam will be condensed. Let's just -- you know, we are back to -- just make a few basic assumptions and maybe we get a ballpark figure.

That's what we are looking for.

MR. GLASSPIEGEL: Well, Ms. Hiatt can make all the assumptions she wants to. But if she wants the witness to make estimates or calculations, then that is up to the witness as to whether they can do that reliably in the middle of a hearing.

JUDGE GLEASON: Well, that's what I asked him, and can you do that on an estimated basis?

WITNESS FULS: I believe so. What you are asking -- would you ask the question again, please?

1 BY MS. HIATT: (Continuing)

2 A All right. We will assume that all the steam
3 is condensed. We will neglect further air addition from the
4 vacuum breaker operation during depressurization. I think
5 maybe the temperature, we can perhaps assume possibly -- we
6 can assume -- I can make some assumptions, but why don't
7 we calculate the final concentrations of nitrogen, oxygen,
8 and hydrogen, following the condensation of all the steam.

9 A (Witness Fuls) Well, taking your assumptions
10 at face value, and assuming that the steam somehow gets out
11 of there, not granting that it can get out, you would be taking
12 about 75 percent of the partial pressures out of there, and
13 so you would have 13 percent, I think, was the number that you
14 used for the initial hydrogen concentration, and multiply that
15 by an order of by about four, so you would be in the range,
16 based on your assumption, of about fifty-two percent hydrogen.

17 The same thing would apply to the oxygen. I forgotten
18 the number. I believe you said it was -- it would be about
19 eight percent orders of magnitude.

20 Q With no steam, we are assuming?

21 A That is correct. But you would also have a
22 concomitant decrease in the pressure by a factor of --
23 instead of 24 psia, you would be down to like 6 psia. A very
24 rarified atmosphere.

25 Q Is that a combustible mixture?

1 A Yes.

2 Q Is it a detonable mixture?

3 A No.

4 Q Go ahead.

5 A You have sufficient hydrogen, but you have a
6 deficit of oxygen when you get into the detonable region.

7 Q Could you predict -- lets say the adiabatic
8 isochoric theoretical pressure rise from the combustion of
9 that mixture?

10 A I will defer to one of my colleagues.

11 A (Witness Lewis) You want the pressure that
12 would arise from the combustion of this?

13 Q Correct.

14 A All right. First of all, I can tell you that the
15 oxygen is 8 percent.

16 Q Pardon sir? I am having trouble hearing you.

17 A Oxygen is 8 percent.

18 Q Yes, sir.

19 A Nitrogen is 35 percent, and hydrogen is 57 percent.

20 Q I believe it was 52. Is that what you said.

21 A 57.

22 Q I thought you said 52, Dr. Fuls?

23 A (Witness Fels) I said 52.

24 A (Witness Lewis) But I have done it accurately.

25 JUDGE GLEASON: You are impeaching your own witness.

1 WITNESS LEWIS: Well, this is an estimate he
2 made, you see.

3 This, obviously, is a very rich mixture. You see
4 you are on the downward slope, and that can't be done off the
5 top of your head. I will venture a guess that the pressure
6 would be -- it is very close to the limit of detonation, if
7 you can get the light ignition.

8 So, the pressure would be of the order of 50 pounds
9 -- 50 to 55 pounds.

10 Starting from atmospheric pressure. This is a
11 Delta-T of 50 to 55 pounds.

12 A (Witness Fuls) She was talking about 6 psia, so --

13 A (Witness Lewis) Oh. You mean reduced pressures?

14 Q The intial pressure.

15 A Oh, well, I didn't hear that. 23 psia.

16 Q Okay. Now, isn't it true in actuality in that
17 situation, Dr. Fuls, you would expect more oxygen to be into
18 the drywell due to the action of the vacuum breakers during
19 depressurization?

20 A (Witness Fuls) I would expect that there would
21 be more oxygen, but I also expect a tremendous amount of steam
22 to be residual in the -- at the same time.

23 Q Now, the Marsh Code was used to calculate steam
24 and hydrogen releases as input to your containment response
25 analysis, correct?

1 A That is correct.

2 Q Do you know what version of the Marsh Code was
3 used?

4 A I understand it was version 1.1.

5 Q And is that something the NRC informed you, or
6 --

7 A Yes. They did the calculation.

8 Q I am handing you a document that has been purported
9 to be a listing of input values for the Marsh Code that was
10 used as input. Is that what it looks like to you?

11 A That is what it looks like, yes.

12 Q This listing consists mainly of unidentified
13 numerical values, correct?

14 A That is correct. Without the manual it would be
15 virtually impossible to tell what the numbers mean.

16 Q But you do think this is -- these are input
17 variables into the Marsh Code?

18 MR. GLASSPIEGEL: Ms. Hiatt, from where did you
19 get the document? Rather than playing guessing games, why don't
20 we find out where the document comes from?

21 MS. HIATT: We got it from you. You supplied this
22 during discovery.

23 MR. GLASSPIEGEL: That is fine. Let's have an
24 identification of it, that is all. There is no date or title
25 or anything.

1 MS. HIATT: It says on the top: Listing of
2 Input Data for Case 1, Grand Gulf Degraded Core of Hydrogen.
3 It was provided in response to my Interrogatory
4 13-65.

5 MR. GLASSPIEGEL: Well, our version has the top
6 portion cut off, I think, but I appreciate having the
7 identification where it came from given.

8 JUDGE GLEASON: Proceed, Ms. Hiatt.

9 BY MS. HIATT: (Continuing)

10 Q If you have the March Manual, could you identify
11 to which input variables these numbers correspond?

12 And the manual we are referring to is NUREG CR 1711.

13 A (Witness Fuls) I don't remember the CR number.

14 Q Is this a copy of the March manual document?

15 A That appears to be the same one that I used.

16 Q Could identify where the input variables for
17 which these numbers correspond?

18 A You mean in the manual, in the back of the manual?

19 Q Could you identify the input variables to which
20 they correspond?

21 MS. WOODHEAD: Ms. Hiatt, we think these are
22 misidentified.

23 MS. HIATT: That is what I thought, too. But --

24 MS. WOODHEAD: Well, I think we need to have an
25 accurate identification of the document before you use it.

1 JUDGE GLEASON: Who can identify it correctly?

2 MS. WOODHEAD: Mr. Notafrancesco produced the
3 document.

4 JUDGE GLEASON: Is the author here? Identify it.

5 MR. NOTAFRANCESCO: This is input to IMPEL Delta-T
6 28 Code.

7 WITNESS FULS: To the best of my knowledge, this
8 was what was sent to me by Battelle Memorial Institute,
9 through the NRC, as being the input to the March program
10 used in production of the base run used in this analysis.

11 JUDGE GLEASON: Can you corroborate that, Mr.
12 Notafrancesco?

13 MR. NOTAFRANCESCO: I definitely think the input
14 is --

15 JUDGE GLEASON: It is not from the March Code?

16 MR. NOTAFRANCESCO: The results of March are used
17 as input for the IMPEL codes.

18 MS. HIATT: Well, let them look at it a little
19 longer.

20 JUDGE GLEASON: All right.

21 JUDGE GLEASON: Can you respond to her question.
22 Can you identify that?

23 MR. FULS: No, I -- all I can tell you is that
24 this, to the best of my knowledge, this was transmitted to me
25 by a devious route, and purported to be the import to the

1 March program used to generate the Grand Gulf result.

2 JUDGE GLEASON: Mr. Richardson?

3 WITNESS RICHARDSON: I think I can clarify a
4 little bit, in that the input into the CLASIX Code that was
5 necessary was derived from the March Code, and it -- at the
6 time Battelle National Laboratories had conducted the RUSMAP
7 Study, which Ms. Hiatt had identified earlier, and had used
8 March for the Grand Gulf plant.

9 They had done that work for the Nuclear Regulatory
10 Commission, and when we initially did the studies for CLASIX
11 we requested, through the NRC, that the output of March be
12 provided for use in the studies of the hydrogen generation
13 event, and for use in the CLASIX.

14 So, the output of the March Code came from
15 Battelle and the NRC to Mississippi Power and Light, and was
16 sent to Dr. Fuls.

17 Dr. Fuls, I think, says that that was attached
18 to the output information from March as the input that went
19 in.

20 The important parameter was the output of March,
21 and that is what we were interested in. That was just sent
22 as additional information.

23 JUDGE GLEASON: Now, can you corroborate that?
24 What he just said.

25 MR. NOTAFRANCESCO: I am not sure of all the

1 details.

2 JUDGE GLEASON: All right.

3 BY MS. HIATT: (Continuing)

4 Q Mr. Fuls, you still believe that this is an
5 input listing for the March Code?

6 A (Witness Fuls) Not according to this manual, no,
7 it is not.

8 Q Okay. Now, isn't it true that the CLASIX 3 Code
9 -- for purposes of the CLASIX 3 Code, the hydrogen steam output
10 values of March are linearly interpolated between the data
11 points?

12 A That is correct.

13 Q Now, the CLASIX 3 Code is a proprietary code, is
14 it?

15 A That is correct.

16 Q And that is not widely available, or available at
17 all in the public domain?

18 A That is the meaning of proprietary.

19 Q Has the CLASIX 3 Code been validated by comparison
20 with experimental data?

21 A It certainly has.

22 Q Could you describe that?

23 A There were innumerable comparisons with information
24 from Penwall and other small volume tests and recently there
25 were some comparisons made with the NTS test, which as you

1 know, is a large volume test.

2 Q Now, by comparisons, you mean comparisons of the
3 actual results achieved from the Code and any comparisons for
4 input value, such as burn parameters?

5 A We use the data available from the test, such
6 as initial conditions. Hydrogen concentrations. Whatever
7 information was available on the initial conditions, and the
8 analysis was performed with the CLASIXs, and the output
9 compared with the test data.

10 Q Are you talking about CLASIX, or CLASIX 3?

11 A CLASIX 3.

12 Q Now, there have been comparisons made between
13 CLASIX and other response codes which model hydrogen combustion,
14 correct?

15 A Only one available, and that is the Coco Class 9
16 from Westinghouse, which is also a proprietary code.

17 Q Now, isn't it true that Sandia National Laboratory
18 made a comparison between March and CLASIX and Hector?

19 A Yes, that is true.

20 Q And that comparison is documented in a document
21 Number NUREG CR 2530? Full Length Review of the Grand Gulf
22 Hydrogen Igniter System?

23 A I have read that document some time, and I don't
24 remember all of the details. That may be true.

25 Q Do you recall whether March and Hector predicted

1 higher pressures and temperatures from hydrogen combustion than
2 did CLASIX 3?

3 A I recall statements to that effect; I can't say
4 from my own recollection.

5 Q Now, you performed a number of sensitivity studies
6 on the CLASIX 3 Code, correct?

7 A Yes, I did.

8 Q And these sensitivity studies addressed wetwell spray
9 carryover as a parameter?

10 A That is true.

11 Q And did you find that increasing the wetwell spray
12 carryover resulted in an increase in temperature?

13 A An increase in temperature in the wetwell, yes.

14 Q I call your attention to Table 9 of Appendix A
15 to the preliminary analysis. You used for the Perry CLASIX
16 3 analysis a wetwell spray carryover fraction of .4669?

17 A That is correct.

18 Q I will direct your attention to Figure 2.4-12 of
19 the preliminary analysis. According to this figure, after
20 6 -- 89 foot six inch elevation at Perry, the cross sectional
21 floor area of the containment is 2,778 square feet?

22 A That is what the figure says, yes.

23 Q Doesn't that correspond to about 25 percent of the
24 total cross sectional area of the containment?

25 A Offhand, I don't know.

1 Q You don't know.

2 A That is correct. I don't know the full cross
3 sectional area.

4 Q Now, the containment spray headers are up above
5 that elevation, correct?

6 A Yes. Considerably above it.

7 Q So, wouldn't we only expect about 25 percent of the
8 spray to directly enter the wetwell?

9 A If your numbers are correct, yes.

10 Q Okay. Did your carryover fraction of .4469 also
11 include sheet flow of water?

12 A It was based on sheet flow, yes.

13 Q And you made an assumption that sheet flow is
14 one half as effective as droplet flow and heat transfer?

15 A That is correct.

16 Q Do you have an experimental basis for that
17 assumption?

18 A No, I do not.

19 Q So, it is certainly possible that spray effectiveness
20 in the wetwall would be less than what you assumed?

21 A It is also possible it could be considerably more.

22 Q If we assume that it is less, wouldn't the hydrogen
23 burn temperatures be greater than was calculated?

24 A In the wetwell, if the spray were less, the peak
25 temperature would be higher -- would be expected to be higher.

1 Q So, the CLASIX 3 analysis models -- you go on.

2 A There is one consideration. I would tend to
3 expect them to be higher, but the magnitude would not be
4 directly proportional, because the spray and the spray carry-
5 over tend to reduce the temperature in the wetwell.

6 Therefore, because of the lower temperature, it
7 requires more pounds of hydrogen to equal eight percent. So,
8 there may be some offsetting conditions there.

9 You are burning more pounds. Initiating at a lower
10 temperature. You have -- there is some offsetting character-
11 istics there. But offhand, I would say they would be expected
12 to be higher peak temperatures.

13 Q Okay. Now, the CLASIX 3 analysis will model only
14 deflagrations, and not diffusion flame, correct?

A That is correct.

15 Q Mr. Richardson, at one point on your scale test
16 you referred to in your testimony demonstrated that
17 continuous diffusion flames exist in the wetwell for hydrogen
18 releases greater than .4 to .5 pounds per second, is that
19 true?

20 A (Witness Richardson) Feel that there was a
21 threshold, and the threshold was in the vicinity of 0.4 to
22 .5 pounds mass per second. And above that threshold, diffusion
23 flame would occur.

24

25

End 10.

MS 1018. Am. Federal Reporters, Inc.

Sim 11-1

1 Q Isn't it true that the fusion flames pose a
2 thermal threat to equipment survivability and containment
3 integrity in the wetwell region?

4 A (Witness Richardson) Part of the Hydrogen Control
5 Owners Group program is to evaluate thermal environment from
6 the fusion flames by conducting a large-scale test, a
7 quarter-scale test to determine what that thermal environment
8 is, and I feel confident that the results of that test would
9 show that the thermal environment is not a threat to the
10 equipment.

11 Q On June 29th, 1983 did not the Hydrogen Control
12 Owners Group and the NRC conduct a meeting to discuss the
13 results of the 1/20th scale tests?

14 A If you have a document that shows that. I
15 don't remember the dates of all the meetings.

16 (Pause while the witness reviews a document.)

17 Yes, there was a meeting.

18 Q And at that meeting did you not make a statement
19 that standing diffusion standing diffusion flames will result
20 in unacceptable loading to equipment for a 75 metal-water
21 reaction?

22 A I can't remember if I made that exact statement.
23 If I made the statement, it would have been with certain
24 conditions which stated for certain release rates of hydrogen
25 which could not exist for a 75 percent metal-water reaction.

Sim 11-2

1 Q Let me direct your attention to one of the
2 viewgraphs here. Did you present this one at that meeting,
3 the conclusions?

4 A I probably did. I can't remember.

5 Q Why don't you just read that into the record.

6 A The slide is a slide that says conclusions,
7 and the particular bullet or section says resulting thermal
8 loading to equipment is unacceptable for 75 percent metal-
9 water reaction. However, that statement is somewhat out of
10 context because this is a slide, and it was a very brief
11 statement.

12 It has a very big qualifier on it which is
13 for the release rates used in the 20th scale facility, which
14 are not capable again for a 75 percent metal-water reaction,
15 then the thermal loading might impair the equipment.

16 We did say, and if you read further, it does
17 say that it is likely acceptable for a realistic source term,
18 and that is exactly the point I am making.

19 Q Didn't you perform an analysis based on the
20 1/20th scale test results, which would indicate that the
21 transformer in the igniter assembly would reach a temperature
22 of 900 degrees Fahrenheit?

23 A There was some analysis conducted evaluating the
24 20th scale data. I am not which analysis you are talking
25 about. There were some very gross preliminary analyses

Sim 11-3

1 done prior to the time I left Mississippi Power and Light
2 and there were some better analyses conducted after the
3 time I left MPL. If you could tell me which ones you are
4 referring to.

5 Q Let me show you this. This is a document dated
6 July 15th, 1983, a memorandum for A. Schwencer from M. D.
7 Houston, Project Manager for Grand Gulf, subject, Summary
8 of the BWR Hydrogen Control Owners Group Meeting on June
9 29th, 1983, and it summarizes the main points in the HCOG
10 presentation.

11 You might look that over.

12 Have you ever seen it before?

13 (Pause.)

14 A I don't remember reading it before.

15 Q Does it accurately summarize the presentation
16 that you made?

17 A Just reading this, and I haven't read the whole
18 document ---

19 Q Well, if you would like to, take your time.

20 (Pause.)

21 JUDGE GLEASON: If I understand correctly,
22 this purports to be a summary of a HCOG meeting. Did
23 you ever seen this summary before?

24 WITNESS RICHARDSON: This was not a summary
25 by the HCOG. It is the meetings minutes internal to the

Sim 11-4

1 NRC.

2 JUDGE GLEASON: All right.

3 WITNESS RICHARDSON: Someone in the HCOG may
4 have had it, but right after this date I left MP&L.

5 JUDGE GLEASON: All right.

6 (Pause.)

7 JUDGE GLEASON: We are spending an inordinate
8 amount of time on a three-page document to get a simply
9 statement as to whether it is an accurate summary or not.10 WITNESS RICHARDSON: It does summarize the
11 meeting. It has some facts in it that I am not sure were
12 the actual facts presented. I can't tell from just what
13 is here.14 MS. HIATT: Well, let me read this statement
15 to you.16 "The transformer on the hydrogen igniter
17 assembly was identified as a critical item on the basis that
18 it is qualified to 400 degrees Fahrenheit and was calculated
19 to reach a temperature of approximately 900 degrees
20 Fahrenheit.21 Is that an accurate characterization of the
22 material you presented at that meeting?23 WITNESS RICHARDSON: Yes. I don't remember
24 the exact temperature that was presented. It is a
25 characterization of the fact that if you take the release

Sim 11-5

1 rate that was used in the facility, which we discussed at
2 that meeting that it was not possible for a 75 percent
3 metal-water reaction, but if you took the release rates
4 that were evaluated in the 20th scale testing and carried
5 them out for extended periods of time, the temperatures would
6 continue to increase until the point where the hydrogen
7 igniter would reach very high temperatures and fail.

8 If you take any elevated temperature out long
9 enough, the temperature is going to increase. That analysis
10 was to take the temperature, to take the component past
11 failure to see what the peak temperature was.

12 BY MS. HIATT:

13 Q Do you recall whether the 1/20th scale tests
14 indicated that a maximum gas temperature below the HCU
15 floor was around 1200 degrees Fahrenheit?

16 A (Witness Richardson) I don't remember the
17 number for the maximum gas temperature.

18 (Pause.)

19 Q Didn't your evaluation of the 1/20th scale
20 test facility indicate that at the HCU floor the temperatures
21 would be in the range of 500 to 700 degrees Fahrenheit?

22 A Yes, and I am not sure which evaluation you
23 are referring to. There were several evaluations, you know,
24 conducted, some with some preliminary data and there were
25 some done for the meeting and then there were some that

Sim 11-6

1 were conducted after the meeting which were better predictions
2 using better data. So I really do need to know which
3 time frame.

4 Q Well, this figure is part of what you presented
5 at the meeting, or you and your colleagues presented?

6 JUDGE GLEASON: What document is that?

7 MS. HIATT: This is the document, the HCOG/NRC
8 meeting in Bethesda, Maryland on June 29th, 1983.

9 (Pause.)

10 WITNESS RICHARDSON: This is a chart showing
11 some data taken from the 20th scale testing which, as we
12 had stated in the presentation, was very conservative
13 temperatures. It would be much higher than expected because
14 the scaling relationships were off. The scaling relation-
15 ships, once you go beyond about one in ten, break down
16 and you start getting very conservative temperatures. So
17 these values do appear to be what was presented there from
18 the 20th scale data.

19 BY MS. HIATT:

20 Q And they range around 500 to 700 degrees at the
21 HCM floor?

22 A (Witness Richardson) It looks like five to
23 six hundred, something like that, 625, or something like
24 that.

25 Q Now at normal pool water level, the top of the

Sim 11-7 1 pool surface is at 593 feet elevation approximately?

2 A I think that is correct.

3 A (Witness Buzzelli) That is correct.

4 Q Now the drywell equipment hatch and the lower
5 personnel airlock are located on the 599 elevation?

6 A Could you repeat the question?

7 Q The drywell equipment hatch and the lower
8 personnel airlock in the containment are located at the
9 599 elevation; is that true?

10 A I believe that is correct.

11 Q And both of these use polymeric seals as
12 leakage barriers?

13 A (Witness Richardson) Both of those use seals.
14 I don't know if it is that type. I would have to check that
15 material.

16 Q Well, a polymer is a very general class of
17 materials. There are polymeric seals, right?

18 A (Witness Buzzelli) They both have sealing
19 arrangements in the hatch and in the airlock that you
20 referred to.

21 Q Isn't it a concern that standing diffusion
22 flames persisting for a length of time could degrade the
23 seals in both the drywell equipment hatch and the lower
24 personnel airlock?

25 A (Witness Richardson) Those hatches are

Sim 11-8

1 included on the equipment survivability list in the
2 preliminary evaluation and they will be evaluated for the
3 thermal environments which could exist from standing
4 diffusion flames as a result of the quarter-scale testing.

5 Q And it is a goal of that quarter-scale
6 facility to generally define the thermal environment to
7 which equipment will be subjected from the diffusion flames?

8 A It is an objective of that testing to define
9 the thermal environment which may result from standing
10 diffusion flames and to use that thermal environment for
11 evaluating the equipment response.

12 Q Do you intend to put actual items of equipment
13 in that facility to test them?

14 A No.

15 Q Is your methodology there to measure heat
16 fluxes and extrapolate them to full scale and then use
17 those inputs to analytical models of equipment thermal
18 response?

19 A The methodologies use more than just heat
20 fluxes. We are measuring several parameters, heat fluxes,
21 gas velocities, temperatures, several things. We are
22 going to use the information measured and we have an
23 extensive network of instrumentation in the facility. We
24 are going to use that information to define what the
25 full-scale thermal environment would be and use that

Sim 11-9

1 thermal environment in computer models of the equipment
2 to determine what the equipment response is.

3 In addition, we have placed what we call a
4 complex calorimeter, which is an instrumented device, a
5 well instrumented device of a complex geometry where we
6 will measure the temperature response of this complex
7 calorimeter, not only on the outside, but also internal
8 to the device and use the thermal environment which is
9 measured and apply it in the same manner to the computer
10 models of that device and compare the analysis to the tested
11 results in order to validate the methodology.

12 Q Dr. Lewis, did you Mr. Karlovitz perform a
13 study of hydrogen control at the Grand Gulf Nuclear Station
14 in 1981?

15 A (Witness Lewis) Of the test program.

16 Q I am just asking did you perform or write a
17 report on the study of hydrogen control for the Grand Gulf
18 Nuclear Station around 1981?

19 A I think so, yes.

20 Q And in your evaluation didn't you recommend
21 that full-scale testing of diffusion flames above the
22 suppression pool be conducted?

23 A (Witness Karlovitz) May I answer this question,
24 please?

25 Q Sure.

Sim 11-10

1 A When we recognized that above the water
2 level out come bubbling hydrogen and formed diffusion
3 flames, we realized that these diffusion flames differed
4 in geometry essentially from diffusion flames known from
5 experiments. The usual diffusion flames are formed by fuel
6 gas come out at a pretty high velocity from a tube blowing
7 into air, entering air and forming a diffusion flame.

8 Here we have hydrogen bubbling out at a
9 relatively slow velocity over a large area. So we will
10 have a large cross-section area of slow-moving hydrogen
11 flow entering air. For this case we could not find
12 experimental data and proposed that experiments should be
13 carried out to be able to measure and determine the dimensions
14 of particularly the height of these diffusion flames.

15 Then while this was a joy to discover a
16 situation in flames which has not been fully explored in
17 experiments, we wanted to do this, then we realized that
18 the hydrogen flow rate from a single sparger would be only
19 about half a pound per second, which could be handled in
20 a large laboratory.

21 Therefore, we proposed why don't we make a
22 square tower built of concrete blocks or so with water
23 and a single sparger in full scale because it can be done
24 in full scale without a great effort, and then all considera-
25 tions of scaling can be omitted.

_Sim 11-11

1 Then came around ERPI and other people involved
2 and they said yes, there is another problem, too. Hydrogen
3 comes up, but air has to come down.

4 Previously we compared an area on which air
5 can flow down and found it plenty large to bring in air. So
6 it did not seem so important, but our other people insisted
7 because we have different stairways and platforms and so on
8 in this angular shell, and it would be a nice thing to make
9 an experiment, not a single sparger, but on the entire ring.

10 Now when we get to the entire ring, then the
11 dimensions get out of the scale of a laboratory and then
12 you have to go to a lower scale model.

13 So there is no contradiction between our original
14 recommendation to make full-scale tests. We did not say
15 you have to make a full-scale test. We said it is possible
16 to carry it out and now it is obvious that you have to make
17 scaled down model.

18
19
20
21
22
23
24
25
end Sim
sue fols

#12-1-SueT

Q Is this document a copy of the recommendation?

A (Witness Karlovitz) This is an attachment to that report, yes.

MS. HIATT: I would ask that this be admitted as OCRE exhibit.

JUDGE GLEASON: All right, the document will be designated as OCRE Exhibit Number 17.

MR. GLASSPIEGEL: May I have a copy to share with my witnesses?

(The document referred to is marked as OCRE Exhibit Number 17 for identification.)

MR. GLASSPIEGEL: We don't have any objection.

JUDGE GLEASON: Any objections?

MS. WOODHEAD: No.

JUDGE GLEASON: All right. The exhibit will be admitted as OCRE Exhibit 17.

(The document previously marked as OCRE Exhibit Number 17 for identification is admitted in evidence as OCRE Exhibit Number 17.)

(The document, OCRE Exhibit Number 17 follows.)

INDEXX

EXX

ATTACHMENT A

Experimental Study of H_2 Diffusion Flames
Burning Above a Pool of Water

While the general character of H_2 diffusion flames burning above a pool of water with restricted air supply can be predicted there is considerable uncertainty regarding the height of such flames. An experimental study of these flames is proposed which will allow the measurement of flame height and temperature, and observation of ignition by glow plugs and of flame stability.

The maximum H_2 flow rate through a single sparger is .5 lb/sec. Thus it is possible to do the experiment at full scale and avoid the scaling problem.



The experimental arrangement would consist of a 20' x 20' x 50' high concrete structure open at the top and containing an 18 foot deep pool of water. A single full scale sparger would be arranged in a position similar to that in the wetwell with three horizontal vent holes representing the connection between the drywall and wetwell (Figure A-1).

Glow plug igniters will be placed at locations corresponding to those in the wetwell. Observation windows and sampling ports will be arranged in the side walls for measurement of flame height, temperature and H_2 distribution along the flame.

In order to measure the transient ignition pressure the top of the structure may be closed temporarily with a cover containing an appropriate vent opening.

The experimental system described above will also be suitable to study the effect of splashing water and water sprays on the igniters and on the flame. Also tests of equipment survivability will be possible.

For safety the tests should be carried out at an open site with remote controls.



TOP VIEW

FIGURE A-1
WETWELL TEST CHAMBER

#12-2-SueT

1 MR. GLASSPIEGEL: Do you plan to ask any questions,
2 Susan, on the document?

3 MS. HIATT: I think I might have a couple, yes.

4 BY MS. HIATT: (Continuing)

5 Q The second paragraph of the document --

6 A Yes.

7 Q -- makes reference to doing the experiment at full
8 scale and avoiding the scaling problem.

9 A Yes.

10 Q Would you please elaborate on what problems there
11 are with scaling?

12 A In engineering experiments, one is frequently faced
13 with the necessity to carry out not full scale but reduced
14 scale experiments. You cannot put a 747 into a 747 into a
15 wind tunnel full scale. And there are innumerable such cases.

16 Now, the scaling law is different for different
17 physical phenomena. It's different for turbine generation in
18 a stream where you have to use the Reynolds number similarity. If this
19 is fulfilled, then the model is dynamically similar to the
20 full scale case and gives reliable results. This has been
21 used for many, many years.

22 In diffusion flame case, we are faced with a
23 buoyancy phenomenon. The hot gases move up and this movement
24 produces the turbulence which brings in the air to the flame.

25 Here, the modeling has to be done by the Froud

#12-3-SueT 1 number. And it turns out that if you go from a full scale
2 situation to a reduced scale situation, and your problem is
3 not a single phenomenon but several involved, you cannot
4 scale everything properly. You have to select the most
5 important phenomenon and scale that properly and show that
6 the other phenomena, for example, Reynolds number similarity,
7 also would be negligible. The error would be negligible.

8 That's what we've done here when we went from full
9 scale down to the one-twentieth order, one quarter scale.

10 Q The document also states that for the experimental
11 system you had proposed that tests of equipment survivability
12 would be possible.

13 Did you envision actual placement of items in the
14 specific --

15 A Yes. In the full scale model, you could put in
16 actual boxes and models and whatever you want to use. Sure.

17 Q Would you consider that approach preferable to
18 measuring heat fluxes and other parameters in a scaled
19 facility?

20 A No. Here we are faced with two separate problems.
21 Our original problem would have allowed full scale testing.
22 But extended problem brought in by EPRI and other people does
23 not allow a full scale testing.

24 Q Let me ask this. Would you generally consider
25 it preferable to test an actual piece of equipment than to

#12-4-SueT

1 measure heat fluxes and other parameters and do an analytical
2 calculation of its thermal response?

3 A It depends what is the situation, what are you
4 forced to do, what can you do, and what can you not do.

5 Modeling is used in the technique all the time for
6 very different purposes.

7 Q Mr. Richardson, isn't it true that the hydrogen re-
8 lease histories to be used in the quarter scale test facility
9 are to be developed from the BWR heatup code?

10 A (Witness Richardson) That's correct. Except for
11 one release history which we have proposed, which is to
12 simulate a low release rate from a possible prolonged degraded
13 core which possibly may get to seventy-five percent metal-
14 water reaction.

15 Q Is that BWR heatup code a public domain code?

16 A The BWR heatup code was developed in the Industry
17 Degraded Core Rulemaking Group, and it has been further
18 developed from that point through the Hydrogen Control Owners'
19 Group utilizing the Electric Power Research Institute, EPRI.

20 The code -- I'm not sure if the code is public
21 domain or not. I think we did submit the BWR heatup code
22 users' manual to the NRC and it was, to my knowledge, not a
23 proprietary document.

24 Q Has this code been verified by comparison with
25 experimental data?

#12-5-SueT

1 A There were some experimental data that was
2 evaluated in order to evaluate some of the correlations and
3 equations, but as you know it was no BWR with a degraded core
4 that could be used as a model to evaluate the whole core in
5 an experiment.

6 It has been verified against hand calculations and
7 problems that are well known and well founded, and that
8 experimental data as available on fuel and reactor inter-
9 actions has been used.

10 Q This code has undergone some limited NRC review;
11 isn't that true?

12 A It has undergone some NRC review.

13 Q Didn't the NRC's review uncover some faults with
14 the code?

15 A I would disagree that they uncovered faults. I
16 would say that there are some questions the NRC raised and
17 some issues they identified for the Owners' Group to take
18 under advisement and study further.

19 I think it involves a question as to whether ad-
20 ditional conservatisms should be added to account for any
21 uncertainties that might be in the code.

22 Q Isn't a feature of this code an irreversible
23 termination of zirconium oxidation, at a core known tempera-
24 ture greater than that specified by the input variable TOXOFF?

25 A That's correct.

#12-6-SueT

Q Has that been shown through experimental data?

A There are -- there is some experimental data that has been shown to substantiate the phenomena. The best data that has been provided was an evaluation by a gentleman during an NRC meeting from EG&G in Idaho, and his presentation showed that such oxidation -- oxidation is reduced above temperatures on the order of magnitude assumed by the Owners' Group if the localized oxidation fractions are less than on the order of point six eight, which the Owners' Group has evaluated the use of that in the BWR heatup code and shown that the assumptions made is consistent with that data.

Q Do you intend to conduct hydrogen combustion tests in the quarter scale facility using a quantity of hydrogen equivalent to that produced from a seventy-five percent metal-water reaction?

MS. WOODHEAD: Objection. Mr. Chairman, we've had about fifteen questions now on the final analysis which is still under development by the Owners' Group and NRC. And it clearly is beyond the scope of this contention.

JUDGE GLEASON: It is and it isn't. We have gone through this argument once before. And I made a ruling with respect to it.

And that same ruling applies. Your objection is denied. Please answer the question.

WITNESS RICHARDSON: Would you repeat the question?

BY MS. HIATT: (Continuing)

Q Okay. Do you intend to conduct hydrogen combustion tests in the quarter scale facility using a quantity of hydrogen equivalent to that released from a seventy-five percent metal-water reaction?

A At the present time, it is our intent to test a -- to conduct tests with a hydrogen release rate which would be consistent with a release rate from a degraded core which may reach seventy-five percent metal-water reaction.

Q Let me ask this. For tests in which you intend to produce diffusion flames, will the hydrogen release history there be equivalent to a seventy-five percent metal-water reaction?

A No. The rates which will sustain diffusion flame will not allow you to reach seventy-five percent metal-water reaction.

The oxidation rate is so high in generating that types of hydrogen generation that it would drive you into a very rapid and very high core melt which is beyond the scope of degraded cores and beyond the scope of this testing.

Q Now, when you define the thermal environments from the quarter scale facility, what type of margins do you intend to incorporate therein?

JUDGE GLEASON: Ms. Hiatt, you are drawing a pretty fine line with some of these questions. And I think you are

#12-8-SueT

1 entitled to find out just the general objectives as far as
2 the final analysis report is concerned. But as far as details,
3 I think that is beyond the scope of this contention.

4 So I think -- I agree that if Ms. Woodhead were to
5 raise that objection again that she raised before, I would
6 sustain it. But inasmuch as she didn't, I will have to say
7 that you can ask some general questions with respect to the
8 final analysis, but you ought to keep them general.

9 MS. HIATT: Mr. Chairman, I don't think it has
10 been determined yet exactly what is an appropriate --

11 JUDGE GLEASON: I understand that. But I think
12 there are some limits where we have to say that nobody in his
13 right mind would conclude that that could be anything other
14 than having to be included in the final analysis.

15 Now, when we reach that point I think you have to
16 make the questions more general, is what I'm saying. And I
17 think we have reached that point.

18 BY MS. HIATT: (Continuing)

19 Q Ms. Buzzelli, Page 21-D of your preliminary
20 analysis, you refer to the containment vacuum breaker and
21 hydrogen mixing compressor check valves as having an external
22 design pressure exceeded by hydrogen burn pressure; is that
23 correct?

24 (The witness is looking at a document.)

25 JUDGE GLEASON: Did you say Page 21-D?

#12-9-SueT 1

2 MS. HIATT: There was a March 21st, 1985 update
3 to the preliminary analysis which I received. I'm not sure
4 if it's in there.

5 JUDGE GLEASON: All right.

6 WITNESS BUZZELLI: Page 21-D?

7 MS. HIATT: Correct.

8 BY MS. HIATT: (Continuing)

9 Q Yes.

10 A Can you repeat your question?

11 Q Okay. Do you not refer therein to the containment
12 vacuum breaker and hydrogen mixing compressor discharge check
13 valves having a design pressure which is exceeded by hydrogen
14 burn pressures?

15 A That is -- the report does reflect that the ex-
16 ternal peak design pressure, which is provided and is exceeded
17 by the hydrogen burn peak pressure, that's correct.

18 Q But do you not anticipate that these components
19 will withstand pressures higher than the design pressures?

20 A Yes. And the reasoning is identified in that para-
21 graph if you care for me to read that into the record.

22 Q Well, let me just ask this. Has that assumption
23 been confirmed by testing?

24 A Specific tests on those components has not been
25 conducted to that hydrogen peak pressure. The expectation is
based on the component and its design, the material is used in

#12-10-SueT1

the expected capability of that component.

2 It reflects our preliminary evaluation of equipment
3 survivability, all of which will be dealt with again in the
4 long term program on a final basis.

5 Q Are Tables 5.6-1 and 5.6-2 of the preliminary
6 analysis intended to be complete lists of equipment to be
7 evaluated for survivability?

8 A (Witness Richardson) The preliminary evaluation --
9 in the preliminary evaluation they are intended to be complete
10 lists. There are some, as we discussed, the Hydrogen Control
11 Owners' Group program plan was still under discussion with the
12 NRC and if there are any additional items which must be con-
13 sidered as a result of discussions with the NRC on a long term
14 program, then further evaluations may be conducted.

15 Q Now, your tables do not list any components of the
16 reactor recirculation system, the B33 system. Is that true?

17 A That's true.

18 Q And isn't that system part of the reactor coolant
19 pressure boundary?

20 A The system, the piping, is part of the reactor
21 coolant pressure boundary.

22 Q And your tables do not list any components in the
23 control rod drive or C-11 system; isn't that true?

24 A That's correct.

25 Q And why do you exclude these components?

#12-11-SueT 1

2 A Most of the components that are inside the
3 containment, the control rod drive hydraulic system, are
4 used for normal operation of rods, and in some cases some
5 of the components are used for inserting the rods. And that
6 function would have occurred long before hydrogen combustion
7 so, therefore, the components are not included on the list.

8 Q Well, wouldn't it be true that if the accident
9 scenario producing the degraded core accident were an antici-
10 pated transient without scram, this equipment would be
11 important to maintain in a safe condition?

12 A If it is an anticipated transient without scram,
13 then those components didn't work in the first place.

14 Q But wouldn't you want to hope that their function
15 might be recovered at some point?

16 A First of all, the anticipated transient without
17 scram is not an event which is considered for evaluation and
18 has been eliminated because of the low probability of event.

19 Q Are you finished, sir?

20 A Yes.

21 Q Ms. Buzzelli, are you aware that Part Numbers
22 1-C-11-F0010, F -- 1-C-11-F0011, 1-C-11-F0 --

23 MR. GLASSPIEGEL: Would you slow down a little,
24 Ms. Hiatt?

25 BY MS. HIATT: (Continuing)

Q 1-C-11-F0180, 1-C-11-F0181, are scram discharge

#12-12-SueT 1 volume vent and drain valves located in the containment?

2 A (Witness Richardson) Would you repeat those numbers
3 again? I didn't hear them.

4 Q All right. 1-C-11-F0010, 1-C-11-F0011, 1-C-11-F0180,
5 1-C-11-F0181.

6 MR. GLASSPIEGEL: And the question was?

7 BY MS. HIATT: (Continuing)

8 Q Are you not aware that these are scram discharge
9 volume vent and drain valves located in containment?

10 A (Witness Buzzelli) Those may be the correct MPL
11 numbers. I don't have those memorized. We do have scram
12 discharge volume vent and drain valves.

13 Q Are you aware that they have only been qualified
14 to 185 degrees Fahrenheit?

15 A (Witness Richardson) That may be the case. They
16 are not included on the list, because they have performed
17 a function before the hydrogen event and, therefore, it's
18 not necessary to evaluate their survivability during and after
19 a hydrogen burn.

20 Q And are you aware that the HCU scram pilot valve
21 solenoid has only been qualified to 215 degrees Fahrenheit and
22 17 psig?

23 A That's -- I'm not aware of what they actually are
24 qualified to. It certainly is acceptable for the design
25 basis case, and they have performed their function prior to

#12-13-SueT 1 the hydrogen burning. Therefore, they are not included on
2 this list. It's not pertinent to this discussion.

3 Q Your tables also do not list any components of
4 the standby loop control system or the C-41 system, do
5 they?

6 A That's correct.

7 Q And why have you excluded those components from
8 the list?

9 A Again, the -- we have not included anticipated
10 transient without scram as an event that should be considered
11 for degraded cores, recoverable degraded cores, because of
12 the probability of event and also the probability of recovery
13 of that event to consider it for this analysis.

14 Since it's not necessary to consider it for this
15 analysis, the system is not necessary and don't meet the
16 criteria that were established and, therefore, systems which
17 should be included on this list and their criterias are
18 also included in the hydrogen rule.

END #12 19

Walsh flws 20

21

22

23

24

Ace-Federal Reporters, Inc.

25

1 Q Isn't it true that in a degraded core accident,
2 once the control blade sheath has melted, or has otherwise
3 been breached, that the boron carbide material therein will
4 react quite rapidly with steam?

5 A That has been postulated to occur for severe
6 cores, and things such as that. Severely degraded core.

7 Q Now if you were to recover a coolant injection
8 system, wouldn't there be a possibility of injecting cold
9 water into a core with diminished control rod worth?

10 A Excuse me. I guess I didn't follow that question.

11 Q All right. Supposing in the degraded core
12 accident, we have substantial oxidation of the boron --
13 reaction steam with the boron carbide. Then you recover
14 coolant injection system. Wouldn't there be a problem in
15 injecting cold water into a core with diminished control rod
16 worth?

17 MR. GLASSPIEGEL: I am going to object. If I
18 understood my witness' answer, and I am not 100 percent sure
19 I did on the last question, he testified that the hypothetical
20 that Ms. Hiatt is proposing involves a severely degraded
21 core. That again is well outside the scope of the issue.

22 JUDGE GLEASON: What is the purpose of the
23 question?

24 MS. HIATT: We are determining whether or not
25 components such as those in a standby with the control system

1 had been improperly excluded from the equipment list, and
2 this is a situation in which standby with the control system
3 would be important to have operational and functional in a
4 degraded core accident.

5 I want to know how far a degraded core can go
6 before it is not recoverable is, I understand, a question of
7 uncertainty. It is quite arbitrary to say in a severe accident
8 with no further explanation on it.

9 MR. GLASSPIEGEL: That is why we have expert
10 witnesses in hearings.

11 We could be here for a long time litigating
12 severe accident rulemaking. The Commission intended that we
13 not do that.

14 JUDGE GLEASON: Thank you, Mr. Glasspiegel.
15 Objection is denied. Respond to the question.

16 WITNESS RICHARDSON: Could we repeat the question.

17 MS. HIATT: Could you possibly reread it. I am
18 sorry.

19 REPORTER: It will take me a while. It is way
20 back there.

21 MS. HIATT: All right.

22 REPORTER: Want me to read it back?

23 MS. HIATT: Yes.

24 (Reporter reads last question to witness.)

25 WITNESS RICHARDSON: The question started out

1 with the premise it was a degraded core accident.

2 As I said, I could not answer the question in
3 context with recovery of degraded core. It would be much
4 beyond that point in time, and if you get much beyond that
5 point in time, then the question asked about the reduced
6 rod worth and whether it would be a problem or not when you
7 inject your water back in, it would depend on how much rod
8 worth, how much reaction, and a number of questions that
9 have not been -- or at least I have not evaluated because
10 it is beyond the scope of the recovery of degraded core.

11 Q Wouldn't it be useful in such a situation to
12 have the standby control system operable?

13 MR. GLASSPIEGEL: Objection. We are not litigating
14 whether --

15 JUDGE GLEASON: I think we had better get back on
16 course here, Ms. Hiatt. Those questions go too much beyond
17 where we are.

18 BY MS. HIATT: (Continuing)

19 Q Now, your tables list no components of the D-17
20 plant radiation monitoring system, is that correct?

21 A (Witness Richardson) That is correct.

22 Q Do you know why those components have been
23 excluded?

24 A Because those components do not provide any
25 direct automatic actions in the plant, and they are only

1 provided for monitoring, and the operator is not instructed
2 to take any action there from those monitors. Not necessary
3 to have those monitors on equipment possibility list for
4 evaluation for a hydrogen burn.

5 Q Wouldn't that give the operator some useful
6 information on the course of an accident, even if they are
7 not directed to consider them?

8 MR. GLASSPIEGEL: Objection. The witness
9 testified that the operator doesn't use the monitor.

10 She is asking: Wouldn't it be useful? What
11 does a question like that contribute to the record? He has
12 already answered the question.

13 BY MS. HIATT: (Continuing)

14 Q Your table lists no components of the drywell
15 containment, the M-14 systems, is that true?

16 A That is correct.

17 Q And why are those components excluded?

18 A They are not necessary for the hydrogen generation
19 event.

20 Q Don't they perform a containment isolation function?

21 A There are a number of valves which perform a
22 containment isolation function, and those components perform
23 their function long before the hydrogen generation event, and
24 therefore there is no need to evaluate them for the effects of
25 hydrogen combustion.

1 Q Doesn't the system contain large butterfly
2 valves with polymeric sheaths?

3 MR. GLASSPIEGEL: Objection. I think the witness'
4 answers have established --

5 JUDGE GLEASON: Whay? Go ahead.

6 MR. GLASSPIEGEL: My objection is the witness has
7 established that this particular component has no relevance
8 whatsoever in the hydrogen event.

9 Further questions along this line are --

10 JUDGE GLEASON: I don't know why she asked this
11 question. Go ahead, respond to it.

12 WITNESS RICHARDSON: I don't know the actual
13 details of those components, because we haven't looked at them
14 in detail since they are not on the list.

15 WITNESS BUZZELLI: The answer to your question
16 is, yes.

17 BY MS. HIATT: (Continuing)

18 Q Wouldn't it be possible for high containment
19 temperatures to degrade the polymeric sheaths on those valves?

20 A (Witness Richardson) I would say that I doubt it
21 seriously, because the type of temperature that we have-
22 evaluated for deflagrations, any component that is relatively
23 large, the temperature response of the component does not
24 result in that high temperatures.

25 Typically in the order of temperatures that most of

1 the components qualify for.

2 I am not sure where those components are located
3 exactly, but they are probably high in the containment, and
4 therefore they would not be affected by the diffusion flame.

5 So, without looking at them, I couldn't say for
6 sure, but my judgment is that they would have little effect.

7 Q Now, if you had thermal degradation of the valve
8 sheet, couldn't that cause leaks?

9 MR. GLASSPIEGEL: Objection. We are pursuing a
10 line of questions about --

11 JUDGE GLEASON: Sustained.

12 BY MS. HIATT: (Continuing)

13 Q Have you considered the potential for combustible
14 material in containment for a drywell to be ignited by
15 hydrogen burning?

16 A (Witness Richardson) That has been considered.

17 Q Is there any evaluation of that in your preliminary
18 analysis?

19 A There is no statement that -- specific issue.
20 There are analyses that were conducted in the preliminary
21 evaluation to show that the temperatures that result from the
22 Perry analysis, for the pressure and temperature response,
23 in the Perry analysis, are predicted -- that are predicted in
24 CLASIX results in equipment response which is less than that
25 which was predicted and analyzed for the Grand Gulf case.

1 And Grand Gulf evaluated those components --
2 basically the same components, for the potential for secondary
3 fires and things, and presented that to the NRC and showed that
4 there was no potential for secondary fires.

5 Q Did you evaluate this potential assuming diffusion
6 flames existed?

7 A Diffusion flames, thermal environment from the
8 diffusion flames has not been defined yet. It is quite a long
9 term program, and the capability of equipment will be
10 evaluated after the thermal environment of diffusion flames
11 is defined.

12 MS. HIATT: I have no further questions.

13 JUDGE GLEASON: I think this is an appropriate
14 time to take a break.

15 (Short recess taken.)

16 MR. GLASSPIEGEL: Thank you. I am ready.

XX INDEX

17 REDIRECT EXAMINATION

18 BY MR. GLASSPIEGEL:

19 Q Mr. Alley I would like to ask you a number of
20 questions concerning some of the testimony you gave yesterday
21 on the structural analysis. Have O ring seals been a safety
22 problem in your judgment for up to 300 degrees environmental
23 conditions?

24 A (Witness Alley) No, it is not.

25 Q Why not?

1 A We had reviewed some of the available information
2 on those seals. As noted earlier, they are etholene,
3 propalene, dyamene, compound number 603 seals, made by
4 Pethra Corporation.

5 The data available on those seals, as indicated
6 in the O ring reference guide, and also as calculated by
7 an erraneous equation, indicates that the compression set
8 is not a factor for the temperature, range, and durations
9 for which we are talking about for the hydrogen burn event.

End 13.
MS fols.

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Sim 14-1

1 Q In your structural analysis have you considered
2 mating surfaces between equipment hatch flanges and whether
3 there will be sufficient smoothness at the surfaces to prevent
4 any leakage?

5 A Yes, we have. We really manufacture drawings
6 for those mating surfaces because of a smoothness on that
7 mating surface of 80 micro-inches, which would be more than
8 adequate to facilitate the leak tightness of the seals.

9 Q Beginning at transcript 3283, Mr. Alley, you
10 gave testimony in response to questions from Ms. Hiatt
11 relating to the use of mean lower bound values in some of
12 your analyses. I believe you testified that analyses using
13 mean and lower-bound values as contained in your final
14 report were included primarily for informational purposes.

15 Would you please explain why your final report
16 contains analyses utilizing mean and lower-bound values
17 as well as the results of analyses using ASME service level
18 values?

19 A In approximately 1981 we had a request from the
20 NRC which stated several considerations that they wanted
21 us to make in establishing a containment ultimate capacity.
22 Two of those parameters were to consider as-built material
23 strengths and to consider a lower-bound mean and upper-bound
24 material properties.

25 The report was originally generated based on

Sim 14-2

1 those very early NRC requirements. The finally report,
2 which addressed the NRC request to establish the structural
3 integrity for a 45 psig and service level C limits did not
4 delete that earlier information.

5 The report as it is written today provides
6 all the information necessary that we satisfy the current
7 rule requirements for the pressure capacities at service
8 level C limits. However, the report does not clearly call
9 this out as a requirement in the report itself. It is a
10 little bit difficult to search through and find that
11 information.

12 Q What are the principal differences in the
13 analytical approaches that are used in these various
14 analyses discussed in your report?

15 A The analytical approaches are essentially
16 identical for the general shell. The main area of difference
17 between the analyses to address the 45 psig service level
18 C limits and the original penetration analyses were that
19 finite element analyses were done for the final analyses
20 to get a better prediction of their capability.

21 Q What differences in allowables were used in the
22 various analyses discussed in your final report?

23 A The original report addressed both mean and
24 lower-bound pressure capacities using yield as the guideline.
25 The final report used solely the service level C limits,

1 which for the membrane stress in the shell is also a yield
2 limit.

3 For other stress components, such as the bending
4 stresses, different allowables are permitted for those
5 particular stress components.

6 Q Thank you. Mr. Alley, I think it might be
7 helpful for the record if you were to highlight the portions
8 of your final report, Exhibit 8-4, which set out your
9 conclusions relating to ASME service level C allowables.

10 A Okay. The controlling pressure, as indicated
11 in our preliminary evaluation report, Exhibit 8-1 was the
12 50 psig pressure for the penetration four one four. This
13 value is found in our final report in Table 10, in Note
14 No. 5 of Table 10.

15 The general shell allowables at service level
16 C are provided in Table 8. These values have not been
17 factored up to give the pressure capacity of the containment
18 at service level C.

19 One of the key numbers to reference would be
20 for the cylinder. The stress intensity shown in Table 8
21 currently is 21,625 psi. The allowable stress intensity
22 at service level C is 38,000 psi. That particular stress
23 is calculated by the simple equation for a cylinder
24 unrestrained by stiffeners or other boundary conditions.

25 By merely ratioing the results up to the

Sim 14-4

1 allowable of 38,000 over 21,625 times the 35 psig pressure
2 included in the table, the cylinder capacity of 79.1 psi
3 can be easily calculated.

4 Q The term "KSI" was used yesterday and I believe
5 the day before. Would you please define the term for the
6 record?

7 A KSI is a unit meaning kips per square inch. A
8 kip is equal to a thousand pounds. So 10 KSI is 10,000
9 pounds.

10 Q And for what purpose are qualifications based
11 on kips used with respect to your analysis?

12 A They are used to quantify the stress.

13 Q Are the material properties of SA-516 rolled
14 plate used in the containment taken in the test strength
15 direction?

16 A For SA-516, Grade 70 plate, since that is a
17 normalized plate material, it does not make any difference
18 which direction the coupon is taken for your tensile test.
19 The material has homogeneous properties in each direction.

20 Q At transcript 3286 you discuss the fact that
21 for the temperature ranges expected to result following a
22 hydrogen event the ASME Code provides for a reduction in
23 stress allowables of approximately 10 percent. Would
24 this reduction be applicable to the 50 psi controlling
25 stress limit calculated for penetration 414 in your final

14-5 1 report?

2 A Yes, it would. However, the analysis of
3 penetration 414 did not include the actual material strengths
4 of that penetration.

5 A review of those material certs. indicates that
6 it has an actual material strength a minimum of 30 percent
7 higher than the minimum specified material strengths.

8 Q And, therefore, what is your conclusion with
9 respect to the 10 percent value that was discussed previously?

10 A This actual material cert. showing it is 30
11 percent higher would mean we would have 30 percent greater
12 capacity for that particular penetration.

13 Q Is this further evidence of the conservatism in
14 your analysis?

15 A Yes, it is, and even beyond that, that addi-
16 tional analytical techniques could be used to demonstrate
17 the further capability of that particular penetration.

18 Q Based on your interpretation of the final
19 hydrogen rule, is the use of ---

20 MS. HIATT: Objection. It calls for a legal
21 conclusion, interpretation of the rule.

22 MR. GLASSPIEGEL: We must interpret the rule
23 in order to try to comply with ---

24 JUDGE GLEASON: We are not really going to
25 be necessarily bound by it. So let him interpret it.

Sim 14-6 1

BY MR. GLASSPIEGEL:

2 Q Based on your interpretation of the rule,
3 Mr. Alley, were the analytical techniques that you just
4 discussed, are these analytical techniques consistent with
5 the guidelines provided in the rule?

6 A (Witness Alley) Yes, they are.

7 Q Turning to the version of the final rule, the
8 Federal Register version dated January 25, 1985, in Section
9 50.44 C-3 4-B and the various sub-sections thereunder, I
10 would ask you whether you have since preparing your final
11 report had occasion to review the final requirements set
12 forth in that section?

13 A Yes, I have.

14 Q And based on your interpretation of the language
15 in the rule, is your report on the analytical techniques
16 utilized in your report fully consistent with the guidelines
17 set forth in the rule?

18 A Yes, it is.

19 Q I want to show you a copy of the section and
20 ask you if you could to just track through the section and
21 comment upon the extent to which your report follows the
22 guidelines set forth in subsection B of 50.44 C-3 4-B?

23 (Pause.)

24 The first sentence in subsection B of 50.44
25 C-3-4 states that "Containment structural integrity must

Sim 14-7

1 be demonstrated by use of an analytical technique that is
2 accepted by the NRC staff."

3 Was your report consistent with this
4 requirement?

5 A Yes, it was.

6 Q The subsection reads further "This demonstration
7 must include sufficient supporting justification to show
8 that the technique describes the containment response to
9 the structural loads involved."

10 Do the techniques that you have utilized in
11 your final report adequately describe the containment
12 response to the structural loads involved?

13 A Yes, it does.

14 Q The subsection further states that "This method
15 could include the use of actual material properties with
16 suitable margins to account for uncertainties in modeling,
17 in material properties, in construction tolerances, and
18 so on."

19 To what extent have you used actual material
20 properties with suitable margins in your analysis,
21 Mr. Alley?

22 A We have only used actual material certs.
23 currently in one case for the service level C limits
24 established in our report.

25 Q Did the use of those material properties

Sim 14-8

1 include suitable margins?

2 A Yes, they did.

3 Q The rule further states that another method
4 could include a showing of the following specific
5 criteria of the ASME boiler and pressure vessel code are
6 met, and the rule sets forth a number of criteria there-
7 under. Could you state for the record which of those
8 criteria are applicable to your final report?

9 A We have established that the containment
10 vessel and all key components meet the service level C
11 requirements of the ASME code.

12 Q And was this based on a consideration of
13 pressure and dead weight alone?

14 A Yes, it was.

15 Q Using actual material properties and taking
16 into account the temperatures expected following a hydrogen
17 event, do any parts of the containment, other than the
18 limiting penetration 414, have a stress limit below 15 psi?

19 A No, I do not believe so.

20 Q There was discussion in OCRE Exhibit 13 of the
21 Aptech review yesterday. I want to ask you whether the
22 Aptech review, to your knowledge, considered the temperatures
23 expected following a hydrogen event?

24 A No, it did not.

25 Q Would the conclusions in the Aptech report

Sim 14-9

1 be affected by considerations of the elevated temperatures
2 expected following a hydrogen event?

3 A No, they would not, and I would like to read
4 you, if I may, two references out of that report.

5 On page 2-5 of OCRE Exhibit No. 13 it states
6 "The temperature dependence of toughness properties means
7 that at ambient or higher temperatures both SA-516 steel
8 and E-7018 weld metal are above their lower shelf values
9 on a fracture energy versus temperature curve. This, in
10 turn, implies that the use of standard elastic fracture
11 mechanics will be conservative."

12 A second reference, which is on page 5-5, of
13 the same report states "The test temperature used to
14 evaluate K sub IC, which is the fracture toughness, is
15 minus 20 degrees F, whereas a higher temperature during
16 operation will result in correspondingly higher toughness."

17 My conclusion is that the analysis is in fact
18 conservative and were you to use higher temperatures, the
19 results would even be more favorable.

20 JUDGE GLEASON: Which analysis?

21 WITNESS ALLEY: The Aptech fracture fatigue
22 analysis.

23 BY MR. GLASSPIEGEL:

24 Q There were some references that you gave
25 in response to Ms. Hiatt's questions when we were talking

Sim 14-10 1

2 about the Aptech report and your report and in some cases
3 you referred to our review.

4 In the context of the Aptech study it might
5 be helpful to clarify for the record what the relationship
6 was between Gilbert and Aptech.

7 A Gilbert/Commonwealth hired Aptech Engineering
8 Services, who are specialists in the area of fracture
9 fatigue analyses to evaluate the defects in these weld
10 joints to demonstrate their acceptability to the operation
11 of the plant for the 40-year life of the plant.

12 Q When the Aptech report was complete did you
13 review that report?

14 A We did review that report.

15 Q Were you satisfied with the conclusions
16 in the report?

17 A Yes, we were.

18 Q In testimony on Tuesday at transcript 3306
19 you referred to "postulated hydrogen burn pressures at
20 50 psi." Would you care to clarify that reference?

21 A Yes. I inadvertently said postulated hydrogen
22 burn pressures of 50. I should have been referring to
23 the 21 psi that was postulated. The 50 is the limiting
24 containment pressure capacity for penetration 414.

25 Q To your knowledge, did the Aptech report, OCRE
Exhibit 13, in Table 3-1 take credit for the concrete in

Sim 14-11

1 the Perry containment annulous?

2 A No, it did not. Again, stresses were
3 conservatively calculated to ensure the conservatism
4 of the report.

5 Q At transcript 3314 you testified that the
6 potentially rejectable weld defects referred to in the
7 Aptech report are in the area that is backed by annulous
8 concrete. Would you care to clarify your answer to that
9 question?

10 A Yes, I would.

11 JUDGE GLEASON: This is strange kind of
12 redirect, some of your question, Mr. Glasspiegel. Your
13 redirect is supposed to be talking about new facts
14 developed in cross-examination. You are supposed to
15 rehabilitate the witness as far as impeachment is
16 concerned and, you know, you are just using this as a
17 method of getting new testimony and you know that is
18 improper.

19 MR. GLASSPIEGEL: The question referred to
20 testimony in response to Ms. Hiatt's questions at
21 transcript 3314, and I wanted to address the testimony that
22 was given in response to Ms. Hiatt's questions.

23 JUDGE GLEASON: That is not the way I heard
24 it. You referred to testimony again and you asked him
25 to amplify his testimony.

Sim 14-12 1

MR. GLASSPIEGEL: Well, on that particular
one is was more in the way of a clarification of the
testimony or a correction of the testimony.

JUDGE GLEASON: That is what I am saying. I
just think redirect is not supposed to be used for that
purpose. You know, we went through a whole series of
questions which I didn't say anything to, and of course
you have got to be held to a higher standard than of
course the intervenor.

You talked about the rule and I let you go
through all that thing and it was merely putting in
new testimony. That is rebuttal inforamtion. It is not
redirect information.

MR. GLASSPIEGEL: The purpose of my examination
is to attempt to clarify the record. On the rule, the
problem I had with Ms. Hiatt's cross-examination for a
day and a half was many of the questions fell outside the
rule as we interpret it.

Now I thought it would be helpful for the
record to clarify which portions of the structural
analysis ---

JUDGE GLEASON: All I am saying to you is
I think that is refutational type of material and it should
be put in with rebuttal testimony so we keep the record
straight.

Sim 14-13

1 MR. GLASSPIEGEL: Well, as I ask my questions
2 I will pause and see if you consider them to be appropriate.

3 JUDGE GLEASON: Well, I don't really like to
4 proceed that way. All I am doing is pointing out to you
5 to keep redirect in the redirect area.

6 BY MR. GLASSPIEGEL:

7 Q At transcript 3345, Mr. Alley, Ms. Hiatt asked
8 about different stress levels. I frankly don't recall, but
9 Mr. Silberg believes that I didn't get an answer to the
10 last question. I don't know whether you want to permit
11 an answer.

12 JUDGE GLEASON: I don't want to permit it.

13 MR. GLASSPIEGEL: All right, fine. I will
14 move on.

15 BY MR. GLASSPIEGEL:

16 Q At transcript 3345, Ms. Hiatt asked, Mr. Alley,
17 about different stress levels due to differences between
18 as-built dimensions of the containment vessel and the values
19 called for in the specification. Ms. Hiatt asked you to
20 compare the ideal circumferential stress for element No. 88,
21 a 5.886 KSI to the as-built calculation of 7.103 KSI.

22 You stated that the difference was a little more
23 than 1 KSI, which is about 20 percent. What is the effect
24 of the 20 percent increase in calculated stress levels due
25 to as-built conditions?

Sim 14-14

1 A In that non-conformance report Newport News
2 had summarized in the conclusions of that report on page 6
3 of Attachment 6 that NCR 17-426 that the largest increase
4 in the circumferential stress, which was a bending stress,
5 was approximately 4.37 percent.

6 In the vertical direction the increase in vertical
7 bending stress was approximately 9 percent.

8 I would like to clarify that the shell
9 capacity in the cylindrical shell region is only marginally
10 affected by those slight increases in stress caused by the
11 as-built conditions. The pressure capacity in the cylindrical
12 shell region is about 79 KSI. Even if you very conservatively
13 assume that that stress was proportionately reduced, you would
14 still have a pressure capacity well above the 50 psi minimum
15 for the controlling penetration.

16 Q You were asked a number of questions by
17 Ms. Hiatt about the dome region and the buckling analysis.
18 Why is the dome region a limiting region with respect to
19 buckling?

20 A The dome region is limited with respect to
21 buckling, it is the only area of the containment vessel which
22 is affected by buckling for an internal pressure. The
23 pressure capacity of the dome in that region is about 78 psi.

#15-1-SueT

1 Q What is the pressure capacity for the cylindrical
2 region about which you were asked?

3 A (Witness Alley) About 79 psi.

4 Q At Transcript 3350, you stated that the methodology
5 used in your ultimate capacity report was to analyze the shell
6 first and then separately analyze the penetrations including
7 a large segment of the shell.

8 Is this technique the standard method of analysis?

9 A Yes, it is.

10 Q At Transcript 3361, there was a discussion on
11 different yield criteria.

12 Did your analyses use the maximum shear stress
13 yield criteria as provided for in the ASME code?

14 A Yes, it did.

15 Q At Transcript 3361, you stated that you would ex-
16 pect to see displacements on the order of one-half inch for
17 penetrations.

18 Would you expect a one-half inch displacement to
19 cause leakage or loss of structural integrity?

20 A No, I would not. The stresses are well within the
21 elastic range and that's a small displacement for the
22 geometry of the structure involved.

23 Q You were asked at Transcript 3400 about whether
24 finite element analysis provides upper bounds on buckling
25 loads. And I believe you were unsure of this question at that

#15-2-SueT

1 time. Have you considered the question since then?

2 Are you now able to answer the question?

3 A Yes. We have considered it some more. We do
4 believe that nonlinear finite element analyses used to evaluate
5 buckling would provide upper bounds on the buckling loads.

6 However, Gilbert Commonwealth did not use finite
7 element analyses to predict buckling capacities to analyze
8 ultimate capacities of the containment vessel.

9 Q In those areas where you did use finite element
10 analyses, is it your professional opinion that the use of
11 that technique was consistent with accepted standards of
12 structural analysis?

13 A Yes, it is.

14 Q At Transcript 3411, you were asked by Ms. Hiatt
15 whether there was a lower factor of safety at 50 psi than at
16 15 psi, using service level C limits.

17 I would like you to clarify whether there is
18 a different factor of safety for the 50 psig stress capacity
19 limit calculated in your report as compared with a factor of
20 safety for the 15 psig design limit.

21 A No, there isn't. For the 15 psig design basis,
22 there are additional loads which must be included in calculat-
23 ing the stress.

24 Some of these load combinations use both service
25 level C and service level D limits of the code, and as permitted

#15-3-SueT

1 by the NRC. The new hydrogen rule requires the use of the
2 service level C limits; therefore, there is no reduction in
3 the factor of safety.

4 Q Ms. Buzzelli, I have a couple of redirect questions
5 for you. At Transcript 3264 and adjoining pages, you were
6 asked about a November 15, 1984 meeting that was held with
7 the Staff, and there was a discussion of offsite dose values.

8 I would like you to describe in greater detail the
9 meeting that occurred.

10 A (Witness Buzzelli) The meeting between CEI re-
11 presentatives and NRC Staff was a meeting to discuss contain-
12 ment system issues, and related to pool dynamic loads as
13 well as 10 CFR of Appendix J, containment testing.

14 In that meeting, proposed increase to bypass leakage,
15 and very preliminary offsite dose estimates were discussed.
16 The tables that we presented were for bounding estimates to
17 characterize the changes to the input parameters and the off-
18 site dose calculations.

19 Q Has subsequent work been performed in light of
20 the offsite dose analyses that were the subject of that meet-
21 ing?

22 A Yes. Additional calculations have been made. They
23 have been performed in accordance with the NRC requirements
24 and in accordance with the Regulatory Guides.

25 And the preliminary results relative to the numbers

#15-4-SueT

1 identified in the November 15th meeting, specifically the
2 299.6 rem thyroid dose at the exclusion boundary, present
3 results factoring in -- taking into account the assumptions
4 for the NRC requirements show that dose value to be less than
5 200, more on the order of 170 rem.

6 This is based on taking into account accident
7 meteorology, using seven year data as well as factoring in
8 the iodine removal. When you factor containment sprays into
9 account, a similar reduction in the low population zone dose
values would be expected.

11 Q Are there any other differences between the cur-
12 rent work that is being performed and the values presented
13 in that November 15, 1984 meeting?

14 A No. All of the other parameters are as identified.

15 Q In your judgment, are the current dose values
16 that have been calculated conservative?

17 A Yes. The current results that have not been
18 finalized in the FSAR are conservative because of the
19 conservatisms inherent in the NRC requirements, such as
20 extending the maximum leakage for a full thirty day duration
21 of the event, using the fifth percentile meteorology values,
22 using -- taking no credit for pool scrubbing, and a number
23 of other conservatisms.

24 Q How much of an overestimate of the doses does this
25 represent, the actual doses would this represent, in your

#15-5-1 SueT

judgment?

2 A An exact number -- I don't have an exact number,
3 together all of these parameters and others would be at less
4 an order of magnitude or greater.

5 Q And is it your conclusion that the current leakage
6 in offsite dose limits being considered provide significant
7 margins over the expected values?

8 A That is correct.

9 Q Mr. Holtzclaw, I would like to ask you a number of
10 questions about some of the exhibits that Ms. Hiatt referred
11 to over the last two days.

12 OCRE Exhibit 12 has been introduced and it relates
13 to your testimony concerning the likelihood of degraded cores
14 or severe accidents.

15 Please provide some background on why the Exhibit 12
16 letter was sent to GE.

17 A (Witness Holtzclaw) The Nuclear Regulatory Com-
18 mission has a proposed policy regarding severe accidents. It
19 requires an application for a future standard plant design,
20 such as the GESSAR II design, to comply with requirements of
21 10 CFR 50.34(f), which has been commonly referred to as the
22 construction permit manufacturing license, or CP/ML rule.

23 Paragraph 1(i) of the CP/ML rule requires the
24 applicant to assess improvements in the plant design that have
25 potential for significant risk reduction and are practical but

- #15-6-SueT 1 do not impose an excessive economic impact on the plant.

2 I might point out that Perry does not involve an
3 application for future standard plant design.

4 The April 13th NRC letter, OCRE Exhibit 12, was
5 sent to GE, to aid GE in assessment of a number of potential
6 design improvements in accordance with the Paragraph 1(i) of
7 the CP/ML rule.

8 Q Does the evaluation of these proposed design im-
9 provements identified in the exhibit, in your view, reflect
10 a perception of the level of safety as indicated by the likeli-
11 hood of degraded core accidents for the Perry BWR-6 MARK III
12 design?

13 A No, because the rule requires, as I said, that an
14 applicant for a future standard plant design perform these
15 evaluations of proposed design improvements irrespective of
16 the likelihood of degraded core or severe accidents for the
17 design that is undergoing review.

18 As I also indicated, Perry does not involve an
19 application for a future standard plant design.

20 Q Based on your knowledge of the discussions between
21 GE and the NRC, has the NRC suggested the design improvements
22 listed in OCRE Exhibit 12 because the NRC disagrees with the
23 likelihood of degraded core or severe accidents is extremely
24 remote?

25 A No. The NRC has not suggested that these design --

- #15-7-SueT 1 or has not suggested these design improvements because they
2 do not agree with the low likelihood of degraded core or
3 severe accidents.

4 As noted in my testimony, an independent review by
5 the NRC Staff and its contractors resulted in a core damage
6 frequency value of approximately two times ten to the minus
7 fifth per reactor year, which supports the conclusion that
8 core damage events which lead to significant quantities of
9 hydrogen generation are very low in likelihood.

10 Q Did GE's assessment of the suggested improvements
11 identify any need for these improvements?

12 A No, it did not. In fact, many of the suggested
13 improvements had already been incorporated in the BWR-6
14 MARK III design prior to the April 13th, 1984 NRC letter.

15 For example, the NRC letter included a number of
16 design modifications such as the post-Three Mile Island accident
17 modifications covered in NUREG 0737 that had been incorporated
18 into the design.

19 GE's evaluation of those items that were not already
20 included in the design indicated that none provided significant
21 risk reduction and none could be incorporated into the plant
22 design without excessive impact.

23 In NUREG 0979, Supplement Number 2, which is the
24 NRC Safety Evaluation Report related to the final design
25 approval of the GESSAR II BWR-6, Nuclear Island Design, dated

#15-8-SueT 1 November 1984, the Staff states, and I quote: "On the
2 basis of the results of current Staff analyses using cur-
3 rently available methodology, the Staff believes that very
4 costly preventive or mitigative plant design modifications
5 to the GESSAR II design cannot be justified on a risk reduction
6 basis."

7 Q Ms. Hiatt asked you a number of questions about
8 NUREG CP-0038 at Transcript 3286 and adjoining pages. And
9 I believe you testified that you were not intimately familiar
10 with the paper that was included among the papers in that
11 proceeding.

12 The paper was by General Electric, and it was
13 entitled "Assessment of Hydrogen Combustion Effects in a
14 BWR-6 MARK III Standard Plant."

15 Have you now had the opportunity to become familiar
16 with that paper?

17 A Yes, I have.

18 Q What was the purpose and the scope of the study
19 discussed in the paper?

20 A As stated in the abstract on Page 266 of NUREG
21 CP-0038, the study was performed as part of the GESSAR II
22 probabilistic risk assessment. As part of the PRA, it consider-
23 ed the full range of possible hydrogen phenomena regardless of
24 how improbable they might be. The report discussed the GE
25 consideration of potential hydrogen combustion effects on the

#15-9-SueT 1 standard plant MARK III containment during postulated severe
2 accident sequences, which were assumed to progress directly
3 to full core melt.

4 It should be noted that at the time the analysis
5 was performed, the GESSAR II design did not incorporate a
6 hydrogen igniter system which would have controlled the com-
7 bustion of hydrogen as it evolves. Therefore, the study dealt
8 with uncontrolled combustion of hydrogen during postulated
9 severe accidents which are allowed to progress to full core
10 melt.

11 Q Mr. Holtzclaw, let me show you a page from the
12 transcript of the April 30th proceedings in which one of
13 the witnesses read into the record a paragraph from that
14 paper.

15 (Mr. Glasspiegel is showing the witness the
16 transcript.)

17 What is the applicability of the information
18 given in that paragraph that Ms. Hiatt asked to be read into
19 the record? It starts at Transcript 3287, Line 16, for the
20 record.

21 A The information provided in Transcript 3287,
22 Line 16, is not applicable to the Perry Plant preliminary
23 evaluation of hydrogen control for two principal reasons.

24 The first is that that paragraph assumed non-
25 recoverable 4 core melt sequences and, therefore, the hydrogen

#15-10-SueT1 release history is substantially different than that for a
2 recoverable sequence.

3 Secondly, as I stated in response to a previous
4 question, there was no distributed ignition system utilized
5 in the design which would control the combustion of hydrogen
6 as it evolved. In fact, the design assumed no system for
7 controlling large quantities of hydrogen.

8 Therefore, based on these two reasons, the tempera-
9 tures, heat fluxes and burn characteristics were not re-
10 presentative of those expected for a recoverable event.

11 Q Mr. Holtzclaw, there was some testimony given dur-
12 ing the cross-examination today regarding the role of net
13 positive suction head NPSH, as related to suppression pool
14 cooling.

15 Is it true that in the BWR-6 design the LPCI,
16 L-P-C-I, LPSC, L-P-S-C, and HPCS, H-P-C-S, pumps are designed
17 for adequate NPSH with maximum flow and thermally saturated
18 pool temperatures? That is, 212 degrees Fahrenheit at atmos-
19 pheric pressure?

20 A Yes, that's true.

21 Q And is it true that GE has performed analyses for
22 events well beyond the design basis with no suppression pool
23 cooling and has shown that the BWR-6 RHR pumps, which perform
24 the containment spray and LPCI functions, will continue to
25 operate at pool suction temperatures of at least 210 degrees

#15-11-SueT 1

Fahrenheit?

2 A Yes, sir. That has been shown.

3 Q Mr. Richardson and Ms. Buzzelli, there was some
4 discussion today about OCRE Exhibit Number 16, the location
5 of igniters.6 And I would like to ask either of you one or two
7 questions about that document and its applicability to your
8 preliminary analysis.9 If one were comparing the information in OCRE
10 Exhibit Number 16 with corresponding information contained
11 in Applicants' Exhibit 8-1, the preliminary evaluation, and
12 if, with respect to any particular igniter, the information
13 in the two documents indicated that there was for the same
14 igniter the same elevation, the same azimuth, and the same
15 center lines given for that particular igniter, would it
16 necessarily be true that the final location of the igniter
17 in the plant would be the same?18 A (Witness Buzzelli) No, it would not necessarily
19 be true. The same elevation and the same azimuth, the same
20 distance from the center line, that information as reflected
21 in OCRE Exhibit 16 was preliminary information.22 The as-built information contained in the prelimi-
23 nary evaluation did allow for installation tolerances in
24 accordance with the spacing criteria that was defined and is
25 established in the preliminary evaluation. So, it would not

#15-12-SueT

1 be a one-to-one correspondence between the proposed location
2 and the final as-built locations because of construction and
3 installation tolerances.

4 Q And I believe Ms. Hiatt, in referring to OCRE
5 Exhibit Number 16, pointed to the column of the document
6 entitled "Location Description," and I want to ask you with
7 respect to the location descriptions that are given in the
8 exhibit whether those descriptions were intended for, or are
9 in fact, precise descriptions of the locations of the igniters
10 with respect to any adjacent structures in particular?

11 A That description was not intended to be a precise
12 description of the adjacent structures relative to the igniter.

13 It was intended to be a qualitative reference.
14 For example, it may have said HCU floor, and that igniter
15 would have -- could have been above the HCU floor or below
16 the HCU floor, and that was not specifically called out. In
17 addition, when it said room ceiling, for instance, an igniter
18 would not necessarily be at the ceiling. It could be at a
19 location high on the wall and near that ceiling.

20 There was no intention of representing exactly the
21 adjacent structures with that written description in the
22 column of the preliminary list.

23 Q Ms. Hiatt asked a number of questions today about
24 the possibility that there might be a need to vent or purge
25 the containment. I want to ask the panel what the likelihood

#15-13-SueT 1

2 would be in your judgement that there would be a need to
3 vent or purge the containment in the event of a hydrogen
4 generation event such as that that you have analyzed in the
5 preliminary analysis?

6 A (Witness Richardson) The probability of such a
7 venting during a hydrogen generation event would be very low.

8 Q Ms. Hiatt also asked some questions about a station
9 blackout scenario. With respect to potential station blackout,
10 Mr. Richardson, at what point would you expect significant
11 quantities of hydrogen to first get generated?

12 A Well, the events that we have analyzed consider
13 hydrogen generation in the early part of the event, and for
14 station blackout event is the reactor core isolation cooling
15 system which would still be operable and would maintain coolant
16 makeup.

17 As long as coolant -- as long as there is coolant
18 makeup and water level is maintained there is no hydrogen
19 generation.

20 Now, the evaluation is conducted on this plant to
21 show that the reactor core isolation cooling system has the
22 capability to maintain core makeup in a station blackout
23 event to at least nine hours. And it makes it more of a
24 long term containing heat removal event as opposed to a
25 hydrogen generation event, as we have analyzed it.

Q During this nine hour period, what things can be

#15-14-SueT 1

done to restore or maintain containment cooling?

2

A Well, there is one point that most risk studies

3

do not consider, the things that can be done during this

4

time period, in that the operators have a lot of time over

5

nine hours to provide additional sources of makeup into the

6

vessel which might not normally be lined up.

7

For instance, they can provide ways of getting

8

water either into the vessel, or into the containment, by

9

using the diesel driven fire pumps. There are a number of

10

ways that can be used to get additional makeup into the

11

vessel or the containment for decay heat removal.

12

And in nine hours, you can do a considerable number

13

of things, and you have plenty of time to restore power even.

14

END #15 15

Walsh flws 16

17

18

19

20

21

22

23

24

25

1 Q Is suppression pool temperature, by which you
2 were asked by Ms. Hiatt today, a relevant consideration for
3 a hydrogen generation event?

4 A No. The questions that were asked previously
5 by Ms. Hiatt have to do with the design basis calculations
6 for suppression pool, and the peaks varies after a long period
7 of time after the initiation of design basis event on the order
8 of like four hours or so, and as you can see in the preliminary
9 evaluation most of the hydrogen burning is occurring early
10 in the first one or two hours, and it would be an insignificant
11 effect on suppression pool.

12 Q Thank you. I believe Ms. Hiatt asked the panel
13 today about the draft emergency procedure guidelines, and
14 what draft instructions are in those guidelines for the
15 operator.

16 Do the draft emergency procedure guidelines
17 instruct an operator to actuate sprays at high, high temperature
18 regardless of core temperature?

19 A No.

20 Q Would there be a situation in which the -- under
21 the emergency procedure guideline draft instructions, -- sprays
22 would be actuated by the operator on temperature irrespective
23 of core cooling?

24 A There is no step in the guidelines for actuating
25 the sprays based on containment temperature, irrespective of

1 core cooling.

2 Q Are the sprays in the PNPP containment redundant,
3 and do they meet all NRC requirements and single failure
4 criteria?

5 A Yes.

6 Q What assures maintenance of the containment
7 integrity if the operator follows the emergency procedure
8 guidelines in the areas of my questions?

9 A Well, there are other steps in the guidelines
10 which the operator would take to assure that containment
11 integrity is maintained, and there are a number of steps
12 throughout the guideline.

13 Q What systems are required for heat removal follow-
14 ing a hydrogen event?

15 A RHR System is a system designed to meet long term
16 decay heat removal. There are two RHR systems that remove
17 long term decay heat removal, RHR-A and RHR-B.

18 Q And how do you know that these systems will survive
19 the hydrogen event, and assure safe shutdown?

20 A The components -- pressure pool cooling, for
21 instance, are all located -- all the active components are
22 located outside the containment.

23 Q Ms. Hiatt asked a number of questions today about
24 the impact of local suppression pool temperatures. What is
25 the impact of local suppression pool temperatures. Elevated

1 temperatures following a hydrogen event?

2 A Localized elevated temperatures in a suppression
3 pool have really no effect on hydrogen generation event.

4 Q And why not?

5 A Because, as I said before, the temperature of the
6 suppression pool has not increased to the types -- considerations
7 Ms. Hiatt was mentioning this morning during the time that we
8 have considered hydrogen burning.

9 Q If you only have the containment sprays available
10 hypothetically, and no additional pool cooling, will the
11 operators at the Perry Plant still be able to ensure long term
12 decay heat removal?

13 A Yes.

14 Q Why is that?

15 A As I said, in the testimony previously, the RHR
16 system, even in the spray mode, goes through the RHR heat
17 exchanges, so the heat would be removed to the heat exchanger
18 and would be sprayed into the containment.

19 So, you would have long term decay heat removal
20 irrespective of whether it was in cooling mode or in the
21 spray mode.

22 Q Mr. Richardson, Ms. Hiatt asked you today -- and
23 I can't quote her words exactly -- but I believe she asked
24 you whether Mr. Humphrey's work was valid. And you replied
25 yes to that. How were you interpreting the phrase, 'valid,' in

1 that context?

2 A My interpretation of the phrase, 'valid' were some
3 of his engineering calculations and analyses valid, and I would
4 have to say that some of his calculations which were just
5 straight forward, simple calculations -- simplified calculations
6 were valid.

7 However, the conclusions reached were certainly not
8 valid. Those issues were, as I said this morning, were reviewed
9 by Mississippi Power and Light and other Mark-3 utilities, and
10 the NRC and several presentations were made before the
11 Advisory Committee for Reactor Safeguards on those issues, and
12 I think the conclusion was that they were all second or third
13 order effects and not significant from the safety standpoint.

14 Q With respect to the paragraph that Ms. Hiatt asked
15 you to read into the record today, were the issues discussed in
16 that paragraph issues associated with design basis accident
17 or were they issues associated with hydrogen generation
18 conditions?

19 A They were associated with design basis considerations
20 and design basis calculations. The effects are even minimal
21 for design basis considerations, yet alone hydrogen generation.

22 Q Doctor Lewis, Ms. Hiatt asked you today a number
23 of questions about ionizing radicals -- ionized radicals, and
24 I want to ask you a followup question to that.

25 Based on your review of the PNPP hydrogen control

1 system, how that system would operate, what is your judgment
2 as to whether the ionizing radiation level that would be
3 expected following a hydrogen event would create enough
4 radicals to cause detonations?

5 A (Witness Lewis) It would be much too low.

6 REPORTER: Judge, may I ask the witness to
7 please speak up. I didn't hear you well, sir.

8 WITNESS LEWIS: The ionizing radicals would be
9 much too low for generating a detonation.

10 The radicals would not -- it they were in high
11 concentration would not be effected by virtue of their being
12 ionized, but by virtue of their being radicals.

13 Q Thank you. Have the NPSH curves been reviewed
14 for the Perry ECCS pumps?

15 A (Witness Richardson) Yes, they have.

16 Q Will the, 'caution,' which was discussed in
17 answers to Ms. Hiatt's questions earlier today apply to the
18 Perry Plant?

19 A No. There is no need to include that caution
20 in the Perry emergency procedures, because the calculation
21 shows that the NPSH would be adequate for the worse case
22 expected condition.

23 Q Ms. Buzzelli, do you know what the tech spec limit
24 is for drywell bypass leakage in terms of A over square root
25 K?

1 A (Witness Buzzelli) The tech spec limit in terms
2 of A over square root K, is .168. Earlier today -- and I
3 would like to clarify -- the table in the preliminary
4 evaluation that was referenced, that value represents the
5 tech spec value for drywell bypass leakage, not the design
6 allowable value.

7 Q Does this fact change any of the conclusions in
8 the report about the ability of the Perry containment to handle
9 drywell bypass leakage?

10 A No, it does not.

11 Q Doctor Lewis, Ms. Hiatt asked you about certain
12 experiments by Dr. Lee's earlier today, and I believe she
13 cited some statistics to you about eight percent hydrogen
14 and a flame speed of 20 m per second.

15 Do you have knowledge about the specific conditions
16 of Dr. Lee's experiments and whether those conditions are
17 applicable to the Perry hydrogen analysis?

18 A (Witness Lewis) Yes. His experimental conditions
19 were quite different from the conditions which prevail -- that
20 exists for determining a value of five feet per second.

21 He had all of his openings -- he has all of his
22 openings through which a sonic jet of flaming gas would pass,
23 and an apparent large propagation rate. This did not actually
24 exist by basic calculations.

25 Q And what is the applicability of those conditions

1 and those findings to the Perry hydrogen analysis?

2 A None whatsoever.

3 Q Why not?

4 A We don't have that kind of a condition at all.

5 We don't have openings in baffels through which a flame could
6 be propogated at sonic velocities.

7 Q Dr. Lewis, based on your review of the Perry Plant
8 and of the hydrogen analysis, are there any conditions under
9 which you could get direct detonation following a hydrogen
10 event?

11 A In an open space, the only way you can get direct
12 initiation of detonation is by using high explosive charges.
13 And we have no such initiating charge. We only have thermal
14 igniters, such as the hatch stobs and the glow plug itself.

15 Q Can you get detonation by acceleration from
16 deflagration at Perry following a hydrogen event?

17 A Not with thermal igniters under the Perry
18 conditions.

19 Q Dr. Lewis, Ms. Hiatt asked you about a paper from
20 the Fifth Symposium discussing ionizing radiation. Does
21 that paper have any relevance or impact on your analysis of
22 the ability of the igniters to function following a hydrogen
23 event?

24 A No, not at all.

25 Q Why not?

1 A They don't relate to ignition problems. They
2 only relate to flame propagation rates as affected by ionizing
3 radiation.

4 Q Ms. Buzzelli, Ms. Hiatt asked you to read
5 sentences, and portions of sentences into the record today.
6 And specifically, her question related to pages 6.2-22 and
7 6.2-23 of the PNPP Final Safety Analysis Report.

8 I believe that she asked you to stop reading
9 in the middle of a sentence, so I would like to let you
10 complete that sentence, and perhaps you could reread the
11 section, because there is only a few sentences before it,
12 and if you have any comments to make about the portions of
13 the paragraph that Ms. Hiatt did not let you read, please
14 make them at this time.

15 A (Witness Buzzelli) I am reading from Section
16 6.2.1.1.4.1, evaluation of drywell negative differential
17 pressure.

18 Following the blowdown phase of a LOCA, air
19 initially contained in the drywell has been purged to
20 containment and the drywell is full of steam. During this
21 period the ECCS is injecting cooling water from the suppression
22 pool into the reactor pressure vessel.

23 When the reactor pressure vessel is flooded to
24 a level of the break, water begins spilling into the drywell
25 condensing the steam and causing rapid depressurization of the

1 drywell.

2 A bounding calculation of the peak drywell negative
3 pressure differential is based upon the following conservative
4 assumption: All air has been purged out of the drywell. So,
5 vacuum breakers do not open, the suppression pool is at peak
6 short term post-blowdown temperature, as determined from
7 Figure 6212, containment is at the suppression pool temperature
8 and 100 percent relative to humidity. Steam in the drywell is
9 cooled to the suppression pool temperature.

10 The point I would like to make with respect to
11 reading this section, this is a design basis accident, CA LOCA,
12 large break.

13 We were referring to a small break, small break
14 in the preliminary evaluation when we were comparing and
15 assessing the conditions from the various tables. This is a
16 bounding calculation in the FSAR, with some very conservative
17 assumptions.

18 Drywell vacuum breakers, we have redundant drywell
19 vacuum breakers. Both are assumed to fail. A number of other
20 very conservative assumptions here.

21 Do you have anything to add?

22 A (Witness Richardson) Just that this calculation
23 is done in a --

24 JUDGE GLEASON: You are questioning one witness,
25 I believe.

1 MR. GLASSPIEGEL: I thought I gave them as
2 questions to the panel, but you are right, I did ask Ms.
3 Buzzelli. If Mr. Richardson has something to add, I would
4 like him to have the opportunity.

5 WITNESS RICHARDSON: That analysis is done in a
6 worse case manner. The worse that could exist in order to
7 maximize the potential loading from the water from that
8 event, and it does that, and the plant is designed to accommo-
9 date the loadings which may occur from such a worse case
10 situation.

11 Q All right. Dr. Fuls, earlier today there was
12 a discussion about a computer listing that was handed to you
13 by Ms. Hiatt. I would like to ask you whether that listing
14 or any of the discussion that took place earlier today causes
15 you to question in any respect the analysis and conclusions
16 set forth with respect to your analysis of the Perry hydrogen
17 combustion event?

18 A (Witness Fuls) No. It doesn't make me change
19 any of my conclusions.

20 Q Why not?

21 A The -- there is an apparent misunderstanding of
22 what that represented.

23 The results of the program has been reviewed and
24 qualified. They are in a QA program, and so that all of the
25 results from the March analysis were appropriately used in the
analysis.

Sim 17-1

1 Q Ms. Hiatt asked you questions, Dr. Fuls, about
2 the HECTOR Code earlier today. Does the fact that the HECTOR
3 Code came up with higher temperatures suggest that your
4 analysis, which did not use the HECTOR Code, was in any way
5 less conservative than the HECTOR Code analysis?

6 A (Witness Fuls) Not in my opinion. Extensive
7 verification of the CLASIXS 3 program has been done and
8 extensive hand calculations have been performed to demonstrate
9 that the equations developed were appropriately incorporated
10 in the program. Numerous test comparisons have been made
11 with Fenwal tests and others, the latest being some of the
12 tests from the NTS, the Nevada Test Station in a large
13 diameter sphere, and in only one case were the predicted
14 pressures of the same magnitude of the test results. In all
15 other cases the pressures predicted by CLASIXS were conser-
16 vatively high and the temperatures were all consistently
17 conservative relative to the test data.

18 Q Ms. Hiatt asked you about one of the assumptions
19 in your analysis, namely the assumption that sheet flow
20 would be about half as effective as sprays. Do you believe
21 that your assumption was a reasonable one and, if so, please
22 explain why.

23 A Yes. I think it is reasonable in that the
24 accumulation of the spray on floor surfaces running off into,
25 down into the annular area as well as from equipment would

Sim 17-2

1 form curtains around and off the floors. When combustion
2 would occur in the wetwell, the expanding gases must expand
3 outward and propagate up into the containment and thus
4 entraining the sheet flow and intimately mixing with it and
5 it should be a very good suppression mechanism.

6 Q Mr. Richardson, Ms. Hiatt asked you today about
7 the release rates that were used in the 20th scale testing,
8 and I believe you testified that those are not reasonable
9 release rates to use for a 75 percent metal water reaction.

10 Please explain the basis for that testimony.

11 A (Witness Richardson) Those release rates were
12 based on some other work that was done based on release
13 rates from the MARCH Code which were known to be conservatively
14 high and for excessive durations.

15 Later work that was conducted by the Owners
16 Group using the BWR Heatup Code, which is a more accurate
17 code for predicting release rates during a degraded core, a
18 recoverable core shows that the release rates would be
19 lower and of shorter duration. There might be some short
20 spikes which are in that same order of magnitude, as the
21 release rates tested in the "20th scale," but they are
22 of relatively short duration.

23 The basis for that is, as I stated earlier,
24 that if you are going to try to sustain -- well, you can't
25 sustain a high release rate, a high hydrogen release rate

Sim 17-3

1 because the oxidation reaction gives off so much energy that
2 it rapidly puts the core into a severely melted core and
3 this analysis and testing is supposed to be for a recoverable
4 degraded core which would therefore not be a high release
5 rate of long duration.

6 Q Ms. Hiatt also asked today about the effects
7 of expected diffusion flames on the polymeric seals used
8 in the Perry drywell equipment hatch and lower personnel
9 airlock hatches, and I believe there was testimony by one
10 of the witnesses that it was that witness' judgment that the
11 seals would be able to survive the expected temperatures
12 from diffusion flame burning.

13 Please give the basis for that judgement.

14 A There are several factors. One is the previous
15 equipment survivability analysis that has been conducted for
16 deflagrations shows that those seals do not reach a relatively
17 high temperature and there is a lot of margin between the
18 temperature that results from hydrogen burning and the
19 temperatures that they are qualified for. That is because
20 they are next to a large mass of metal and there is a
21 tremendous amount of heat sink. So they are typically not
22 a limiting component.

23 In addition, for instance, the equipment hatch,
24 the ceiling material that was mentioned is between the
25 flange materials, which is essentially outside or on the

Sim 17-4 1 outside of the containment structure and would not be exposed
2 directly to the hydrogen burning environment, but would
3 require heat transfer through the metal and therefore would
4 not be expected to reach high temperatures.

5 Additionally, the personnel hatch has two doors,
6 an inboard and an outboard, and only the inboard would really
7 see the possible high temperatures from the hydrogen
8 combustion.

9 Q Ms. Hiatt also asked earlier today about whether
10 actual components were planned to be used in the quarter scale
11 test, and the testimony was that there is no present attempt
12 to use actual components. Why not?

13 A Because the quarter scale test is a scale test
14 and it was developed that way because we wanted to get --
15 as Mr. Karlovitz testified this morning, there were other
16 issues that the Owners Group wanted to assure were accounted
17 for in order to take account for the full geometry of the
18 containment and, therefore, in order to take account for
19 the full geometry of the containment and resolve all issues
20 and therefore be conservative, you had to go through a quarter
21 scale since you couldn't build a full-scale containment to
22 do the testing.

23 With a scale test facility you can't really
24 scale equipment and put it into the facility. You are not
25 able to do that. If you put actual equipment in there it

Sim 17-5

1 would not be appropriate since you have got a scaled facility
2 with large size equipment.

3 Therefore, the program that we have laid out,
4 which is a very comprehensive one, is to put a component in
5 there and not really a real component, but a piece of material
6 which is of complex geometry and made of material similar
7 to the components that would be in the plant and instrument
8 it to a high degree and evaluate its response and compare
9 that using the same analytic techniques that will be used
10 for the actual equipment based on the thermal environment
11 in the quarter scale, and this in effect will validate the
12 methodology that is going to be used, which is certainly
13 an appropriate technique used in many other instances
14 throughout the industry.

15 . With respect to Ms. Hiatt's questions about
16 the NRC's comments on the BWR Heatup Code, has HCOG and CEI
17 considered or are they in the process of considering the
18 additional conservatisms identified by the NRC?

19 A The areas that have been under discussion have
20 been evaluated -- well there are ongoing evaluations of those
21 areas, some of which have been completed and there have been
22 sensitivity studies conducted based on those issues, and
23 to date none of those show any significant change in the
24 hydrogen release rates based on sensitivity studies accounting
25 for those issues.

Sim 17-6

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. GLASSPIEGEL: Mr. Chairman, I may be done.

I would appreciate a five-minute break to consult with counsel and the witnesses.

JUDGE GLEASON: All right. We will take five minutes.

(Recess taken.)

JUDGE GLEASON: Come to order, please.

May I ask how many more questions you have?

MR. GLASSPIEGEL: I was just asking my co-counsel here.

(Pause.)

About five more questions.

JUDGE GLEASON: Proceed.

REDIRECT EXAMINATION (Resumed)

BY MR. GLASSPIEGEL:

Q Mr. Richardson and Dr. Lewis, Ms Hiatt asked a number of questions about the Nevada Test Site results, and I believe in one context she cited a test result in which the igniters did not ignite at low concentrations, and I believe the concentration used was around six percent.

Taking low concentration as a concentration of about six percent hydrogen and based on your review of the Perry situation and the possibility of a hydrogen event, would you expect any conditions in which the Perry igniters would not ignite at such low concentrations?

Sim 17-7

1 A (Witness Richardson) No. The conditions that
2 were existent for those tests, first of all, there were
3 several tests that were conducted at low concentrations where
4 the hydrogen did ignite on the order of as low as 5.2 percent
5 if I remember correctly. There were several other tests
6 conducted at 6 and 7 percent where the hydrogen did ignite

7 The igniter for the test Ms. Hiatt was referring
8 to was a single igniter that was very high in the -- right
9 at the very top of this volume, and the conditions were such
10 that it just would not allow a hydrogen ignition because
11 of the way it was physically located and we would expect that
12 to really be applicable to the number of igniters we have
13 in the Perry containment.

14 A (Witness Lewis) Let me just add one thing.
15 Hundreds of ignition tests were carried out by Fenwal, Incor-
16 porated with a whole variety of compositions, including
17 many of them down to five percent, and there never was one
18 that failed to ignite leading me to believe that the igniters
19 are highly reliant.

20 A (Witness Richardson) I might just add that the
21 only place in the containment that even comes close to that
22 exact physical arrangement is right at the very top of the
23 dome where there are two igniters up there, and it is really
24 not important because there are a hundred other igniters
25 distributed throughout that will ignite the hydrogen.

Sim 17-8

1 The reference was made and it sounded like there
2 were other types of igniters that had to be used to get this
3 ignition, and what it was was the reference was really to
4 igniters in other locations that were used. There were
5 several igniters in the test facility, but not all were turned
6 on during any particular test. Usually it was one igniter
7 at one location.

8 Q Dr. Fuls, would all the hydrogen in a postulated
9 hydrogen event bypass the suppression pool if the drywell
10 leakage is at the allowable tech spec rate?

11 A (Witness Fuls) The allowable tech spec rate
12 of leakage from the drywell is of the same order of magnitude
13 as the compressors in the combustible gas controlled sytem.
14 And when you consider the accident and releases from the
15 reactor vessel, there are hugh volumes of steam and hydrogen
16 being released at the same time. So that the vast majority
17 of this release must go through the vents in the suppression
18 pool and only a small fraction, because of the mixing effect,
19 will go out through the bypass leakage.

20 Q Mr. Holtzclaw, have you assessed the potential
21 for hydrogen bypass through the drywell?

22 A (Witenss Holtzclaw) GE has done some parametric
23 calculations to determine the flow of hydrogen through the
24 SRV's or the horizontal vents and bypass during a small
25 break LOCA assuming a bypass equivalent of .168 A over

Sim 17-9

1 the square root of K per square foot.

2 Under the expected conditions of hydrogen gas
3 generation rate, steam flow and reactor pressure for this
4 event, only a small fraction of hydrogen, about 14 to 19
5 percent of that total generated would exit through the
6 postulated bypass I guess which is consistent with what
7 Dr. Fuls was just talking about.

8 In other words, the bulk would go through the
9 vents or the SRV pathway. From these results it can be
10 concluded that drywell bypass leakage is of no concern to
11 the operation of the Perry hydrogen control system.

12 Q There were questions by Ms. Hiatt about Sandia's
13 1/32nd scale test. What is the relevance of the snap-through
14 buckling that occurred of the representation of the equipment
15 hatch?

16 A (Witness Alley) That particular snap-through
17 buckling is not applicable to Perry. The equipment hatch
18 indicated in that particular test was concave inward, which
19 means the pressure is acting against the curvature. In
20 Perry our equipment hatches are oriented in the opposite
21 direction where the pressures would tend to produce tensions
22 in the membrane and therefore buckling is not a consideration
23 on our equipment hatches.

24 Q Ms. Hiatt also asked questions about 1/8th
25 scale testing performed by Sandia. What was the design

Sim 17-10

1 pressure used in that test?

2 A I believe the design pressure was 40 psig.

3 Q And what was the failure pressure identified
4 in that test?

5 A It was approximately five times higher, or
6 186 psig.

7 Q What conclusions, if any, do you draw with
8 respect to your analysis of the Perry structural integrity
9 following a hydrogen event?

10 A As I have said before in my testimony, most
11 of the Sandia tests were for the explicit purpose of trying
12 to correlate and predict failure modes of containment vessels
13 and key components. Our analyses, which are linear elastic
14 analyses, we have used the service level C limits as the
15 determining criteria and therefore most of the conclusions
16 reached by those reports are not applicable to our analysis.

17 Q In that Sandia 1/8th scale test what code was
18 used to predict performance?

19 A The MARCH finite element code was used. That
20 code is primarily used for non-linear elastic type analyses,
21 which is outside the range of the applications for our
22 analysis.

23 Q And it is your testimony that your analysis
24 looked at elastic ranges?

25 A Yes, it is.

Sim 17-11

1 MR. GLASSPIEGEL: No further questions.

2 JUDGE GLEASON: My Hiatt, do you have some
3 recross?

4 MS. HIATT: Yes, I do. I would really appreciate
5 the opportunity to take some time to prepare a little better.
6 There is a tremendous amount of material obviously and I
7 would like either to resume it tomorrow morning or if we
8 could take a rather long break this afternoon.

9 JUDGE GLEASON: Do you have any estimation
10 of time?

11 MS. HIATT: For the recross I wouldn't have that
12 many questions, and I do not have a tremendous amount of
13 questions for the NRC staff either.

14 JUDGE GLEASON: Well, what is your preference?

15 MR. GLASSPIEGEL: Mr. Chairman, I want to
16 be reasonable here. I would prefer not to take an overnight
17 break. I think we were required to move into redirect after
18 a rather long cross-examination today, and I would be willing
19 to take a half hour or 45-minute break if she only has a
20 few questions. And I would also like to ask if Ms. Hiatt
21 has any further questions for Mr. Karlovitz or Dr. Lewis.
22 If not, I would like to request that they be temporarily
23 excused.

24 JUDGE GLEASON: Well, I think she wants a chance
25 to look over ---

MS. HIATT: Yes. I really can't say right

Sim 17-12 1 now whether I will have questions for them.

2 MR. GLASSPIEGEL: Fair enough.

3 JUDGE GLEASON: Well, just hold it a minute.

4 (Board conferring.)

5 JUDGE GLEASON: If we can have your attention,
6 please.

7 We really think it puts too much of a burden
8 on everybody to prolong the times of these sessions like
9 this, and we think that the intervenor ought to have an
10 adequate opportunity to look over what the recross will be.
11 She operates by herself and you at least have some assistance
12 to help you even though your time was short.

13 So I think we will recess tonight and it sounds
14 to me like we ought to be able to finish by 12 o'clock tomorrow
15 anyway because you indicated you didn't have a lot of questions
16 of the staff. So let's get back at 9 o'clock tomorrow morning.

17 MR. GLASSPIEGEL: May I ask the Board, do you
18 intend to ask any questions of the panel?

19 JUDGE GLEASON: We have a few we could ask now
20 if you would like to get those over with.

21 MR. GLASSPIEGEL: I think it would be helpful.

22 JUDGE GLEASON: All right. There are very few.

23 BOARD EXAMINATION

INDEX

Ace-Federal Reporters, Inc.

24 BY JUDGE BRIGHT:

25 Q Ms. Buzzelli, Ms. Hiatt was asking you about the

Sim 17-13

1 loss of offsite power, if I recall correctly. Am I right?

2 A (Witness Buzzelli) Yes, she had an initial
3 question on the loss of offsite power.

4 Q And you indicated that the igniters were not
5 hooked into the emergency power system; is that correct?

6 A No. The igniters are supplied by the emergency
7 diesel generator system.

8 Q They are supplied by the emergency diesel
9 generator?

10 A They are supplied by the emergency diesel
11 generator, yes.

12 Q So in the event of a loop LOCA you would be
13 able to operate; is that correct?

14 A That is correct.

15 JUDGE BRIGHT: Thank you.

end Sim
Sue fols

16

17

18

19

20

21

22

23

24

25

#18-1-SueT 1

BOARD EXAMINATION

2 BY JUDGE KLINE:

3 Q I'm not completely clear on the conditions of
4 the model for hydrogen deflagration and detonation.

5 First, I would like to ask whether the assumptions
6 that went into the modeling of hydrogen combustion are de-
7 pendent on a complete mixing assumption with -- of the hydrogen
8 with the containment air?

9 A (Witness Karlovitz) The transition from deflagra-
10 tion to detonation is not dependent on complete mixing. The
11 mixture has to be such that it could detonate.

12 Q Yeah.

13 A Whether the mixture is fully mixed or not plays
14 no role. And the transition is essentially a turbulence
15 effect.

16 Somehow, the flame as it is ignited, the deflagra-
17 tion progressing has to be constrained in some ways. Like in
18 a long tube. Where the burned gases push forward, the flame,
19 and produces large intensity turbulence, whereby the propagat-
20 ing flame can reach a propagating velocity, not a flame
21 velocity. The flame can go -- approach some velocity.

22 And at that time, the front of the flame is highly
23 turbulent, involved. And little pockets burn suddenly pro-
24 ducing pressure waves. They run forward, and as they reach
25 the cold gas they are slowed down, they pile up. And piling

#18-2-SueT 1 up they produce the detonation rate.

2 Q Okay. That was my question, as to whether or not
3 nonhomogenous conditions, that is to say, higher localized
4 concentrations of hydrogen could produce --

5 A It can produce it if the concentration is high
6 enough. But whether it is variable at places doesn't play
7 any role.

8 Q As I understand it, the intent is to initiate
9 thermal ignition at around eight percent hydrogen concentra-
10 tion?

11 A Yes.

12 Q Have you ruled out completely that a localized
13 concentration of hydrogen could build up to fourteen or
14 fifteen percent before ignition?

15 A It could happen and play no role. The essential
16 point is --

17 Q No, I don't understand why it doesn't play a role.

18 A That's what I want to explain, please. Because
19 it need not only the detonable concentration but also the
20 specific geometry which confines the flame and produces the
21 very fast flame progress and higher turbulence intensity.

22 And for this condition, we don't have anywhere
23 in the containment.

24 Q I guess -- would these, the conditions you have
25 just described hold for all conditions, even suppose that you

#18-3-SueT 1 did not intend to initiate a thermal ignition, what is the
2 consequence of not igniting hydrogen then until it reaches
3 very high concentrations and then igniting it in a burn if
4 there is no detonation?

5 A It could produce a sudden pressure depending on
6 the volume of the accumulated hydrogen mixture. But under
7 the geometry of the containment structure, it could not go
8 over into detonation.

9 Q In the modeling that has been done that produced
10 certain estimates of temperature in the containment, are
11 those temperatures the temperature of the containment atmosphere
12 after detonation?

13 A You are back to the calculations. The flame
14 temperature depends on the concentration only. But the
15 temperature of the environment of the whole structure --

16 Q That's what I'm trying to distinguish between
17 the flame temperature and the environmental temperature.

18 A The temperature of the structure depends on the
19 calculations -- is given by the calculations.

20 Q The curves that are shown in this preliminary
21 report show temperatures on the order of 300 degrees or
22 something. Those are environmental --

23 A That is the structure temperature.

24 Q Okay.

25 A (Witness Buzzelli) Atmosphere.

#18-4-SueT

(Witness Richardson) Atmosphere.

Q The containment air, that's what I'm getting at.
Now, the flame temperature itself is much higher?

A (Witness Karlovitz) Yes. That depends only on
the concentration.

Q Now, given that, why is it not possible to initiate
secondary fires? For example, in cable trays?

A Because the high temperatures would last only for
a very short time, then comes again a cold blast of air or
steam.

(Witness Lewis) It's intermittent.

(Witness Karlovitz) Intermittent. The average
temperature is --

(Witness Lewis) The average time of a flame is
short.

(Witness Karlovitz) The average temperature is
given by the calculations is the low value. And that would
act to ignite a cable also.

JUDGE KLINE: Okay. That's enough. Thank you.

CROSS EXAMINATION

BY JUDGE GLEASON:

Q Could somebody explain to me who invented this
igniter system as it is in the Perry Plant?

(Laughter.)

A (Witness Karlovitz) I recall that this solution

INDEXXX

#18-5-SueT 1 came up through a discussion at Westinghouse, and recently I
2 learned that the first suggestion came from Dr. Fuls.

3 Q We can hold him responsible?

4 (Laughter.)

5 A At this discussion, particularly Dr. Lewis and
6 myself, resisted strongly until we got convinced that in this
7 case this is the solution.

8 (Witness Fuls) I came up with the idea. I didn't
9 invent the entire system.

10 Q Who did that?

11 A (Witness Richardson) A lot of the initial work,
12 design and things like that were done by the ice condensor
13 plants. Tennessee Valley Authority and Duke Power Company
and the Cook Plant, Sequoyah, McGuire and Cook Plants, ice
15 condensor plants.

16 Q Somebody put it in a pattern to be used in those
plants?

18 A Yes. Those utilities, using the guidance from
19 Dr. Fuls and Dr. Lewis and Mr. Karlovitz. Then a design
20 and the criteria that they used were evaluated by Mississippi
21 Power and Light and the Hydrogen Control Owners' Group and
22 was developed further.

23 Their initial design was not a Class I-E safety
24 grade system, and the system was then designed for Mississippi
25 Power and Light, was then upgraded to a Class 1-E system and

#18-6-SueT

1 then criteria developed through the Hydrogen Control Owners'
2 Group.

3 (Witness Fuls) May I add that the concept of the
4 igniter itself was developed by the Tennessee Valley Authority.
5 They investigated a number of different sources, particularly
6 spark plugs and found that they created too much radio-
7 transmission and interfered with a lot of their equipment and
8 instrumentation.

9 Using the glow plug was very benign and didn't
10 interfere with any of their --

11 (Witness Karlovitz) The glow plug is an industrial
12 product.

13 Q And was this, Dr. Fuls, for a nuclear plant?

A (Witness Fuls) Yes. This is for the Sequoyah.

15 Q All right. Would it be an inaccurate assessment
16 to say we've got -- everybody agrees we have got a great
system here but nobody has seen it really work?

18 A (Witness Karlovitz) The system was subjected to
19 a large experimental trial at Fenwall Corporation.

20 Q Where?

21 A At Fenwall Corporation. Near Boston, Massachusetts.
22 I have here test results. And the system never failed.

23 Q In what kind of a structure was this?

24 A It was a large spherical room, which they established
25 the proper conditions carefully and then ignited in the center.

- #18-7-SueT 1 They are -- it's a well known, respected --

2 Q How many igniters were in this room?

3 A One.

4 Q One. I see. We have a hundred and two here.

5 A That makes it a hundred and two times safer.

6 (Laughter.)

7 Q Refer to Murphy's Law and all that kind of stuff.

8 (Laughter.)

9 A Fenwall is a highly respected corporation. Their
10 main line is explosion protection and fire protection where
11 they develop explosion conditions and blow in suddenly large
12 volume -- spreading large volume of elements which kill the
13 fire. They are very successful.

14 Again, the system never failed except a few cases
15 when the owners monkeyed with it.

16 Q Well, that can happen at Perry, too.

17 (Laughter.)

18 A Supposedly not.

19 Q I don't know whether Mr. Richardson or Ms.

20 Buzzelli would be the proper person to answer this. I am
21 referring now to the OCRE Exhibit 16 on which there were
22 some questions and comments on redirect.

23 If I understood those questions, it was to demon-
24 strate that one could not go from one -- from the exhibit over
25 to your exhibit 8-1 with any degree of accuracy. You couldn't

#18-8-SueT 1 locate the igniters by the information in this exhibit?

2 A (Witness Buzzelli) You could not locate the
3 igniters by the information in this exhibit. It would take
4 some translation from --

5 Q It would take some translation. Would you say
6 generally that their location points in OCRE's Exhibit --
7 I think you said they are substantially changed, but is
8 the distance substantial for each igniter or is it small
9 distances in most cases?

10 A Many are substantial change -- large distances.

11 Q Large distances?

12 A The others may be more on the order of small
13 distances.

14 Q Have you been able to -- not that you have been
15 asked to, but I raise the question, been able to put a date
16 on this exhibit?

17 A No. I have not been able to put a date. I would
18 estimate -- this was an early draft document in the develop-
19 ment of the system and its design that eventually was super-
20 seded and resulted in the preliminary evaluation.

21 I would estimate for this interim report possibly
22 late '83, early '84 time frame. Late '83 possibly. That's
23 an estimate on my part. I could do some checking to find out
24 what that date is.

25 Q All right. We appreciate you doing that if you

#18-9-SueT 1 could. Also as to whether this is -- is this the first
2 layout of this system or is it --

3 A No. Prior to this document, there was a preliminary
4 report.

5 Q You say a preliminary --

6 A A pre-preliminary report that preceded this interim
7 report in this form, and again showed very, even the earlier
8 estimated locations, proposed locations, for igniters.

9 So there is a report before this one that you have
10 as an exhibit. Once again, the final evaluation is that which
11 we submitted in March of '85.

12 BOARD EXAMINATION

13 BY JUDGE KLINE:

INDEXXX

14 Q In the subsequent stages of evolution, I would say,
15 are those changes produced by analysis of hydrogen combustion
16 or were they produced by something practical, or you just
couldn't find a place to hang it when you got there?

18 (Laughter.)

19 A (Witness Buzzelli) More from practical reasons
20 and from following and reevaluating and insuring that the
21 criteria established, spacing criteria established, for the
22 Owners' Group and established for Perry was followed.

23 So, more from a practical standpoint and insuring
24 available supports and so on. There was no feedback from the
25 analysis to the specific igniter locations.

#18-10-SueT1

(The Board members are conferring.)

BOARD EXAMINATION

BY JUDGE GLEASON:

DEXXX

Q Essentially, the idea is to have one of these igniter parts everywhere that hydrogen can go; isn't that right?

A (Witness Richardson) That's correct. I might also point out that you were asking about the analysis and the feedback and everything, and the analysis essentially assumes that there are igniters there. It's not important as to specifically what location they are.

The location is based on criteria that has been established originally by the ice condensor plants and carried over through the MARK III plants. And most of the placement changes were, as Ms. Buzzelli said, meeting -- meet the criteria. And when you find there is no place to locate it, evaluate it, place it in a different location, and then that might be the location of another one because you are trying to meet the criteria.

Q If I understood some comment that was made yesterday, during the visit there, generally about thirty feet apart?

A That's the criteria.

Q And that's based on what?

A Well, the criteria is that they are approximately

thirty feet apart from one another, both divisions of power are available, and approximately sixty feet from one another for a given, you know, one division of power supply available and --

MR. GLASSPIEGEL: Judge Gleason, just one point. I want to make sure that there is an understanding here. You referred a couple of times to the hundred and two igniters, and I just -- there was an implication, at least to me, that you might think that all hundred and two igniters would be needed. And I would just like --

JUDGE GLEASON: No. I understand. All right. We will see you all tomorrow at 9 o'clock.

(Whereupon, the hearing is recessed at 5:00 p.m., Thursday, May 2, 1985, to reconvene on Friday, May 3, 1985 at 9:00 a.m.)

* * * * *

CERTIFICATE OF OFFICIAL REPORTER

This is to certify that the attached proceedings before the UNITED STATES NUCLEAR REGULATORY COMMISSION in the matter of:


NAME OF PROCEEDING: Perry Nuclear Power Plant, Units 1 & 2
The Cleveland Electric Illuminating Co., et al

DOCKET NO.: 50-440/50-441


PLACE: Perry, OH

DATE: Thursday, May 2, 1985


were held herein appears, and that this is the official transcript thereof for the file of the United States Nuclear Regulatory Commission.

(sig) 
(TYPED)

GARRETT J. WALSH, JR.

(sig) 
(TYPED)

MYRTLE H. TRAYLOR

(sig) 
(TYPED)

MARY SIMONS

Official Reporters

Reporter's Affiliation

ACE Federal Reporters